

**TXU Power**  
Comanche Peak Steam  
Electric Station  
P. O. Box 1002 (E01)  
Glen Rose, TX 76043  
Tel: 254 897 5209  
Fax: 254 897 6652  
mike.blevins@txu.com

**Mike Blevins**  
Senior Vice President &  
Chief Nuclear Officer

REF: 10 CFR 50.55a(3)(i)

CPSES-200601660  
Log # TXX-06142

August 24, 2006

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

**SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NO. 50-445  
WITHDRAWAL OF RELIEF REQUEST A-6 TO THE UNIT 1  
INSERVICE INSPECTION (ISI) PROGRAM PLAN FROM THE  
1998 EDITION OF ASME CODE, SECTION XI. THROUGH 2000  
ADDENDA (INTERVAL START DATE-AUGUST 13, 2000,  
SECOND INTERVAL)  
TAC NUMBER D1134**

- REF: 1. TXU Power letter, logged TXX-06052, from Mike Blevins to the U. S. Nuclear Regulatory Commission, dated March 31, 2006.
2. NRC letter from David Terao to R. T. Redenoure, Vice President – Chief Nuclear Officer, Omaha Public Power District, dated May 10, 2006.

Gentlemen:

TXU Generation Company LP (TXU Power) requests withdrawal of the relief requested in Reference 1. After discussion with the NRC staff and review of Reference 2, neither a request for relief from ASME Code requirements nor authorization of an alternative to NRC requirements in 10 CFR 50.55a is needed for TXU Power to use phosphor imaging plates in lieu of film.

TXU Power will use radiographic technique requirements in ASME Section III (which references ASME Section V) in place of nondestructive examination requirements of our original construction code (as allowed by ASME Section XI), which is authorized in 10 CFR 50.55a. A reconciliation of the later Code Editions will be performed in accordance with ASME Section XI.

TXX-06142

Page 2 of 2

This communication contains no new licensing basis commitments regarding CPSES.

If you have any questions regarding this request, please contact Jack Hicks at (254) 897-6725.

Sincerely,

TXU Generation Company LP

By: TXU Generation Management Company LLC,  
Its General Partner

Mike Blevins

By:   
Fred W. Madden  
Director, Regulatory Affairs

JCH

c - B. S. Mallet, Region IV  
M. C. Thadani, NRR  
Resident Inspectors, CPSES