- MEMORANDUM TO: William H. Ruland, Deputy Director Licensing and Inspection Directorate Spent Fuel Project Office, NMSS
- FROM: Christopher M. Regan, Senior Project Manager /RA/ Licensing Section Licensing and Inspection Directorate Spent Fuel Project Office, NMSS
- SUBJECT: SUMMARY OF SEPTEMBER 8, 2006, MEETING WITH HOLTEC INTERNATIONAL REGARDING THERMAL ISSUES ASSOCIATED WITH PROPOSED AMENDMENT TO THE HI-STORM 100 CERTIFICATE OF COMPLIANCE 1014 (TAC NO. L23850)

On September 8, 2006, the Nuclear Regulatory Commission (NRC) staff from the Spent Fuel Project Office met with representatives of Holtec International (Holtec) at NRC Headquarters in Rockville, Maryland. The purpose of the meeting was to provide Holtec with the opportunity to present details of its thermal analyses relating to staff concerns regarding information provided in response to the NRC's second Request for Additional Information (RAI) dated June 6, 2006. The RAI pertained to the proposed amendment to the 10 CFR Part 72 Certificate of Compliance (CoC) for the HI-STORM 100 dry cask storage system. In addition, the staff was prepared to present the specific details of its concerns regarding Holtec's analytical methods in the thermal discipline. The desired outcome was to have a mutual understanding of the outstanding thermal issues and have an agreed upon approach for resolution of the staff's concerns in the thermal area. The meeting was noticed on August 25, 2006. Enclosure 1 is a list of attendees; Enclosure 2 contains the NRC presentation slides.

The staff began by presenting the historical background of the technical review of the amendment application. This included reference to conference calls held between Holtec and the staff in early August regarding thermal issues and disagreement over the analytical methods used by Holtec. At that time, these issues were communicated to Holtec. Also, in those conference calls, the staff suggested an approach to address the outstanding thermal issues which would resolve the technical disagreement. At that time, Holtec declined to agree that the staff's suggested approach was appropriate.

After the historical perspective was provided, the staff reviewed for the meeting attendees the details of its concerns with the methods used by Holtec to calculate peak fuel cladding temperatures (Enclosure 2). These issues focused principally on the methods used by Holtec to calculate the friction factor in the "porous media model" computer analysis. The staff considered Holtec's approach non-conservative but noted that the results indicated, for the cases analyzed, the peak fuel cladding temperatures were still below acceptable limits. Holtec provided evidence of a parametric study that showed that the peak fuel cladding temperatures calculated using both the staff's suggested method and by the method, as submitted by Holtec, yielded temperatures that were in agreement.

W. Ruland

The staff insisted that the method suggested by the staff would more accurately represent the thermal dynamic taking place inside each fuel assembly, specifically the fuel heated region. The staff stated that a model that discretely considered the heated and non-heated regions in the fuel assembly using the "wall shear stress" method would address the staff's concerns and resolve the technical disagreement. The staff considered its suggested approach to be a more conservative method and one which would preclude any concerns with implementation of an approved analysis in the future, should any changes be made to it as permitted by 10 CFR 72.48. It is for this reason the staff noted that the approach suggested by the staff, if agreed to by Holtec, should be used as the licensing basis for approval of the amendment request. As such, any and all information in the Final Safety Analysis Report (FSAR), as currently submitted for review, that references the original methology proposed by Holtec should be revised to reflect the new approach that addresses the staff's concerns.

Holtec agreed to revise the analysis and use the staff's suggested approach. Specifically, the analysis will model the heated fuel region and non-heated regions. Holtec would perform cases for the MPC-68, for the boiling water reactor (BWR) case, and the MPC-32, for the pressurized water reactor (PWR) case. The analyses will be run considering water rods would be blocked. After completing these analyses, the staff agreed to a conference call with Holtec in a approximately a weeks time to permit Holtec to share the results of the analysis. At this time, the staff would be able to convey any additional concerns before Holtec would proceed with the more significant FLUENT analyses for the entire storage system.

The staff shared the current status of the review schedule in the other disciplines and indicated that the additional thermal analyses to be performed by Holtec may result in a delay but that this was highly dependent on when Holtec submits the additional information. No regulatory decisions were made by the NRC during the meeting on the material presented. There were no questions from the members of the public.

Docket No. 72-1014 TAC No. L23850

- Enclosures: 1. Attendance List
 - 2. Presentation Slides

W. Ruland

The staff insisted that the method suggested by the staff would more accurately represent the thermal dynamic taking place inside each fuel assembly, specifically the fuel heated region. The staff stated that a model that discretely considered the heated and non-heated regions in the fuel assembly using the "wall shear stress" method would address the staff's concerns and resolve the technical disagreement. The staff considered its suggested approach to be a more conservative method and one which would preclude any concerns with implementation of an approved analysis in the future, should any changes be made to it as permitted by 10 CFR 72.48. It is for this reason the staff noted that the approach suggested by the staff, if agreed to by Holtec, should be used as the licensing basis for approval of the amendment request. As such, any and all information in the Final Safety Analysis Report (FSAR), as currently submitted for review, that references the original methology proposed by Holtec should be revised to reflect the new approach that addresses the staff's concerns.

Holtec agreed to revise the analysis and use the staff's suggested approach. Specifically, the analysis will model the heated fuel region and non-heated regions. Holtec would perform cases for the MPC-68, for the boiling water reactor (BWR) case, and the MPC-32, for the pressurized water reactor (PWR) case. The analyses will be run considering water rods would be blocked. After completing these analyses, the staff agreed to a conference call with Holtec in a approximately a weeks time to permit Holtec to share the results of the analysis. At this time, the staff would be able to convey any additional concerns before Holtec would proceed with the more significant FLUENT analyses for the entire storage system.

The staff shared the current status of the review schedule in the other disciplines and indicated that the additional thermal analyses to be performed by Holtec may result in a delay but that this was highly dependent on when Holtec submits the additional information. No regulatory decisions were made by the NRC during the meeting on the material presented. There were no questions from the members of the public.

Docket No. 72-1014 TAC No. L23850

Enclosures: 1. Attendance List

2. Presentation Slides

DISTRIBUTION:

 NMSS r/f
 SFPO r/f
 DMcIntyre, OPA

 NJensen, OGC
 NRC attendees/without attachments

 E:\Filenet\ML062570324.wpd

OFC	SFPO	Е	SFPO		SFPO	N	SFPO	
NAME	CRegan		Lcampbell ABB for		EZiegler		RNelson	
DATE	09/11/06		09/11/06		09/12/06		09/14 /06	

Official Record Copy

Enclosure 1

Attendee List

Meeting with Holtec International HI-STORM 100 Amendment Application Thermal Issues September 8, 2006

ATTENDANCE LIST

<u>Name</u>

Affiliation

Ed Hackett Bill Ruland Christopher Regan Jorge Solis Rob Tripathi
Dob Thpathi Dob Showmakar
DOD SHEWINAKEI
Larry Campbell
Gordon Bjorkman
Michel Call
Stephan Anton
Kris Singh
Alan Soler
Debebrata Mitra-Majumdar Thecla Fabian Maureen Conley

NRC/NMSS/SFPO NRC/NMSS/SFPO NRC/NMSS/SFPO NRC/NMSS/SFPO NRC/NMSS/SFPO NRC/NMSS/SFPO NRC/NMSS/SFPO NRC/NMSS/SFPO Holtec International Holtec International Holtec International Holtec International Holtec International Fuel Cycle Week Platts/McGraw-Hill

Enclosure 2

Presentation Slides