- (5) ENO pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.
- C. This amended license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) <u>Maximum Power Level</u>

ENO is authorized to operate the facility at steady state reactor core power levels not in excess of 2536 megawatts (thermal).

(2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendix A, as revised through Amendment No. 286, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) <u>Fire Protection</u>

ENO shall implement and maintain in effect all provisions of the approved fire protections program as described in the Final Safety Analysis Report for the facility and as approved in the SER dated November 20, 1972; the SER Supplement No. 1 dated February 1, 1973; the SER Supplement No. 2 dated October 4, 1974; the SER dated August 1, 1979; the SER Supplement dated October 3, 1980; the SER Supplement dated February 13, 1981; the NRC Letter dated February 24, 1981; Technical Specification Amendments 34 (dated January 31, 1978), 80 (dated May 22, 1984), 134 (dated July 19, 1989), 135 (dated September 5, 1989), 142 (dated October 23, 1989), 164 (dated August 10, 1990), 176 (dated January 16, 1992), 186 (dated February 19, 1993), 190 (dated June 29, 1993), 191 (dated July 7, 1993), 206 (dated February 28, 1994), and 214 (dated June 27, 1994); and NRC Exemptions and associated safety evaluations dated April 26, 1983, July 1, 1983, January 11, 1985, April 30, 1986, September 15, 1986 and September 10, 1992 subject to the following provision:

ENO may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

Amendment No. 286

L

3.8 ELECTRICAL POWER SYSTEMS

3.8.4 DC Sources - Operating

LCO 3.8.4 The following DC electrical power subsystems shall be OPERABLE:

a. Two 125 VDC subsystems; and

b. Two 419 VDC low pressure coolant injection (LPCI) MOV independent power supply subsystems.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION		REQUIRED ACTION		COMPLETION TIME	
A.	One battery charger on One 125 VDC power subsystem inoperable.	A.1	Restore battery terminal voltage to greater than or equal to the minimum established float voltage (127.8 VDC).	2 hours	
		AND			
	· · ·	A.2	Verify battery float current ≤ 2 amps.	Once per 12 hours	
		AND			
		A.3	Restore battery charger to OPERABLE status.	7 days	

(continued)

JAFNPP

ACTIONS (continued)

CONDITION		REQUIRED ACTION		COMPLETION TIME
В.	One 125 VDC electrical power subsystem inoperable for reasons other than Condition A.	B.1	Restore 125 VDC electrical power subsystem to OPERABLE status.	8 hours
C.	Required Action and associated Completion Time of Condition A or B not met.	C.1. <u>AND</u> C.2.	Be in MODE 3. Be in MODE 4.	12 hours 36 hours
D.	One or both 419 VDC LPCI MOV independent power supply subsystems inoperable.	D.1	Declare associated LPCI subsystem(s) inoperable.	Immediately

١

SURVEILLANCE REQUIREMENTS

1

SR 3.8.4.1Verify battery terminal voltage on float charge is: a. ≥ 127.8 VDC for 125 VDC batteries, and b. ≥ 396.2 VDC for 419 VDC LPCI MOV independent power supply batteries.7 daySR 3.8.4.2Verify each 125 VDC battery charger supplies ≥ 270 amps at ≥ 128 VDC for24 m	/s
b. ≥ 396.2 VDC for 419 VDC LPCI MOV independent power supply batteries. SR 3.8.4.2 Verify each 125 VDC battery charger supplies ≥ 270 amps at ≥ 128 VDC for 24 m	. <u></u>
SR 3.8.4.2Verify each 125 VDC battery charger supplies \geq 270 amps at \geq 128 VDC for24 m	
≥ 4 hours. <u>OR</u>	onths
Verify each 125 VDC battery charger can recharge the battery to the fully charged state within 24 hours while supplying the largest combined demands of the various continuous steady state loads, after a battery discharge to the bounding design basis event discharge state.	
SR 3.8.4.3 This Surveillance shall not normally be performed in MODE 1, 2, or 3 for the 125 VDC batteries. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.	
Verify battery capacity is adequate to 24 mo supply, and maintain in OPERABLE status, the required emergency loads for the design duty cycle when subjected to a battery service test or a modified performance discharge test.	onths

١

Amendment 286

DC Sources - Operating 3.8.4

SURVEILLANCE REQUIREMENTS (continued)

ţ

	SURVEILLANCE	FREQUENCY
SR 3.8.4.4	This Surveillance shall not normally be performed in MODE 1, 2, or 3 for the 125 VDC batteries. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.	
	Verify battery capacity is ≥ 80% of the manufacturer's rating when subjected to a performance discharge test or a modified performance discharge test.	60 months <u>AND</u> 12 months when battery shows degradation or has reached 85% of expected life with capacity < 100% of manufacturer's rating <u>AND</u> 24 months when battery has reached 85% of the expected life with capacity ≥ 100% of manufacturer's rating

JAFNPP