

September 19, 2006

MEMORANDUM TO: File

FROM: Maitri Banerjee, Senior Project Manager/**RA**/
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3 - REGION III
REQUEST TO REVIEW LICENSEE'S RESPONSE TO TASK
INTERFACE AGREEMENT 2005-009 RELATED TO EMERGENCY
DIESEL TESTING (TAC NOS. MD1493 AND MD1494)

The Electrical Engineering Branch (EEEB) and the Component Performance and Testing Branch (CPTB) of the Office of Nuclear Reactor Regulation (NRR) have reviewed additional information associated with Task Interface Agreement 2005-009 provided by Exelon Generation Company, LLC (Exelon) on June 8, 2006 (Agencywide Documents Access and Management System Accession No. ML062090025), and discussed their findings with Region III in a conference call on August 1, 2006. EEEB AND CPTB staff reaffirmed their position that the Dresden emergency diesel generator testing must envelope the long-term design-basis accident loads.

Region III will communicate this reaffirmation to Exelon and take the next course of action. No further review is required from the NRR staff.

The TACs will be closed.

Docket Nos. 50-237 and 50-249

September 19, 2006

MEMORANDUM TO: File

FROM: Maitri Banerjee, Senior Project Manager/**RA**/
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: DRESDEN NUCLEAR POWER STATION, UNITS 2 AND 3 - REGION III
REQUEST TO REVIEW LICENSEE'S RESPONSE TO TASK
INTERFACE AGREEMENT 2005-009 RELATED TO EMERGENCY
DIESEL TESTING (TAC NOS. MD1493 AND MD1494)

The Electrical Engineering Branch (EEEB) and the Component Performance and Testing Branch (CPTB) of the Office of Nuclear Reactor Regulation (NRR) have reviewed additional information associated with Task Interface Agreement 2005-009 provided by Exelon Generation Company, LLC (Exelon) on June 8, 2006 (Agencywide Documents Access and Management System Accession No. ML062090025), and discussed their findings with Region III in a conference call on August 1, 2006. EEEB AND CPTB staff reaffirmed their position that the Dresden emergency diesel generator testing must envelope the long-term design-basis accident loads.

Region III will communicate this reaffirmation to Exelon and take the next course of action. No further review is required from the NRR staff.

The TACs will be closed.

Docket Nos. 50-237 and 50-249

Distribution:

PUBLIC	LPL3-2 R/F	SUnikewicz, NRR	TKoshy, NRR
RidsNrrDeEeeb	RidsNrrDciCptb	MRing, RIII	CPhillips, RIII
JLara, RIII	RidsNrrPMMBanerjee	RidsNrrLADClarke	
TWengert, NRR	RidsNrrDorlLpl3-2		

ADAMS: ML062610269

OFFICE	LPL3-2/PM	LPL3-2/LA	DE/EEEB	DCI/CPTB	LPL3-2/BC
NAME	MBanerjee	DClarke	GWilson	TLiu	DCollins
DATE	9/18/06	9/18/06	9/18/06	9/19/06	9/19/06

OFFICIAL AGENCY RECORD