

From: "Harrington, Craig" <charrington@epri.com>
To: "Ganesh Cheruvenki" <GSC@nrc.gov>, "Ted Sullivan" <EJS@nrc.gov>
Date: 09/18/2006 2:48:01 PM
Subject: BMN Inspection Volumetric Inspections

Ganesh,

Per your recent request, the attached letter details the bottom mounted nozzle volumetric inspections completed and reported to the MRP.

Craig

Mail Envelope Properties (450EE9D5.E97 : 12 : 32407)

Subject: BMN Inspection Volumetric Inspections
Creation Date 09/18/2006 2:47:38 PM
From: "Harrington, Craig" <charrington@epri.com>

Created By: charrington@epri.com

Recipients

nrc.gov

OWGWPO03.HQGWDO01
GSC (Ganesh Cheruvenki)

nrc.gov

TWGWPO02.HQGWDO01
EJS (Edmund Sullivan)

Post Office

OWGWPO03.HQGWDO01
TWGWPO02.HQGWDO01

Route

nrc.gov
nrc.gov

Files	Size	Date & Time
MESSAGE	170	09/18/2006 2:47:38 PM
TEXT.htm	2299	
MRP letter 2006-032 - BMNs.doc		58368
Mime.822	84679	

Options

Expiration Date: None
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standar

972-556-6519 charrington@epri.com

MRP Materials Reliability Program _____ MRP 2006-032

(via email)

September 15, 2006

To: MRP Technical Advisory Group
 Subject: Bottom Mounted Nozzle (BMN) Inspection Summary (Summer 2006 Update)

This letter provides a summary of US and international BMN volumetric inspection results.

US PWR BMN Volumetric Inspection

Inspections Performed

Fifty-eight of the US PWRs include bottom mounted nozzles in their design. Based on information provided to the MRP through the spring 2006 outage season, the following twelve plants (since the findings at STP-1) have inspected the Alloy 600 bottom mounted nozzle base material with ultrasonic methods. The inspection probes also typically include eddy current capabilities. The NDE methods used were demonstrated in the MRP Alloy 600 BMN blind demonstration program. Note that several plants were unable to inspect one or two of their nozzles.

Byron 1	Catawba 2	McGuire 2	Turkey Point 3
Callaway	Diablo Canyon 1	Surry 1	Turkey Point 4
Catawba 1	Diablo Canyon 2	Surry 2	Wolf Creek

Results

No indications of in-service degradation were identified in these inspections.

The thirteen US inspections have examined twenty percent (716 of a total 3095 including STP-1) of the bottom mounted nozzles in the US fleet.

International PWR BMN Volumetric Inspection

Inspections Performed

Although the MRP does not track all international BMN inspection activities, based on information that has been provided, at least 19 foreign PWRs have conducted volumetric BMN inspections.

Results

No indications of in-service degradation were identified in these inspections.

Please contact me if you have any questions.

Best Regards,
 Craig Harrington
 Project Manager, EPRI MRP Assessment ITG