



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION

Division of Environmental Safety and Health
Radiation Protection and Release Prevention Element
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700
Fax (609) 984-7513

JON S. CORZINE
Governor

LISA P. JACKSON
Commissioner

August 1, 2006

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Salem Generating Station Units 1 and 2
Docket Nos. 50-272 and 50-311
License Change Request S06-05
Request for Change to Technical Specifications
Elimination of the Requirements for Hydrogen Recombiners and
Hydrogen Analyzers Using the Consolidated Line Item Improvement Process

PSEG Nuclear LLC submitted the proposed change to the Salem Technical Specifications by letter to the NRC dated June 7, 2006. The proposed amendment would eliminate the requirements for hydrogen recombiners and hydrogen analyzers. These changes are consistent with Revision 1 of the NRC approved Industry/Technical Specification Task Force (TSTF) Standard Technical Specification (STS) Change Traveler, TSTF-447, "Elimination of Hydrogen Recombiners and Change to Hydrogen and Oxygen Monitors". The availability of this technical specification improvement was announced in the Federal Register on September 25, 2003, as part of the Consolidated Line Item Improvement Process.

The BNE has no comments on the proposed change. If you need to discuss this subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A001

Ditribution

Dr. Jill Lipoti, DEP

Paul Baldauf, DEP

Dennis Zannoni, DEP

Elliot Rosenfeld, DEP

Nancy McNamara, NRC

Stewart Bailey, NRC Licensing Project Manager

Daniel Orr, Sr Resident Inspector

Steven Mannon, Salem Regulatory Assurance Manager, PSEG Nuclear LLC