



State of New Jersey
DEPARTMENT OF ENVIRONMENTAL PROTECTION

JON S. CORZINE
Governor

LISA P. JACKSON
Commissioner

Division of Environmental Safety and Health
Radiation Protection and Release Prevention Element
Bureau of Nuclear Engineering
P. O. Box 415
Trenton, New Jersey 08625-0415
Tel (609) 984-7700
Fax (609) 984-7513

August 24, 2006

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Dear Sir:

Subject: Salem Generating Station Units 1 and 2
Docket Nos. 50-272 and 50-311
License Change Request S05-12
Request for Change to Technical Specifications
Relocation of Movable Incore Detectors and Radioactive
Gaseous Effluent Oxygen Monitoring Instrumentation

PSEG Nuclear LLC submitted the proposed change to the Salem Technical Specifications by letter to the NRC dated June 30, 2006. The proposed amendment would relocate the requirements for "Movable Incore Detectors" and "Radioactive Gaseous Effluent Oxygen Monitoring Instrumentation" from the technical specifications to Updated Final Safety Analysis Report. These changes are consistent with guidance in NRC Generic Letter 95-10, "Relocation of Selected Technical Specification Requirements Related to Instrumentation". These changes are also consistent with NUREG-1431, "Standard Technical Specifications, Westinghouse Plants".

The BNE has no comments on the proposed change. If you need to discuss this subject further, please contact Elliot Rosenfeld at (609) 984-7548.

Sincerely,

Kent W. Tosch, Manager
Bureau of Nuclear Engineering

A001

Ditribution

Dr. Jill Lipoti, DEP

Paul Baldauf, DEP

Dennis Zannoni, DEP

Elliot Rosenfeld, DEP

Nancy McNamara, NRC Region 1

Marjorie McLaughlin, NRC Region1

Stewart Bailey, NRC Licensing Project Manager

~~Daniel Schroeder, Sr Resident Inspector~~

Steven Mannon, Salem Regulatory Assurance Manager, PSEG Nuclear LLC