

September 26, 2006

MEMORANDUM TO: File

FROM: Donald B. Allen, Project Manager */RA/*
New Reactor Licensing Branch
Division of New Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: ESBWR DESIGN CERTIFICATION REVIEW - SUMMARY OF
TELEPHONE CALL HELD ON SEPTEMBER 11, 2006

This memorandum documents actions to be taken as result of telephone conference between the NRC staff and General Electric on September 11, 2006.

Summary of call is attached.

Attachment: As stated

Docket 52-010

September 26, 2006

MEMORANDUM TO: File

FROM: Donald B. Allen, Project Manager */RA/*
New Reactor Licensing Branch
Division of New Reactor Licensing
Office of Nuclear Reactor Regulation

SUBJECT: ESBWR DESIGN CERTIFICATION REVIEW - SUMMARY OF
TELEPHONE CALL HELD ON SEPTEMBER 11, 2006

This memorandum documents actions to be taken as result of telephone conference between the NRC staff and General Electric on September 11, 2006.

Summary of call is attached.

Attachment: As stated

Docket 52-010

Distribution:
NRBA Rdg.
DAllen
JColaccino
ACubbage

ADAMS ACCESSION NO. ML062650326

OFFICE	PM:NRBA
NAME	DAllen
DATE	09/26/2006

OFFICIAL RECORD COPY

Telephone Call Summary

Subject: Discussion of GE's Response to RAI Number 10.4-6 Related to Turbine Gland Seal System

Date of Call: September 11, 2006

Participants

NRC

Amy Cubbage
Jorge Hernandez
Don Allen

GE

Wayne Massie
George Stramback
David Hinds
Kurt Schaefer
John Stryhal
Gary Anthony
Frostie White

Referenced documents

<u>Accession Number</u>	<u>Title</u>	<u>Date</u>
ML061220003	NRC Request for Additional Information Letter No. 23 Related to ESBWR Design Certification Application	May 3, 2006
ML061660143	Response to NRC Request for Additional Information Letter No. 23 Related to ESBWR Design Certification Application - Steam and Power Conversion System - RAI Numbers 10.2-1 through 10.2-19 and 10.4-2 through 10.4-9	June 12, 2006

Actions

Topic

NRC

GE

Response to RAI 10.4-6

GE will revise their response to RAI 10.4-6 by October 20, 2006.

Other Discussion

General Electric agreed to add a design description of the turbine gland seal system in the DCD Tier 1. GE expects to have revised their response to the Request for Additional Information by October 20, 2006.