

Security

NMC > Sites > Point Beach - Action Request > Corrective Actn Program (CAP) AR
Section 1

Activity Request Id: CAP064648

Activity Type: CAP Submit Date: 5/18/2005 10:59:43 AM

One Line Description: 24-Hour FFD ENS Report issued by NRC Operations Center Contained Error

Detailed Description: 5/18/2005 10:59:43 AM - FLENTJE, FRITZIE:
A 24-hour FFD ENS report (EN # 41705) was submitted by PBNP on 05/17/05. The report was submitted on the Unit 1 docket, as is the practice for reporting of events that are non-physical plant and not unit-specific, such as security events. The NRC daily report of the event indicated that Unit 2 was at full power. Unit 2 is shut down for its refueling outage. (Copies of the as-submitted ENS worksheet and daily event report are attached.)

Initiator: FLENTJE, FRITZIE Initiator Department: SRL Licensing

Date/Time of Discovery: 5/18/2005 10:41:35 AM Date/Time of Occurrence: 5/18/2005 10:41:35 AM

Identified By: Site-identified System: (None)

Equipment # (1st): (None) Equipment Name (1st): (None)

Equipment # (2nd): (None) Equipment Name (2nd): (None)

Equipment # (3rd): (None) Equipment Name (3rd): (None)

Site/Unit: Point Beach - None

Why did this occur?: 5/18/2005 10:59:43 AM - FLENTJE, FRITZIE:
Data provided appears to have been modified following receipt at NRC Operations Center.

Immediate Action Taken: 5/18/2005 10:59:43 AM - FLENTJE, FRITZIE:
Discussed with PBNP NRC Senior Resident Inspector. Item was also noted by NRC during daily phone call. NRC will follow up with Operations Center.

Recommendations: 5/18/2005 10:59:43 AM - FLENTJE, FRITZIE:
None. Per NRC Senior Resident Inspector, no further action is required on the part of NMC.

SRO Review Required?: N

Section 2

Operability Status: NA Compensatory Actions: N

Basis for Operability: 5/18/2005 10:59:43 AM - FLENTJE, FRITZIE:
Not an operability issue.
5/18/2005 12:30:26 PM - JESSESSKY, TOM:
No system, structure or component important to nuclear safety is identified as being degraded.

Unplanned TSAC Entry: N External Notification: N

CC-42