



September 20, 2006

L-2006-216
10 CFR 50.4
10 CFR 50.54(f)

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Clarification for St. Lucie Response
To Generic Letter 2006-03

On April 10, 2006, the NRC issued Generic Letter (GL) 2006-03, "Potentially Nonconforming Hemyc and MT Fire Barrier Configurations." Florida Power and Light Company (FPL) docketed the St. Lucie Plant response to GL 2006-03 in Attachment 1 to FPL letter L-2006-118 dated June 9, 2006. In the St. Lucie response to question 1.b, FPL stated that the electrical raceway fire barrier system (ERFBS) design requirement fire resistance equivalency evaluations were performed pursuant to GL 86-10 guidance. The NRC staff subsequently inquired if the above evaluations were performed under the guidance of Supplement 1 to GL 86-10. This letter provides clarification that the fire resistance equivalency evaluations for Thermolag ERFBS were performed pursuant to GL 86-10 Supplement 1 guidance.

Please contact Ken Frehafer at (772) 467-7748 if there are any questions about this submittal.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on the 20th day of SEPTEMBER 2006.

Very truly yours,

A handwritten signature in black ink, appearing to read 'Gordon L. Johnston', is written over a large, stylized circular flourish.

Gordon L. Johnston
Site Vice President
St. Lucie Plant

GLJ/KWF

A125