

Exelon Generation Company, LLC www.exeloncorp.com
LaSalle County Station
2601 North 21st Road
Marseilles, IL 61341-9757

RA-06-64

September 15, 2006

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001

LaSalle County Station, Units 1 and 2
Facility Operating License Nos. NPF-11 and NPF-18
NRC Docket Nos. 50-373 and 50-374

SUBJECT: 2005 Regulatory Commitment Change Summary Report

Enclosed is the Exelon Generation Company, LLC, (EGC), 2005 commitment change summary for LaSalle County Station. Revisions to docketed correspondence were processed using the Nuclear Energy Institute's (NEI) 99-04, Revision 0, "Guidelines for Managing NRC Commitment Changes," dated July 1999.

Should you have any questions concerning this letter, please contact Mr. Terrence Simpkin at (815)-415-2800.

Respectfully,



Daniel Enright
Plant Manager
LaSalle County Station

Attachment

cc: Regional Administrator, NRC Region III
 NRC Senior Resident Inspector - LaSalle County Station

A001

ATTACHMENT
2005 LaSalle County Station Commitment Change Summary

Commitment Change Tracking No.	Date of Commitment Change	Original Document	Original Commitment	Changed Commitment	Basis for Change
05-001	6/24/2005	GL 89-13	The portion of the Lake Screen House Intake Structure from the area downstream of the bar grill to the circulating water system pump inlets is inspected for accumulation of silt, corbicula or zebra mussel infestation, biological debris and concrete degradation <u>once each year</u> .	The portion of the Lake Screen House Intake Structure from the area downstream of the bar grill to the circulating water system pump inlets is inspected for accumulation of silt, corbicula or zebra mussel infestation, biological debris and concrete degradation <u>once every two years</u> .	The Lake Screen House Intake Structure has shown significant decrease in the amount of silt and debris over the last three years. In addition, changing the inspection frequency to once every two years will meet the minimum requirements of GL 89-13 to visually inspect once per refueling cycle.
05-002 Number Not Used					
05-003	8/5/2005	Notice of Violation Response dated 2/14/1989, Inspection Report Nos. 50-373/88022 and 374-88021	Conduct detailed technical review meetings with the fuel vendors on each reload design.	Deleted the commitment.	Improvements made in the current Exelon reload process made the commitment for additional review meetings redundant.