

September 28, 2006

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Vermont Yankee Nuclear Power Station

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON  
AUGUST 7, 2006, BETWEEN THE U.S. NUCLEAR REGULATORY  
COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING  
INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR  
POWER STATION LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Entergy Nuclear Operation, Inc., held a telephone conference call on August 7, 2006, to discuss and clarify the applicant's response to questions asked during the staff's audits associated with the Vermont Yankee Nuclear Station license renewal application. The conference call was useful in clarifying the staff's questions.

Enclosure 1 provides a listing of the conference call participants. Enclosure 2 contains a listing of the issues discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Jonathan Rowley, Project Manager  
License Renewal Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:  
As stated

cc w/encls: See next page

September 28, 2006

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Vermont Yankee Nuclear Power Station

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON AUGUST 7, 2006, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Entergy Nuclear Operation, Inc., held a telephone conference call on August 7, 2006, to discuss and clarify the applicant's response to questions asked during the staff's audits associated with the Vermont Yankee Nuclear Station license renewal application. The conference call was useful in clarifying the staff's questions.

Enclosure 1 provides a listing of the conference call participants. Enclosure 2 contains a listing of the issues discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Jonathan Rowley, Project Manager  
License Renewal Branch B  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:  
As stated

cc w/encls: See next page

ADAMS ACCESSION NUMBER: ML062710359

OFFICE	PM:RLRB	LA:RLRB	BC:RLRB
NAME	Jrowley /RA/	lking /RA/	Jzimmerman /RA/
DATE	09/27/06	09/26/06	09/28/06

OFFICIAL RECORD COPY

Vermont Yankee Nuclear Power Station

cc:

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406-1415

Mr. David R. Lewis  
Pillsbury, Winthrop, Shaw, Pittman, LLP  
2300 N Street, N.W.  
Washington, DC 20037-1128

Mr. David O'Brien, Commissioner  
Vermont Department of Public Service  
112 State Street  
Montpelier, VT 05620-2601

Mr. James Volz, Chairman  
Public Service Board  
State of Vermont  
112 State Street  
Montpelier, VT 05620-2701

Chairman, Board of Selectmen  
Town of Vernon  
P.O. Box 116  
Vernon, VT 05354-0116

Operating Experience Coordinator  
Vermont Yankee Nuclear Power Station  
320 Governor Hunt Road  
Vernon, VT 05354

G. Dana Bisbee, Esq.  
Deputy Attorney General  
33 Capitol Street  
Concord, NH 03301-6937

Chief, Safety Unit  
Office of the Attorney General  
One Ashburton Place, 19th Floor  
Boston, MA 02108

Ms. Deborah B. Katz  
Box 83  
Shelburne Falls, MA 01370

Ms. Carla A. White, RRPT, CHP  
Radiological Health  
Vermont Department of Health  
P.O. Box 70, Drawer #43  
108 Cherry Street  
Burlington, VT 05402-0070

Mr. James M. DeVincentis  
Manager, Licensing  
Vermont Yankee Nuclear Power Station  
P.O. Box 0500  
185 Old Ferry Road  
Brattleboro, VT 05302-0500

Resident Inspector  
Vermont Yankee Nuclear Power Station  
U. S. Nuclear Regulatory Commission  
P.O. Box 176  
Vernon, VT 05354

Director, Massachusetts Emergency  
Management Agency  
ATTN: James Muckerheide  
400 Worcester Rd.  
Framingham, MA 01702-5399

Jonathan M. Block, Esq.  
Main Street  
P.O. Box 566  
Putney, VT 05346-0566

Mr. John F. McCann  
Director, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Gary J. Taylor  
Chief Executive Officer  
Entergy Operations  
1340 Echelon Parkway  
Jackson, MS 39213

Vermont Yankee Nuclear Power Station

cc:

Mr. John T. Herron  
Sr. VP and Chief Operating Officer  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Oscar Limpias  
Vice President, Engineering  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Christopher Schwartz  
Vice President, Operations Support  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Michael J. Colomb  
Director of Oversight  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Travis C. McCullough  
Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Ted Sullivan  
Site Vice President  
Entergy Nuclear Operations, Inc.  
Vermont Yankee Nuclear Power Station  
P.O. Box 0500  
185 Old Ferry Road  
Brattleboro, VT 05302-0500

Mr. James H. Sniezek  
5486 Nithsdale Drive  
Salisbury, MD 21801

Ms. Stacey M. Lousteau  
Treasury Department  
Entergy Services, Inc.  
639 Loyola Avenue  
New Orleans, LA 70113

Mr. Raymond Shadis  
New England Coalition  
Post Office Box 98  
Edgecomb, ME 04556

Mr. James P. Matteau  
Executive Director  
Windham Regional Commission  
139 Main Street, Suite 505  
Brattleboro, VT 05301

Mr. William K. Sherman  
Vermont Department of Public Service  
112 State Street  
Drawer 20  
Montpelier, VT 05620-2601

Mr. Michael D. Lyster  
5931 Barclay Lane  
Naples, FL 34110-7306

Ms. Charlene D. Faison  
Manager, Licensing  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. James Ross  
Nuclear Energy Institute  
1776 I Street, NW, Suite 400  
Washington, DC 20006-3708

Diane Curran, Esq.\*  
Harmon, Curran, Spielberg  
& Eisenberg, L.L.P.  
1726 M Street, NW., Suite 600  
Washington, DC 20036

Letter to Licensee Entergy Nuclear Operations, Inc., from Jonathan Rowley dated September 28, 2006

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON AUGUST 7, 2006, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

**HARD COPY**

DLR R/F

**E-MAIL:**

JFair  
RWeisman  
AMurphy  
RPettis  
GGalletti  
DShum  
GBagchi  
SSmith (srs3)  
SDuraiswamy  
YL (Renee) Li  
RidsNrrDir  
RidsNrrDirRlra  
RidsNrrDirRlrb  
RidsNrrDirRlrc  
RidsNrrDirReba  
RidsNrrDirRebb  
RidsNrrDe  
RidsNrrDci  
RidsNrrEemb  
RidsNrrDeEeeb  
RidsNrrDeEqva  
RidsNrrDeEqvb  
RidsNrrDss  
RidsNrrDnrl  
RidsOgcMailCenter  
RidsNrrAdes

-----  
JRowley  
RLauffer  
JShea  
CAnderson, RI  
R.Powell, RI  
DScrenci, RI  
MModes, RI  
DPelton, Sr. Resident  
MYoung  
RidsOpaMail

**LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL  
TO DISCUSS THE VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION**

August 7, 2006

**PARTICIPANTS**

Jonathan Rowley  
Michael Morgan  
Kaihwa Hsu  
James DeVincentis  
David Lach  
Michael Hamer

**AFFILIATIONS**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
NRC  
Entergy Nuclear Operation, Inc. (ENO)  
ENO  
ENO

**VERMONT YANKEE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION**

August 7, 2006

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Entergy Nuclear Operation, Inc., held a telephone conference call on August 7, 2006, to discuss and clarify the applicant's response to questions asked during the staff's aging management program (AMP), aging management review (AMR), and time-limited aging analysis (TLAA) audits associated with the Vermont Yankee Nuclear Station (VYNPS) license renewal application (LRA). The following issues were discussed during the telephone conference call:

1. Upon review of revision 3 of the VYNPS AMP/AMR/TLAA Audit Question and Answer database (ADAMS Accession number ML062200562), staff required clarification of the applicant's response to audit item 318. Item 318 states:

"The [cumulative usage factor] CUF values in LRA Table 4.3-1 that are based on NUREG CR 6260 are not applicable to VY and need to be removed and the issue addressed. Please clarify the commitment to perform a fatigue re-analysis to be used to address environmental impact. The re-analysis needs to be made to a single code date."

The staff requested that the applicant make the appropriate changes to Table 4.3-3 as where done to Table 4.3-1. In addition, the staff disagreed with the wording of the commitment. In part 2 of the commitment, the applicant states that "...locations with a valid CUF may be substituted for..." The staff's position is that the locations addressed are a minimum, and that the use of the word "substituted" is inaccurate. The staff requested that applicant consider modifying its commitment.

**Discussion:** The applicant indicated that the question is clear. The applicant indicated that they would consider the request and modify the response accordingly. The applicant indicated that any changes would appear in the net revision of the question and answer database.

2. The staff had a question concerning the applicant's license renewal commitments #27 and #29. The staff's position is that the applicant must submit analysis for NRC review and approval two years prior to the period of extended operation. The commitments indicated that only submittal for review was required.

**Discussion:** The applicant indicated that the question is clear and the commitments would be reworded. The revised commitments would appear in a forthcoming letter.

Enclosure 2