

From: Ed Miller
To: michael_okeefe@fpl.com
Date: 09/28/2006 3:04:26 PM
Subject: LAR 05-08

Mike,

Currently, FPLE procedurally limits operational primary-to-secondary leakage to 150 gallons per day (gpd) per Steam Generator (SG) compared to the Technical Specification (TS) limit of 500 gpd per SG. Upon further review, the staff determined that this procedural restriction needs to be contained in a license condition stating that FPLE will maintain the operational limit of primary-to-secondary leakage at 150 gpd per SG and if this limit is exceeded, Seabrook will take the appropriate actions in accordance with TS 3.4.6.2, "Reactor Coolant System Leakage." An e-mail, to be docketed, confirming the acceptability of this condition will be sufficient.

G. Edward Miller
Project Manager
Division of Operating Reactor Licensing
U.S. Nuclear Regulatory Commission
(301) 415-2481

Mail Envelope Properties

(451C1CBA.C19 : 9 : 35080)

Subject: LAR 05-08
Creation Date 09/28/2006 3:04:26 PM
From: Ed Miller

Created By: GXM@nrc.gov

Recipients

fpl.com
PM

michael_okeefe (michael_okeefe@fpl.com)

Action

Transferred

Date & Time

09/28/2006 3:04:52

Post Office**Delivered****Route**

fpl.com

Files

MESSAGE
TEXT.htm

Size

1233
1178

Date & Time

09/28/2006 3:04:26 PM

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject:
Security:

No
Standard

To Be Delivered:
Status Tracking:

Immediate
Delivered & Opened