

**From:** <michael\_okeefe@fpl.com>  
**To:** <GXM@nrc.gov>  
**Date:** 09/28/2006 4:24:13 PM  
**Subject:** Re: LAR 05-08

Ed,

FPL Energy Seabrook LLC concurs with the proposed license condition to limit primary-to-secondary leakage to 150 gallons per day per steam generator and if the limit is exceeded to take appropriate action in accordance with Technical Specification 3.4.6.2, Reactor Coolant System Leakage."

Mike O'Keefe  
FPLE Seabrook  
Regulatory Compliance Supervisor  
603-773-7745 (office)  
603-771-7939 (pager)  
765-6319 (cell)

"Ed Miller"  
<GXM@nrc.gov> To: michael\_okeefe@fpl.com

CC:  
09/28/2006 03:04 Subject: LAR 05-08

PM

Mike,

Currently, FPLE procedurally limits operational primary-to-secondary leakage to 150 gallons per day (gpd) per Steam Generator (SG) compared to the Technical Specification (TS) limit of 500 gpd per SG. Upon further review, the staff determined that this procedural restriction needs to be contained in a license condition stating that FPLE will maintain the operational limit of primary-to-secondary leakage at 150 gpd per SG and if this limit is exceeded, Seabrook will take the appropriate actions in accordance with TS 3.4.6.2, "Reactor Coolant System Leakage." An e-mail, to be docketed, confirming the acceptability of this condition will be sufficient.

G. Edward Miller  
Project Manager  
Division of Operating Reactor Licensing  
U.S. Nuclear Regulatory Commission  
(301) 415-2481

**Mail Envelope Properties**

(451C2F61.42C : 22 : 21548)

**Subject:** Re: LAR 05-08  
**Creation Date** 09/28/2006 4:25:39 PM  
**From:** <michael\_okeefe@fpl.com>

**Created By:** michael\_okeefe@fpl.com

**Recipients**

nrc.gov  
TWGWPO01.HQGWDO01  
GXM (Ed Miller)

**Post Office**

TWGWPO01.HQGWDO01

**Route**

nrc.gov

**Files**

MESSAGE  
Mime.822

**Size**

2306  
3683

**Date & Time**

09/28/2006 4:25:39 PM

**Options**

**Expiration Date:** None  
**Priority:** Standard  
**ReplyRequested:** No  
**Return Notification:** None

**Concealed Subject:** No  
**Security:** Standard

**Junk Mail Handling Evaluation Results**

Message is eligible for Junk Mail handling  
This message was not classified as Junk Mail

**Junk Mail settings when this message was delivered**

Junk Mail handling disabled by User  
Junk Mail handling disabled by Administrator  
Junk List is not enabled  
Junk Mail using personal address books is not enabled  
Block List is not enabled