

September 29, 2006

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Vermont Yankee Nuclear Power Station

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON
AUGUST 10, 2006, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING
INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR
POWER STATION LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on August 10, 2006, to discuss and clarify the staff's requests for additional information concerning the Vermont Yankee Nuclear Station license renewal application. The conference call was useful in clarifying the staff's questions.

Enclosure 1 provides a listing of the conference call participants. Enclosure 2 contains a listing of the issues discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Jonathan Rowley, Project Manager
License Renewal Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:
As stated

cc w/encls: See next page

September 29, 2006

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Vermont Yankee Nuclear Power Station

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON AUGUST 10, 2006, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR POWER STATION LICENSE RENEWAL APPLICATION

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on August 10, 2006, to discuss and clarify the staff's requests for additional information concerning the Vermont Yankee Nuclear Station license renewal application. The conference call was useful in clarifying the staff's questions.

Enclosure 1 provides a listing of the conference call participants. Enclosure 2 contains a listing of the issues discussed with the applicant, including a brief description on the status of the items.

The applicant had an opportunity to comment on this summary.

/RA/

Jonathan Rowley, Project Manager
License Renewal Branch B
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-271

Enclosures:
As stated

cc w/encls: See next page

ADAMS ACCESSION NUMBER: **ML062720218**

OFFICE	PM:RLRB	LA:RLRB	BC:RLRB
NAME	Jrowley /RA/	I. King /RA/	Jzimmerman /RA DJM for/
DATE	09/28/06	09/28/06	09/29/06

OFFICIAL RECORD COPY

Vermont Yankee Nuclear Power Station

cc:

Regional Administrator, Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. David R. Lewis
Pillsbury, Winthrop, Shaw, Pittman, LLP
2300 N Street, N.W.
Washington, DC 20037-1128

Mr. David O'Brien, Commissioner
Vermont Department of Public Service
112 State Street
Montpelier, VT 05620-2601

Mr. James Volz, Chairman
Public Service Board
State of Vermont
112 State Street
Montpelier, VT 05620-2701

Chairman, Board of Selectmen
Town of Vernon
P.O. Box 116
Vernon, VT 05354-0116

Operating Experience Coordinator
Vermont Yankee Nuclear Power Station
320 Governor Hunt Road
Vernon, VT 05354

G. Dana Bisbee, Esq.
Deputy Attorney General
33 Capitol Street
Concord, NH 03301-6937

Chief, Safety Unit
Office of the Attorney General
One Ashburton Place, 19th Floor
Boston, MA 02108

Ms. Carla A. White, RRPT, CHP
Radiological Health
Vermont Department of Health
P.O. Box 70, Drawer #43
108 Cherry Street
Burlington, VT 05402-0070

Mr. James M. DeVincentis
Manager, Licensing
Vermont Yankee Nuclear Power Station
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Resident Inspector
Vermont Yankee Nuclear Power Station
U. S. Nuclear Regulatory Commission
P.O. Box 176
Vernon, VT 05354

Director, Massachusetts Emergency
Management Agency
ATTN: James Muckerheide
400 Worcester Rd.
Framingham, MA 01702-5399

Jonathan M. Block, Esq.
Main Street
P.O. Box 566
Putney, VT 05346-0566

Mr. John F. McCann
Director, Licensing
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Gary J. Taylor
Chief Executive Officer
Entergy Operations
1340 Echelon Parkway
Jackson, MS 39213

cc:

Mr. John T. Herron
Sr. VP and Chief Operating Officer
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Oscar Limpias
Vice President, Engineering
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Christopher Schwartz
Vice President, Operations Support
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Michael J. Colomb
Director of Oversight
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Travis C. McCullough
Assistant General Counsel
Entergy Nuclear Operations, Inc.
440 Hamilton Avenue
White Plains, NY 10601

Mr. Theodore Sullivan
Site Vice President
Entergy Nuclear Operations, Inc.
Vermont Yankee Nuclear Power Station
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Mr. James H. Sniezek
5486 Nithsdale Drive
Salisbury, MD 21801

Mr. Garrett D. Edwards
814 Waverly Road
Kennett Square, PA 19348

Ms. Stacey M. Lousteau
Treasury Department
Entergy Services, Inc.
639 Loyola Avenue
New Orleans, LA 70113

Mr. Norman L. Rademacher
Director, NSA
Vermont Yankee Nuclear Power Station
P.O. Box 0500
185 Old Ferry Road
Brattleboro, VT 05302-0500

Mr. Raymond Shadis
New England Coalition
Post Office Box 98
Edgecomb, ME 04556

Mr. James P. Matteau
Executive Director
Windham Regional Commission
139 Main Street, Suite 505
Brattleboro, VT 05301

Mr. William K. Sherman
Vermont Department of Public Service
112 State Street
Drawer 20
Montpelier, VT 05620-2601

Mr. Michael D. Lyster
5931 Barclay Lane
Naples, FL 34110-7306

Ms. Charlene D. Faison
Manager, Licensing
440 Hamilton Avenue
White Plains, NY 10601

Mr. James Ross
Nuclear Energy Institute
1776 I Street, NW, Suite 400
Washington, DC 20006-3708

Vermont Yankee Nuclear Power Station

-3-

cc:

Diane Curran, Esq.
Harmon, Curran, Spielberg &
Eisenberg, L.L.P
1726 M Street, NW, Suite 600
Washington, DC 20036

Note to Entergy Nuclear Operations, Inc., from Jonathan Rowley dated September 29, 2006

SUBJECT: SUMMARY OF A TELEPHONE CONFERENCE CALL HELD ON
AUGUST 10, 2006, BETWEEN THE U.S. NUCLEAR REGULATORY
COMMISSION AND ENTERGY NUCLEAR OPERATIONS, INC., CONCERNING
INFORMATION PERTAINING TO THE VERMONT YANKEE NUCLEAR
POWER STATION LICENSE RENEWAL APPLICATION

HARD COPY

DLR R/F
JRowley

E-MAIL:

JFair
RWeisman
AMurphy
RPettis
GGalletti
DShum
GBagchi
SSmith (srs3)
SDuraiswamy
YL (Renee) Li
RidsNrrDir
RidsNrrDirRlra
RidsNrrDirRlrb
RidsNrrDirRlrc
RidsNrrDirReba
RidsNrrDirRebb
RidsNrrDe
RidsNrrDci
RidsNrrEemb
RidsNrrDeEeeb
RidsNrrDeEqva
RidsNrrDss
RidsNrrDnrl
RidsOgcMailCenter
RidsNrrAdes

JRowley
RLaufer
JShea
CAnderson, RI
R.Powell, RI
DScrenci, RI
MModes, RI
DPelton, Sr. Resident
MYoung
RidsOpaMail

**LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL
TO DISCUSS THE VERMONT YANKEE NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION**

August 10, 2006

PARTICIPANTS

Jonathan Rowley
Ronald Young
Ganesh Cheruvenki
Jim Nicholas
Mike Hamer
Andy Taylor
Lori Potts
Allan Cox

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)
NRC
NRC
Pacific Northwest National Laboratory
Entergy Nuclear Operations, Inc. (ENO)
ENO
ENO
ENO

**VERMONT YANKEE NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION**

August 10, 2006

The U.S. Nuclear Regulatory Commission staff (the staff) and representatives of Entergy Nuclear Operations, Inc., held a telephone conference call on August 10, 2006, to discuss and clarify the staff's requests for additional information (RAIs) concerning the Vermont Yankee Nuclear Power Station (VYNPS) license renewal application (LRA). The following issues were discussed during the telephone conference call:

RAI-B.1.2-1

The applicant states that the Control Rod Drive (CRD) return line nozzle has been capped at the VYNPS unit. The staff requests that the applicant provide the following information regarding the cap and the weld:

- (1) Describe the configuration, location and material of construction of the capped nozzle. This should include the existing base material for the nozzle, piping (if piping remnants exist) and cap material, and any welds.
- (2) Describe how the aging effects for this weld and the cap are managed in accordance with the guidelines of Boiling Water Reactor Vessel and Internals Project-75 (BWRVIP-75), "BWR Vessel and Internals Project, Technical Basis for Revisions to Generic Letter 88-01 Inspection Schedule."
- (3) Discuss whether the event at Pilgrim Nuclear Power Station (Pilgrim)(leaking weld at capped nozzle, September 30, 2003) is applicable to VYNPS. The staff issued Information Notice 2004-08, "Reactor Coolant Pressure Boundary Leakage Attributable to Propagation of Cracking in Reactor Vessel Nozzle Welds," dated April 22, 2004, which states that the cracking occurred in an Alloy 182 weld that was previously repaired extensively. Discuss experience with previous leakage at the VYNPS capped nozzle, if any. Include in your discussion the past inspection techniques applied, the results obtained, and mitigative strategies imposed. Provide information as to how the plant-specific experience related to this aging effect impacts the attributes specified in Aging Management Program B.1.2, "BWR CRD Return Line Nozzles."

Discussion: The applicant believed that this question was similar to an RAI issued for the Pilgrim LRA. The staff pointed out the differences. The applicant indicated that the question is clear.

RAI-B.1.2-2

The applicant also states that CRD return lines are connected to the reactor water clean-up (RWCU) piping system which is classified as a non-safety system. Since previous inspection results for these welds indicated no cracking, the applicant proposed to delete the inspection requirements for these welds during the extended period of operation. In order to effectively evaluate this proposal, provide the following information regarding the welds between the CRD return line and the RWCU piping:

Enclosure 2

- (1) Provide information regarding the total number of the CRD return lines that are welded to the RWCU piping.
- (2) Provide a drawing or a sketch indicating the safety/non-safety boundary of these welds. Additionally, the applicant should confirm that all safety-related welds will be inspected per the American Society of Mechanical Engineers Code, Section XI, Inservice Inspection program. Since the applicant intends to not perform inspections of these welds during the extended period of operation, the applicant should provide a technical justification for not performing the inspections of these welds taking into account the effects of aging degradation and effective techniques that will be used to mitigate the aging process.
- (3) Provide information regarding the type of base metal and weld metal that are used in these welds. If austenitic stainless steel weld metal is used for these welds, the applicant should provide information regarding the amount of delta ferrite that is present in these welds. This information is necessary in assessing the susceptibility of these welds to intergranular stress-corrosion cracking (IGSCC). If the predominant aging mechanism in these welds is other than IGSCC, the applicant should identify the aging mechanism, the techniques it intends to use in mitigating the aging degradation, and aging monitoring program for these welds.

Discussion: The applicant indicated that the question is not clear. The staff will reword this RAI.

RAI 2.3.3.2a-1

License Renewal (LR) Drawing LRA-G-191159-SH-01-0, Location H-12, depicts pipe section 2"-SW-566C to be within the scope of LR. Upstream from where 2"-SW-566C enters the RX Building from outside there is no drawing continuation to depict the LR boundary. Provide details for the continuation of 2"-SW-566C to the LR boundary and justify the boundary locations with respect to the applicable requirements of Title 10 of the *Code of Federal Regulations* Section 54.4(a) (10 CFR 54.4(a)).

Discussion: The applicant indicated that the question is clear.

RAI 2.3.3.2a-2

LR Drawing LRA-G-191159-SH-01-0, at Location H-11, Drawing Note 16 indicates piping section (4"-SW-567) and supports on the Reactor Building Air Conditioning supply piping where the vacuum breakers tie in are structure and components 2 for structural integrity. This pipe section from Valve 23D through Valves RBAC-1A, 1B, 1C and 1D is not within the scope of LR. Failure of this section of pipe could have an effect on the LR intended pressure boundary function for the service water piping. Provide additional information on why this section of pipe and components are not within the scope for LR and justify the boundary locations with respect to the applicable requirements of 10 CFR 54.4(a).

Discussion: The applicant indicated that the question is clear and directed the staff to a different location of the LRA where the information could be found. The staff was requested to determine if the information in Table 2.3.3.13-B addresses the concern. The staff will evaluate the information in the table and withdraw the RAI if found adequate.

RAI 2.3.3.3-1

LR Drawing, LRA-G-191159-SH-05-0, Location P-10 at Valve 29 is within the scope of LR. This section of pipe is the RBCCW return to the Alternate Cooling System. There is not a drawing continuation provided. Provide details for the continuation of this piping section to the LR boundary and justify the boundary locations with respect to the applicable requirements of 10 CFR 54.4(a).

Discussion: The applicant indicated that the question is not clear. The staff incorrectly referenced the drawing of interest. The staff will issue this RAI with the correct drawing reference of LRA-G-191159-SH-03-0.

RAI 2.3.3.6-1

LR Drawing, LRA-G-191162 Sheet 2, provides details about the fail open (FO) supported emergency diesel generators, diesel-driven fire pump, and house heating boiler systems. However, the drawing does not provide details about the John Deere Diesel system that is also supported by the FO system, e.g., details about the transfer system between the 75,000 gallon fuel oil storage tank and the day tanks for the two John Deere diesels and single fire pump diesel which are required to provide an intended function for 10 CFR 54.4 (a)(3) in support of the fire protection regulation (10 CFR 50.48). The LRA text mentions only that a 500-gallon portable tank is used to transport fuel oil to those diesels. Typical aging management review (AMR) components for diesels like the day tank, strainer, etc., for the John Deere Diesel are not covered. Provide the FO system drawings to include a schematic of the John Deere diesel system to establish the relationship to the FO system and to clarify where and what the AMR tables should include in both Sections 2.3.3.6 and 2.3.3.12. Also, provide additional information for the LR boundary and justify its location with respect to the applicable requirements of 10 CFR 54.4(a).

Discussion: The applicant indicated that the question is clear. The staff agreed to allow the applicant to describe the system rather than having to provide a system drawing.

RAI 2.2-2

The Nuclear System Leakage Rate Limits and Leakage Detection Systems are described in Section 4.10 of the VYNPS Updated Final Safety Analysis Report (UFSAR). Identified and unidentified leakage rates are an important aspect of plant operation and Technical Specifications. Section 4.10 of the UFSAR does not specifically address a single “leakage detection system,” but describes a “leakage detection method” with references to other supporting systems. There were no LRA sections identified to address the leakage detection methods and systems described in UFSAR Section 4.10. The applicant is asked to clarify if the leakage detection systems and components are included in the LR scope or the basis for their exclusion.

Discussion: The applicant indicated that the question is too general and requested the staff be more specific. The staff will reword the RAI accordingly prior to submittal.