



Westinghouse

R2/E73

Westinghouse Electric Company
Nuclear Fuel
Columbia Fuel Site
P.O. Drawer R
Columbia, South Carolina 29250
USA

U. S. Nuclear Regulatory Commission
ATTN: Regional Administrator, RII
Region II
61 Forsyth Street SW, Suite 23T85
Atlanta, GA 30303

Direct tel: 803-647-1000

Our ref: LTR-RAC-04-10

August 30, 2004

Dear Sir:

Subject: SNM-1107/70-1151

The following report fulfills regulatory requirements as listed in 10CFR 40.65 and 10CFR 70.59 "Effluent Monitoring Requirements." For the six-month period January 1, 2004 through June 30, 2004, the following quantities of radionuclides were released to the unrestricted area by the Westinghouse Electric Company's Columbia, South Carolina Nuclear Fuel Plant:

- A. Gaseous 314.8 uCi Uranium (Analyzed as gross alpha)
- B. Liquid Effluent 22,354.9 uCi - U-234
1276.7 uCi - U-235
3181.6 uCi - U-238

Gaseous effluent results were obtained from point source gross alpha analysis of stack gas effluent, and the individual radionuclide composition is inferred from the calculated average enrichment (85.0% U-234, 3.0% U-235, and 12.0% U-238). A detailed summary report by stack is provided as Attachment "A."

Liquid effluent values were obtained by analysis of composite proportional samples prior to discharge to the Congaree River and basing the activity on the calculated average enrichment. All liquid discharges are pumped through a single discharge line to Congaree River. A detailed summary liquid discharge report is provided as Attachment "B."

Sincerely,

WESTINGHOUSE ELECTRIC COMPANY

Samuel G. McDonald, Manager
Environment, Health and Safety

cc: U.S. NRC, (2)
ATTN: William Gloerson
61 Forsyth Street SW, Suite 23T85
Atlanta, GA 30303

Document Control Desk, Director (2)
Office of Nuclear Material Safety and Safeguards
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

L-11

ATTACHMENT "B"
LIQUID EFFLUENT DISCHARGES
FIRST HALF 2004

- A. Report Period: January 1, through June 30, 2004
B. Sample Location: Composite Sampler at Waste Treatment, prior to discharge to Congaree River
C. Total Liquid Flow: 7.770 E+07 liters
D. Sample Collection: Effluent Composite Sampler

Radioisotope	Concentration		LLD, uCi/ml	Quantity Released, uCi
	uCi/ml	Error		
U-234	2.88 E-07	+/-0.08 E-08	6.00 E-10	22,354.9
U-235	1.64 E-08	+/-0.19 E-08	6.00 E-10	1276.7
U-238	4.09 E-08	+/-0.27 E-08	6.00E-10	3181.6
Total				26,813.3

Note:

1. Liquid effluent composites were analyzed by alpha spectroscopy, and significant quantities of U-236 were not detected using this method.

Attachment "A" GASEOUS EFFLUENT DISCHARGES -JANUARY 1 THROUGH JUNE 30, 2004

2004 FIRST HALF GASEOUS EFFLUENTS STACK IDENTIFICATION	QUANTITY RELEASED uCi URANIUM/6months	GROSS ALPHA (URANIUM)			LLD, uCi/ml	Flow Rate Meters/sec	Derived Isotopic Concentration uCi/ml			DERIVED ISOTOPIC DISCHARGE, uCi		
		Conc., uCi/ml	ERROR	+			U234	U235	U238	U234	U235	U238
1 FURNACE EX LINE 1	3.74	8.66E-14	+/-	3.33E-14	8.00E-14	2.78	7.36E-14	2.60E-15	1.04E-14	3.18	0.11	0.45
2 FURNACE EX LINE 2	4.72	1.09E-13	+/-	3.74E-14	8.00E-14	2.78	9.27E-14	3.27E-15	1.31E-14	4.01	0.14	0.57
3 FURNACE EX LINE 3	4.31	9.98E-14	+/-	3.58E-14	8.00E-14	2.78	8.48E-14	2.99E-15	1.20E-14	3.66	0.13	0.52
4 FURNACE EX LINE 4	3.85	8.92E-14	+/-	3.38E-14	8.00E-14	2.78	7.58E-14	2.68E-15	1.07E-14	3.27	0.12	0.46
5 FURNACE EX LINE 5	5.45	5.45E-14	+/-	2.64E-14	8.00E-14	2.78	4.63E-14	1.64E-15	6.54E-15	4.63	0.16	0.65
6 NEW DECON RM	18.15	7.12E-13	+/-	1.54E-13	8.00E-14	1.64	6.05E-13	2.14E-14	8.54E-14	15.43	0.54	2.18
7 MET LAB EX	4.76	5.51E-13	+/-	1.35E-13	8.00E-14	0.56	4.68E-13	1.65E-14	6.61E-14	4.05	0.14	0.57
8 INCINER EX	2.72	4.01E-13	+/-	1.15E-13	8.00E-14	1.89	3.41E-13	1.20E-14	4.81E-14	2.31	0.08	0.33
9 SUPPL INC EX	2.18	3.80E-13	+/-	1.12E-13	8.00E-14	0.94	3.23E-13	1.14E-14	4.56E-14	1.85	0.07	0.26
10 CONVERTS 1-A EX	14.83	2.31E-13	+/-	5.44E-14	8.00E-14	4.17	1.96E-13	6.93E-15	2.77E-14	12.61	0.44	1.78
11 CONVERSION 1-B	0.23	4.48E-13	+/-	7.58E-14	8.00E-14	4.17	3.81E-13	1.34E-14	5.38E-14	0.20	0.01	0.03
12 S-1030-A	12.52	1.13E-13	+/-	3.80E-14	8.00E-14	7.50	9.61E-14	3.39E-15	1.36E-14	10.64	0.38	1.50
13 S-1030-B	4.10	5.61E-13	+/-	8.48E-14	8.00E-14	7.50	4.77E-13	1.68E-14	6.73E-14	3.49	0.12	0.49
14 MAINT ENCL 4B	0.00	4.50E-13	+/-	7.59E-14	8.00E-14	3.89	3.83E-13	1.35E-14	5.40E-14	0.00	0.00	0.00
15 CONV ENCL EX 4C	8.66	1.43E-13	+/-	4.28E-14	8.00E-14	3.89	1.22E-13	4.29E-15	1.72E-14	7.36	0.26	1.04
16 CONV ENCL EX 4D	0.00	2.59E-13	+/-	5.76E-14	8.00E-14	3.89	2.20E-13	7.77E-15	3.11E-14	0.00	0.00	0.00
17 CONV EMERG EX 4E	1.24	4.33E-13	+/-	7.45E-14	8.00E-14	3.89	3.68E-13	1.30E-14	5.20E-14	1.05	0.04	0.15
18 CHEM LAB FILTERED EX	9.01	1.04E-13	+/-	3.65E-14	8.00E-14	5.56	8.84E-14	3.12E-15	1.25E-14	7.66	0.27	1.08
19 DECON ROOM EX	15.02	6.82E-13	+/-	9.35E-14	8.00E-14	1.42	5.80E-13	2.05E-14	8.18E-14	12.77	0.45	1.80
20 CAL COMBGAS LN 1	2.29	8.97E-13	+/-	1.07E-13	8.00E-14	0.16	7.62E-13	2.69E-14	1.08E-13	1.95	0.07	0.27
21 CAL COMBGAS LN 2	1.35	5.29E-13	+/-	9.35E-14	8.00E-14	0.16	4.50E-13	1.59E-14	6.35E-14	1.15	0.04	0.16
22 CAL COMBGAS LN 3	0.63	2.48E-13	+/-	5.64E-14	8.00E-14	0.16	2.11E-13	7.44E-15	2.98E-14	0.54	0.02	0.08
23 CAL COMBGAS LN 4	0.56	2.21E-13	+/-	0.00E+00	8.00E-14	0.16	0.00E+00	0.00E+00	0.00E+00	0.48	0.02	0.07
24 CAL COMBGAS LN 5	2.31	9.07E-13	+/-	1.08E-13	8.00E-14	0.16	7.71E-13	2.72E-14	1.09E-13	1.96	0.07	0.28
25 CHEM LAB # 2	3.71	4.09E-13	+/-	7.24E-14	8.00E-14	0.16	3.48E-13	1.23E-14	4.91E-14	3.15	0.11	0.45
26 CHEM LAB #3	0.48	9.70E-14	+/-	3.53E-14	8.00E-14	0.58	8.25E-14	2.91E-15	1.16E-14	0.41	0.01	0.06
27 HP LAB EX	0.94	1.04E-13	+/-	3.65E-14	8.00E-14	0.64	8.84E-14	3.12E-15	1.25E-14	0.80	0.03	0.11
28 DEV LAB 1 EX	2.31	1.57E-13	+/-	4.48E-14	8.00E-14	0.58	1.33E-13	4.71E-15	1.88E-14	1.96	0.07	0.28
29 DEV LAB 2 EX	7.83	5.33E-13	+/-	8.26E-14	8.00E-14	0.94	4.53E-13	1.60E-14	6.40E-14	6.66	0.23	0.94
30 PELLET COMBINED	16.82	2.29E-13	+/-	5.42E-14	8.00E-14	0.94	1.95E-13	6.87E-15	2.75E-14	14.30	0.50	2.02
31 SOLV X N	13.47	3.03E-13	+/-	6.23E-14	8.00E-14	4.72	2.58E-13	9.09E-15	3.64E-14	11.45	0.40	1.62
32 SOLV X S	1.72	2.32E-13	+/-	5.45E-14	8.00E-14	3.33	1.97E-13	6.96E-15	2.78E-14	1.46	0.05	0.21
33 SCRAP REC DRY	16.16	1.10E-12	+/-	1.19E-13	8.00E-14	3.33	9.35E-13	3.30E-14	1.32E-13	13.74	0.48	1.94
34 MAP COMBINED	0	3.67E-13	+/-	6.86E-14	8.00E-14	0.94	3.12E-13	1.10E-14	4.40E-14	0.00	0.00	0.00
35 ABF HOOD TORIT EX	6.66	3.02E-13	+/-	6.22E-14	8.00E-14	1.42	2.57E-13	9.06E-15	3.62E-14	5.66	0.20	0.80
36 IFBA EX	6.14	8.35E-14	+/-	3.27E-14	8.00E-14	4.72	7.10E-14	2.51E-15	1.00E-14	5.22	0.18	0.74
37 MAINT WELD EX	3.94	2.68E-13	+/-	5.86E-14	8.00E-14	0.94	2.28E-13	8.04E-15	3.22E-14	3.35	0.12	0.47
38 AC-3	5.58	9.50E-14	+/-	3.49E-14	8.00E-14	3.78	8.08E-14	2.85E-15	1.14E-14	4.74	0.17	0.67
39 BULK BLEND EX	3.84	8.88E-14	+/-	3.37E-14	8.00E-14	2.78	7.55E-14	2.66E-15	1.07E-14	3.26	0.12	0.46
40 AC-5	6.28	1.07E-13	+/-	3.70E-14	8.00E-14	3.78	9.10E-14	3.21E-15	1.28E-14	5.34	0.19	0.75
41 AC-8	4.91	8.36E-14	+/-	3.27E-14	8.00E-14	3.78	7.11E-14	2.51E-15	1.00E-14	4.17	0.15	0.59
42 AMMONIA FUME SC 1008-A	3.12	1.08E-13	+/-	3.72E-14	8.00E-14	1.89	9.18E-14	3.24E-15	1.30E-14	2.65	0.09	0.37
43 AMMONIA FUME SC 1008-B	0.19	3.63E-13	+/-	6.82E-14	8.00E-14	1.89	3.09E-13	1.09E-14	4.36E-14	0.16	0.01	0.02
44 AC-4	5.16	8.53E-14	+/-	3.31E-14	8.00E-14	3.89	7.25E-14	2.56E-15	1.02E-14	4.39	0.15	0.62
45 HOT OIL RM EX	35.21	5.82E-13	+/-	8.63E-14	8.00E-14	3.89	4.95E-13	1.75E-14	6.98E-14	29.93	1.06	4.23
46 ERBIA FURNACE EX	37.77	2.97E-13	+/-	6.17E-14	8.00E-14	8.17	2.52E-13	8.91E-15	3.56E-14	32.10	1.13	4.53
47 ERBIA SCRUBBER EX	5.7	8.46E-14	+/-	3.29E-14	8.00E-14	4.33	7.19E-14	2.54E-15	1.02E-14	4.85	0.17	0.68
48 ERBIA CHANGE ROOM	4.18	1.42E-13	+/-	4.27E-14	8.00E-14	1.90	1.21E-13	4.26E-15	1.70E-14	3.55	0.13	0.50

Total uCi 314.8

TOTAL DERIVED ISOTOPIC 267.5 9.4 37.8 Total 314.8