



October 3, 2006

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Serial No. 06-801
KPS/LIC/GR: R0
Docket No. 50-305
License No. DPR-43

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION
2004 INSERVICE INSPECTION SUMMARY REPORT CORRECTION

On February 24, 2005, Kewaunee Power Station (KPS) submitted the KPS 2004 Inservice Inspection (ISI) Summary Report (ADAMS Accession No. ML050620242). Subsequently, an error was discovered in a Form NIS-2, "Owners Report for Repair/Replacement Activity," which was included in the report. This Form NIS-2 is located in Enclosure 9 of the ISI Summary Report and is labeled as Work Order number 04-008484.

The corrected Form NIS-2 is enclosed. Dominion Energy Kewaunee, Inc. (DEK) requests the Form NIS-2 for Work Order 04-008484 submitted in the February 24, 2005 ISI Summary Report be replaced with the enclosed corrected Form NIS-2. DEK apologizes for any inconvenience this may cause.

If you have questions or require additional information, please feel free to contact Mr. Gerald O. Riste, at 920-388-8424.

Very truly yours,

A handwritten signature in black ink, appearing to read "Gerald T. Bischof".

Gerald T. Bischof
Vice President - Nuclear Engineering

Enclosure – Corrected Form NIS-2 for Work Order 04-008484

Commitments made by this letter: None

cc: Regional Administrator
U. S. Nuclear Regulatory Commission
Region III
2443 Warrenville Road
Suite 210
Lisle, Illinois 60532-4352

Mr. D. H. Jaffe
Project Manager
U.S. Nuclear Regulatory Commission
Mail Stop O-7-D-1
Washington, D. C. 20555

Mr. S. C. Burton
NRC Senior Resident Inspector
Kewaunee Power Station

FORM NIS-2 OWNER'S REPORT FOR REPAIR/REPLACEMENT ACTIVITY

As Required by the Provisions of the ASME Code Section XI

- | | |
|--|---|
| 1. Owner <u>Dominion Energy-Kewaunee</u> | Date <u>09/07/2006</u> |
| <u>N490 Highway 42, Kewaunee, Wisconsin 54216-9511</u> | Sheet <u>1</u> of <u>2</u> |
| 2. Plant <u>Kewaunee Power Station</u> | Unit <u>No. 1</u> |
| <u>N490 Highway 42, Kewaunee, Wisconsin 54216-9511</u> | Work Order <u>04-008484</u> |
| 3. Work Performed By <u>Dominion Energy-Kewaunee</u> | Type Code Sym. Stamp <u>NA</u> |
| <u>N490 Highway 42, Kewaunee, Wisconsin 54216-9511</u> | Authorization No. <u>NA</u> |
| 4. Identification of System <u>35</u> Class <u>2</u> <u>CHEMICAL AND VOLUME CONTROL</u> | Expiration Date <u>NA</u> |
| 5. (a) Applicable Construction Code <u>B16.34-SEC. III-1982</u> | (c) Applicable Section XI Code Case <u>NA</u> |
| (b) Applicable Edition of Section XI Used for Repair/Replacement Activity <u>1998 Edition 2000 Addenda</u> | |
| 6. Identification of Components | |

Name of Component	Name of Manufacturer	Manufacturer Serial No.	National Board No.	Other ID	Year Built	Corrected, Removed, or Installed	ASME Code Stamped
CVC-5C	KEROTEST MFG CORP	AJ 03-7	NA	CS002-015	1986	INSTALLED	N

7. Description of Work REPLACE CLASS 2 CHEMICAL AND VOLUME CONTROL SYSTEM 2" VALVE CVC-5C AND 6 - 2" SOCKET WELDS.

8. Tests conducted
- | | | | | | | | |
|-------------|--------------------------|-----------|--------------------------|----------------------------|-------------------------------------|--------|--------------------------|
| Hydrostatic | <input type="checkbox"/> | Pneumatic | <input type="checkbox"/> | Nominal Operating Pressure | <input checked="" type="checkbox"/> | Exempt | <input type="checkbox"/> |
| Other | <input type="checkbox"/> | Pressure | <u>2235</u> psi | Test Temp. | <u>112</u> deg. F | | |

9. Remarks NIS-2 FORM IS A CORRECTED COPY PER KEWAUNEE CAP 036348. IN DESCRIPTION OF WORK CHANGED 2" VALVE CVC-5C AND 2 - 2" SOCKET WELDS TO 2" VALVE CVC-5C AND 6 - 2" SOCKET WELDS.

Applicable Manufacturer's Data Reports to be Attached

NIS-2 (Back)

Sheet 2 of 2

Date: 09/07/2006

Name of Component: CVC-5C

Work Order Number: 04-008484

CERTIFICATE OF COMPLIANCE

I certify that the statements made in the report are correct and that this INSTALLED conforms to the requirements of the ASME Code, Section XI.

Type Code Symbol Stamp NA

Certificate of Authorization No. NA

Expiration Date NA

Signed Phillip E. Baker Inspection Program Owner Date September 8, 20 06
Owner or Owner's Designee, Title

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Wisconsin and employed by Hartford Steam Boiler Inspection and Insurance Company of CT have inspected the components described in this Owner's Report during the period 9/8/06 to 9/8/06, and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

James A. Limery
Inspector's Signature

Commissions NB 11622, I, N, B, A WIS 100131
National Board, State, Province, and Endorsements

Date 8 SEPTEMBER, 20 06