



10 CFR 50.90

LR-N06-0398  
LCR H05-04  
September 25, 2006

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

Hope Creek Generating Station  
Facility Operating License No. NPF-57  
NRC Docket No. 50-354

Subject: Partial Withdrawal of License Amendment Request to Relocate  
Overcurrent Protective Devices

- References:
- 1) PSEG letter LR-N05-0030, "Request for Change to Technical Specifications: Relocation of Overcurrent Protective Devices," October 11, 2005
  - 2) NRC letter, "Hope Creek Generating Station - Issuance of Amendment Re: Deletion of Component Identification for Overcurrent Protective Devices (TAC No. MD1090)," April 10, 2006
  - 3) NRC letter, "Hope Creek Generating Station - Request for Additional Information Related to Amendment Request to Relocate Overcurrent Protective Devices (TAC NO. MC8602)," August 24, 2006

In Reference 1, PSEG Nuclear LLC (PSEG) requested changes to the Technical Specifications (TS) for Hope Creek Generating Station to relocate TS requirements for overcurrent protective devices to the Updated Final Safety Analysis Report (UFSAR). Relocation of the TS requirements for primary containment penetration overcurrent protective devices is consistent with NUREG-1433, "Standard Technical Specifications General Electric Plants, BWR/4." In Reference 2, the NRC approved a portion of the proposed change, specifically relocation of the component identifiers from the overcurrent protective device lists in TS 3/4.8.4.1 and TS 3/4.8.4.5. In addition, the NRC stated that it would continue reviewing the proposed relocation of the remainder of TS 3/4.8.4.1 and TS 3/4.8.4.5.

4001

LR-N06-0398  
September 25, 2006  
Page 2

Reference 3 stated that additional information is necessary for the NRC staff to complete its review. PSEG has determined that the portion of the proposed change approved in Reference 2 is sufficient to support current operation and maintenance activities and that the remainder of the request from Reference 1 is not required. Therefore PSEG withdraws the remainder of the proposed change still under NRC review.

If you have any questions or require additional information, please contact Paul Duke at 856-339-1466.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael Jesse", with a stylized flourish at the end.

Michael Jesse  
Regulatory Assurance Manager  
Hope Creek

cc: S. Collins, Regional Administrator – NRC Region I  
S. Bailey, Project Manager - Hope Creek, USNRC  
NRC Senior Resident Inspector - Hope Creek  
K. Tosch, Manager IV, NJBNE