

From: "Tran, Phuong T. (GE Infra, Energy)" <phuong.tran@ge.com>
To: "Alan Wang" <ABW@nrc.gov>
Date: 08/17/2006 2:41:36 AM
Subject: RE: DRAFT SAFETY EVALUATION BY THE OFFICE OF NUCLEARREACTORREGULATION

Hi Alan,

Thanks for converting to WORD documents. I could not see the Tables. I found one item that needs to be corrected. It's in section 4.0 item 3 as shown below. The changes made as shown reflect the technical information of the DSS-CD solution and not wording change.

3. The existing Solution III is already approved for plant operation up to 20 percent EPU. DSS-CD is an extension of Solution III, where the need to determine the PBDA scram setpoint with a DIVOM correlation is eliminated by setting the setpoint to the Amplitude Discriminator value (i.e., coherent oscillations just above a nominal noise level will result in an automated scram). Thus, DSS-CD is, in essence, a Solution III implementation with the PBDA setpoint set at very conservative setting. Therefore, the NRC staff concludes that DSS-CD is a technically acceptable methodology for any reactor operating up to EPU conditions.

Thanks,

PT

Mail Envelope Properties (44E40F94.2EE : 1 : 45806)

Subject: RE: DRAFT SAFETY EVALUATION BY THE OFFICE OF
NUCLEARREACTORREGULATION
Creation Date 08/17/2006 2:40:53 AM
From: "Tran, Phuong T. (GE Infra, Energy)" <phuong.tran@ge.com>
Created By: phuong.tran@ge.com

Recipients

nrc.gov
 TWGWPO04.HQGWDO01
 ABW (Alan Wang)

Post Office

TWGWPO04.HQGWDO01

Route

nrc.gov

Files	Size	Date & Time
MESSAGE	3387	08/17/2006 2:40:53 AM
Mime.822	5339	

Options

Expiration Date: None
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standard

Junk Mail Handling Evaluation Results

Message is eligible for Junk Mail handling
 This message was not classified as Junk Mail

Junk Mail settings when this message was delivered

Junk Mail handling disabled by User
 Junk Mail handling disabled by Administrator
 Junk List is not enabled
 Junk Mail using personal address books is not enabled
 Block List is not enabled