- (3) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use at any time any byproduct, source, and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
- (4) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source, or special nuclear material without restriction to chemical or physical form for sample analysis or equipment and instrument calibration or associated with radioactive apparatus or components;
- (5) Pursuant to the Act and 10 CFR Parts 30 and 70, to possess but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.
- C. This renewed operating license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:
 - (1) <u>Maximum Power Level</u>

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 3293 megawatts thermal.

(2) <u>Technical Specifications</u>

The Technical Specifications contained in Appendices A and B, as revised through Amendment No.263, are hereby incorporated in the renewed operating license. The licensee shall operate the facility in accordance with the Technical Specifications.

For Surveillance Requirements (SRs) that are new in Amendment 234 to Facility Operating License DPR-33, the first performance is due at the end of the first surveillance interval that begins at implementation of the Amendment 234. For SRs that existed prior to Amendment 234, including SRs with modified acceptance criteria and SRs whose frequency of performance is being extended, the first performance is due at the end of the first surveillance interval that begins on the date the surveillance was last performed prior to implementation of Amendment 234.

> Renewed License No. DPR-33 Amendment No.263

	SURVEILLANCE	FREQUENCY
	Verify the concentration and temperature of boron in solution are within the limits of Figure 3.1.7-1.	Once within 8 hours after discovery that SPB concentration is > 9.2% by weight <u>AND</u> 12 hours thereafter
SR 3.1.7.5	Verify the minimum quantity of Boron-10 in the SLC solution tank and available for injection is \ge 186 pounds.	31 days
SR 3.1.7.6	Verify the SLC conditions satisfy the following equation: $\frac{(C)(Q)(E)}{(13 \text{ wt. \%})(86 \text{ gpm})(19.8 \text{ atom\%})} \ge 1$ where, C = sodium pentaborate solution concentration (weight percent) $Q = pump flow rate (gpm)$ $E = Boron-10 enrichment (atom percent Boron-10)$	31 days <u>AND</u> Once within 24 hours after water or boron is added to the solution
SR 3.1.7.7	Verify each pump develops a flow rate \geq 39 gpm at a discharge pressure \geq 1275 psig.	24 months

(continued)

BFN-UNIT 1

Amendment No. 234, 251, 263

	SURVEILLANCE	FREQUENCY
SR 3.1.7.8	Verify flow through one SLC subsystem from pump into reactor pressure vessel.	24 months on a STAGGERED TEST BASIS
SR 3.1.7.9	Verify all piping between storage tank and pump suction is unblocked.	24 months
SR 3.1.7.10	Verify sodium pentaborate enrichment is within the limits established by SR 3.1.7.6 by calculating within 24 hours and verifying by analysis within 30 days.	24 months <u>AND</u> After addition to SLC tank
SR 3.1.7.11	Verify each SLC subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position is in the correct position, or can be aligned to the correct position.	31 days

	SURVEILLANCE	FREQUENCY
SR 3.1.8.1	NOTENOTE Not required to be met on vent and drain valves closed during performance of SR 3.1.8.2.	
	Verify each SDV vent and drain valve is open.	31 days
SR 3.1.8.2	Cycle each SDV vent and drain valve to the fully closed and fully open position.	92 days
SR 3.1.8.3	Verify each SDV vent and drain valve:	24 months
	 a. Closes in ≤ 60 seconds after receipt of an actual or simulated scram signal; and 	
	 Opens when the actual or simulated scram signal is reset. 	

BFN-UNIT 1

	SURVEILLANCE	FREQUENCY
SR 3.3.1.1.10	Perform CHANNEL CALIBRATION.	184 days
SR 3.3.1.1.11	(Deleted)	
SR 3.3.1.1.12	Perform CHANNEL FUNCTIONAL TEST.	24 months
SR 3.3.1.1.13	NOTENOTENOTENOTENOTENOTE	
	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.1.1.14	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months
SR 3.3.1.1.15	Verify Turbine Stop Valve — Closure and Turbine Control Valve Fast Closure, Trip Oil Pressure — Low Functions are not bypassed when THERMAL POWER is \geq 30% RTP.	24 months
SR 3.3.1.1.16	For Function 2.a, not required to be performed when entering MODE 2 from MODE 1 until 12 hours after entering MODE 2.	
	Perform CHANNEL FUNCTIONAL TEST.	184 days

- -----NOTES------
- 1. Refer to Table 3.3.2.1-1 to determine which SRs apply for each Control Rod Block Function.
- 2. When an RBM channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains control rod block capability.

	SURVEILLANCE	FREQUENCY
SR 3.3.2.1.1	Perform CHANNEL FUNCTIONAL TEST.	184 days
SR 3.3.2.1.2	NOTENOTENOTE Not required to be performed until 1 hour after any control rod is withdrawn at \leq 10% RTP in MODE 2.	
	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.2.1.3	NOTENOTENOTE Not required to be performed until 1 hour after THERMAL POWER is ≤ 10% RTP in MODE 1.	
•	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.2.1.4	NOTENOTENOTENOTENOTENOTE	
	Perform CHANNEL CALIBRATION.	24 months

Amendment No.-234, 262, 263

	SURVEILLANCE	FREQUENCY
SR 3.3.2.1.5	Verify the RWM is not bypassed when THERMAL POWER is ≤ 10% RTP.	24 months
SR 3.3.2.1.6	NOTENOTE Not required to be performed until 1 hour after reactor mode switch is in the shutdown position.	
	Perform CHANNEL FUNCTIONAL TEST.	24 months
SR 3.3.2.1.7	Verify control rod sequences input to the RWM are in conformance with BPWS.	Prior to declaring RWM OPERABLE following loading of sequence into RWM
SR 3.3.2.1.8	NOTENOTENOTENOTENOTENOTE	
	Verify the RBM: a. Low Power Range - Upscale Function is not bypassed when THERMAL POWER is ≥ 27% and ≤ 62% RTP.	24 months
	 b. Intermediate Power Range - Upscale Function is not bypassed when THERMAL POWER is > 62% and ≤ 82% RTP. 	х
	 c. High Power Range - Upscale Function is not bypassed when THERMAL POWER is > 82% RTP. 	

١

When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided feedwater and main turbine high water level trip capability is maintained.

·	SURVEILLANCE	FREQUENCY
SR 3.3.2.2.1	Perform CHANNEL CHECK.	24 hours
SR 3.3.2.2.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.2.2.3	Perform CHANNEL CALIBRATION. The Allowable Value shall be ≤ 586 inches above vessel zero.	24 months
SR 3.3.2.2.4	Perform LOGIC SYSTEM FUNCTIONAL TEST including valve actuation.	24 months

BFN-UNIT 1

Amendment No.-234, 263

	SURVEILLANCE	FREQUENCY
SR 3.3.3.1.1	Perform CHANNEL CHECK for each required PAM instrumentation channel.	31 days
SR 3.3.3.1.2	(Deleted).	
SR 3.3.3.1.3	Perform CHANNEL CALIBRATION of the Reactor Pressure Functions.	184 days
SR 3.3.3.1.4	Perform CHANNEL CALIBRATION for each required PAM instrumentation channel except for the Reactor Pressure Function.	24 months

BFN-UNIT 1

	SURVEILLANCE	FREQUENCY
SR 3.3.3.2.1	Verify each required control circuit and transfer switch is capable of performing the intended function.	24 months
SR 3.3.3.2.2	Perform CHANNEL CALIBRATION for the Suppression Pool Water Level Function.	24 months
SR 3.3.3.2.3	Perform CHANNEL CALIBRATION for each required instrumentation channel except for the Suppression Pool Water Level Function.	24 months

١

Amendment No. 234, 263

· · · · · · · · · · · · · · · · · · ·	SURVEILLANCE	FREQUENCY
SR 3.3.4.1.1	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.4.1.2	Verify TSV - Closure and TCV Fast Closure, Trip Oil Pressure - Low Functions are not bypassed when THERMAL POWER is \geq 30% RTP.	24 months
SR 3.3.4.1.3	Perform CHANNEL CALIBRATION. The Allowable Values shall be: TSV - Closure: \leq 10% closed; and TCV Fast Closure, Trip Oil Pressure - Low: \geq 550 psig.	24 months
SR 3.3.4.1.4	Perform LOGIC SYSTEM FUNCTIONAL TEST including breaker actuation.	24 months

BFN-UNIT 1

Amendment No. 234,263

--NOTE-

When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains ATWS-RPT trip capability.

	SURVEILLANCE	FREQUENCY
SR 3.3.4.2.1	Perform CHANNEL CHECK of the Reactor Vessel Water Level - Low Low, Level 2 Function.	24 hours
SR 3.3.4.2.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.4.2.3	Perform CHANNEL CALIBRATION. The Allowable Values shall be:	24 months
	 Reactor Vessel Water Level - Low Low, Level 2: ≥ 471.52 inches above vessel zero; and 	
	 b. Reactor Steam Dome Pressure - High: ≤ 1146.5 psig. 	
SR 3.3.4.2.4	Perform LOGIC SYSTEM FUNCTIONAL TEST including breaker actuation.	24 months

BFN-UNIT 1

١

Amendment No. 234, 263

- -----NOTES------
- 1. Refer to Table 3.3.5.1-1 to determine which SRs apply for each ECCS Function.
- 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed as follows: (a) for up to 6 hours for Functions 3.c and 3.f; and (b) for up to 6 hours for Functions other than 3.c and 3.f provided the associated Function or the redundant Function maintains ECCS initiation capability.

· ·	SURVEILLANCE	FREQUENCY
SR 3.3.5.1.1	Perform CHANNEL CHECK.	24 hours
SR 3.3.5.1.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.5.1.3	Perform CHANNEL CALIBRATION.	92 days
SR 3.3.5.1.4	Perform CHANNEL CALIBRATION.	184 days
SR 3.3.5.1.5	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.5.1.6	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

١

- 1. Refer to Table 3.3.5.2-1 to determine which SRs apply for each RCIC Function.
- 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed as follows: (a) for up to 6 hours for Function 2 and (b) for up to 6 hours for Function 1 provided the associated Function maintains RCIC initiation capability.

	SURVEILLANCE	FREQUENCY
SR 3.3.5.2.1	Perform CHANNEL CHECK.	24 hours
SR 3.3.5.2.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.5.2.3	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.5.2.4	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

BFN-UNIT 1

- -NOTES--
- 1. Refer to Table 3.3.6.1-1 to determine which SRs apply for each Primary Containment Isolation Function.
- 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains isolation capability.

	SURVEILLANCE	FREQUENCY
SR 3.3.6.1.1	Perform CHANNEL CHECK.	24 hours
SR 3.3.6.1.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.6.1.3	Perform CHANNEL CALIBRATION.	92 days
SR 3.3.6.1.4	Perform CHANNEL CALIBRATION.	122 days
SR 3.3.6.1.5	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.6.1.6	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

BFN-UNIT1

Amendment No.-234, 260, 263

Primary Containment Isolation Instrumentation 3.3.6.1

Table 3.3.6.1-1 (page 2 of 3) Primary Containment Isolation Instrumentation

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
3.	HPCI System Isolation (continued)					
	 d. HPCI Steam Line Space HPCI Pump Room Area Temperature - High 	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 200°F
	e. HPCI Steam Line Space Torus Area (Exit) Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 180°F
	 f. HPCI Steam Line Space Torus Area (Midway) Temperature - High 	1,2,3	2	. F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≲ 180°F
	 g. HPCI Steam Line Space Torus Area (Entry) Temperature - High 	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 180°F
4.	Reactor Core Isolation Cooling (RCIC) System Isolation	•		•		
	a. RCIC Steam Line Flow - High	1,2,3	1	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR3.3.6.1.6	≤ 450" H₂O
	b. RCIC Steam Supply Line Pressure - Low	1,2,3	3	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 50 psig
	c. RCIC Turbine Exhaust Diaphragm Pressure - High	1,2,3	3	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 20 psig
	 RCIC Steam Line Space RCIC Pump Room Area Temperature - High 	1,2,3	2	F .	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 180°F
	e. RCIC Steam Line Space Torus Area (Exit) Temperature - High	1,2,3	2	F .	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 180°F
	f. RCIC Steam Line Space Torus Area (Midway) Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≲ 180°F
	 g. RCIC Steam Line Space Torus Area (Entry) Temperature - High 	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 180°F

(continued)

BFN-UNIT 1

Amendment No. 234, 260, 263

		FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
5.	Re (R	eactor Water Cleanup WCU) System Isolation					
	a.	Main Steam Valve Vault Area Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 201°F
	ь.	Pipe Trench Area Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 135°F
	с.	Pump Room A Area Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 152°F
	d.	Pump Room B Area Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 152°F
	e.	Heat Exchanger Room Area (West Wall) Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 170°F
	f,	Heat Exchanger Room Area (East Wall) Temperature - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 143°F
	g.	SLC System Initiation	1,2	1(a)	н	SR 3.3.6.1.6	NA ·
	h.	Reactor Vessel Water Level - Low, Level 3	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 528 inches above vessel zero
6.	Sh Iso	utdown Cooling System lation					
	a.	Reactor Steam Dome Pressure - High	1,2,3	1 .	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 115 psig
	b.	Reactor Vessel Water Level - Low, Level 3	3,4,5	. 2 ^(b)	. I	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≥ 528 inches above vessel zero
		Drywell Pressure - High	1,2,3	2	F	SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.6	≤ 2.5 psig

Table 3.3.6.1-1 (page 3 of 3) Primary Containment Isolation Instrumentation

(a) One SLC System Initiation signal provides logic input to close both RWCU valves.

(b) Only one channel per trip system required in MODES 4 and 5 when RHR Shutdown Cooling System integrity maintained.

BFN-UNIT 1

١

3.3-60

Amendment No. 234, 258, 260, 263

-NOTES-

- 1. Refer to Table 3.3.6.2-1 to determine which SRs apply for each Secondary Containment Isolation Function.
- 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains secondary containment isolation capability.
- 3. For Functions 3 and 4, when a channel is placed in an inoperable status solely for performance of a CHANNEL CALIBRATION or maintenance, entry into associated Conditions and Required Actions may be delayed for up to 24 hours provided the downscale trip of the inoperable channel is placed in the tripped condition.

	SURVEILLANCE	FREQUENCY
SR 3.3.6.2.1	Perform CHANNEL CHECK.	24 hours
SR 3.3.6.2.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.6.2.3	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.6.2.4	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

		S	F	T	C	N	
--	--	---	---	---	---	---	--

- 1. Refer to Table 3.3.7.1-1 to determine which SRs apply for each CREV Function.
- 2. When a channel is placed in an inoperable status solely for performance of required Surveillances, entry into associated Conditions and Required Actions may be delayed for up to 6 hours provided the associated Function maintains CREV initiation capability.
- 3. For Functions 3 and 4, when a channel is placed in an inoperable status solely for the performance of a CHANNEL CALIBRATION or maintenance, entry into the associated Conditions and Required Actions may be delayed for up to 24 hours provided the downscale trip of the inoperable channel is placed in the trip condition.

	<u> </u>	
	SURVEILLANCE	FREQUENCY
SR 3.3.7.1.1	Perform CHANNEL CHECK.	24 hours
SR 3.3.7.1.2	Perform CHANNEL FUNCTIONAL TEST.	92 days
SR 3.3.7.1.3	Perform CHANNEL CALIBRATION.	92 days
SR 3.3.7.1.4	Perform LOGIC SYSTEM FUNCTIONAL TEST.	184 days
SR 3.3.7.1.5	Perform CHANNEL CALIBRATION.	24 months
SR 3.3.7.1.6	Perform LOGIC SYSTEM FUNCTIONAL TEST.	24 months

BFN-UNIT 1

	SURVEILLANCE	FREQUENCY
SR 3.3.8.2.1	Perform CHANNEL FUNCTIONAL TEST.	184 days
SR 3.3.8.2.2	Perform CHANNEL CALIBRATION. The Allowable Values shall be:	184 days
. ·	a. Overvoltage ≤ 132 V, with time delay set to ≤ 4 seconds.	
	 b. Undervoltage ≥ 108.5 V, with time delay set to ≤ 4 seconds. 	
	 c. Underfrequency ≥ 56 Hz, with time delay set to ≤ 4 seconds. 	
SR 3.3.8.2.3	Perform a system functional test.	24 months

BFN-UNIT 1

Amendment No. 234,263

١

	SURVEILLANCE		FREQUENCY
SR 3.4.3.1	Verify the safety functio required 12 S/RVs are v setpoint as follows:	n lift settings of the within \pm 3% of the	In accordance with the Inservice Testing Program
	Number of <u>S/RVs</u>	Setpoint <u>(psig)</u>	
	4 4 5	1105 1115 1125	
; ·	Following testing, lift set ± 1%.	tings shall be within	
SR 3.4.3.2	NO Not required to be perfo after reactor steam pres adequate to perform the	TE rmed until 12 hours sure and flow are test.	
	Verify each required S/F manually actuated.	RV opens when	24 months

Amendment No. 234, 263

	SURVEILLANCE	FREQUENCY
SR 3.4.5.1	Perform a CHANNEL CHECK of required primary containment atmospheric monitoring system instrumentation.	12 hours
SR 3.4.5.2	Perform a CHANNEL FUNCTIONAL TEST of required primary containment atmospheric monitoring system instrumentation.	31 days
SR 3.4.5.3	Perform a CHANNEL CALIBRATION of required drywell sump flow integrator instrumentation.	184 days
SR 3.4.5.4	Perform a CHANNEL CALIBRATION of required leakage detection system instrumentation.	24 months

BFN-UNIT 1

	SURVEILLANCE	FREQUENCY
SR 3.5.1.7	Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test.	
	Verify, with reactor pressure \leq 1010 and \geq 920 psig, the HPCI pump can develop a flow rate \geq 5000 gpm against a system head corresponding to reactor pressure.	92 days
SR 3.5.1.8	NOTENOTE Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test.	
· ·	Verify, with reactor pressure \leq 165 psig, the HPCI pump can develop a flow rate \geq 5000 gpm against a system head corresponding to reactor pressure.	24 months
SR 3.5.1.9	NOTENOTENOTENOTENOTENOTE	
	Verify each ECCS injection/spray subsystem actuates on an actual or simulated automatic initiation signal.	24 months

(continued)

BFN-UNIT 1

Amendment No. 234,263

	SURVEILLANCE	FREQUENCY
SR 3.5.1.10	NOTENOTENOTE	
·.	Verify the ADS actuates on an actual or simulated automatic initiation signal.	24 months
SR 3.5.1.11	NOTENOTE Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test.	
	Verify each ADS valve opens when manually actuated.	24 months
SR 3.5.1.12	(Deleted).	

BFN-UNIT 1

١

Amendment No. 234, 254, 263

	SU	RVEILLANC	E	·	FREQUENCY
SR 3.5.2.4	Verify each required ECCS pump develops the specified flow rate against a system head corresponding to the specified pressure.			In accordance with the Inservice Testing Program	
	<u>SYSTEM</u> CS <u>SYSTEM</u> LPCI	<u>FLOW RATE</u> ≥ 6250 gpm <u>FLOW RATE</u> ≥ 9,000 gpm	NO. OF <u>PUMPS</u> 2 NO. OF <u>PUMPS</u>	SYSTEM HEAD CORRESPONDING TO A VESSEL TO TORUS DIFFERENTIAL <u>PRESSURE OF</u> ≥ 105 psid INDICATED SYSTEM <u>PRESSURE</u> ≥ 125 psig	
SR 3.5.2.5	NOTENOTE Vessel injection/spray may be excluded. 			24 months	
	automatic initiation signal.				

	SURVEILLANCE	FREQUENCY
SR 3.5.3.1	Verify the RCIC System piping is filled with water from the pump discharge valve to the injection valve.	31 days
SR 3.5.3.2	Verify each RCIC System manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR 3.5.3.3	 Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. Verify, with reactor pressure ≤ 1010 psig and ≥ 920 psig, the RCIC pump can develop a flow rate ≥ 600 gpm against a system head corresponding to reactor pressure. 	92 days
SR 3.5.3.4	 Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test. Verify, with reactor pressure ≤ 165 psig, the RCIC pump can develop a flow rate ≥ 600 gpm against a system head corresponding to reactor pressure. 	24 months
· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·	(continued)

١

Amendment No. 234, 263

	SURVEILLANCE	FREQUENCY
SR 3.5.3.5	NOTENOTEVessel injection may be excluded.	
	Verify the RCIC System actuates on an actual or simulated automatic initiation signal.	24 months

BFN-UNIT 1

Amendment No. 234, 263

١

	SURVEILLANCE	FREQUENCY
SR 3.6.1.1.1	Perform required visual examinations and leakage rate testing except for primary containment air lock testing, in accordance with the Primary Containment Leakage Rate Testing Program.	In accordance with the Primary Containment Leakage Rate Testing Program
SR 3.6.1.1.2	Verify drywell to suppression chamber differential pressure does not decrease at a rate > 0.25 inch water gauge per minute over a 10 minute period at an initial differential pressure of 1 psid.	24 months

Amendment No. 234, 263

١

	SURVEILLANCE	FREQUENCY
SR 3.6.1.3.5	Verify the isolation time of each power operated, automatic PCIV, except for MSIVs, is within limits.	In accordance with the Inservice Testing Program
SR 3.6.1.3.6	Verify the isolation time of each MSIV is ≥ 3 seconds and ≤ 5 seconds.	In accordance with the Inservice Testing Program
SR 3.6.1.3.7	Verify each automatic PCIV actuates to the isolation position on an actual or simulated isolation signal.	24 months
SR 3.6.1.3.8	Verify each reactor instrumentation line EFCV actuates to the isolation position on a simulated instrument line break signal.	24 months
SR 3.6.1.3.9	Remove and test the explosive squib from each shear isolation valve of the TIP System.	24 months on a STAGGERED TEST BASIS
SR 3.6.1.3.10	Verify leakage rate through each MSIV is \leq 100 scfh and that the combined leakage rate for all four main steam lines is \leq 150 scfh when tested at \geq 25 psig.	In accordance with the Primary Containment Leakage Rate Testing Program
SR 3.6.1.3.11	Verify combined leakage through water tested lines that penetrate primary containment are within the limits specified in the Primary Containment Leakage Rate Testing Program.	In accordance with the Primary Containment Leakage Rate Testing Program

Reactor Building-to-Suppression Chamber Vacuum Breakers 3.6.1.5

SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.6.1.5.1	 Not required to be met for vacuum breakers that are open during Surveillances. Not required to be met for vacuum breakers open when performing their intended function. 	
	Verify each vacuum breaker is closed.	14 days
SR 3.6.1.5.2	Perform a functional test of each vacuum breaker.	92 days
SR 3.6.1.5.3	Verify the opening setpoint of each vacuum breaker is ≤ 0.5 psid.	24 months

BFN-UNIT 1

	SURVEILLANCE	FREQUENCY
SR 3.6.1.6.1	 Not required to be met for vacuum breakers that are open during Surveillances. One drywell suppression chamber vacuum 	
	breaker may be nonfully closed so long as it is determined to be not more than 3° open as indicated by the position lights. 	14 days
SR 3.6.1.6.2	Perform a functional test of each required vacuum breaker.	In accordance with the Inservice Testing Program
SR 3.6.1.6.3	Verify the differential pressure required to open each vacuum breaker is ≤ 0.5 psid.	24 months

BFN-UNIT 1

Amendment No. 234,263

	SURVEILLANCE	FREQUENCY
SR 3.7.5.1	Verify one complete cycle of each main turbine bypass valve.	31 days
SR 3.7.5.2	Perform a system functional test.	24 months
SR 3.7.5.3	Verify the TURBINE BYPASS SYSTEM RESPONSE TIME is within limits.	24 months

BFN-UNIT 1

Amendment No. 234, 263