

*J. White (RI)*  
*J. Noggle (RI)*

**From:** "Adler, Joseph J." <jadler@entergy.com>  
**To:** <jrw1@nrc.gov>, <jdn@nrc.gov>  
**Date:** 05/18/2006 1:20:46 PM  
**Subject:** Trigger values at IPEC

John / Jim:

Trigger values for our monitoring well / REMP water sampling program are as follows:

- \* MW-38
  - o 5000 pCi/L H-3
  - o 3 pCi/L Sr-90
  
- \* MW-40, MW-48 and MW-51
  - o 2000 pCi/L H-3
  - o 2 pCi/L Sr-90

The H-3 trigger values are based on 25% and 10% of the drinking water criteria. The basis for the Sr-90 trigger value are also 25% and 10% of the drinking water criteria, plus an allowance for background in drinking water based on EPA RADNET data for NYS at the 95th PC (~0.4 pCi/L), and then raised to the next highest whole number.

If you have any questions or would like to discuss them please call me at 914 734 6606

Jay Adler

**CC:** "Hinrichs, Gary H" <ghinric@entergy.com>

G-2