M-113

NOTES:

1. FOR LOCATION OF LOUVERS AND FAN OPENINGS SEE ARCHITECTURAL DWG'S.
2. FOR PLATFORM DETAILS SEE STRUCTURAL DWG'S.
3. DUCTWORK FABRICATION AND HANGER DETAILS SHALL BE IN ACCORDANCE WITH SMACNA RECOMENDATIONS FOR LOW PRESSURE DUCTWORK NOT LABELED TO BE EQUIPPED WITH TURNING VANES.
4. CONTR. TO INSTALL STIFFNERS AROUND DUCT OPENING AS REQUIRED.

REFERENCE DRAWINGS:

M-112	HEATING AND VENTILATION TURBINE BUILDING PLAN EL. 607'-0"
M-114	HEATING AND VENTILATION TURBINE BUILDING SECTIONS
M-118	HEATING AND VENTILATION AUXILIARY AND CONTAINMENT PLAN EL. 607'-6" AND 611'-0"
A-221	HEATING AND VENTILATION TURBINE BUILDING MISCELLANEOUS DETAILS
M-218	PIPING AND INSTRUMENT DIAGRAM CONTROL ROOM HEATING, VENTILATION & AIR CONDITIONING.
M-121 SH. 3	VENTILATION FOR POST ACCIDENT MONITORING G.E.M. ENCLOSURE.
M-1047	HEATING & VENTILATION TURBINE BLDG.

PART PLAN - DETAIL "A"
NEW BATTERY RM. VENTILATION
SCALE 1/4"=1'-0"

SECTION
SCALE - NONE

PLAN OF LOUVERS & DUCT WORK
SCALE - NONE

WARNING
ENERGIZED WIRING PRESENT IN DUCTWORK
ELECTRIC SHOCK POTENTIAL

BECHTEL COMPANY

PALISADES PLANT
CONSUMERS POWER COMPANY

HEATING & VENTILATION
TURBINE BUILDING
PLAN OF ELEV. 625'-0"

5935 M-113 11