

or indirectly any control over (i) the facility, (ii) power or energy produced by the facility, or (iii) the licensees of the facility. Further, any rights acquired under this authorization may be exercised only in compliance with and subject to the requirements and restrictions of this operating license, the Atomic Energy Act of 1954, as amended, and the NRC's regulations. For purposes of this condition, the limitations of 10 CFR 50.81, as now in effect and as they may be subsequently amended, are fully applicable to the equity investors and any successors in interest to the equity investors, as long as the license for the facility remains in effect.

- (b) Entergy Louisiana, LLC (or its designee) to notify the NRC in writing prior to any change in (i) the terms or conditions of any lease agreements executed as part of the above authorized financial transactions, (ii) any facility operating agreement involving a licensee that is in effect now or will be in effect in the future, or (iii) the existing property insurance coverages for the facility, that would materially alter the representations and conditions, set forth in the staff's Safety Evaluation enclosed to the NRC letter dated September 18, 1989. In addition, Entergy Louisiana, LLC or its designee is required to notify the NRC of any action by equity investors or successors in interest to Entergy Louisiana, LLC that may have an effect on the operation of the facility.

- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter 1 and is subject to all applicable provisions of the Act and to the rules, regulations and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

1. Maximum Power Level

EOI is authorized to operate the facility at reactor core power levels not in excess of 3716 megawatts thermal (100% power) in accordance with the conditions specified herein.

2. Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No.209, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. EOI shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

EMERGENCY CORE COOLING SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

2. A visual inspection of the safety injection system sump and verifying that the subsystem suction inlets are not restricted by debris and that the sump components (trash racks, screens, etc.) show no evidence of structural distress or corrosion.
 3. Verifying that a minimum total of 380 cubic feet of granular trisodium phosphate dodecahydrate (TSP) is contained within the TSP storage baskets.
 4. Verifying that when a representative sample of 13.07 ± 0.03 grams of TSP from a TSP storage basket is submerged, without agitation, in 4 ± 0.1 liters of $120 \pm 10^\circ\text{F}$ water borated to 3011 ± 30 ppm, the pH of the mixed solution is raised to greater than or equal to 7 within 3 hours.
- e. At least once per 18 months by:
1. Verifying that each automatic valve in the flow path actuates to its correct position on SIAS and RAS test signals.
 2. Verifying that each of the following pumps start automatically upon receipt of a safety injection actuation test signal:
 - a. High pressure safety injection pump.
 - b. Low pressure safety injection pump.
 3. Verifying that on a recirculation actuation test signal, the low pressure safety injection pumps stop, the safety injection system sump isolation valves open.
- f. By verifying that each of the following pumps required to be OPERABLE performs as indicated on recirculation flow when tested pursuant to the Inservice Testing Program:
1. High pressure safety injection pump differential pressure greater than or equal to 1429 psid.
 2. Low pressure safety injection pump differential pressure greater than or equal to 168 psid.

CONTAINMENT SYSTEMS

3/4.6.2 DEPRESSURIZATION AND COOLING SYSTEMS (Continued)

SURVEILLANCE REQUIREMENTS (Continued)

- d. At least once per 18 months by:
 - 1. Verifying that each automatic valve in the flow path actuates to its correct position on a CSAS test signal.
 - 2. Verifying that upon a recirculation actuation test signal, the safety injection system sump isolation valves open and that a recirculation mode flow path via an OPERABLE shutdown cooling heat exchanger is established.
 - 3. Verifying that each spray pump starts automatically on a CSAS test signal.

- e. At least once per 10 years by performing an air or smoke flow test through each spray header and verifying each spray nozzle is unobstructed.

PLANT SYSTEMS

3/4.7.3 COMPONENT COOLING WATER AND AUXILIARY COMPONENT COOLING WATER SYSTEMS

LIMITING CONDITION FOR OPERATION

3.7.3 At least two independent component cooling water and associated auxiliary component cooling water trains shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

With only one component cooling water and associated auxiliary component cooling water train OPERABLE, restore at least two trains to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.3 Each component cooling water and associated auxiliary component cooling water train shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power-operated, or automatic) servicing safety-related equipment that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 18 months by verifying that each automatic valve servicing safety-related equipment actuates to its correct position on SIAS and CSAS test signals.
- c. At least once per 18 months by verifying that each component cooling water and associated auxiliary component cooling water pump starts automatically on an SIAS test signal.

PLANT SYSTEMS

3/4.7.12 ESSENTIAL SERVICES CHILLED WATER SYSTEM

LIMITING CONDITION FOR OPERATION

3.7.12 Two independent essential services chilled water loops shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4

ACTION:

With only one essential services chilled water loop OPERABLE, restore two loops to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.12.1 Each of the above required essential services chilled water loop shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power-operated, or automatic) servicing safety-related equipment that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 31 days by verifying that the water outlet temperature is $\leq 42^{\circ}\text{F}$ at a flow rate of ≥ 500 gpm.
- c. Deleted
- d. At least once per 18 months, by verifying that each essential services chilled water pump and compressor starts automatically on a safety injection actuation test signal.

4.7.12.2 The backup essential services chilled water pump and chiller shall be demonstrated OPERABLE in accordance with Specification 4.7.12.1 whenever it is functioning as part of one of the required essential services chilled water loops.