

October 16, 2006

Ms. Andrea Sterdis, Manager  
Licensing and Customer Interface  
Regulatory Affairs and Standardization  
Westinghouse Electric Company  
Nuclear Power Plants  
P.O. Box 355  
Pittsburgh, PA 15230-0355

SUBJECT: WESTINGHOUSE AP1000 COMBINED LICENSE PRE-APPLICATION  
TECHNICAL REPORT 36 - REQUEST FOR ADDITIONAL INFORMATION (TAC  
NO. MD2109)

Dear Ms. Sterdis:

By letter dated June 5, 2006 (DCP/NRC1749), you submitted AP1000 Technical Report 36, "AP1000 Pressurizer Design," which summarized the design changes for the AP1000 pressurizer. In response to requests for additional information (RAI), you submitted letter dated September 22, 2006 (DCP/NRC1779). The U.S. Nuclear Regulatory Commission staff has reviewed the application, along with your RAI responses, and has determined that additional information is required. Our question are provided in the Enclosure. We discussed these issues with your staff on October 11, 2006. Your staff indicated that you would attempt to provide your response by December 18, 2006.

Please contact me at (301) 415-1313, if you have any other questions on these issues.

Sincerely,

**/RA/**

Steven D. Bloom, Senior Project Manager  
AP1000/EPR Projects Branch  
Division of New Reactor Licensing  
Office of Nuclear Reactor Regulation

Project No. 740

Enclosure: Request for Additional Information

cc w/encl: See next page

Ms. Andrea Sterdis, Manager  
Licensing and Customer Interface  
Regulatory Affairs and Standardization  
Westinghouse Electric Company  
Nuclear Power Plants  
P.O. Box 355  
Pittsburgh, PA 15230-0355

SUBJECT: WESTINGHOUSE AP1000 COMBINED LICENSE PRE-APPLICATION  
TECHNICAL REPORT 36 - REQUEST FOR ADDITIONAL INFORMATION (TAC  
NO. MD2109)

Dear Ms. Sterdis:

By letter dated June 5, 2006 (DCP/NRC1749), you submitted AP1000 Technical Report 36, "AP1000 Pressurizer Design," which summarized the design changes for the AP1000 pressurizer. In response to requests for additional information (RAI), you submitted letter dated September 22, 2006 (DCP/NRC1779). The U.S. Nuclear Regulatory Commission staff has reviewed the application, along with your RAI responses, and has determined that additional information is required. Our question are provided in the Enclosure. We discussed these issues with your staff on October 11, 2006. Your staff indicated that you would attempt to provide your response by December 18, 2006.

Please contact me at (301) 415-1313, if you have any other questions on these issues.

Sincerely,

**/RA/**

Steven D. Bloom, Senior Project Manager  
AP1000/EPR Projects Branch  
Division of New Reactor Licensing  
Office of Nuclear Reactor Regulation

Project No. 740

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC S. Bloom RidsNrrDnrlNapb (S. Coffin) SSun  
J. Nakoski M. Viera (hard copy)

ADAMS Accession No.: ML062840413

OFFICE	DNRL/NAPB: LA	DNRL/NAPB: PM	DNRL/NAPB: BC
NAME	MViera	SBloom	SCoffin
DATE	10/12/06	10/16/06	10/16/06

**OFFICIAL RECORD COPY**

REQUEST FOR ADDITIONAL INFORMATION

WESTINGHOUSE AP1000 DOCUMENT NO. APP-GW-GLR-016, Rev 0

TECHNICAL REPORT 36 - AP1000 PRESSURIZER DESIGN

PROJECT NUMBER 740

TR36-11

In the request for additional information (RAI) response in the Enclosure 1 to September 22, 2006, letter, Westinghouse qualitatively discussed the effects of the pressurizer design changes on the depressurization and Automatic Depressurization System (ADS) flow rates, and categorically stated that the chapter 15 analysis remains valid and bounding.

The pressurizer design changes affects many parameters such as the cross-section area of the pressurizer, pressurizer vessel height, initial pressurizer water level, pressurizer setpoints, ADS stages 1, 2 and 3 elevation and pressurizer heater length. We are concerned about the combined effects of the values changed for the about parameters on the thermal hydraulic response during transient and accident conditions. We determined that the qualitative statement in the RAI response is not sufficient to resolve the RAI issue. We request Westinghouse perform quantitative analyses for the limiting event for each of the following Standard Review Plan chapter 15 event categories:

- (1) increased heat removal from the primary system
- (2) decreased heat removal by the secondary system
- (3) decrease reactor coolant system flow
- (4) reactivity and power distribution anomalies
- (5) increase in reactor coolant inventory
- (6) decrease in reactor coolant inventory including loss-of-coolant accidents
- (7) anticipated transients without scram

and demonstrate that the applicable acceptance criteria for each limiting event are met or the existing analysis is bounding.

Enclosure

AP 1000 Mailing List

cc:

Mr. W. Edward Cummins  
AP600 and AP1000 Projects  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355

Mr. Bradley F. Maurer, Acting Manager  
Regulatory Compliance and Plant Licensing  
Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230

Mr. Barton Z. Cowan, Esq.  
Eckert Seamans Cherin & Mellott, LLC  
600 Grant Street 44<sup>th</sup> Floor  
Pittsburgh, PA 15219

Mr. Charles Brinkman, Director  
Washington Operations  
Westinghouse Electric Company  
12300 Twinbrook Parkway, Suite 330  
Rockville, MD 20852

Mr. Adrian Heymer  
Nuclear Energy Institute  
1776 I Street NW  
Suite 400  
Washington, DC 20006

Mr. David Lochbaum  
Nuclear Safety Engineer  
Union of Concerned Scientists  
1707 H Street NW, Suite 600  
Washington, DC 20006-3919

Mr. Paul Gunter  
Nuclear Information & Resource Service  
1424 16th Street, NW., Suite 404  
Washington, DC 20036

Mr. James Riccio  
Greenpeace  
702 H Street, NW, Suite 300  
Washington, DC 20001

Mr. Ed Wallace, General Manager  
Projects  
PBMR Pty LTD  
PO Box 9396  
Centurion 0046  
Republic of South Africa

Mr. Glenn H. Archinoff  
AECL Technologies  
481 North Frederick Avenue  
Suite 405  
Gaithersburg, MD 20877

Mr. Gary Wright, Manager  
Office of Nuclear Facility Safety  
Illinois Department of Nuclear Safety  
1035 Outer Park Drive  
Springfield, IL 62704

Mr. Paul Leventhal  
Nuclear Control Institute  
1000 Connecticut Avenue, NW  
Suite 410  
Washington, DC 20036

Mr. Jay M. Gutierrez  
Morgan, Lewis & Bockius, LLP  
1111 Pennsylvania Avenue, NW  
Washington, DC 20004

Mr. Brendan Hoffman  
Research Associate on Nuclear Energy  
Public Citizens Critical Mass Energy  
and Environmental Program  
215 Pennsylvania Avenue, SE  
Washington, DC 20003

Mr. Ronald P. Vijuk  
Manager of Passive Plant Engineering  
AP1000 Project  
Westinghouse Electric Company  
P. O. Box 355  
Pittsburgh, PA 15230-0355

Mr. Russell Bell  
Nuclear Energy Institute  
Suite 400  
1776 I Street, NW  
Washington, DC 20006-3708

Mr. Ron Simard  
6170 Masters Club Drive  
Suwanne, GA 30024

Ms. Sandra Sloan  
Areva NP, Inc.  
3315 Old Forest Road  
P.O. Box 10935  
Lynchburg, VA 24506-0935

Mr. George Alan Zinke  
Project Manager  
Nuclear Business Development  
Entergy Nuclear  
M-ECH-683  
1340 Echelon Parkway  
Jackson, MS 39213

Ms. Marilyn Kray  
Vice President, Special Projects  
Exelon Generation  
200 Exelon Way, KSA3-E  
Kennett Square, PA 19348

Dr. Regis A. Matzie  
Senior Vice President and  
Chief Technology Officer  
Westinghouse Electric Company  
2000 Day Hill Road  
Windsor, CT 06095-0500

Mr. Jerald S. Holm  
Framatome ANP, Inc.  
3315 Old Forest Road  
P.O. Box 10935  
Lynchburg, VA 24506-0935

E-Mail:  
tom.miller@hq.doe.gov or  
tom.miller@nuclear.energy.gov  
mwetterhahn@winston.com  
whorin@winston.com  
gcesare@enercon.com  
sandra.sloan@areva.com  
louis.quintana@ge.com  
steven.hucik@ge.com  
david.hinds@ge.com  
chris.maslak@ge.com  
crpierce@southernco.com  
tomccall@southernco.com  
garry.miller@pgnmail.com  
gzinke@entergy.com  
rclary@scana.com  
pshastings@duke-energy.com  
James1.Beard@ge.com  
patriciaL.campbell@ge.com  
bob.brown@ge.com  
erg-xl@cox.net  
mark.beaumont@wsms.com  
sfrantz@morganlewis.com  
ksutton@morganlewis.com  
jgutierrez@morganlewis.com  
mgiles@entergy.com  
sterdia@westinghouse.com  
cristina.lonescu@pgnmail.com  
gwcurtis2@tva.gov  
robert.kitchen@pgnmail.com  
sterdiA@westinghouse.com  
mike\_moran@fpl.com  
amonroe@scana.com  
george.stramback@gene.ge.com