

October 12, 2006

Mr. John T. Conway
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT (MNGP) - CORRECTION OF
AMENDMENT RE: IMPROVED TECHNICAL SPECIFICATIONS
(TAC NO. MC7505)

Dear Mr. Conway:

On June 5, 2006, the Nuclear Regulatory Commission (NRC) issued Amendment No. 146 to Facility Operating License No. DPR-22 for MNGP. The amendment converted the Technical Specifications (TSs) from the previous custom format to the Improved Technical Specifications (ITSs) format.

Subsequent to issuance, the NRC staff noted that, due to an administrative error, the direction of the allowable value sign for Function 2.i (regarding recirculation pump differential pressure - high) was inadvertently reversed in Table 3.3.5.1-1, "Emergency Core Cooling System Instrumentation." The associated Bases (a licensee-controlled document) correctly reflects the previous requirement as specified in the custom TSs, stating that the differential pressure (dp) switches will trip when the dp across the pump is greater than a pre-determined value.

The NRC staff regrets any inconvenience these errors may have caused you.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure:
TS Page 3.3.5.1-8

cc w/encl: See next page

Mr. John T. Conway
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

October 12, 2006

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT (MNGP) - CORRECTION OF
AMENDMENT RE: IMPROVED TECHNICAL SPECIFICATIONS
(TAC NO. MC7505)

Dear Mr. Conway:

On June 5, 2006, the Nuclear Regulatory Commission (NRC) issued Amendment No. 146 to Facility Operating License No. DPR-22 for MNGP. The amendment converted the Technical Specifications (TSs) from the previous custom format to the Improved Technical Specifications (ITSS) format.

Subsequent to issuance, the NRC staff noted that, due to an administrative error, the direction of the allowable value sign for Function 2.i (regarding recirculation pump differential pressure - high) was inadvertently reversed in Table 3.3.5.1-1, "Emergency Core Cooling System Instrumentation." The associated Bases (a licensee-controlled document) correctly reflects the previous requirement as specified in the custom TSs, stating that the differential pressure (dp) switches will trip when the dp across the pump is greater than a pre-determined value.

The NRC staff regrets any inconvenience these errors may have caused you.

Sincerely,

/RA/

Peter S. Tam, Senior Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure:
TS Page 3.3.5.1-8

cc w/encl: See next page

DISTRIBUTION

PUBLIC
RidsNrrLATHarris
G. Hill, OIS

LPL3-1 r/f
RidsOGCRp
RidsRgn3MailCenter

RidsNrrDorlLpl3-1
RidsAcrsAcnwMailCenter
RidsNrrDorlDpr

RidsNrrPMPTam
RidsNrrDirsltsb
RidsNrrDorlDpr

Amendment Accession No.: **ML062850028 TS: ML06292004 PKG: ML062920301**

OFFICE	LPL3-1/PM	LPL3-1/LA	LPL3-1/BC(A)
NAME	PTam	THarris	Ptam for MMurphy
DATE	10/6/06	10/12 /06	10/6/06

OFFICIAL RECORD COPY

Monticello Nuclear Generating Plant

cc:

Jonathan Rogoff, Esquire
Vice President, Counsel & Secretary
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
2807 W. County Road 75
Monticello, MN 55362

Manager, Nuclear Safety Assessment
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

Commissioner
Minnesota Pollution Control Agency
520 Lafayette Road
St. Paul, MN 55155-4194

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
Suite 210
2443 Warrenville Road
Lisle, IL 60532-4351

Commissioner
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, MN 55440

Douglas M. Gruber, Auditor/Treasurer
Wright County Government Center
10 NW Second Street
Buffalo, MN 55313

Commissioner
Minnesota Department of Commerce
85 7th Place East, Suite 500
St. Paul, MN 55101-2198

Manager - Environmental Protection Division
Minnesota Attorney General's Office
445 Minnesota St., Suite 900
St. Paul, MN 55101-2127

Michael B. Sellman
President and Chief Executive Officer
Nuclear Management Company, LLC
700 First Street
Hudson, MI 54016

Nuclear Asset Manager
Xcel Energy, Inc.
414 Nicollet Mall, R.S. 8
Minneapolis, MN 55401

November 2005