

From: D. Ashley
To: John Hufnagel
Date: 06/05/2006 2:37:15 PM
Subject: supplemental information RAI 4.3-4

John-

In reviewing your RAI response to question RAI 4.3-4, the reviewer needs clarification on the following...

In the May 1, 2006, submittal, the response to RAI 4.3-4 lists the environmental multiplier, Fen, for the feedwater nozzle as 2.19.

This multiplier does not appear to be correct for the LAS nozzle.

Do we need to arrange a followup call to discuss this issue? or is this a typo?

thanks

=====
regards,

Donnie Ashley
NRR/DLR/RLRA
Oyster Creek
License Renewal Project Manger
301-415-3191
dja1@nrc.gov

Mail Envelope Properties (448479DB.737 : 9 : 10848)**Subject:** supplemental information RAI 4.3-4**Creation Date** 06/05/2006 2:37:15 PM**From:** D. Ashley**Created By:** DJA1@nrc.gov**Recipients**

exeloncorp.com

john.hufnagel (John Hufnagel)
PM**Action**

Transferred

Date & Time

05 June, 2006 2:38:19

Post Office**Delivered****Route**

exeloncorp.com

Files

MESSAGE

D. Ashley.vcf

Size

1339

232

Date & Time

05 June, 2006 2:37:15 PM

05 June, 2006 2:37:15 PM

Options**Auto Delete:**

No

Expiration Date:

None

Notify Recipients:

No

Priority:

Standard

ReplyRequested:

No

Return Notification:

None

Concealed Subject:

No

Security:

Standard

To Be Delivered:

Immediate

Status Tracking:

Delivered & Opened