



NRC/NEI Meeting on Spent Fuel Storage and Transportation Licensing and Technical Issues

Meraj Rahimi

Senior Project Manager
Spent Fuel Licensing Branch
Office of Nuclear Material
Safety and Safeguards

Carl Withee

Senior Criticality &
Shielding Engineer
Criticality, Shielding and
Dose Assessment Branch
Office of Nuclear Material
Safety and Safeguards

Andrew Barto

Nuclear Engineer
Criticality, Shielding and
Dose Assessment Branch
Office of Nuclear Material
Safety and Safeguards



NRC/NEI Meeting

- **Purpose**

- To provide an opportunity for communicating Part 71 and 72 licensing and technical issues.

- **Expected Outcome**

- To reach an understanding of the issues and the process for addressing them.



Issues for Today

- Burnup Credit
 - Part 71/72 vs. Part 50
 - Burnup measurement
- Other Issues for roundtable discussions
 - Damaged fuel (ISG-1)
 - Control of cask licensing basis
 - Risk informing the regulations and review guidance
 - 72.48 guidance and implementation
 - Part 72 licensing and renewal period (SECY-06-152)



Part 71/72 vs. Part 50

- Casks (Part 71/72)
 - Generic analyses
 - Generic in-core depletion parameter values used
 - Analyses must bound all plants and fuel designs
 - Multiple environments – storage, transport, pools
 - Intermittent monitoring of closure system only
 - Stored and transported in open environment
 - Mobile and passive system
- Spent Fuel Pools (Part 50)
 - Plant Specific Analyses
 - Site-specific in-core depletion data available
 - Analyses specific to that plant and associated fuel designs
 - Single environment – spent fuel pools
 - Continuous monitoring of most of the components
 - Maintained in closed, confined, and controlled environment
 - Stationary and active system



Part 71/72 vs. Part 50

- Site-specific vs. generic analyses
 - Under part 50, site-specific fuel depletion history is available for storage racks burnup credit analyses
 - Under Part 71/72, generic fuel depletion analyses are used for generic cask designs
 - Under Part 50, site-specific reactor restarts can be used to confirm or fine-tune the criticality computer code predictions over the years
 - Under Part 71/72, there are no confirmation of predicted k_{eff} for storage or transport casks flooded with fresh water



Part 71/72 vs. 50 (criteria)

Part 71/72

- Actinides reactivity credit
- No Fission product reactivity credit yet
- 75% to 90% credit for fixed neutron absorbers no surveillance program is feasible

→ Fresh water in-leakage under Part 71. Under Part 72, soluble boron in pools can be relied on as a control to maintain subcriticality during fuel loading/unloading

Part 50

- Actinides reactivity credit
 - Fission product reactivity credit
 - Full credit for fixed neutron absorbers with surveillance program
- Soluble boron provides defense-in-depth to prevent criticality



Why the Difference

- Full vs. partial burnup credit
 - Under Part 71/72, K_{eff} for casks with non-site specific spent fuels need to be calculated by quantifying the biases and uncertainties, through applicable benchmarks, with higher accuracy because casks:
 - In an open environment
 - Susceptible to fresh water in-leakage
 - No soluble boron available for defense in-depth



BENCHMARKING

- Determining the Bias and Uncertainty of the Code Calculations for a Specific Application, i.e., Need to establish the systematic error (consistent offset) and bias uncertainty of the code calculations.



BURNUP CALCULATIONS

- Two-Step Process for More Rigorous Benchmarking
- Depletion Codes
 - Isotopic Content
- Criticality Codes
 - Determine k-effective



DEPLETION BENCHMARKS

- Measured Assays
 - Irradiation History
 - Actinides
 - Fission Products



CRITICALITY BENCHMARKS

- Critical Experiments
 - Code Performance
 - Modeling Approach & Code Options
 - Nuclear Cross Section Data




BENCHMARKS MUST REPRESENT THE APPLICATION

- Material Content
 - Fissile Isotopes
 - Absorber Isotopes
 - Moderator
- Geometry/Configuration
 - Spatial Variations
- Neutron Spectrum
 - Test the Proper Cross Section Region



NEUTRON CROSS SECTION DEVELOPMENT (^{241}Am)





123-GROUP LIBRARY PERFORMANCE




Figure 4 SCALE 123-group validation results for highly enriched uranium cases



CASKS vs. REACTOR CRITICALS (CRCs)

- Temperatures – 275° K vs. 570° K
- Beginning of Cycle – All Fuel is 3rd Cycle vs. 1/3 Fresh, 1/3 One Cycle, 1/3 Two Cycle
- BOC – Boron Concentration is 0 vs. High
- Poison Plates vs. Infinite Lattice (Isotropy)
- Benchmarking Two Step vs. One Step
- Isotopic Content – Long- vs. Short-lived
- Can't Use CRC Alone



CORE PHYSICS CODE LIMITATIONS

- One step benchmarking has limitations
- Can't infer that a good final answer validates all intermediate and input values
- Burnup is a proxy for fuel reactivity



CURRENT AVAILABLE ASSAY DATA

- Actinides
 - Data from 8 Reactors
 - Other
- Fission Products
 - Calvert Cliffs
 - Takahama
 - Other
- TMI



CURRENT AVAILABLE CRITICAL DATA

- Fresh UO_2
- MOX – Pre 1977
- Reactor Startup and Shutdown – CRCs
- Sandia ^{103}Rh
- French ^{149}Sm
- French Actinide – DOE (not yet released)



DATA NEEDED FOR BURNUP CREDIT

- Isotopic Assay Data
 - Fission Products
 - Combined Actinides and Fission Products
- Critical Experiments
 - Fission Products
 - Integrated Isotopes
- Applicability of Benchmarks



FUNDAMENTAL CONSIDERATIONS

- Must Validate the Correct Cross Section Region(s)
- Part 71 Requires Fresh Water Flooding
- Lack of Mitigating/Monitoring Systems
- No Shutdown Mechanism Designed
- Commission Policy of No Inadvertent Criticalities
- NRC Still Endorses Defense in Depth and Safety Margin In Addition to PRA Considerations



Measurements

- Reduce the probability of misloads in casks
 - misloads shown to be credible event
 - potential to reduce probability
 - identify systematic loading errors
- Quantify the uncertainty in reactor burnup records
 - varies from site to site and over time
 - difficult to provide bounding uncertainty for population of fuel assemblies



Measurements

- Relative vs. absolute measurements
- Criticality safety based on measured quantities, not estimates
- Inspection and verification to ensure presence of poisons
- Recommended by RG 3.71 and required by international standards (IAEA TS-R-1)



Fuel Handling

- Misloads in Spent Fuel Pools
 - Easily corrected when discovered
 - High ^{10}B ppm in pool = large margin on k_{eff}
- Misloads in Dry Storage Casks
 - Not easily corrected
 - Large margin on k_{eff} with fresh fuel assumption
 - More likely with more complicated loading patterns



Measurements & Fuel Handling

- Conclusions:
 - Cask misloads are credible and should be considered in BUC analyses
 - Assembly burnup measurements should be performed to confirm assigned burnup loading value and to prevent misloads to the extent possible