

RS-06-163

October 30, 2006

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Clinton Power Station, Unit 1
Facility Operating License No. NPF-62
NRC Docket No. 50-461

Subject: Withdrawal of Request for Emergency Amendment to Control Room Ventilation System Technical Specification


Reference: Letter from Thomas S. O'Neill (AmerGen Energy Company, LLC) to U. S. NRC, "Request for Emergency Amendment to Control Room Ventilation System Technical Specification," dated October 25, 2006

In the referenced letter, AmerGen Energy Company, LLC (AmerGen) submitted a request for an emergency amendment to Facility Operating License No. NPF-62 for Clinton Power Station (CPS), Unit 1. The proposed change requested an amendment to Technical Specification (TS) 3.7.3, "Control Room Ventilation System" to increase the TS Completion Time for one inoperable Control Room (CR) Ventilation subsystem (i.e., TS 3.7.3, Required Action A.1) from seven (7) days to fourteen (14) days, on a one-time basis. This additional Completion Time was required to support replacement and testing following a non-repairable failure of the 'B' CR Ventilation Supply Fan.

On October 28, 2006, AmerGen completed the supply fan replacement and testing, and returned the 'B' CR Ventilation subsystem to operable status, within the initial seven (7) day Completion Time allowed by TS 3.7.3, Required Action A.1. Therefore, AmerGen has elected to withdraw the referenced emergency amendment request.

If you have any questions concerning this letter, please contact Mr. David Gullott at (630) 657-2819.

Respectfully,



Kenneth M. Nicely
Manager – Licensing