

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>B. One SW subsystem inoperable.</p>	<p>B.1 -----NOTES----- 1. Enter applicable Conditions and Required Actions of LCO 3.8.1, "AC Sources - Operating," for diesel generator made inoperable by SW System. 2. Enter applicable Conditions and Required Actions of LCO 3.4.9, "Residual Heat Removal (RHR) Shutdown Cooling System - Hot Shutdown," for RHR shutdown cooling subsystem made inoperable by SW System. ----- Restore SW subsystem to OPERABLE status.</p>	<p>72 hours*</p>

(continued)

* On a one-time basis, during the refurbishment/replacement of the 1B Service Water Pump during Cycle 18, the Completion Time for an inoperable service water subsystem is extended to 144 hours.

3.7 PLANT SYSTEMS

3.7.1 Standby Service Water (SW) System and Ultimate Heat Sink (UHS)

LCO 3.7.1 Division 1 and 2 SW subsystems and UHS shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. Average sediment depth in one or both spray ponds ≥ 0.5 ft and < 1.0 ft.	A.1 Restore average sediment depth to within limits.	30 days

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. (continued)	B.2 Declare required feature(s), supported by the inoperable DG, inoperable when the redundant required feature(s) are inoperable.	4 hours from discovery of Condition B concurrent with inoperability of redundant required feature(s)
	<u>AND</u>	
	B.3.1 Determine OPERABLE DG(s) are not inoperable due to common cause failure.	24 hours
	<u>OR</u>	
	B.3.2 Perform SR 3.8.1.2 for OPERABLE DG(s).	24 hours
<u>AND</u>		
B.4 Restore required DG to OPERABLE status.	72 hours* <u>AND</u> 6 days from discovery of failure to meet LCO	

(continued)

* On a one-time basis, during the refurbishment/replacement of the 1B Service Water Pump during Cycle 18, the Completion Time for the Division 2 DG is extended to 144 hours.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Two offsite circuits inoperable.</p> <p><u>AND</u></p> <p>One required DG inoperable.</p>	<p>C.1 Declare required feature(s) inoperable when the redundant required feature(s) are inoperable.</p> <p><u>AND</u></p> <p>C.2 Restore one offsite circuit to OPERABLE status.</p>	<p>12 hours from discovery of Condition C concurrent with inoperability of redundant required feature(s).</p> <p>24 hours</p>
<p>D. One offsite circuit inoperable.</p> <p><u>AND</u></p> <p>One required DG inoperable.</p>	<p>-----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.8.7, "Distribution Systems - Operating," when Condition D is entered with no AC power source to any division. -----</p> <p>D.1 Restore offsite circuit to OPERABLE status.</p> <p><u>OR</u></p> <p>D.2 Restore required DG to OPERABLE status.</p>	<p>12 hours</p> <p>12 hours</p>

(continued)