

Bill,

We have reviewed GE's responses in MFN 06-071. We find that we agree with your response to RAI 14.2-1, but your correction for RAI 14.2-2 in Revision 1 of the DCD still references Table 6.2-50, which does not exist.

Here are the RAI and the response :

"NRC RAI 14.2-2

In section 14.2.8.1.33, "Containment Isolation Valve Functional and Closure Timing Tests, " there is a reference to Table 6.2-50, but no such Table exists in the DCD. Clarify this discrepancy.

GE Response (MFN 06-071)

The correct reference is "Tables 6.2-16 to 6.2-42" instead of "Table 6.2-50". Section 14.2.8.1.33 has been modified by making this correction in Revision 01 of the DCD."

However, the corrected DCD section 14.2.8.1.33 from Revision 1:

"General Test Methods and Acceptance Criteria

The Containment Isolation System is discussed in Section 6.2 with characteristics of and requirements for individual valves listed in **Tables 6.2-16 through 6.2-42**. Preoperational functional and closure timing tests of valves performing containment isolation functions will be done as part of the testing of the systems to which such valves belong (see **Table 6.2-50** for system affiliation of individual valves). Overall containment isolation initiation logic is a function of the leak detection and isolation system testing that is described in Subsection 14.2.8.1." [emphasis added]

We would appreciate your reply in a timely manner.

Don

Mail Envelope Properties (45460E6B.AC1 : 4 : 63552)

Subject: Supplement to RAI 14.2-2 (MFN 06-071)
Creation Date 10/30/2006 9:38:35 AM
From: Don Allen

Created By: DBA@nrc.gov

Recipients	Action	Date & Time
ge.com	Transferred	10/30/2006 9:39:03
AM		
william1.leonard (William (GE Infra Energy Non-GE) Leonard)		

nrc.gov

OWGWPO03.HQGWDO01
AM

AEC CC (Amy Cabbage)
AM

Delivered

10/30/2006 9:38:50

Opened

10/30/2006 9:51:08

Post Office

OWGWPO03.HQGWDO01

Delivered

Route

ge.com

10/30/2006 9:38:50 AM

nrc.gov

Files

MESSAGE

Size

2653

Date & Time

10/30/2006 9:38:35 AM

Options

Auto Delete:

No

Expiration Date:

None

Notify Recipients:

Yes

Priority:

Standard

ReplyRequested:

No

Return Notification:

None

Concealed Subject:

No

Security:

Standard

To Be Delivered:

Immediate

Status Tracking:

Delivered & Opened