

PA-LR

From: "Ford, Bryan" <BFord@entergy.com>
To: <arw1@nrc.gov>
Date: 10/03/2006 10:44:21 AM
Subject: Information from the Conference call on 9/26/06

Please see the attached file that contains population dose risk (PDR) reduction in unit of % for each SAMA and for RAIs 5e, 5f, 5g, and 5h.

<<PDR reduction.doc>>

With 3 significant figures, the values for CDF, PDR, and OECR SAMAs 6 (equivalent to 18, and 20), 48, and 52 are as follows:

Original Submittal	Re-analysis			
SAMA CDF	PDR	OECR CDF	PDR	OECR
6,18,20 1.46E+01	6.41E-06 5.26E+04	1.35E+01	4.59E+04	6.41E-06
48 1.46E+01	6.41E-06 5.26E+04	1.35E+01	4.59E+04	6.41E-06
52 1.46E+01	6.40E-06 5.26E+04	1.35E+01	4.59E+04	6.40E-06
Base 1.46E+01	6.41E-06 5.26E+04	1.36E+01	4.59E+04	6.41E-06

Small benefits could result from minor differences in CDF, PDF, or OECR. For example, slight difference in PDR for SAMA 6 and Base results in a benefit of \$2153 and an upper bound benefit of \$12,915 with a multiplier of 6 in the original submittal. However, there is no such difference for the reanalysis. Therefore, the estimated benefit for SAMA 6 is \$0.

Also, the Reduction in Off-site Economic Cost Risk (OECR) reduction for SAMA 27 on Table RAI.6-1 should be 15.02% (same as RAI 5e) rather than 1.71%.

CC: "Ellis, Douglas" <dellis1@entergy.com>, "Mogolesko, Fred" <fmogole@entergy.com>

Mail Envelope Properties (4522770A.D0B : 13 : 40203)

Subject: Information from the Conference call on 9/26/06
Creation Date 10/03/2006 10:43:11 AM
From: "Ford, Bryan" <BFord@entergy.com>

Created By: BFord@entergy.com

Recipients

nrc.gov

TWGWPO04.HQGWDO01
 ARW1 (Alicia Williamson)

entergy.com

fmogole CC (Fred Mogolesko)
 dellis1 CC (Douglas Ellis)

Post Office

TWGWPO04.HQGWDO01

Route

nrc.gov
 entergy.com

Files	Size	Date & Time
MESSAGE	1470	10/03/2006 10:43:11 AM
TEXT.htm	5180	
PDR reduction.doc	101888	
Mime.822	148990	

Options

Expiration Date: None
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standard

Junk Mail Handling Evaluation Results

Message is eligible for Junk Mail handling
 This message was not classified as Junk Mail

Junk Mail settings when this message was delivered

Junk Mail handling disabled by User
 Junk Mail handling disabled by Administrator
 Junk List is not enabled

Pre-Dec

Reduction in Population Dose Risk (PDR)

SAMA ID	SAMA Description	PDR Reduction (%)
1	Install an independent method of suppression pool cooling.	4.79%
2	Install a filtered containment vent to provide fission product scrubbing.	18.49%
3	Install a containment vent large enough to remove ATWS decay heat.	1.37%
4	Create a large concrete crucible with heat removal potential under the base mat to contain molten core debris.	48.97%
5	Create a water-cooled rubble bed on the pedestal.	48.97%
6	Provide modification for flooding the drywell head.	0.00%
7	Enhance fire protection system and standby gas treatment system hardware and procedures.	1.37%
8	Create a core melt source reduction system.	48.97%
9	Install a passive containment spray system.	4.79%
10	Strengthen primary and secondary containment.	26.03%
11	Increase the depth of the concrete basemat or use an alternative concrete material to ensure melt-through does not occur	0.68%
12	Provide a reactor vessel exterior cooling system	0.00%
13	Construct a building to be connected to primary/secondary containment that is maintained at a vacuum	1.37%
14	Dedicated Suppression Pool Cooling	4.79%
15	Create a larger volume in containment.	26.03%
16	Increase containment pressure capability (sufficient pressure to withstand severe accidents).	26.03%
17	Install improved vacuum breakers (redundant valves in each line).	0.00%
18	Increase the temperature margin for seals.	0.00%
19	Install a filtered vent	18.49%
20	Provide a method of drywell head flooding.	0.00%
21	Use alternate method of reactor building spray.	1.37%
22	Provide a means of flooding the rubble bed.	22.60%

Reduction in Population Dose Risk (PDR)

SAMA ID	SAMA Description	PDR Reduction (%)
23	Install a reactor cavity flooding system.	48.97%
24	Add ribbing to the containment shell.	26.03%
25	Provide additional DC battery capacity.	2.74%
26	Use fuel cells instead of lead-acid batteries.	2.74%
27	Modification for Improving DC Bus Reliability	16.44%
28	Provide 16-hour SBO injection.	2.74%
29	Provide an alternate pump power source.	5.48%
30	AC Bus Cross-Ties	8.22%
31	Add a dedicated DC power supply.	16.44%
32	Install additional batteries or divisions.	16.44%
33	Install fuel cells.	2.74%
34	DC Cross-Ties	2.05%
35	Extended SBO provisions.	2.74%
36	Locate RHR inside containment.	0.00%
37	Increase frequency of valve leak testing.	0.68%
38	Improve MSIV design.	0.00%
39	Install an independent diesel for the CST makeup pumps.	0.00%
40	Provide an additional high pressure injection pump with independent diesel.	2.05%
41	Install independent AC high pressure injection system.	2.05%
42	Install a passive high pressure system.	2.05%
43	Improved high pressure systems	1.37%
44	Install an additional active high pressure system.	2.05%
45	Add a diverse injection system.	2.05%
46	Increase SRV reseal reliability.	0.68%
47	Install an ATWS sized vent.	1.37%

Reduction in Population Dose Risk (PDR)

SAMA ID	SAMA Description	PDR Reduction (%)
48	Diversify explosive valve operation.	0.00%
49	Increase the reliability of SRVs by adding signals to open them automatically.	0.68%
50	Improve SRV design.	3.42%
51	Provide self-cooled ECCS pump seals.	0.68%
52	Provide digital large break LOCA protection.	0.00%
53	Control containment venting within a narrow band of pressure	4.79%
54	Install a bypass switch to bypass the low reactor pressure interlocks of LPCI or core spray injection valves.	0.68%
55	Improve SSW System and RBCCW pump recovery.	6.85%
56	Provide redundant DC power supplies to DTV valves.	3.42%
57	Proceduralize the use of diesel fire pump hydroturbine in the event of EDG A failure or unavailability.	3.42%
58	Proceduralize the operator action to feed B1 loads via B3 when A5 is unavailable post-trip.	3.42%
59	Provide redundant path from fire protection pump discharge to LPCI loops A and B cross-tie.	17.12%
RAI 5e	Equivalent to SAMA 27	16.44%
RAI 5f	Firewater injection	4.11%
RAI 5g	Redundant diesel firewater pump	8.22%
RAI 5h	Passive direct torus vent	14.38%