

PA-LR

**From:** Ram Subbaratnam  
**To:** fmogole@entergy.com  
**Date:** 8/28/2006 9:18:39 AM  
**Subject:** Meeting summary for your information

Fred:

Please look at the meeting summary and see if you have any comments and confirm ASAP.

I am issuing the RAs on the two TLAs which we discussed (CRD return nozzle end cap weld and the thermal sleeve crack on the Rx recirculation nozzle) as soon as I receive concurrence from my legal staff.

There are 7-8 RAs on Neutron embrittlement for which I owe you a draft transmittal and perhaps a phone call with your staff. These are on P-T limits, ART calculations and EFPY math and so forth. So, stand by.

RamSubbaratnam  
PM Pilgrim LRA  
US NRC, 415-1478

**CC:** bford@entergy.com; Dellis1@entergy.com

**Mail Envelope Properties** (44F2ED2F.AA3 : 19 : 10294)

**Subject:** Meeting summary for your information  
**Creation Date** 8/28/2006 9:18:39 AM  
**From:** Ram Subbaratnam

**Created By:** RXS2@nrc.gov

<b>Recipients</b>	<b>Action</b>	<b>Date &amp; Time</b>
entergy.com		
bford CC ( <u>bford@entergy.com</u> )		
dellis1 CC ( <u>Dellis1@entergy.com</u> )		
fmogole ( <u>fmogole@entergy.com</u> )		

<b>Post Office</b>	<b>Delivered</b>	<b>Route</b>
	Pending	entergy.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1062	8/28/2006 9:18:39 AM
MeetingSummaryAugust12006.wpd	36145	8/28/2006 9:04:38
AM		

**Options**

<b>Auto Delete:</b>	No
<b>Expiration Date:</b>	None
<b>Notify Recipients:</b>	Yes
<b>Priority:</b>	Standard
<b>ReplyRequested:</b>	No
<b>Return Notification:</b>	None

<b>Concealed Subject:</b>	No
<b>Security:</b>	Standard

<b>To Be Delivered:</b>	Immediate
<b>Status Tracking:</b>	Delivered & Opened

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Pilgrim Nuclear Power Station

SUBJECT: SUMMARY OF CONFERENCE CALL ON AUGUST 1, 2006 WITH ENTERGY NUCLEAR OPERATIONS, INC., ON POTENTIAL TIME LIMITED AGING ANALYSIS QUESTIONS ON THE PILGRIM LICENSE RENEWAL APPLICATION (TAC NO. MC9669)

The U.S. Nuclear Regulatory Commission staff conducted a conference call with Entergy Nuclear Operations, Inc. (Entergy or the applicant), on potential time-limited aging analysis (TLAA) questions on the Pilgrim License Renewal Application (LRA). The conference call was conducted on Tuesday, August 1, 2006, between 12:30 p.m. and 1:30 p.m. at 11555 Rockville Pike, Rockville, MD 20852. The list of participants is shown in the enclosure. The following is a summary of the meeting.

The Project Manager for the LRA provided an introduction and said that there were a few remaining questions from the staff's previous Generic Aging Lessons Learned audit conducted at the applicant site during May - July, 2006. These were related to the following three unresolved audit questions that could become potential TLAA's: (i) Control rod drive nozzle-to-end cap weld, (ii) Reactor recirculation nozzle thermal sleeves, and (iii) N2F reactor recirculation nozzle. At the end of the conference call it was resolved that with the exception of item (ii), the other two items were TLAA's. It was decided during the call that a request for additional information would follow in the future.

The applicant had an opportunity to comment on the meeting summary.

Ram Subbaratnam, Project Manager  
License Renewal Branch A  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure:  
List of Participants

cc w/encl: See next page

LICENSEE: Entergy Nuclear Operations, Inc.

FACILITY: Pilgrim Nuclear Power Station

SUBJECT: SUMMARY OF CONFERENCE CALL ON AUGUST 1, 2006 WITH ENTERGY NUCLEAR OPERATIONS, INC., ON POTENTIAL TIME LIMITED AGING ANALYSIS QUESTIONS ON THE PILGRIM LICENSE RENEWAL APPLICATION (TAC NO. MC9669)

The U.S. Nuclear Regulatory Commission staff conducted a conference call with Entergy Nuclear Operations, Inc. (Entergy or the applicant), on potential time-limited aging analysis (TLAA) questions on the Pilgrim License Renewal Application (LRA). The conference call was conducted on Tuesday, August 1, 2006, between 12:30 p.m. and 1:30 p.m. at 11555 Rockville Pike, Rockville, MD 20852. The list of participants is shown in the enclosure. The following is a summary of the meeting.

The Project Manager for the LRA provided an introduction and said that there were a few remaining questions from the staff's previous Generic Aging Lessons Learned audit conducted at the applicant site during May - July, 2006. These were related to the following three unresolved audit questions that could become potential TLAA's: (i) Control rod drive nozzle-to-end cap weld, (ii) Reactor recirculation nozzle thermal sleeves, and (iii) N2F reactor recirculation nozzle. At the end of the conference call it was resolved that with the exception of item (ii), the other two items were TLAA's. It was decided during the call that a request for additional information would follow in the future.

The applicant had an opportunity to comment on the meeting summary.

Ram Subbaratnam, Project Manager  
License Renewal Branch A  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-293

Enclosure:  
List of Participants

cc w/encl: See next page

**ADAMS Accession No.: ML06**

C:\temp\MeetingSummaryAugust12006\_1.wpd

OFFICE	PM:RLRA:DLR	PM:RLRC:DLR	LA:DLR	BC:REBB:DLR
NAME	RSubbaratnam	JDavis	YEdmonds	LLund
DATE	8/ /06	8/ /06	8/ /06	8/ /06

OFFICIAL RECORD COPY

Conference Call Summary dated August xx, 2006

SUBJECT: SUMMARY OF A CONFERENCE CALL WITH ENTERGY NUCLEAR  
OPERATIONS, INC., ON POTENTIAL TIME LIMITED AGING ANALYSIS  
QUESTIONS ON PILGRIM LICENSE RENEWAL APPLICATION  
(TAC NO. MC9669)

**HARD COPY**

DLR R/F

**E-MAIL:**

JFair  
RWeisman  
AMurphy  
RPettis  
GGalletti  
DShum  
GBagchi  
SSmith (srs3)  
SDuraiswamy  
YL (Renee) Li  
RidsNrrDlr  
RidsNrrDlrRlra  
RidsNrrDlrRlrb  
RidsNrrDe  
RidsNrrDci  
RidsNrrEemb  
RidsNrrDeEeeb  
RidsNrrDeEqva  
RidsNrrDss  
RidsNrrDnrl  
RidsOgcMailCenter  
RidsNrrAdes  
DLR Staff

-----  
RSubbaratnam  
SHoffman  
SUttal  
JShea  
JDavis  
CAnderson, Region 1  
WRaymond, Region 1  
NSheehan, Region 1

Pilgrim Nuclear Power Station

cc:

Regional Administrator, Region I  
U. S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, PA 19406-1415

Senior Resident Inspector  
U. S. Nuclear Regulatory Commission  
Pilgrim Nuclear Power Station  
Post Office Box 867  
Plymouth, MA 02360

Chairman, Board of Selectmen  
11 Lincoln Street  
Plymouth, MA 02360

Chairman  
Nuclear Matters Committee  
Town Hall  
11 Lincoln Street  
Plymouth, MA 02360

Chairman, Duxbury Board of Selectmen  
Town Hall  
878 Tremont Street  
Duxbury, MA 02332

Office of the Commissioner  
Massachusetts Department of  
Environmental Protection  
One Winter Street  
Boston, MA 02108

Office of the Attorney General  
One Ashburton Place  
20th Floor  
Boston, MA 02108

MA Department of Public Health  
Radiation Control Program  
Schrafft Center, Suite 1M2A  
529 Main Street  
Charlestown, MA 02129

Secretary of Public Safety  
Executive Office of Public Safety  
One Ashburton Place  
Boston, MA 02108

Director, Massachusetts Emergency  
Management Agency  
Attn: James Muckerheide  
400 Worcester Road  
Framingham, MA 01702-5399

Mr. William D. Meinert  
Nuclear Engineer  
Massachusetts Municipal Wholesale  
Electric Company  
P.O. Box 426  
Ludlow, MA 01056-0426

Mr. Michael A. Balduzzi  
Site Vice President  
Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360-5508

Mr. Stephen J. Bethay  
Director, Nuclear Safety Assurance  
Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360-5508

Mr. Bryan S. Ford  
Manager, Licensing  
Entergy Nuclear Operations, Inc.  
Pilgrim Nuclear Power Station  
600 Rocky Hill Road  
Plymouth, MA 02360-5508

Mr. Gary J. Taylor  
Chief Executive Officer  
Entergy Operations  
1340 Echelon Parkway  
Jackson, MS 39213

cc:

Mr. John T. Herron  
Sr. VP and Chief Operating Officer  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Oscar Limpias  
Vice President, Engineering  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Christopher Schwarz  
Vice President, Operations Support  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. John F. McCann  
Director, Nuclear Safety Assurance  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Ms. Charlene D. Faison  
Manager, Licensing  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. Michael D. Lyster  
5931 Barclay Lane  
Naples, FL 34110-7306

Mr. Michael J. Colomb  
Director of Oversight  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Ms. Stacey Lousteau  
Treasury Department  
Entergy Services, Inc.  
639 Loyola Avenue  
New Orleans, LA 70113

Mr. James Snizek  
5486 Nithsdale Drive  
Salisbury, MD 21801

Mr. Travis C. McCullough  
Assistant General Counsel  
Entergy Nuclear Operations, Inc.  
440 Hamilton Avenue  
White Plains, NY 10601

Mr. James Ross  
Nuclear Energy Institute  
1776 I Street, NW, Suite 400  
Washington, DC 20006-3708

Plymouth Public Library  
Attn: Dinah O'Brien  
132 South Street  
Plymouth, MA 02360

Duxbury Free Library  
ATTN: Ms. Elaine Winquist  
77 Alden Street  
Duxbury, MA 02332

Kingston Public Library  
ATTN: Reference Librarian  
6 Green Street  
Kingston, MA 02364

Ms. Mary Lampert  
Duxbury Nuclear Advisory, Chair  
Pilgrim Watch, Director  
148 Washington Street  
Duxbury, MA 02332

**LIST OF PARTICIPANTS FOR TELEPHONE CONFERENCE CALL  
TO DISCUSS THE PILGRIM NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION**

**August 1, 2006**

**PARTICIPANTS**

Ram Subbaratnam  
James Davis  
Peter Wen  
Dan Hoang  
Kenneth Chang  
James Medoff  
Ganesh Cheruvenki  
Simon Scheng  
Bryan Ford  
Fred Mogolesko  
Laris Chan  
Erac Patel  
Doug Ellis

**AFFILIATION**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
NRC  
NRC  
NRC  
NRC  
NRC  
NRC  
Entergy Nuclear Operations, Inc. (Entergy)  
Entergy  
Entergy  
ATL  
Entergy

**ENCLOSURE**