



# **State-of-the-Art Reactor Consequence Analyses (SOAR CA)**

**October 25, 2006**

**United States Nuclear Regulatory  
Commission**



# AGENDA

- **Objectives**
- **Method**
- **Potential Uses**
- **Motivation**
- **Schedule**
- **Details**
- **Conclusion**
- **Public questions and comments**



# OBJECTIVES

- **Realistic evaluation of severe accident progression, radiological releases and offsite consequences**
  - **Provide a more accurate assessment of potential offsite consequences**
- **Focus on a spectrum of scenarios most likely to contribute to release and subsequent offsite consequences, using a risk-informed approach**



# METHOD

- **Use realistic, detailed integral modeling of plant systems, radionuclide transport and deposition, and release pathways (i.e., PRA, MELCOR, MACCS etc.)**
- **Use updated emergency preparedness modeling assumptions**
- **Account for plant improvements, including insights from newer, more realistic NRC evaluations**
- **Account for use of mitigation strategies for the delay or prevention of core damage, and further reduction in offsite consequences**



# POTENTIAL USES

- **Safety-related decision making**
- **Emergency preparedness and emergency response**
- **Regulatory analysis guidelines**
- **Communication with the public, DHS**
- **Insights for future regulatory and research activities**



# MOTIVATION

- **Improved PRA modeling**
- **Improved plant performance**
- **Added plant design features (e.g., alternative AC power for SBO)**
- **Better understanding of physical phenomena of severe accidents**
- **MELCOR integrated severe accident analysis code**
- **Computing speed**
- **More realistic assessment of radiological source term and potential consequences**



# SCHEDULE

- **Three-year project**
  - **1<sup>st</sup> year: Westinghouse 4-loop large dry, GE Mark I, and GE Mark III plants**
  - **2<sup>nd</sup> year: GE Mark II, Ice Condenser, and other Westinghouse plants**
  - **3<sup>rd</sup> year: B&W and CE plants**
- **Six plants selected as lead plants on the basis of providing a mixture of offsite populations**
  - **Westinghouse 4-loop large dry**
    - **Diablo Canyon, Salem, Seabrook**
  - **GE Mark I**
    - **Duane Arnold, Fermi, Peach Bottom**



# TECHNICAL CONSIDERATIONS

- **Select scenarios**
- **Identify and quantify likelihood of operator actions (e.g., EOPs)**
- **Estimate accident progression and fission product release to environment using MELCOR**
  - Design-specific (e.g., Mark I)
  - Realistic containment performance modeling
- **Estimate offsite radiological consequences using MACCS**
  - **Site-specific**
    - Emergency response modeling
    - Population densities
    - Weather



# INFORMATION NEEDS

- **Detailed reactor plant data for each reactor class (e.g., Mark I)**
  - **Develop/confirm the MELCOR model for accident progression and fission product release**
- **Site-specific information to calculate offsite consequences**
  - **Emergency response modeling information**
  - **Hourly meteorological information**



# **INFORMATION NEEDS (cont.)**

- **Human Reliability Analysis**
  - **Plant-specific information (e.g., relevant procedures and how procedures are implemented)**
  - **Plant site visits may be needed**
  - **Plant variability information**
    - **Has an Owner's Group report regarding the variation between plants on how procedures been written?**




# ACCIDENT SCENARIO SELECTION

- **Focus on dominant accident scenarios**
  - Focus should be on accident scenarios with a  $\geq 10^{-6}$  (i.e., one in one million) per year release frequency
  - Where possible, also consider high-consequence scenarios with somewhat lower frequencies (e.g., ISLOCA)
    - Lower the release frequency screening threshold by an order of magnitude for bypass scenarios
- **Account for plant improvements which have been incorporated, but not credited in current PRAs**
- **Complete the preliminary offsite consequence calculations for two (or three) groups of plants within the first year**
  - Start with six lead plants
  - The results for all plants will be finalized and released in a final report issued in 2009



# SCENARIO SELECTION PROCESS





# SCENARIO SCREENING APPROACH

- **Approach focuses on selecting scenarios for plant/containment groups (i.e., MELCOR groups)**
  - The SPAR models for each plant within the group undergoes the internal events screening
  - Identify general scenarios that exceeded the  $10^{-6}$  threshold (based on CDF)
  - Not all scenarios will exceed the  $10^{-6}$  threshold (based on CDF) for all the plants within the group
- **A defined case for each general scenario is developed for input into MELCOR calculations**
  - Sensitivity studies will be performed to address important scenario variations
- **Reviewed IPEEEs and EE SPAR models (if available)**
  - Determine external event contribution to internal event scenarios
  - Identify unique external event scenarios that are close to or exceed the  $10^{-6}$  threshold



# BWR MARK I SCENARIOS

- **Three preliminary internal event scenarios have been identified:**
  - Transients with RCIC/HPCI unavailabilities and failures of RCS depressurization
  - SBO with failure to recover power prior to battery depletion
  - Transients with RHR/SW unavailabilities and containment venting/late injection failures that lead to unavailability of SPC/SDC and containment failure
- **Dominant external event scenarios tend to be functionally (i.e., system response) equivalent to one or more of the selected internal event scenarios**
- **No LOCA (including ISLOCA) scenarios have exceeded the screening threshold**
  - Most Mark I BWRs have LOCA CDFs one to two orders of magnitude below the  $10^{-6}$  threshold
- **ATWS CDFs are lower than the  $10^{-6}$  threshold (based on CDF)**
- **Selected scenarios may later screen out if strong mitigation credit is applicable**
  - Plant improvements, SAMGs may result in lowering of frequency
- **Important to realistically capture the timing of events**



# WESTINGHOUSE 4-LOOP/LARGE DRY PWR SCENARIOS

- **Five preliminary internal event scenarios have been identified:**
  - Transients with AFW unavailabilities and failures to bleed and feed
  - SBO with failure to recover power either prior to battery depletion or prior to core uncover in case of RCP seal LOCA
  - Loss of service water or component cooling water with failure of RCP seals
  - Interfacing systems LOCA from RHR system
  - Steam generator tube rupture
- **All other LOCA scenarios screen out either due to low CDFs or strong post-core damage and/or release mitigation credit**
- **A few ATWS CDFs exceed the  $10^{-6}$  threshold (based on CDF), however this is due to modeling simplifications currently be corrected by INL**
- **Dominant external event scenarios tend to be functionally (i.e., system response) equivalent to one or more of the selected internal event scenarios**
- **Scenarios with very long times to core damage (>24 hours) could be screened out due to the large amount of time available for mitigation**



# ADDITIONAL TECHNICAL ISSUES

- **Evaluation of Mitigation Measures**
  - Data collection and evaluation of plant enhancements
  - HRA credit for operator actions
- **Scenario Selection Output**
  - Quantitative scenario calculations
  - Release frequency estimations uncertainties



**QUESTIONS?**