

Chapter 14 From Revision 1 to Revision 2 Change List

Item	Location	Description of Change
1.	S14.02.01.04, Startup Group section 3 rd sentence	Clarified responsibilities
2.	S14.02.01.04, General Electric Company section, 2 nd sentence	Clarified responsibilities
3.	S14.02.02, 2 nd para.	Changed to indicate made available 60 days prior to use
4.	S14.02.07, 2 nd para, 2 nd sentence	Clarified cross-reference to other DCD section
5.	S14.02.08.01, 3 rd para	Clarified by adding "standard design" here, consistent with use elsewhere in this subsection. (The list is site specific items
6.	S14.02.08.01.03, 7 th and 8 th bullets, Note added	Stated concentration will be surveilled prior to TS mode entry, versus preoperational test
7.	S14.02.08.01.19, 5 th bullet	Changed to “ <u>air</u> temperatures and pressures” to clarify that the requirement is on the air system, and testing will be prior to heatup of the serviced components.
8.	S14.02.08.01.19, 11 th bullet	Changed to clarify component tests may be done separately from integrated system Instrument and Service Air Preoperational tests
9.	S14.02.08.01.23, 2 nd para	Deleted Aux. Boiler as redundant to “appropriate heating source”.
10	S14.02.08.01.25, 2 nd para	Reworded to allow separate tests
11	S14.02.08.01.39 4 th sentence	Additional details for clarity in response to RAI#14.2-4 “in accordance with the criteria in codes and standards listed in Table 9.5-1”
12	S14.02.08.01.39 4 th sentence	Additional details for clarity in response to RAI#14.2-4 “and meet all functional requirements described in subsection 9.5.1.1”.
13	S14.02.08.01.39	Additional details in response to RAI#14.2-4

	1 st level list 4 th bullet	Verification of proper installation of all fire protection equipment, including sprinkler heads, spray nozzles, fire detectors, annunciators, hose stations, and portable fire extinguishers;
14	S14.02.08.01.39 1 st level list 7 th bullet	Rewritten for clarity in response to RAI# 14.2-4 Replaced “smoke, heat and flame” with “all fire”
15	S14.02.08.01.39 1 st level list 8 th bullet	Rewritten for clarity in response to RAI# 14.2-4 Deleted “and” for format
16	S14.02.08.01.39 1 st level list 9 th bullet	Rewritten for clarity in response to RAI# 14.2-4 Deleted “, including fire protection diesel generator” for clarity”
17	S14.02.08.01.39 1 st level list 10 th bullet	Additional details provided in response to RAI# 14.2-4 “Verification of proper installation and integrity of all fire barriers, including penetration seals, fire doors and fire dampers”
18	S14.02.08.01.39 1 st level list 12 th bullet	Additional details provided in response to RAI# 14.2-4 “Proper installation and operation of HVAC systems used for smoke control and exhaust”
19	S14.02.09	Changed COL Applicant to COL holder, consistent with RAIs 14.2-15 thru 21 response.
20	S14.02.09.01, added section	Added information provided RAIs14.2-15 thru 21
21	S14.3.6	Changed section title
22	S14.3.7, added section	Added new subsection to provide the process for determining Tier 1 changes and additions in response to RAI 14.3-1 S01.