

•• [•]

GE Energy

David H. Hinds Manager, ESBWR

PO Box 780 M/C L60 Wilmington, NC 28402-0780 USA

T 910 675 6363 F 910 362 6363 david.hinds@ge.com

MFN 06-418

Docket No. 52-010

October 26, 2006

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555-0001

Subject: Response to Portion of NRC Request for Additional Information Letter No. 69 – Acceptance Criteria for Infrequent Events – RAI Numbers 15.0-17

Enclosure 1 contains GE's response to the subject NRC RAI transmitted via the Reference 1 letter.

If you have any questions about the information provided here, please let me know.

Sincerely,

Bathy Sedney for

David H. Hinds Manager, ESBWR



MFN 06-418 Page 2 of 2

•.

Reference:

1. MFN 06-381, Letter from U.S. Nuclear Regulatory Commission to David Hinds, Request for Additional Information Letter No. 69 Related to ESBWR Design Certification Application, October 11, 2006

Enclosure:

1. MFN 06-418 – Response to Portion of NRC Request for Additional Information Letter No. 69 – Acceptance Criteria for Infrequent Events – RAI Number 15.0-17

cc: AE Cubbage USNRC (with enclosures) GB Stramback GE/San Jose (with enclosures) eDRF 0058-8864

ENCLOSURE 1

.**·** •

MFN 06-418

Response to Portion of NRC Request for Additional Information Letter No. 69 Related to ESBWR Design Certification Application Acceptance Criteria for Infrequent Events RAI Number 15.0-17 MFN 06-418 Enclosure 1

. • •

NRC RAI 15.0-17:

Standard Review Plan (SRP) Section 15.2.8.II.A.1, Revision 1, July 1981, states that pressure in the reactor coolant and main steam systems should be maintained below 110% of the design pressures [ASME Boiler and Pressure Vessel Code, Section III, Service Level B] for low probability events and below 120% of the design pressures [ASME Boiler and Pressure Vessel Code, Section III, Service Level C] for very low probability events such as double-ended guillotine breaks.

DCD Tier 2, Rev. 1, Table 15.0-5, Acceptance Criteria for Infrequent Events, states that "pressures in the reactor coolant and main steam systems shall be maintained below the ASME Service Level C limit, which corresponds to 120% of design pressure."

Revise DCD Tier 2, Table 15.0-5 consistent with the SRP acceptance criteria for low probability events that the pressure in the reactor coolant and main steam systems should be maintained below 110 percent (Service Level B) of the design pressures.

Response to RAI 15.0-17:

Standard Review Plan (SRP) Section 15.2.8, Revision 1, July 1981 is titled "FEEDWATER SYSTEM PIPE BREAKS INSIDE AND OUTSIDE CONTAINMENT (PWR)," and thus, is not applicable to BWRs.

Determination criteria for "low probability events" and "very low probability events" are not provided in the SRPs or the 10 CFRs, and thus, the ESBWR event types vs. Service Levels were compared to those of the operating plants and the ABWR. For the operating BWRs, the ABWR and the ESBWR, AOOs are considered to be (the low probability) events that apply ASME Boiler and Pressure Vessel Code, Section III, Service Level B, and the infrequent incidents/events. ATWS and accidents are considered to be (the very low probability) events that apply ASME Boiler and Pressure Vessel Code, Section III, Service Level C/D. Therefore, the ESBWR Service Level C acceptance criterion for infrequent events is consistent with past and existing BWR licensing bases.

No DCD change results from this RAI response.