

SURVEILLANCE REQUIREMENTS (continued)

| SURVEILLANCE | | FREQUENCY |
|--------------|--|--|
| SR 3.6.4.1.3 | Verify one door in each access to secondary containment is closed, except during normal entry and exit. | 31 days |
| SR 3.6.4.1.4 | Verify the secondary containment can be drawn down to ≥ 0.25 inch of vacuum water gauge within the time required using one Standby Gas Treatment (SGT) subsystem. | 24 months on a STAGGERED TEST BASIS for each SGT subsystem |
| SR 3.6.4.1.5 | Verify the secondary containment can be maintained ≥ 0.25 inch of vacuum water gauge for 1 hour using one SGT subsystem at a flow rate ≤ 4400 cfm. | 24 months on a STAGGERED TEST BASIS for each SGT subsystem |