

- (4) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and
- (5) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility.

C. This License shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

The Pacific Gas and Electric Company is authorized to operate the facility at reactor core power levels not in excess of 3411 megawatts thermal (100% rated power) in accordance with the conditions specified herein.

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 191, are hereby incorporated in the license. Pacific Gas & Electric Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan, except where otherwise stated in specific license conditions.

(3) Initial Test Program

The Pacific Gas and Electric Company shall conduct the post-fuel-loading initial test program (set forth in Section 14 of Pacific Gas and Electric Company's Final Safety Analysis Report, as amended), without making any major modifications of this program unless modifications have been identified and have received prior NRC approval. Major modifications are defined as:

- a. Elimination of any test identified in Section 14 of PG&E's Final Safety Analysis Report as amended as being essential;

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
1. WCAP-10216-P-A, Revision 1A, Relaxation of Constant Axial Offset Control F_Q Surveillance Technical Specification, February 1994 (Westinghouse Proprietary),
 2. WCAP-9272-P-A, Westinghouse Reload Safety Evaluation Methodology, July 1985 (Westinghouse Proprietary),
 3. WCAP-8385, Power Distribution Control and Load Following Procedures, September 1974 (Westinghouse Proprietary),
 4. WCAP-10054-P-A, Westinghouse Small Break LOCA ECCS Evaluation Model Using the NOTRUMP Code, August 1985. (Westinghouse Proprietary), and
 5. WCAP-10054-P-A, Addendum 2, Revision 1, "Addendum to the Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code: Safety Injection Into the Broken Loop and COSI Condensation Model," July 1997 (Westinghouse Proprietary), and
 6. WCAP-12945-P-A, Westinghouse Code Qualification Document for Best-Estimate Loss of Coolant Analysis, June 1996. (Westinghouse Proprietary), and
 7. WCAP-12945-P-A, Addendum 1-A, Revision 0, "Method for Satisfying 10 CFR 50.46 Reanalysis Requirements for Best Estimate LOCA Evaluation Models," December 2004. (Westinghouse Proprietary) (Unit 1 Only).
- c. The core operating limits shall be determined such that all applicable limits (e.g., fuel thermal mechanical limits, core thermal hydraulic limits, Emergency Core Cooling Systems (ECCS) limits, nuclear limits such as SDM, transient analysis limits, and accident analysis limits) of the safety analysis are met.
- d. The COLR, including any midcycle revisions or supplements, shall be provided upon issuance for each reload cycle to the NRC.

(continued)