



Tennessee Valley Authority, 1101 Market Street, Chattanooga, Tennessee 37402-2801

November 21, 2006

10 CFR 50.55a

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Gentlemen:

In the Matter of _____)
Tennessee Valley Authority)

Docket Nos. 50-327
50-328

SEQUOYAH NUCLEAR PLANT (SQN) UNITS 1 AND 2 - PREEMPTIVE WELD OVERLAYS (PWOL) ON ALLOY 600 PRESSURIZER NOZZLE-TO- PIPE WELDS AND ASSOCIATED ALTERNATIVE REPAIR TECHNIQUES - GENERIC REQUEST FOR RELIEF G-RR-1 - SUPPLEMENTAL INFORMATION (TAC NOS. MD2381 & MD2382)

This letter provides follow-up to TVA's telephone conversation with NRC on November 16, 2006. NRC attendees included Doug Pickett, Acting Chief, Plant Licensing Branch II-2, Terrence Chan, Chief, Piping and Nondestructive Examination (NDE) Branch, Kim Gruss, Chief, Flaw Evaluation and Welding Branch, and Tim Lupold, Piping and NDE Branch. TVA attendees included representatives from Corporate Licensing and SQN.

During the telephone call, NRC provided verbal approval for TVA's Generic Relief Request No. G-RR-1 for SQN Unit 2 in accordance with NRC Office Instruction LIC-102, Revision 1, "Relief Request Reviews." For additional clarification, NRC requested that TVA revise and resubmit the sketches previously provided in TVA's supplemental letter to NRC dated October 20, 2006. Specifically, NRC requested that point A and D on the sketches be relocated to show polished areas of the welds. Accordingly, the revised sketches are enclosed.

A047

U.S. Nuclear Regulatory Commission
Page 2
November 21, 2006


In a follow-up conversation on November 17, 2006, NRC clarified that the issuance of the formal Safety Evaluation Report on G-RR-1 is not a SQN Unit 2 restart constraint for the fall 2006 refueling outage.

SQN UNITS 1 AND 2 COMMITMENTS

Also, in the follow-up telephone conversation, NRC clarified that commitment note No. 3 found in Enclosure 2, "List of Commitments," of TVA's letter dated October 20, 2006, is superseded by the sketches enclosed herewith. Thus, TVA withdraws note No. 3 applicability from the "List of Commitments."

There are no additional commitments made by this letter. If you have any questions, please contact Rob Brown at (423) 751-7228.

Sincerely,



B. A. Wetzel
Manager, Corporate Nuclear Licensing
and Industry Affairs

Enclosure
cc (Enclosure):

U.S. Nuclear Regulatory Commission
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW, Suite 23T85
Atlanta, Georgia 30303-8931

NRC Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, TN 37379

Douglas V. Pickett, Senior Project Manager
U.S. Nuclear Regulatory Commission
Mail Stop 08G9A
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

ENCLOSURE

SEQUOYAH NUCLEAR PLANT (SQN)

Sketches 1 and 2

ILLUSTRATION SKETCH NO.1 (R2)




ILLUSTRATION SKETCH NO.2 (R2)

