# ENGINEERING REPORT ON:

Evaluation of Charging-Safety Injection Pump Motor Bearing Temperatures at

Progress Energy Harris Nuclear Plant

> To: Mr. Todd Wagoner Progress Energy

By: Fred C. Wiesinger Technical Services Manager



Submitted: Revision B October 12, 2006

Since 1920, Providing Solutions To Manufacturers And Users Of Rotating Equipment



Licensee of

ALSTOM and SIEMENS
Westinghouse

www.pioneer1.com sales@pioneer1.com engineering@pioneer1.com

 Engineering, Sales & Manufacturing
 129 Battleground Rd., Kings Mountain, NC 28086, Tel (704) 937-7000, Fax (704) 937-9429, 1-888-813-9001

 Administration & Western Sales
 1601 Bayshore Hwy., Ste. 202, Burlingame, CA 94010, Tel (650) 652-7990, Fax (650) 652-7993, 1-888-812-9001

 Technical Services • Northeast
 1758 Allentown Rd., #130, Lansdale, PA 19446, Tel (215) 362-4074, Fax (215) 362-4074

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

# Summary

Pioneer Motor Bearing has analyzed the performance of the radial bearings of the Charging-Safety Injection Pump Motors from Progress Energy's Harris Nuclear Plant under both normal operating conditions and a potential high ambient temperature condition. Results of the analysis show excellent correlation with the normal running conditions and indicate that the bearing will operate satisfactorily under the high ambient conditions.

# Background

The bearings in question are ring oiled babbitted sleeve bearings installed in a horizontal 900 HP, 1800 RPM Westinghouse squirrel cage induction motor. This motor drives a Charging-Safety Injection Pump for the Harris plant. There was a period of time when one of the A/C Chillers responsible for the heat load in the area where these pumps operate was unavailable. Should these pumps have been operated during this time, it is conservatively estimated that the ambient temperature in this room could have risen to 160 degrees F. The bearings are self contained with all of the heat that is generated in the bearing housings being dissipated through convection to the surrounding air. The normal operating characteristics of this motor bearing yield bearing metal temperatures that are around 50 degrees F higher than the ambient temperature. There is concern that if this delta T remains constant then the bearing metal temperatures will exceed the temperature limits specified by the OEM for this equipment. This temperature limit is currently specified as 203 degrees F.

# Analysis

A numerical analysis was performed on the bearing design using the computer program THBRG. This program was developed by The University of Virginia and is available through their ROMAC Industrial Program. This suite of analytical programs is in active use by bearing

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

manufactures, OEMs and consultants around the world. The following is a brief description of the program itself:

### THBRG [UNIX & PC]

THBRG calculates the pressure profiles, temperature distribution in film and bearing housing, lubricant flow rates, power loss, and dynamic coefficients for a multilobe journal bearing with an incompressible lubricant. A combination of finite element and finite difference methods are used to solve the governing equations. THBRG uses an assumed axial pressure profile and an assumed cross-film viscosity variation to decrease the dimensionality of the problem to the circumferential direction only. This significantly increases the speed of the program while retaining high accuracy. The analysis includes fluid film conduction, cross-film viscosity variation, two-phase cavitation models for the energy equation, conduction in the housing, convection heat transfer from housing and turbulence. ROMAC Report No. 273.

# **Input Data**

Data for modeling the bearing for analysis was obtained through inspection of an existing bearing from a spare motor. This data is as follows:

Bearing Diameter4.507 inchBearing Length4.600 inchEffective pad angle120 degreesDesign Clearance.006 to .008 inch diametralOil SupplyMobil DTE Medium supplied by a single oil ringLoad1000 lbs (conservative estimate)

# Results

As we are primarily concerned with the maximum operating temperature, the bearing was modeled with minimum diametral clearance. The first analytical run was to estimate the normal

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

operating conditions and check the accuracy of predicted performance. With an ambient temperature of 77 degrees F, the predicted maximum bearing operating temperature is 142.85 degrees F. This prediction agrees guite well with the operating data that was provided to Pioneer (127 and 148 degrees F with an ambient temperature of 77 degrees F). The difference in operating temperatures can readily be explained in that one of the bearings is electrically insulated which will provide a certain degree of thermal insulation as well. In this case, the computer program is predicting a temperature very close to the highest temperature observed while the motor is in operation. During the normal operation of this bearing, the predicted minimum oil film thickness is .00247 inch. The next step was to take this same model and increase the ambient temperature to 160 degrees F. Results of this analysis predict the maximum bearing temperature will reach 185.93 degrees F while operating under these conditions. The predicted oil film thickness while operating at this elevated temperature is .00202 inch. In considering a yet more conservative assumption, it is conceivable that while running at this elevated ambient condition the oil sump temperature could reach a maximum stabilized temperature on the order of 180 degrees F. This is based on adding the normal steady state sump surface-to-air delta temperature (20 Degrees F) to the predicted 160 degrees F ambient condition. Analysis under these conditions predicts the babbitt temperature will reach 196.92 degrees F and the minimum film thickness will be .00188 inch.

# Discussion

The original concerns for operation of this motor under the adverse ambient conditions were based on the assumption that the difference in bearing metal temperature and the ambient temperature would remain constant. This is in fact not the case. In the closed system of the bearing housing, the internal temperatures are a result of the heat generated within the housing and the ability of the housing to dissipate this heat to the surrounding atmosphere. While the higher ambient conditions will impact the heat transfer from the housing to the atmosphere, the reduction in effective viscosity of the oil will, at

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

the same time, reduce the heat load that is being generated within the bearing housing. In this specific case, the power loss of the bearing assembly is effectively cut in half. This fact accounts for the significant reduction in the differential between the predicted bearing metal temperatures and the ambient temperature as the ambient temperature is increased. A review of the minimum oil film thickness shows that even when operating in an elevated ambient temperature environment, the predicted operating oil film thickness of .00188 is still nearly double the generally industrially accepted minimum prediction of .001 inch.

The maximum predicted babbitt temperature of 196.92 degrees F is also still below the OEM limit that is set at 203 degrees F. As the operational prediction is close to the current alarm point a discussion on temperature alarms also seems appropriate. The current alarm point of 203 degrees F was certainly not established simply based on protecting the babbitt material. Typical industrial machinery operating on babbitted journal bearings run reliably with alarm and shut down limits between 240 and 260 degrees F. In fact, the main propulsion steam turbine thrust bearing, constructed with tin based babbitt on a steel backing, on a specific class of US Navy warship runs up to 300 degrees F every time the ship is run at flank speed. There has never been a bearing failure attributed to operating at this elevated temperature. Moreover, as the current alarm point for the bearing temperature for this machine is set so much lower than that required to simply protect the babbitt material, it is more likely that the alarm point for this bearing was based on bounding reasonable temperature excursion or deviations beyond the predicted babbitt temperature during normal operating conditions. The intention being to alert the operator of a significant temperature excursion or deviation rather than simply protecting the babbitt material.

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

### Conclusions

Based on the information provided to Pioneer Motor Bearing, the bearing temperatures of the Charging-Safety Injection Pump Motors will remain below the OEM specified bearing temperature limits while operating with an ambient temperature of 160 degrees F.

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

### Appendix A

#### Computer Program Output File Run at 77 Degrees F Ambient

1\*\*\*MULITLOBE BEARING PROGRAM -- THBRG VERSION 2.46 (17 Mar 1) Harris Safety Injection Motor Bearings Hot Operation Analysis [THBRG 10/04/06] 1800 rpm, 1000 #, DTE medium @ 77 F OVERALL GEOMETRY: RADIUS= 2.253 INDIAMETER= 4.507 INRADIAL PAD CLEAR=.00300 INDIAMETRAL= .00600 INAXIAL LENGTH= 4.600 INPAD OUTER DIAMETER=6.500 IN LENGTH/DIAMETER = 1.021PAD GEOMETRY: LEAD PIVOT ARC END PRELOAD DELTH GRANG 
 NUMBER
 ANGLE
 <t OIL PROPERTIES: 

 MU(104.0 F)
 = .5359E-05 LB-SEC/IN2

 MU(212.0 F)
 = .8600E-06 LB-SEC/IN2

 THERMAL SLOPE
 = -.1694E-01 1/F

 INLET VISCOSITY
 = .847E-05 LB-SEC/IN2

 OIL DENSITY
 = .800E-04 LB-S2/IN4

 OIL DENSITY = .800E-04 LB-S2/IN4 SPECIFIC HEAT = .180E+03 BTU-IN/(LB-S2-F) OIL SUPPLY PRESSURE= .00 PSI SUPPLY TEMPERATURE = 77.00 F GENERAL SETUP: 30 ELEMENTS PER PAD ERROR CRITERIA (DIM) = .001000 AXIAL PRESSURE EXPONENT (DIM) = 2.000 INITIAL (X, Y) = (.200, -.200)OPTIONS SELECTED: ITERATED ECCENTRICITY - TO MATCH SPECIFIED LOAD GROOVE TEMPERATURE: FOUND BY ITERATION BOUNDARY CONDITION: REYNOLDS WITH FLOW CORRECTION LAMINAR/TURBULENT FLOW ENERGY EQUATION: INCLUDES PRESSURE GRADIENT TERMS CAVITATION: NEGLECT HEAT GENERATION IN THIS REGION VISCOSITY IN REYNOLDS EQN .: CONSTANT ACROSS FILM VISCOSITY IN ENERGY EQN.: CONSTANT ACROSS THE FILM THERMAL SOLUTION: CONDUCTION TO THE SHAFT AND SHELL

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

FILM THERMAL CONDUCTIVITY = .2000E-05 BTU/IN/S/F
SHELL THERMAL CONDUCTIVIY = .2000E-03 BTU/IN/S/F
SHELL CONDUCTION SOLUTION: 2-DIMENSIONAL
GROOVE MIDLINE TEMPERATURE: AVERAGE ACROSS GROOVE
ITERATIVE SHAFT TEMPERATURE: AVERAGE FILM
INITIAL JOURNAL TEMP = 120.00 F
CONVECTION HEAT TRANSFER TO BACK OF SHELL
AMBIENT TEMP= 77.00 F
H COEFF = .2000E-04 BTU/S/IN^2/F
CONSTANT CONVECTION COEFFICIENT
CAVITATION: INSULATION EFFECT (RATIO= 5.0000)
CAVITATION: LATENT HEAT EFFECT (RATIO= .0000)

Harris Safety Injection Motor Bearings Hot Operation Analysis [THBRG 10/04/06]

1800 rpm, 1000 #, DTE medium @ 77 F

SPEED/LOAD CASE # 1

 SPEED=
 1800.0 RPM
 WEIGHT=
 1000.00 LBS

 EXTERNAL LOADS:
 X=
 .00 LBS
 Y=
 .00 LBS

 LOAD=
 48.23 PSI
 .00000
 Y=
 10.71225

SOMMERFELD # = .2971E+01 FACTOR= 100.00000 POS.RELAX= 1.000

CONVERGENCE IN 53 ITERATIONS TO POSITION (X/CP , Y/CP) = ( .1613 , -.0714 ) (X , Y) = ( .00048 , -.00021 ) IN OPERATING POSITION (E/CP) = .1764 AT 66.1 DEG

ERROR SUMMARY: FORCE (-.5E-05, .1E-02); FILM TEMPERATURE (.1E-03); GROOVE TEMPERATURE (.6E-03)

PAD	PIVOT	PRELOA	AD X	FORCE	Y	FORCE	% CAPACITY	7
PRESS	LEAD	PRESS TR						
1	90.0	.0000	)	.0		.0	100.00	)
.00		.00						
2	270.0	.0000	)	.0		998.1	100.00	)
.00		.00						
KBXX= KYX= KBXY= KYY=	.88 -2 .80	49 KBYX= 116976. LB, 43 KBYY= 699681. LB,	-6.3509 /IN 2.0990 /IN		KXX= KXX=	29- 26	4963. LB/IN 8104. LB/IN	1
CBXX= -1354.	1.73 LB-S/II	00 CBYX= N	7659		CXX=	305	9. LB-S/IN	CYX=
CBXY= 22474.	76	59 CBYY= N	12.7088		CXY=	-135	4. LB-S/IN	СҮҮ=

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

RIGID ROTOR STABILITY THRESHOLD = 5899.4 RPM /SLOPE/ = .381 CIPS /DIFFERENTIAL/ = FLOW: .451 CIPS /SLOPE/ = .099 GPM /DIFFERENTIAL/ = .117 GPM FRICTION LOSS: /UNCAVITATED/ = .674 HP /FULL/ =1.255 HP TEMP RISE: /UNCAVITATED/ = 8.6 DEGF-GPM /FULL/ = 16. DEGF-GPM GROOVE TEMPERATURES AND FLOWS: PAD INLET TEMP (F) INLET (CIPS) OUTLET TEMP (F) OUTLET (CIPS) 1138.952.634136.692.6342129.632.985141.452.534 JOURNAL TEMPERATURE IS 137.55 F MAXIMUM BABBITT TEMPERATURE IS 142.85 F MAXIMUM FILM PRESSURE IS 115.55 PSI MINIMUM FILM THICKNESS IS .002473 IN NO TURBULENCE PREDICTED IN THE OIL FILM

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

### Appendix B Computer Program Output File Run at 160 Degrees F Ambient

1\*\*\*MULITLOBE BEARING PROGRAM -- THBRG VERSION 2.46 (17 Mar 1) Harris Safety Injection Motor Bearings Hot Operation Analysis [THBRG 10/04/06] 1800 rpm, 1000 #, DTE medium @ 160 F OVERALL GEOMETRY: RADIUS= 2.253 INDIAMETER= 4.507 INRADIAL PAD CLEAR=.00300 INDIAMETRAL= .00600 INAXIAL LENGTH= 4.600 INPAD OUTER DIAMETER=6.500 IN LENGTH/DIAMETER = 1.021PAD GEOMETRY: LEAD PIVOT ARC END PRELOAD DELTH GRANG 
 NUMBER
 ANGLE
 <t OIL PROPERTIES: IL PROPERTIES: MU(104.0 F) = .5546E-05 LB-SEC/IN2 MU(212.0 F) = .8600E-06 LB-SEC/IN2 THERMAL SLOPE = -.1726E-01 1/F INLET VISCOSITY = .211E-05 LB-SEC/IN2 OIL DENSITY = .800E-04 LB-S2/IN4 SPECIFIC HEAT = .180E+03 BTU-IN/(LB-S2-F) OIL SUPPLY PRESSURE= .00 PSI SUPPLY TEMPERATURE = 160.00 F GENERAL SETUP: 30 ELEMENTS PER PAD ERROR CRITERIA (DIM) = .001000 AXIAL PRESSURE EXPONENT (DIM) = 2.000 INITIAL (X, Y) = (.200, -.200)OPTIONS SELECTED: ITERATED ECCENTRICITY - TO MATCH SPECIFIED LOAD GROOVE TEMPERATURE: FOUND BY ITERATION BOUNDARY CONDITION: REYNOLDS WITH FLOW CORRECTION LAMINAR/TURBULENT FLOW ENERGY EOUATION: INCLUDES PRESSURE GRADIENT TERMS CAVITATION: NEGLECT HEAT GENERATION IN THIS REGION VISCOSITY IN REYNOLDS EQN.: CONSTANT ACROSS FILM VISCOSITY IN ENERGY EQN .: CONSTANT ACROSS THE FILM THERMAL SOLUTION: CONDUCTION TO THE SHAFT AND SHELL FILM THERMAL CONDUCTIVITY = .2000E-05 BTU/IN/S/F

# Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

<pre>SHELL THERMAL CONDUCTIVIY = .2000E-03 BTU/IN/S/F SHELL CONDUCTION SOLUTION: 2-DIMENSIONAL GROOVE MIDLINE TEMPERATURE: AVERAGE ACROSS GROOVE ITERATIVE SHAFT TEMPERATURE: AVERAGE FILM INITIAL JOURNAL TEMP = 120.00 F CONVECTION HEAT TRANSFER TO BACK OF SHELL AMBIENT TEMP= 160.00 F H COEFF = .2000E-04 BTU/S/IN^2/F CONSTANT CONVECTION COEFFICIENT CAVITATION: INSULATION EFFECT (RATIO= 5.0000) CAVITATION: LATENT HEAT EFFECT (RATIO= .0000)</pre>
Harris Safety Injection Motor Bearings Hot Operation Analysis [THBRG 10/04/06]
1800 rpm, 1000 #, DTE medium @ 160 F
SPEED/LOAD CASE # 1
SPEED=       1800.0 RPM       WEIGHT=       1000.00 LBS         EXTERNAL LOADS:       X=       .00 LBS       Y=       .00 LBS       SPECIFIC         LOAD=       48.23 PSI       .00000       Y=       42.98947
SOMMERFELD # = .7404E+00 FACTOR= 100.00000 POS.RELAX= 1.000
CONVERGENCE IN 60 ITERATIONS TO POSITION (X/CP, Y/CP) = ( .2483, - .2130) (X, Y) = ( .00074,00064) IN OPERATING POSITION (E/CP) = .3272 AT 49.4 DEG
ERROR SUMMARY: FORCE (5E-05, .1E-02); FILM TEMPERATURE ( .1E- 03); GROOVE TEMPERATURE ( .5E-03)
PAD PIVOT PRELOAD X FORCE Y FORCE % CAPACITY
PRESS LEAD         PRESS TR           1         90.0         .0000         .0         100.00
.00         .00           2         270.0         .0000         .0         998.2         100.00           .00         .00         .00         .00         .00         .00
KBXX= 1.0697 KBYX= -4.4034 KXX= 356566. LB/IN
KYX=     -1467787. LB/IN       KBXY=     .5308 KBYY=       2.2753     KXY=       176948. LB/IN
CBXX= 1.2932 CBYX= -1.1093 CXX= 2287. LB-S/IN CYX=
-1962. LB-S/IN CBXY= -1.1093 CBYY= 8.9849 CXY= -1962. LB-S/IN CYY= 15889. LB-S/IN

### Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

RIGID ROTOR STAP	BILITY THRESHO	LD = 598	89.8 RPM		
FLOW:	/SLOPE/	= .545	CIPS	/DIFFERENTIAL/	′ =
.000 0110	/SLOPE/	= .142	GPM	/DIFFERENTIAL/	′ =
.172 GPM FRICTION LOSS:	/UNCAVITATED/	= .369	HP	/FULL/	′ =
TEMP RISE:	/UNCAVITATED/	= 4.7	DEGF-GPM	I /FULL/	′ = 8.0
DEGF-GPM					
GROOVE TEMPERAT	TURES AND FLOWS TEMP (F) INI	S: LET (CIPS)	OUTI	ET TEMP (F)	OUTLET
(CIPS) 1 <sup>-</sup>	179 45	2 629		180 28	2 629
2	L79.40	2.743		184.61	2.083
JOURNAL TEMPER MAXIMUM BABBI MAXIMUM FILM R	RATURE IS 181.5 IT TEMPERATURE PRESSURE IS 12	52 F IS 185.93 21.11 PSI	F		
MINIMUM FILM 7	THICKNESS IS	.002019 IN			

NO TURBULENCE PREDICTED IN THE OIL FILM

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

#### **Appendix C**

Computer Program Output File Run at 160 Degrees F Ambient and 180 Degrees F Oil Inlet Temperature

1\*\*\*MULITLOBE BEARING PROGRAM -- THBRG VERSION 2.46 (17 Mar 1) Harris Safety Injection Motor Bearings Hot Operation Analysis [THBRG 10/13/06] 1800 rpm, 1000 #, DTE medium @ 180F, 160 F ambient OVERALL GEOMETRY: RADIUS= 2.253 INDIAMETER= 4.507 INRADIAL PAD CLEAR=.00300 INDIAMETRAL= .00600 INAXIAL LENGTH= 4.600 INPAD OUTER DIAMETER=6.500 IN LENGTH/DIAMETER = 1.021PAD GEOMETRY: LEAD PIVOT ARC END PRELOAD DELTH GRANG NUMBER ANGLE ANGLE ANGLE ANGLE DIM ANGLE ANGLE 129.0090.00122.00151.00.0004.0758.002209.00270.00122.00331.00.0004.0758.00 1 OIL PROPERTIES: IL PROPERTIES: MU(104.0 F) = .5546E-05 LB-SEC/IN2 MU(212.0 F) = .8600E-06 LB-SEC/IN2 THERMAL SLOPE = -.1726E-01 1/F INLET VISCOSITY = .149E-05 LB-SEC/IN2 OIL DENSITY = .800E-04 LB-S2/IN4 SPECIFIC HEAT = .180E+03 BTU-IN/(LB-S2-F) OIL SUPPLY PRESSURE= .00 PSI SUPPLY TEMPERATURE = 180.00 F GENERAL SETUP: 30 ELEMENTS PER PAD ERROR CRITERIA (DIM) = .001000 AXIAL PRESSURE EXPONENT (DIM) = 2.000 INITIAL (X, Y) = (.200, -.200)OPTIONS SELECTED: ITERATED ECCENTRICITY - TO MATCH SPECIFIED LOAD GROOVE TEMPERATURE: FOUND BY ITERATION BOUNDARY CONDITION: REYNOLDS WITH FLOW CORRECTION LAMINAR/TURBULENT FLOW ENERGY EQUATION: INCLUDES PRESSURE GRADIENT TERMS CAVITATION: NEGLECT HEAT GENERATION IN THIS REGION VISCOSITY IN REYNOLDS EQN .: CONSTANT ACROSS FILM VISCOSITY IN ENERGY EQN.: CONSTANT ACROSS THE FILM THERMAL SOLUTION: CONDUCTION TO THE SHAFT AND SHELL

Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation FILM THERMAL CONDUCTIVITY = .2000E-05 BTU/IN/S/F SHELL THERMAL CONDUCTIVIY = .2000E-03 BTU/IN/S/F SHELL CONDUCTION SOLUTION: 2-DIMENSIONAL GROOVE MIDLINE TEMPERATURE: AVERAGE ACROSS GROOVE ITERATIVE SHAFT TEMPERATURE: AVERAGE FILM INITIAL JOURNAL TEMP = 120.00 F CONVECTION HEAT TRANSFER TO BACK OF SHELL AMBIENT TEMP= 160.00 F H COEFF = .2000E-04 BTU/S/IN^2/F CONSTANT CONVECTION COEFFICIENT CAVITATION: INSULATION EFFECT (RATIO= 5.0000) CAVITATION: LATENT HEAT EFFECT (RATIO= .0000) Harris Safety Injection Motor Bearings Hot Operation Analysis [THBRG 10/13/06] 1800 rpm, 1000 #, DTE medium @ 180F, 160 F ambient SPEED/LOAD CASE # 1 
 SPEED=
 1800.0 RPM
 WEIGHT=
 1000.00 LBS

 EXTERNAL LOADS:
 X=
 .00 LBS
 Y=
 .00 LBS
 SPECIFIC
 EXTERNAL LOADS: X= LOAD= 48.23 PSI DIMENSIONLESS LOAD: X= .00000 Y= 60.71082 SOMMERFELD # = .5243E+00 FACTOR= 100.00000 POS.RELAX= 1.000 CONVERGENCE IN 62 ITERATIONS TO POSITION (X/CP, Y/CP) = ( .2697, -(X, Y) = (.00081, -.00078) IN OPERATING POSITION (E/CP) = .3744 AT 46.1 DEG ERROR SUMMARY: FORCE (-.4E-05, .9E-03); FILM TEMPERATURE ( .1E-03); GROOVE TEMPERATURE ( .5E-03) PAD PIVOT PRELOAD X FORCE Y FORCE % CAPACITY PRESS LEAD PRESS TR 1 90.0 .0000 .0 PRESS LEAD PRESS TR .0 100.00 .00 .00 2 270.0 .0 .0000 998.2 100.00 .00 .00 KBXX= 1.1228 KBYX= -4.1667 KXX= 374282. LB/IN KYX= -1388886. LB/IN KBXY= .4968 KBYY= 2.3 .4968 KBYY= 2.3628 KXY= 165591. LB/IN 787611. LB/IN KYY= CBXX= 1.2621 CBYX= -1.2154 CXX= 2232. LB-S/IN CYX= -2149. LB-S/IN CBXY= -1.2154 CBYY= 8.5677 CXY= -2149. LB-S/IN CYY= 15151. LB-S/IN

#### **PIONEER ENGINEERING PROPOSAL** Progress Energy – Harris Nuclear Plant Bearing Temperature Evaluation

RIGI	D ROTOR STAB	ILITY THR	ESHOLD =	5998	.0 RPM		
FLOW:		/SLOPE/ =	.576	CIPS	/DIFFERE	NTIAL/	=
. 100 0110		/SLOPE/ =	.150	GPM	/DIFFERE	NTIAL/	=
.183 GPM FRICTION .527 HP	LOSS: /UNCAV	ITATED/ =	.321	HP		/FULL/	=
TEMP RISE DEGF-GPM	: /UNCAV	ITATED/ =	4.1	DEGF-GPI	М	/FULL/	= 6.7
GROOVE TE PAD (CIPS)	MPERATURES A INLET TEMP (	ND FLOWS: F) INLE	T (CIPS)	OUT	LET TEMP	(F) (	OUTLET
1	191.61	2	.646		191.93		2.646
2	191.88	2	.649		195.86		1.944
JOURNAL MAXIMUM MAXIMUM MINIMUM	TEMPERATURE BABBITT TEMP FILM PRESSUR FILM THICKNE	IS 193.23 ERATURE I E IS 123 SS IS .0	F S 196.92 .54 PSI 01877 IN	F			

NO TURBULENCE PREDICTED IN THE OIL FILM