

17

**From:** David Dumbacher, RTV  
**To:** Michael S Peck; Patrick Hiland  
**Date:** 04/27/2006 10:57:19 AM  
**Subject:** ACT: Callaway actual surveillance for testing MSIV's per TS SR .37.2.2

Mr. Hiland, Michael

Attached are the appropriate pages of the Callaway procedure OSP-AB-V0002 that verifies , for each train, and each method (handswitch and Steam Line Isolation signal) that each MSIV actuator will perform its design basis function in the required amount of time. The third page clearly states that each actuator must be able to independently meet its required stroke time.

If I can be of further assistance, please let me know. Michael, this pdf file is on our "H" drive under the IIR 2006-003 folder.

Thanks

Dave

David E. Dumbacher  
Callaway Plant Resident Inspector  
(573) 676-3181

H-2