Appendix C	Job Performance Measure Worksheet	Form ES-C-1	
Facility: <u>Indian Point 3</u>	Task No:02400101	01	
K/A Reference: 2.2.12 (3.0)	(3.4) Job Performance Meas	sure No: RO-A-1	
WA Nelelence2.2.12 (0.0/			
Examinee:	NRC Examiner:		
Facility Evaluator:	Date:		
Method of testing:			
Simulated Performance	Actual Performance	<u> </u>	
Classroom X	Simulator	Plant	
READ TO THE EXAMINEE			
I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.			
Initial Conditions: The Weld Channel system is aligned for normal operation. Containmen Integrity is set with the plant operating at 100% Power. The previous Daily Weld Channel Leakage Calculation was performed last mid-shift at 0010. Flow integrators were reset to zero. The time is now today at			
Task Standard: 3-SOP-CB-0	04, Attachment 3 is complete and return	ed to the CRS.	
Required Materials: 3-SOP-CB-004 Attachment 3, Daily Weld Channel Leakage Calculation			
Panel S General References: 3-SOP Pressu	SLF WCCPPS – Current Integrator Indic -CB-004 Weld Channel and Containmen rization System Operation.	ation handout t Penetration	
Initiating Cue: The CRS had Calculation pe	directed you to perform the Daily Weld C r 3-SOP-CB-004, Attachment 3.	Channel Leakage	
Time Critical Task: No			
Validation Time: 15 minutes			

с

<u>≯</u> 4

2

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

#### $\sqrt{1}$ . Performance Step: Record date and time of current reading.

Standard: From initial conditions, records today's date and time 0025

Comment:

#### $\sqrt{2}$ . Performance Step: Record time of previous day readings.

Standard: From initial conditions, records yesterday's date and time 0010

Comment:

### $\sqrt{3}$ . Performance Step: Calculate difference in time (minutes).

Standard: Calculates Delta-T = (24 hrs X 60 min/hr) + 15 minutes = 1455 minutes

Comment:

#### $\sqrt{4}$ . Performance Step: Record current WCCPPS integrator readings.

Standard: From Panel SLF WCCPPS – Current Integrator Indication handout, enters 1440 for Zone I, enters 1960 for Zone II, enters 3120 for Zone III, and 1840 for Zone IV.

3

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

#### $\sqrt{5}$ . Performance Step: Reset integrator counters to zero.

CUE: After each pushbutton is depressed, the integrator display changes to zero

Standard: Describes pressing integrator reset pushbutton to reset integrators to zero

Comment:

 $\sqrt{6}$ . Performance Step: Record previous day integrator readings.

Standard: Enters 0 in each of the L2 Zone I, II, III, and IV positions.

Comment:

#### $\sqrt{7}$ . Performance Step: Subtract integrator readings for each zone

Standard: Calculates LZ=L1 –L2 for each of the four zones.

Comment:

 $\sqrt{8}$ . Performance Step: Record difference as Zone Leakage Since Previous Day

Standard: Records the following zone leakage values: Zone 1 = 1140 Zone II = 1960 Zone III = 3120 Zone IV = 1840

4

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

# $\sqrt{9}$ . Performance Step: Add Zone I, Zone II, Zone III and Zone IV leakages to obtain the day's Total Leakage.

Standard: Records total leakage of 8360

Comment:

# $\sqrt{10.}$ Performance Step: Divide current day Total Leakage by time interval between readings to obtain current day average leakage rate.

Standard: Divides 8360 scf by 1455 minutes to get 5.7 sfcm.

Comment:

### $\sqrt{11.}$ Performance Step: Record instantaneous recorder leak rate from recorder FR-1126 WCCPP Air Flow

CUE: FR-1126 indicates 6.0 SCFM

Standard: Records 6.0 scfm

Comment:

RO-A-1, Rev.0

Appendix C	5	Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

# $\sqrt{12}$ Performance Step:Check average daily leakage and recorder reading < 10scfm.

Standard: Notes that both average leak rate and instantaneous leak rate are less than 10 scfrm

Comment:

#### $\sqrt{13}$ . Performance Step: Review and sign completed calculation sheet

Standard: Signs and dates RO/BOP line.

Comment:

14. Performance Step: Request CRS review and sign completed calculation sheet

CUE: CRS has signed completed calculation sheet.

Standard: States that CRS would review and sign completed form Attachment 3.

Comment:

Terminating Cue: 3-SOP-CB-004, Attachment 3 is complete and returned to the CRS.

	6	Form ES-C-
VI	ERIFICATION OF COMPLETION	
Job Performance Measure N	lo. RO-A-1, Perform Daily Containmer Calculation	nt Leakage
Examinee's Name:		
Date Performed:		
Facility Evaluator:		
Number of Attempts:		
Fime to complete:		
Question Documentation:		
Duestion:		

Result: SAT or UNSAT

.

,

Examiner's signature and date: \_\_\_\_\_

#### **Initial Conditions**

Initial Conditions:

-

- The Weld Channel System is aligned for normal operation.
- Containment Integrity is set with the plant operating at 100% power.
- The previous Daily Weld Channel Leakage Calculation was performed last mid-shift at 0010.
- Flow integrators were reset to zero.
- The time is now today at 0025.

Initiating Cue:

• The CRS had directed you to perform the Daily Weld Channel Leakage Calculation per 3-SOP-CB-004, Attachment 3.

#### **RETURN THIS TO THE EVALUATOR WHEN THE TASK IS COMPLETE**

### WELD CHANNEL AND CONTAINMENT PENETRATION PRESSURIZATION SYSTEM OPERATION

No: 3-SOP-CB-004

Rev: 23

Page 42 of 42

### ATTACHMENT 3, DAILY WELD CHANNEL LEAKAGE CALCULATION (Page 2 of 2)

Calculation  $\Delta$  Time:

Date	Time of Current	Time of Previous	∆ Time in Minutes
	Reading (T <sub>1</sub> )	Day Readings (T <sub>2</sub> )	(T₂ - T₁)
TODAY	0025	0010	1455

WCCPP Integrator Readings:

Zone	Current Reading (L <sub>1</sub> )	Previous Day Reading (L₂)	Zone Leakage (LZ = L <sub>1</sub> - L <sub>2</sub> )
J	1440	0	1440
11	1960	0	1960
	3120	0	3120
١٧	1840	0	1840
	Total Leakage	$(LZ_{I} + LZ_{II} + LZ_{III} + LZ_{IV})$	8360

IF time period is exactly 24 hours, THEN Total Leakage must be less than 14,400 S.C.F.

Leak Rate = Total Leakage = 
$$5,75$$
 scfm  
 $\Delta$  Time (min)

600 X Hours (to nearest tenth) Between Readings = Allowed Leak Rate

Instantaneous Recorder Leak Rate \_\_\_\_\_\_\_ scfm (FR-1126) (Leakage Rate and FR-1126 must be less than 10.0 scfm)

The. RO/BOP

Date

**CRS** 

Date

RO-A-1 KEY DO NOT GIVE TO CANDIDATE ::

Appendix C	Job Performance Measure Form ES-C-1 Worksheet			
Facility: Indian Point 3	Task No. 0040040101			
Task Title: Calculate Shute	Jown Margin			
K/A Reference: 2.1.25 (2.8/	3.1) Job Performance Measure No: <u>RO-A-2</u>			
Examinee:	NRC Examiner:			
Facility Evaluator:	Date:			
Method of testing:				
Simulated Performance	Actual Performance X			
Classroom X	Simulator Plant			
READ TO THE EXAMINEE				
I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.				
Initial Conditions: The plant is at BOL at 100% power with Control Bank D at 224 Steps and RCS Boron at 1000 ppm. During rod motion checks it was determined that control rod K-12 is stuck and untrippable.				
Task Standard: Determin	e shutdown margin within plus or minus 100 ppm.			
Required Materials: Graphs book				
General References: N/A				
Initiating Cue: You have been directed by the CRS to determine shutdown margin at power with control rod K-12 stuck.				
Time Critical Task: No				
Validation Time: 15 minutes				

١

 $\mathbf{r}$ 

2

Appendix C	2	Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

1. Performance Step: Candidate obtains copy of graphs RV-1, RV-7B, and RV-14

Standard: Obtains Reactivity Summary Log Sheet and Graphs book

Comment: Hand the candidate a copy of the Graphs.

 $\sqrt{2}$ . Performance Step: Determine Power Defect in accordance with graph RV-1

Standard: Records Power Defect as +1498 pcm (+/- 10 pcm)

Comment:

#### $\sqrt{3}$ . Performance Step: Determine control bank worth using graph RV-7B

Standard: Records -3451 pcm (read directly from bottom of table – BOL) Comment:

 $\sqrt{4}$ . Performance Step: Determine shutdown bank worth from graph RV-7B

Standard: Records -4055 pcm (read directly from bottom of table – BOL)

Appendix C	2	3	Form ES-C-1	
		Performance Information		
(Denote critical steps with a check mark)				
√ 5. Perfor	mance Step:	Determine worth not available rod	from most reactive stuck	
Standard:	Determines f Assuming on arrive at -170	rom RV-14 that highest worth stuck e additional rod stuck besides rod 0 pcm not available due to two stu	k rod (BOL) is -850 PCM. K-12, doubles this value to ick rods.	

Comment:

12

$\sqrt{6}$ . Performance Step:	Calculates shutdown margin as the sum of Power defect, control bank worth, shutdown bank worth, and
	worth not available due to stuck rods.

Standard: Determines SDM is +1498 - 3451 - 4055 +1700 = - 4308 pcm (+/- 100 pcm) Comment:

### $\sqrt{7}$ . Performance Step: Inform CRS that calculated SDM is - 4308 pcm

CUE: CRS acknowledges

Standard: CRS informed

Comment:

Terminating Cue: Shutdown margin is determined and reported to CRS.

.

4

#### VERIFICATION OF COMPLETION

Job Performance Measure No.: RO-A-2, Calculate Shutdown Margin

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to complete:

Question Documentation:

Question:

Response:

Result: SAT or UNSAT

Examiner's signature and date:

**Initial Conditions** 

**Initial Conditions:** 

- The plant is at BOL at 100% power with Control Bank D at 224 Steps and RCS Boron at 1000 ppm.
- During rod motion checks it was determined that control rod K-2 (in control Bank D) is stuck at 224 steps and is untrippable.

Initiating Cue:

You have been directed by the CRS to perform a tabletop calculation of shutdown margin at power with control rod K-2 stuck (in addition to the assumed stuck most-reactive rod,) using reactivity values from Graphs RV-1, RV-7B, and RV-14.

Appendix C	Job Performance Measure Worksheet	Form ES-C-1
Facility: Indian Point 3	Task No: <u>N/A</u>	
Task Title: Generate A Man	nual Tag-out	<u></u>
K/A Reference: GKA 2.2.13	(3.6/3.8) Job Performance Meas	sure No: <u>RO-A-3</u>
Examinee:	NRC Examiner:	
Facility Evaluator:	Date:	<u>,</u>
Method of testing:		
Simulated Performance	Actual Performance	<u>X</u>
Classroom X	Simulator	Plant

READ TO THE EXAMINEE

.

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: A pump seal failure occurred on 33 CCW Pump. SOMS is not available for protective tagging. Maintenance has requested a tag-out of 33 CCW pump to replace the pump seal. The Field Support Supervisor has prepared Attachment 9.3, Tagout Cover Sheet for 33 CCW Pump Seal Replacement. The FSS has provided you with the following references:

- o EN-OP-102, Protective and Caution Tagging
- o 3-COL-EL-1, 6900 and 480 Volt Ac Distribution
- o 3-COL-CCW-1, Component Cooling Water System
- Drawing 9321-F-27513 Sheet 1, Flow Diagram Aux Coolant Sys

RO-A-3

Appendix C	Job Performance Measure	Form ES-C-1
	Worksheet	

Task Standard: 33 CCW pump is de-energized, isolated from normal flows and pressures, with a vent path available. The following components are expected points identified in the Equipment/Placement Configuration columns for the tag-out:

33 CCW Pump Control Switch 33 CCW Pump 480V Breaker Control Power Fuses 33 CCW Pump 480V Breaker AC-762C 33 CC Pump Disch Isolation AC-760C 33 CC Pump Suction Isolation AC-1858F 33 CC Pump Drain AC-1858E 33 CC Pump Vent PULLOUT FUSES REMOVED RACKED OUT CLOSED CLOSED OPEN OPEN

NOTE: Other valves may be acceptable. Candidate may find other components to accomplish the task. The purpose is to determine appropriate TAGOUT points for a simple tagout. The candidate needs to provide isolation from normal flow and pressures, with a drain or vent path available, and de-energize the motor.

Required Materials: EN-OP-102, Protective and Caution Tagging, Attachment 9.2 Tagout Standards 3-COL-EL-1, 6900 and 480 Volt Ac Distribution

3-COL-CCW-1, Component Cooling Water System Drawing 9321-F-27513 Sheet 1, Flow Diagram Aux Coolant Sys

General References: Same as required Materials, except that the candidate may refer to a complete copy of EN-OP-102 if requested.

Initiating Cue: Using the provided references, specify the type of tag, component number/names, required positions, and hang sequence necessary to provide a tagout boundary for 33 CCW Pump Seal Replacement.

Time Critical Task: No

Validation Time: 20 minutes

3

Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

1. Performance Step: Obtains correct procedure and references.

CUE: FSS provides copies of the required materials:

- Completed Attachment 9.3
- EN-OP-102, Protective and Caution Tagging
- 3-COL-EL-1, 6900 and 480 Volt Ac Distribution
- o 3-COL-CCW-1, Component Cooling Water System
- o Drawing 9321-F-27513 Sheet 1, Flow Diagram Aux Coolant Sys

Standard: Procedure and references obtained

Comment:

#### $\sqrt{2}$ . Performance Step: Determines tag out points and required positions

Standard: Refers to supplied references and determines that the following points need to be placed in the positions listed:

- o 33 CCW Pump Control Switch
- o 33 CCW Pump 480V Breaker
- AC-762C 33 CC Pump Disch Isolation
- AC-760C 33 CC Pump Suction Isolation
- AC-1858F 33 CC Pump Drain

PULLOUT RACKED OUT CLOSED CLOSED OPEN

4

Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

 $\sqrt{3}$ . Performance Step: Enter tagout points on the manual tagout tag sheet.

### Standard: Refers to Attachment 9.2, Tagout Standards and lists placement sequences in the following order:

- 1. 33 CCW Pump Control Switch
- 2. 33 CCW Pump 480V Breaker
- 3. AC-762C 33 CC Pump Disch Isolation
- 4. AC-760C 33 CC Pump Suction Isolation
- 5. AC-1858F 33 CC Pump Drain

PULLOUT RACKED OUT CLOSED CLOSED OPEN

- NOTE: The critical sequence is control switch, breaker, close isolation valves, open drains/vents. The order of Disch and Suction Isolation is not critical.
- NOTE: Candidate may choose additional steps such as removing control power fuses and opening vents. If the candidate does not identify the minimum points listed, additional scrutiny may be required to determine satisfactory completion of the JPM.

Comment:

Terminating Cue:

JPM is complete when isolation points have been recorded, placement configuration determined, and placement sequence specified.

5

#### VERIFICATION OF COMPLETION

Job Performance Measure No. RO-A-3, Generate A Manual Tag-out

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to complete:

Question Documentation:

Question:

Response:

Result: SAT or UNSAT

Examiner's signature and date: \_\_\_\_\_

**Initial Conditions:** 

- A pump seal failure occurred on 33 CCW Pump.
- SOMS is not available for protective tagging.
- Maintenance has requested a tag-out of 33 CCW pump to replace the pump seal.
- The Field Support Supervisor has prepared Attachment 9.3, Tagout Cover Sheet for 33 CCW Pump Seal Replacement.
- The FSS has provided you with the following references:
  - EN-OP-102, Protective and Caution Tagging
  - o 3-COL-EL-1, 6900 and 480 Volt Ac Distribution
  - o 3-COL-CCW-1, Component Cooling Water System
  - o Drawing 9321-F-27513 Sheet 1, Flow Diagram Aux Coolant Sys

#### Initiating Cue:

- The FSS has asked you to fill out Attachment 9.4, Tagout Tag Sheet to tag out 33 CCW Pump for Seal Replacement.
- Using the provided references, specify the type of tag, component number/names, required positions, and hang sequence necessary to provide a tagout boundary for 33 CCW Pump Seal Replacement.

(million and a second s	(		
	NUCLEAR MANAGEMENT		EN-OP-102 REV. 3
<i>Entergy</i>	MANUAL	INFORMATIONAL USE	PAGE 60 of 128
ATTACHMENT 9.	4		TAGOUT TAGS SHEET
CLEARANCE _	MANUAL TAGOUT:		
Tag Tag Equipment	Pla	ce. Place.	Rest. 1st Rest. 2nd Placement/

Tag Serial No.	Tag Type	Equipment Equipment Description Equipment Location	Place. Seq.	Placement Configuration	Place. 1st Venif Date/Time	Place. 2nd Verif Date/Time	Rest. Seq.	Restoration Configuration	Rest. 1st Verif Date/Time	Rest. 2nd Verif Date/Time	Placement Removal Tag Notes
	D	33 Component Cooling Pump Control Switch 53' CCR Panel SGF	1	Pullout							
	D	33 Comp Cooling Water Pump Control Power Fuses 480V Bus 6A, 15' Ctrl Bldg	2	Fuses Removed							
	D	33 Comp Cooling Water Pump 480V Breaker 480V Bus 6A, 15' Ctrl Bldg	3	Racked Out							
	D	AC-760C 33 CC Pump Suction Isolation 41' PAB	4	Closed							
	D	AC-762C 33 CC Pump Disch Isolation 41' PAB	5	Closed							
	D	AC-1858F 33 CC Pump Drain 41' PAB	6	Open							

Appendix C	Job Performance Measure Worksheet	Form ES-C-1				
Facility: <u>Indian Poir</u>	nt 3 Task No:					
K/A Reference:	Job Performance Measur	e No: <u>RO-A-5</u>				
Examinee: Facility Evaluator:	NRC Examiner: Date:					
Method of testing:						
Simulated Performan	ce X Actual Performance					
Classroom	Simulator X	Plant				
READ TO THE EXAN	/INEE					
I will explain the initia cues. When you com measure will be satisf	l conditions, which steps to simulate or discuss, an plete the task successfully, the objective for this jo fied.	d provide initiating b performance				
Initial Conditions: T S N	The plant was tripped following indications of a 30 g Shift Manager has implemented the Emergency Pla Notification of Unusual Event.	pm RCS leak. The n and declared a				
Task Standard: C	Control Room NUE Notification Checklist complete. hitiated within 15 minutes.	Initial Roll Call				
Required Materials:	Completed NYS Part 1 Form (Radiological Eme IP-EP-210 Att 9.3, CCR Offsite Communicator C IP-EP-130, Emergency Notification and Mobiliza Form EP-3, Control Room NUE Notification Che	rgency Data Form) Checklist Ition cklist				
General References: CCR Offsite Communicator Book located in emergency plan locker (contains copies of IP-EP-210 Att 9.3 and IP-EP-130, and blank forms)						
Initiating Cue: The SM has directed you to assume the duties of the CR Offsite Communicator and perform Notification of Unusual Event Initial Notification per IP-EP-130; IP-EP-210, Att 9.3 CCR Offsite Communicator Checklist; Form EP-3 Control Room NUE Notification Checklist.						
Time Critical Task: Ye	es					
Validation Time: 15 minutes						

RO-A-5

 $\checkmark$ 

Ĩ,

Appendix C	2	Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

# EVALUATOR: Enter the time in the blank on line 4 of the Form EP-3 and enter the date and time in box 2 of the Part 1 form. This starts the 15 minute clock for step 8 below.

1. Performance Step: Obtain CCR Offsite Communicator book from E-Plan cabinet

Standard: CCR Offsite Communicator book obtained

Comment:

2. Performance Step: Check if accountability is being performed

CUE: No, accountability is not being performed

Standard: Checks to see if accountability is being performed

Comment:

# $\sqrt{3}$ . Performance Step: Inform SM and CCR staff that you have assumed duties of CCR Offsite Communicator

CUE: Acknowledge as CCR Staff and SM. Inform candidate that he is to make initial notification for NUE.

Standard: CCR staff and SM informed

3

Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

# $\sqrt{4}$ . Performance Step: Obtain completed and signed NYS Radiological Emergency Data Form Part 1 (Form EP-1) from the SM. Review form for completeness.

CUE: Provide completed Part 1 form to candidate. Also, provide Form EP-3 with steps 1-4 already completed by SM

Standard: Form obtained and reviewed.

Comment:

#### $\sqrt{5}$ . Performance Step: Pick Up RECS Handset and initiate conference call

CUE: You have made 3 unsuccessful attempts to initiate a RECS conference call.

Standard: Determines RECS is not operational and advises Emergency Director (SM)

Comment:

#### $\sqrt{6}$ . Performance Step: Use Local Government Radio to make notifications. Verify Power on. Transmit message: "This is to report that an Unusual Event has been declared at Indian Point Energy Center. Stand by for transmission of Part 1 Form information, and fax of the Part 1 Form."

CUE: Remind candidate to Simulate using the Local Government Radio. When candidate locates and simulates turning on the power switch, cue that the LGR power is on.

Standard: Simulates turning on LGR and transmitting message.

4

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

# $\sqrt{7}$ . Performance Step: Fax the Part 1 form to the state and counties warning points and EOCs. Return to step 10.

CUE: When candidate locates the fax machine, cue that the CCR Admin Support clerk will operate the fax machine for you. Cue that the fax has been sent to state and counties warn points and EOCs.

Standard: Part 1 form simulated faxed.

Comment:

 $\sqrt{8}$ . Performance Step: Enter time that roll call is being started

Standard: Time entered is within 15 minutes of time in line 4

Comment:

# $\sqrt{9}$ . Performance Step: Initiate Roll Call by asking each location if they are on the line.

CUE: As each location is polled, respond "(location) on the line."

Standard: Checks off each location and allows each location to identify themselves. All locations polled.

Appendix C		Form ES-C-
	Performance Information	
(Denote critical steps with a	check mark)	
√ 10. Performance Step:	State "an emergency has bee Point Energy Center. A Part I been sent to you via Email wi	n declared at the Indian notification Form #1, has th a follow-up fax."
Standard: Prescribed me	ssage transmitted	
Comment:		
√ 11. Performance Step:	Announce "New York State, d receipt of and Email of fax fro did not receive Email or fax o required contact NYS at (518) assistance."	o you acknowledge m IPEC. If any location r additional information is 292-2200 for
CUE: NYS acknowledges r	receipt of email from IPEC	
Standard: Checks for con	firmation from NYS and repeats a	bove message.
Comment:		
12. Performance Step: En	d Notification by saying "Indian P	oint Out at ( <i>time</i> )"
Standard: Makes prescrib	ed statement and enters time call	completed in box 11
Comment:		

•

6

Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

13. Performance Step: Check with SM to determine if Emergency Response Organization mobilization or notification is required

CUE: The Shift Manager has determined that Envelope A for All ERO mobilization will be used. The SM states that he will initiate the mobilization per envelope A while you continue with the notifications.

Standard: Ensures ERO notification/mobilization intiated

Comment:

14. Performance Step: Notify NRC Resident

CUE: It is normal working hours. Acknowledge phone call as senior resident.

Standard: Simulates notification of resident inspector

Comment:

15. Performance Step: Contact NRC by calling main number listed on ENS Phone

CUE: Trainee should simulate contacting ENS number. Acknowledge notification

Standard: Simulates notification of NRC on ENS line

•

7

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

16. Performance Step:	Record comments.	Date and sign form.	Inform SM of
	completion of NUE	notification.	

CUE: SM acknowledges completion. Cue that the admin assistant clerk will fax the Part 1 form to the State, Counties, TSC, EOF, JIC.

Standard: Form completed and SM notified of completion of notifications.

Comment:

Terminating Cue: Notification checklist complete.

.

8

Form ES-C-1

#### VERIFICATION OF COMPLETION

Job Performance Measure No. RO-A-5, CCR Offsite Communicator – NUE Notification

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to complete:

Question Documentation:

Question:

Response:

Result: SAT or UNSAT

Examiner's signature and date: \_\_\_\_\_

Initial Conditions

**Initial Conditions:** 

.

- The plant was tripped following indications of a 30 gpm RCS leak.
- The Shift Manager has implemented the Emergency Plan and declared a Notification of Unusual Event.

Initiating Cue:

- The SM has directed you to assume the duties of the CR Offsite Communicator and perform Notification of Unusual Event Initial Notification per
  - IP-EP-130;
  - o IP-EP-210, Att 9.3 CCR Offsite Communicator Checklist;
  - and Form EP-3 Control Room NUE Notification Checklist.

#### RETURN THIS TO THE EVALUATOR WHEN THE TASK IS COMPLETE

	r						
		NEW YORK STATE					
		RADIOLOGICAL EMERGENCY DATA FORM Notification #: 1					
$\bigcirc$	·	PART 1					
	Tr	his is the Indian Point Energy Center with a Part 1 Notification on: 8/28/2006 at 14:16					
	1.	This is an EXERCISE at UNIT 3					
		Reactor Status: Unit 2 A. Operational					
		Unit 3 B. Shutdown (Date) S / Sflor 14:5 3 (Time 24 hr clock)					
	2	The Emergency Classification is:					
	2.	A. Unusual Event					
		This Emergency Classification declared on: <u>08/28/06</u> at <u>14:10</u> (Date) (Time 24 hr clock)					
	3	EAL#:3.1.1					
	5.	Water is leaking from the reactor coolant system in excess of allowed limits. This EAL poses no threat to the safety of plant personnel or the general public.					
$\subseteq$	4.	Release of Radioactive Materials due to the Classified Event:					
		A. No Release					
	5.	Wind Speed: 3.2 Meters/Sec at elevation 10 meters					
	6.	Wind Direction: (From) 110 Degrees at elevation 10 meters					
	7.	Stability Class: A B C D E F G					
	8.	The following Protective Actions are recommended to be implemented as soon as practicable:					
		A. NO NEED for PROTECTIVE ACTIONS outside the site boundary					
		2 miles around 5-miles downwind					
	9.	Reported By - Communicator: Telelphone #					
 	10.	Emergency Director Approval: Date/Time: Date/Time:					

Appendix C	Job Performance Measure Worksheet	Form ES-C-1				
Facility: Indian Point 3	Task No: 0240010102	- <u></u>				
Task Title: Review Daily	Containment Leakage Calculation (Faulted)	)				
K/A Reference: 2.2.12 (3	.0/3.4) Job Performance Measur	re No: SRO-A-1				
Examinee:	NRC Examiner:					
Facility Evaluator:	Date:					
Method of testing:						
Simulated Performance _	Actual Performance	х				
Classroom X	Simulator	Plant				
READ TO THE EXAMINEE	E					
I will explain the initial cond cues. When you complete measure will be satisfied.	litions, which steps to simulate or discuss, an the task successfully, the objective for this jo	d provide initiating b performance				
Initial Conditions: The Weld Channel system is aligned for normal operation. Containment Integrity is set with the plant operating at 100% Power. The previous Daily Weld Channel Leakage Calculation was performed last mid-shift at 0010. Flow integrators were reset to zero. The time is now today at 0025.						
Task Standard: 3-SOP-CB	-004, Attachment 3 is reviewed and errors no	oted and corrected.				
Required Materials: 3-SO Calcu	P-CB-004 Attachment 3, Daily Weld Channe ulation	I Leakage				
General References: 3-SO Press	P-CB-004 Weld Channel and Containment P surization System Operation.	enetration				
Initiating Cue: The BOP op Channel Lea	erator has given you for review and approval kage Calculation per 3-SOP-CB-004, Attach	the Daily Weld ment 3.				
Time Critical Task: No						

Validation Time: 15 minutes

SRO-A-1, Rev.0

•

\$

2

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

#### $\sqrt{1}$ . Performance Step: Verify recorded date and time of current reading correct.

Standard: From initial conditions, verifies today's date and time 0025

Comment:

#### $\sqrt{2}$ . Performance Step: Verify time of previous day readings.

Standard: From initial conditions, verifies yesterday's date and time 0010

Comment:

#### $\sqrt{3}$ . Performance Step: Verify difference in time (minutes).

Standard: Calculates Delta-T = (24 hrs X 60 min/hr) + 15 minutes = 1455 minutes.

Comment:

#### $\sqrt{4}$ . Performance Step: Verify Record current WCCPPS integrator readings.

Standard: Observes the following entries recorded: 1440 for Zone I, 1960 for Zone II, 3120 for Zone III, and 1840 for Zone IV.

3

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

#### $\sqrt{5}$ . Performance Step: Verify integrator counters reset to zero.

Standard: Observes from handout that all integrators were reset to zero

Comment:

#### $\sqrt{6}$ . Performance Step: Verify Record previous day integrator readings.

Standard: Verifies 0 entered in each of the L2 Zone I, II, III, and IV positions.

Comment:

#### $\sqrt{7}$ . Performance Step: Verify subtraction of integrator readings for each zone

Standard: Calculates LZ=L1 –L2 for each of the four zones.

Comment:

 $\sqrt{8}$ . Performance Step: Verify Zone Leakage Since Previous Day calculation

Standard: Checks the following zone leakage values: Zone 1 = 1140 Zone II = 1960 Zone III = 3120 Zone IV = 1840

Appendix C	C4	Form ES-C-
	Performance Information	ı
(Denote cri	itical steps with a check mark)	
√9. Perfor	mance Step: Verify sum of Zone I, Zone II, leakages equals the day's Tot	Zone III and Zone IV al Leakage.
Standard:	Verifies total leakage. Adds 1440, 1960, 312 Notes that value is different from what is reco attachment 3 entry.	0 and 1840 and obtains 8360 orded on Att 3 and corrects
Comment:		
√ 10. Perfo	ormance Step: Verify calculation divide cur	rent day Total Leakage by
√ 10. Perfo	ormance Step: Verify calculation divide cur time interval between readin average leakage rate.	rent day Total Leakage by Igs to obtain current day
√ <b>10. Perfo</b> Standard:	Divides 8360 scf by 1455 minutes to get 5.8 son sheet.	rent day Total Leakage by Igs to obtain current day sfcm. Observes 6.7 recorded
√ <b>10. Perfo</b> Standard: Comment:	ormance Step: Verify calculation divide cur time interval between readin average leakage rate. Divides 8360 scf by 1455 minutes to get 5.8 s on sheet. Notes/corrects error.	rent day Total Leakage by Igs to obtain current day
√ <b>10. Perfo</b> Standard: Comment: √ <b>11. Perfo</b>	ormance Step: Verify calculation divide cur time interval between readin average leakage rate. Divides 8360 scf by 1455 minutes to get 5.8 s on sheet. Notes/corrects error.	rent day Total Leakage by Igs to obtain current day sfcm. Observes 6.7 recorded er leak rate from recorder
√ <b>10. Perfo</b> Standard: Comment: √ <b>11. Perfo</b> Standard:	ormance Step:       Verify calculation divide cur time interval between readinaverage leakage rate.         Divides 8360 scf by 1455 minutes to get 5.8 s on sheet.       Notes/corrects error.         ormance Step:       Verify instantaneous recorder FR-1126 WCCPP Air Flow         Observes that value recorded by BOP is 5.0 s 10 SCFM.	rent day Total Leakage by ligs to obtain current day sfcm. Observes 6.7 recorded er leak rate from recorder SCFM and notes it is less that

.....

.

3

5

Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

# $\sqrt{12.}$ Performance Step: Verify average daily leakage and recorder reading < 10scfm.

Standard: Notes that both average leak rate and instantaneous leak rate are less than 10 scfrm

Comment:

# $\sqrt{13}$ Performance Step: Verify BOP operator signed and dated completed calculation sheet

Standard: Notes that BOP did not date the signature block.

Comment:

14. Performance Step: Sign and date completed calculation sheet

Standard: Signs and dates CRS block on completed form Attachment 3.

Comment:

Terminating Cue 3-SOP-CB-004, Attachment 3 is reviewed and errors noted and corrected.

Appendix C	6	Form ES-C-1			
VERIFICATION OF COMPLETION					
Job Performance Measure No.	SRO-A-1, Review Daily ( Calculation (Faulted)	Containment Leakage			
Examinee's Name:					
Date Performed:					
Facility Evaluator:					
Number of Attempts:					
Time to complete:					
Question Documentation:					
Question:					
Response:					

Result: SAT or UNSAT

٠

Examiner's signature and date: \_\_\_\_\_

Initial Conditions

Initial Conditions:

- The Weld Channel System is aligned for normal operation.
- Containment Integrity is set with the plant operating at 100% power.
- The previous Daily Weld Channel Leakage Calculation was performed last mid-shift at 0010.
- Flow integrators were reset to zero.
- The time is now today at 0025.

Initiating Cue:

• The CRS had directed you to perform the Daily Weld Channel Leakage Calculation per 3-SOP-CB-004, Attachment 3.

#### **RETURN THIS TO THE EVALUATOR WHEN THE TASK IS COMPLETE**

### WELD CHANNEL AND CONTAINMENT PENETRATION PRESSURIZATION SYSTEM OPERATION

No: 3-SOP-CB-004

SRO HANDOUT

Rev: 23

Page 42 of 42

### ATTACHMENT 3, DAILY WELD CHANNEL LEAKAGE CALCULATION (Page 2 of 2)

Calculation  $\Delta$  Time:

\* 1

Date	Time of Current	Time of Previous	∆ Time in Minutes
	Reading (T <sub>1</sub> )	Day Readings (T <sub>2</sub> )	(T₂ - T₁)
TODAY	0010	0025	1455

WCCPP Integrator Readings:

Zone	Current Reading (L <sub>1</sub> )	Previous Day Reading (L <sub>2</sub> )	Zone Leakage (LZ = L <sub>1</sub> - L <sub>2</sub> )
1	1440	0	1440
	1960	0	1960
	3120	0	3120
IV	1840	0	1840
	Total Leakage	(LZ <sub>1</sub> + LZ <sub>11</sub> + LZ <sub>111</sub> + LZ <sub>IV</sub> )	8460

IF time period is exactly 24 hours, THEN Total Leakage must be less than 14,400 S.C.F.

Leak Rate =  $\underline{\text{Total Leakage}} = \underline{6.7}$  scfm  $\Delta$  Time (min)

600 X Hours (to nearest tenth) Between Readings = Allowed Leak Rate

5.0 Instantaneous Recorder Leak Rate scfm (FR-1126) (Leakage Rate and FR-1126 must be less than 10.0 scfm)

RO/BOP

Date

Date

Appendix C	Job Performar Works	nce Measure heet	Form ES-C-1				
Facility: Indian Po	int 3	Task No: _0040040102					
Task Title:Review Shutdown Margin Calculation (Faulted)							
K/A Reference: <u>2.</u>	1.25 (2.8/3.1)	Job Performance Measur	e No: SRO-A-2				
Examinee:		NRC Examiner:					
Facility Evaluator:		Date:					
Method of testing:							
Simulated Performation	nce	Actual Performance	x				
Classroom X	Sin	nulator	Plant				
READ TO THE EXA	MINEE						
I will explain the initia cues. When you cor measure will be satis	al conditions, which steps mplete the task successfu sfied.	to simulate or discuss, an Ily, the objective for this jo	d provide initiating b performance				
Initial Conditions:	The plant is at BOL at 100 and RCS Boron at 1000 p determined that control ro rod is untrippable. The R	0% power with Control Ba opm. During rod motion ch od K-12 is stuck. I&C has O has provided you with a	nk D at 224 Steps necks it was reported that the SDM calculation.				
Task Standard:	Determine shutdown mar	gin within plus or minus 10	00 pcm.				
Required Materials:	RO's SDM Calculation Graphs Book						
General References:	N/A						
Initiating Cue: Revi	iew the shutdown margin o	calculation provided by the	RO				
Time Critical Task: N	No						
Validation Time: 15 n	Validation Time: 15 minutes						

 $\checkmark$ 

Ş

Appendix C		2	Form ES-C
		Performance Information	
(Denote crit	ical steps w	ith a check mark)	
1. Performa	ance Step:	Candidate obtains copy of Techni Book and the COLR	cal Specifications, Graphs
Standard:	Obtains Te	echnical Specifications, Graphs Book	and the COLR
Comment:	Provide the Book and	e candidate with a copy of the Techn the COLR	ical Specifications, Graphs
2. Performa Standard:	ance Step: Verifies Po	Verify Power Defect in accordan	ce with graph RV-1
Comment:			
3. Performa	nce Step:	Verify control bank worth using g	graph RV-7B
Standard:	Verifies -34	151 pcm (read directly from bottom o	f table – BOL)
Comment:			
4. Performa	nce Step:	Verify shutdown bank worth from	graph RV-7B
Standard:	Verifies -	4055 pcm (read directly from bottom	of table – BOL)

٠

3

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

#### $\sqrt{5}$ . Performance Step: Verify worth not available from most reactive stuck rod

Standard: Determines from RV-14 that highest worth stuck rod (BOL) is -850 PCM. Assuming one additional rod stuck besides rod K-12, doubles this value to arrive at -1700 pcm not available due to two stuck rods. Corrects the RO mistake of using -850 PCM once instead of twice.

Comment:

√ 6. Performance Step:		Verifies calculated shutdown margin as the sum of Power defect, control bank worth, shutdown bank worth, and worth not available due to stuck rods.
Standard:	Determines S 100 pcm) Corrects mist	6DM should be +1498 - 3451 - 4055 +1700 = - 4308 pcm (+/- take on RO calculation.
Comment:		

Terminating Cue: Correct Shutdown margin is determined assuming an additional stuck rod.

**\***•

4

Form ES-C-1

#### VERIFICATION OF COMPLETION

Job Performance Measure No.: SRO-A-2, Review Shutdown Margin Calculation (Faulted)

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to complete:

Question Documentation:

Question:

Response:

Result: SAT or UNSAT

Examiner's signature and date:

SRO-A-2, Rev.0

Initial Conditions: • The plant is at BOL at 100% power with Control Bank D at 224 Steps and RCS Boron at 1000 ppm. • During rod motion checks it was determined that control rod K-12 is stuck. • I&C has reported that the rod is untrippable. • The RO has provided you with a shutdown margin calculation.

Initiating Cue:

2

• Review the shutdown margin calculation provided by the RO.

#### **RO's SDM Calculation:**

•

÷

Total Power Defect =	+ 1498 pcm
Total Control Bank Worth =	- 3451 pcm
Total Shutdown Bank Worth =	- 4055 pcm
Highest Worth Stuck Rod =	+ 850 pcm
SDDM = Sum of above =	- 5158 pcm

SRO HANDOUT

Appendix C Job Perfo W	rmance Measure Fo /orksheet	orm ES-C-1
Facility: Indian Point 3	Task No: <u>N/A</u>	
K/A Reference: <u>GKA 2.2.13 (3.6/3.8)</u>	Job Performance Measure No:	SRO-A-3
Examinee:	NRC Examiner:	
Method of testing:		
Simulated Performance	Actual PerformanceX	<u></u>
Classroom X	Simulator Plant	

READ TO THE EXAMINEE

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions: A pump seal failure occurred on 33 CCW Pump. SOMS is not available for protective tagging. Maintenance has requested a tag-out of 33 CCW pump to replace the pump seal. The Field Support Supervisor has prepared a manual tagout.

Task Standard: Identifies incorrect placement sequence for AC-1858F 33 CC Pump Drain which should be performed last instead of first. Identifies Incorrect train/valve for Pump Discharge Valve – should be AC-762C for 33 CC Pump Disch Isolation.

Required Materials: EN-OP-102, Protective and Caution Tagging 3-COL-EL-1, 6900 and 480 Volt Ac Distribution 3-COL-CCW-1, Component Cooling Water System Drawing 9321-F-27513 Sheet 1, Flow Diagram Aux Coolant Sys SRO-A-3 Handout (Tagout tag sheet with proposed isolation points, tag types, placement sequence, and placement configuration.)

General References: Same as required Materials

Initiating Cue: The FSS has asked you to perform an independent review of the proposed tagout.

SRO-A-3

Appendix C	Job Performance Measure	Form ES-C-1
	Worksheet	

Time Critical Task: No

â

Validation Time: 20 minutes

 $\smile$ 

3

Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

1. Performance Step: Obtains correct procedure and references.

CUE: FSS provides copies of the required materials:

- o Completed Attachment 9.3
- EN-OP-102, Protective and Caution Tagging
- o 3-COL-EL-1, 6900 and 480 Volt Ac Distribution
- o 3-COL-CCW-1, Component Cooling Water System
- o Drawing 9321-F-27513 Sheet 1, Flow Diagram Aux Coolant Sys

Standard: Procedure and references obtained

Comment:

#### $\sqrt{2}$ . Performance Step: Reviews tag out points and required positions

Standard: Refers to supplied references and determines that an incorrect component: AC-662B 32 CCW Pump Disch Isol is the wrong train. Identifies that AC-662C, 33 CCW Pump Disch Isol should be specified.

Comment:

SRO-A-3

4

Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

 $\sqrt{3}$ . Performance Step: Review tagout points on the manual tagout tag sheet

Standard: Refers to Attachment 9.2, Tagout Standards and determines placement sequence should be in the following order.

- 1. 33 CCW Pump Control Switch
- 2. 33 Comp Cooling Control Power Fuses
- 3. 33 CCW Pump 480V Breaker
- 4. AC-762C 33 CC Pump Disch Isolation
- 5. AC-760C 33 CC Pump Suction Isolation
- 6. AC-1858F 33 CC Pump Drain

PULLOUT Fuses Removed RACKED OUT CLOSED CLOSED OPEN

NOTE: The critical sequence is control switch, breaker, close isolation valves, open drains/vents. The order of Disch and Suction Isolation is not critical. The handout provides the Drain Valve first, but the drain valve should be last.

NOTE: Candidate may choose additional steps such as opening vents. Critical task in this step is to identify incorrect sequence for the pump drain.

Comment:

Terminating Cue:

JPM is complete when the incorrect sequence for drain valve and incorrect component for Discharge Valve have been identified.

5

Form ES-C-1

#### VERIFICATION OF COMPLETION

Job Performance Measure No. SRO-A-3, Review A Manual Tag-out

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to complete:

Question Documentation:

Question:

Response:

Result: SAT or UNSAT

Examiner's signature and date: \_\_\_\_\_

Initial Conditions:

- A pump seal failure occurred on 33 CCW Pump.
- SOMS is not available for protective tagging.
- Maintenance has requested a tag-out of 33 CCW pump to replace the pump seal.
- The Field Support Supervisor has prepared a manual tagout
- The FSS has provided you with the following references:
  - EN-OP-102, Protective and Caution Tagging
  - o 3-COL-EL-1, 6900 and 480 Volt Ac Distribution
  - o 3-COL-CCW-1, Component Cooling Water System
  - o Drawing 9321-F-27513 Sheet 1, Flow Diagram Aux Coolant Sys

#### Initiating Cue:

o The FSS has asked you to perform an independent review of the proposed tagout.

(	<				(						(
		N	IUCLEAR N	ANAGEMENT	-	Qu	AUTY RELA	NTED	EN-OP-1	102	REV. 3
	*Entergy MAN					INFORMATIONAL USE			р	PAGE <u>60</u> of <u>128</u>	
	A	TTACHMENT 9.4							TAGOU	T TAGS SH	EET
		CLEARANCE:MANUAI	*	TA	GOUT:			in an	an an ann an an ann an an ann an ann an		
Tag Serial No.	Tag Type	Equipment Equipment Description Equipment Location	Place. Seq.	Placement Configuration	Place. 1st Verif Date/Time	Place. 2nd Verif Date/Time	Rest. Seq.	Restoration Configuration	Rest. 1st Verif Date/Time	Rest. 2nd Verif Date/Time	Placement/ Removal Tag Notes
	D	AC-1858F 33 CC Pump Drain 41' PAB	1	Open							
	D	33 Component Cooling Pump Control Switch 53' CCR Panel SGF	2	Pullout							
	D	33 Comp Cooling Water Pump Control Power Fuses 480V Bus 6A, 15' Ctrl Bldg	3	Fuses Removed							
	D	33 Comp Cooling Water Pump 480V Breaker 480V Bus 6A, 15' Ctrl Bldg	4	Racked Out							
	D	AC-760C 33 CC Pump Suction Isolation 41' PAB	5	Closed							
	D	AC-762B 32 CC Pump Disch Isolation 41' PAB	6	Closed							

# SRO-A-3 Handout

Appendix C	Job Performance Measure Worksheet	Form ES-C-1
Facility: <u>Indian Point 3</u>	Task No: 20001801	02
Task Title: Perform Indepe	ndent Verification of Gaseous Waste P	Permit
K/A Reference: 2.3.8	Job Performance Mea	sure No: SRO-A-4
Examinee:	NRC Examiner:	
Facility Evaluator:	Date:	<u></u>
Method of testing:		
Simulated Performance	Actual Performance	_ <u>X</u>
Classroom X	Simulator	Plant
READ TO THE EXAMINEE		
I will explain the initial condition cues. When you complete the measure will be satisfied.	ons, which steps to simulate or discuss, a task successfully, the objective for this	and provide initiating s job performance
Initial Conditions: 33 Large Ga tank has been isolated and s	as Decay Tank has been pressurized to sampled by Chemistry. A Gaseous Was	87 psig. The Decay ste Release Permit is

tank has been isolated and sampled by Chemistry. A Gaseous Waste Release Permit is being prepared to discharge the decay tank. The data necessary to support the release permit has been collected and recorded on Attachment 1 "Gaseous Waste Release Permit" of SOP-WDS-13, "Gaseous Waste Releases." The CCR personal computer is inoperable, and the software cannot be executed. The PAB/VC exhaust fans are in service and discharging at 30,000 SCFM.

Task Standard: The calculations for GDT Curie Content, Plant Vent Release Rate, Allowable GDT Release Rate, Release Time, and R-44 Alarm setpoint are done within 10% of actual values.

Required Materials: SOP-WDS-13, Gaseous Waste Releases, Partially filled-out Attachment 1 " Gaseous Waste Release Permit," Calculator

General References: SOP-WDS-13, Gaseous Waste Releases

Initiating Cue: Using the appropriate section of SOP-WDS-13, "Gaseous Waste Releases", perform independent verification of the calculations performed for Attachment 1, "Gaseous Waste Release Permit" for 33 Large Gas Decay Tank.

Time Critical Task: No

Validation Time: 17 minutes

SRO-A-4

2

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

1. Performance Step: Refers to SOP-WDS-013. Reviews P&Ls and section 4.2

Standard: Procedure obtained and reviewed

2. Performa	nce Step:	Reviews steps 4.2.1 through 4.2.9 and verifies that required data has been entered on Attachment 1
Standard:	Steps 4.2.1 th 1, Gaseous V	hough 4.2.9 reviewed against the provided copy of Attachment Vaste Release Permit Form
Comment:		
√ 3. Perforr	nance Step:	Verify GDT Curie Content calculation performed correctly.
Standard:	PERFORMS 1 "Gaseous Wa A = (1.93 E- C = 0 V = 0 P = i	the following calculation and verifies data on Attachment 1, ste Release Permit" +03) * (C) * (V) * (P), where: Concentration of noble gas activity in tank (uCi/cc) (6) unpressurized volume of tank (ft3) (4) nitial pressure of tank, in psia (psia = psig + 14.7) (5)
Comment:		

3

Form ES-C-1

#### Performance Information

(Denote critical steps with a check mark)

4. Performance Step: Check available release rate entered

Standard: Checks block 12 and block 10. Difference is R-27 Channel 4 reading

CUE: If asked, R-27 channel 4 is reading 1e-5 uci/cc

Comment:

5. Performance Step: Check NA recorded in blocks 8a, 13, 15, and 16

Standard: Checks NA in appropriate blocks.

Comment:

6. Performance Step: Checks R-27 in block 11 and setpoint in block 12

Standard: Block 11 and 12 checked.

Comment:

#### $\sqrt{7}$ . Performance Step: Checks Emax calculation

 Standard:
 VERIFIES maximum allowable release rate (Emax), in SCFM for this release using the following equation:

 Emax = D / (C \* 472), where:
 Emax = Maximum allowable release rate (ft3/min)

 D = Available Release Rate (□Ci/sec) (10)
 C = Concentration of noble gas activity in tank (□Ci/cc) (6)

Appendix C		4	Form ES-C-
		Performance Information	n
(Denote critical st	eps with a	check mark)	
√8. Performance	e Step:	Verifies that a conservative SCFM that is less than Ema selected. Per the note, typi of Emax	actual release rate (E), in ax for this release has been cal conservative value is 1%
Standard: Obse	erves that	E is 1% of Emax	
Comment:			
√ 9. Performance	Step:	Check RCV-014 setting aga SCFM	inst Attachment 12 for 67
Standard: Verif	es 67 SCF	<sup>-</sup> M corresponds to 86% open	
Comment:			
√10. Performan	ce Step: (	Check Calculated Release R	Rate (R) in uci/sec in block 9
Standard: DETE Attac	ERMINE C hment 1, a R = E * ( R = Calc E = Rele C = Con fies error i	alculated Release Rate, (R) in is follows: (9) C * 472, where: culated Release Rate (uCi/sec ease rate for RCV 014 position centration of noble gas activit n block 9 entry. Should be 30	n uCi/sec and RECORD on c) n (ft3/min) (30) y in tank (uCi/cc) (6) 0.7, not 3.7 uci/cc
Comment:			
Ferminating Cue:	Terminat	te JPM after error in block 9 is	s identified, or after all

- -

•

;

A	ממ	en	ıdi	x	С
		<b>U</b> 1	101	~	-

\_\_\_\_\_

### VERIFICATION OF COMPLETION

Job Performance Measure No. SRO-A-4, Perform Independent Verification of Gaseous Waste Permit

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to complete:

Question Documentation:

Question:

Response:

Result: SAT or UNSAT

Examiner's signature and date: \_\_\_\_\_

	Initial Conditions
Initial Conditons:	
	• 33 Large Gas Decay Tank has been pressurized to 87 psig.
	<ul> <li>The Decay tank has been isolated and sampled by Chemistry</li> </ul>
	<ul> <li>A Gaseous Waste Release Permit is being prepared to discharge the decay tank.</li> </ul>
	<ul> <li>The data necessary to support the release permit has been collected and recorded on Attachment 1 "Gaseous Waste Release Permit" of SOP-WDS-13, "Gaseous Waste Releases."</li> </ul>
	• The CCR personal computer is inoperable, and the software cannot be executed.
	<ul> <li>The PAB/VC exhaust fans are in service and discharging at 30,000 SCFM.</li> </ul>
Initiating Cue:	
-	<ul> <li>Using the appropriate section of SOP-WDS-13, "Gaseous Waste Releases", perform independent verification of the calculations performed for Attachment 1, "Gaseous Waste Release Permit" for 33 Large Gas Decay Tank.</li> </ul>

•

 $\sim$ 

**GASEOUS WASTE RELEASES** 

No: 3-SOP-WDS-013

Rev: 22

Page 34 of 53

### ATTACHMENT 1, GASEOUS WASTE RELEASE PERMIT FORM

(Page 1 of 1)

Tank/ System (1) 33 LGDTCurrent Date/Time (2) 10/23/06 DateO 800 TimePermit No. (3) 618
Volume (4) $S_{2}S_{1}$ ft <sup>3</sup> Initial Pressure (5) $g_{3}$ psig Noble Gas (C)(6) $9.7e - 4$ $\mu$ Ci
Grab Sample:(7) Sample # 3670 2 Date 10/23/06 Time 0810 OR R-12 Monitor
Activity (A)(8) 99956 μCi Noble Gas Iodine 131 Activity (8a) Η/Α μCi/
VC Purge Only         Calculated Release Rate (R)(9) $3.7$ µCi/sec       Available Release Rate (D)(10) $3.07e+3$ Ci/se
Discharge Monitor (11) $R-27$ Actual Alarm Setpoint (12) $3.08e+3 \mu Ci/s$
Calculated alarm setpoint (13) $N/A$ $\mu$ Ci/sec Alert setpoint (14) 1.50 e + 3 $\mu$ Ci/sec
R-12 Auto Closure/Alarm Setpoints: Calculated (15) $\gamma/A$ $\mu$ Ci/cc Actual (16) $\gamma/A$ $\mu$ Ci/c
IF discharge monitor is OOS, THEN COMPLETE the following:
Monitor (17) NIA placed out service @ NIA NIA
<ul> <li>Vent Sample:(18) Sample # Date Lime Lime Results (19)μCi/ (Noble Gas)</li> </ul>
• Vent flow rate (20) $\frac{\sqrt{4}}{2}$ cfm Continuous Release Rate (CR)(21) $\frac{\sqrt{4}}{2}$ $\mu$ Ci/sec
Release Calculations verified by (22)
Release Path Valve Alignment Verified (23)
CRS/SM
Discharge Authorized (24) Release Start (25) Date Time
Final Pressure (26)psig Release Stop (27)
Calculations Results: S (28) //A Emax (29) 6705 ft <sup>3</sup> /min
E(30)ft <sup>3</sup> /min RCV-014 Setting (31)% open
Comments:(32)

SRO-A-4 HANDOUT

**GASEOUS WASTE RELEASES** 

No: 3-SOP-WDS-013

Rev: 22

Page 34 of 53

### ATTACHMENT 1, GASEOUS WASTE RELEASE PERMIT FORM

(Page 1 of 1)

	Tank/ System (1) 33 LcoT	Current Date/Time (2)_ <b>I</b> Ø	<b>123/06</b> Date	<b>0 % 0 0</b> Time	Permit No. (3)	8
	Volume (4) <u>525</u> ft <sup>3</sup> Grab Sample:(7) Sample # <u>30</u>	Initial Pressure (5	) 87 0123/06	_psig Noble _Time <b>6                                   </b>	Gas (C)(6) 9.7	e -Υ μCi/co Monitor
	Activity (A)(8) 99956 Calculated Release Rate (R)(9)	μCi Nob	le Gas Ci/sec	lodine Available Relea	131 Activity (8a) VC F se Rate (D)(10) <b>3.0</b>	<b>γ/4</b> μCi/cc Purge Only <b>7ε + 3</b> μCi/sec
	Discharge Monitor (11) Calculated alarm setpoint (13) R-12 Auto Closure/Alarm Setpo	-27 Μ/Α μι ints: Calculated (15	Ci/sec ;) 거 (	Actual Alarm S Alert setpoint (΄ <b>Α</b> μCi/cc	etpoint (12) <b>3.38</b> 14) <b>1.50_e_+_3</b> Actual (16)	・ ・ ・ ・ ・ ・ ・ ・ ・ ・ ・ ・ ・ ・
/	<ul> <li>IF discharge monitor is OOS, <u>TH</u></li> <li>Monitor (17) <u>N/A</u></li> <li>Vent Sample:(18) Sample #</li> </ul>	IEN COMPLETE th placed out service	ne following: @ Date 	<b>4</b> <b>A</b> Time	バ/A Time バ/4_ Results (19)	مارى µCi/cc
	Vent flow rate (20) H/A Release Calculations verifier	_cfm Co d by (22)	ontinuous Rele	ease Rate (CR)	21) <b>N/A</b>	(Noble Gas) µCi/sec
	Release Path Valve Alignment V	erified (23)		CRS/SI	М	
	Discharge Authorized (24)	CRS/SM		Release Start (2	25) Date	Time
	Final Pressure (26)	psig	,	Release Stop (2	27) Date	Time
J	Calculations Results: S (28) E(30) Comments:(32)	NIA 67 ft <sup>3</sup> /	min	Emax (29) <b>(</b> RCV-014 Settin	<b>5705</b> ft <sup>3</sup> /min g (31) <b>F6</b>	n % open
	S	RO-r	4 - 4	KE	1	

Appendix C	Job Performance Measure Worksheet	Form ES-C-1					
Facility: Indian Point 3	Task No: N/A						
Task Title: Event Classifi	sk Title: Event Classification and NYS Part 1 Form						
K/A Reference: _2.4.41 (4.	1) Job Performance Measure I	No: SRO-A-5					
Examinee:	NRC Examiner:	NRC Examiner:					
Facility Evaluator:	Date:	_					
Method of testing:							
Simulated Performance	Actual Performance X						
Classroom	Simulator X P	'lant					
READ TO THE EXAMINEE							
I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.							
Initial Conditions: An event has occurred requiring Emergency classification							
Task Standard: Classification is correctly made for the event completed							
Required Materials: IP-EP-120, Emergency Classification IP-EP-130, Emergency Notifications and Mobilization Event Classification Guide (Wall Chart)							
General References: Event Classification Guide IP-EP-AD13, IPEC Emergency Action Level Technical Bases							
Initiating Cue: Classify the event just completed and provide a completed NYS Radiological Emergency Data Part 1 Form for the CCR Offsite Communicator							
Time Critical Task: Yes – 15 minutes from start of JPM to EAL declaration. Time for completion of Part 1 form is not part of 15 minute clock.							
Validation Time: 15 minutes							

SRO-A-5

/

÷

-

2

#### **Performance Information**

(Denote critical steps with a check mark)

# $\sqrt{1}$ . Performance Step: Classify the event in accordance with the Emergency Plan Implementing Procedures.

Standard: Correctly classifies event by selecting the correct EAL within 15 minutes of initiating cue.

For Scenario 1 – EAL 4.2.1, Site Area Emergency Note: EAL 9.1.8 SAE or EAL 3.2.2 SAE, or 4.1.3 SAE are also acceptable

For Scenario 2 – EAL 6.1.4, Site Area Emergency

For Scenario 3 – EAL 1.1.1, Alert Note: EAL 3.1.2 Alert also acceptable since both events occurred at essentially the same time

For Scenario 4 – EAL 1.3.1, Site Area Emergency

Ζ.

3

Form ES-C-1

#### **Performance Information**

(Denote critical steps with a check mark)

#### $\sqrt{2.$ Performance Step: Complete NYS Radiological Emergency Data Part 1 Form

- Standard: See attached keys for each event. The following is critical:
  - 1. Selects this is an exercise
  - 2. Enters notification #1
  - 3. Declared on unit 3
  - 4. Enters EAL 4.2.1
  - 5. Enters date and time of declaration
  - 6. Unit 2 operational
  - 7. Unit 3 shutdown
  - 8. Date and time unit 3 shutdown
  - 9. Selects release above TS to atmosphere
  - 10. Obtains and enters MET data (<u>speed, direction and Stability</u>)from met data display on rear of flight pane
  - 11. Selects Print/Save or Preview to print a copy, or completes required data on a blank form
- CUE: If necessary, ensure candidate selects Exercise NOT REAL EVENT If necessary, provide cue for dates and times If necessary, cue candidate that unit 2 is operating at 100% power
  - If necessary, cue candidate to obtain MET data from the simulator MET display

Comment:

Terminating Cue: Event classified and a completed Part 1 form is ready for the CCR Offsite Communicator

.

4

Form ES-C-1

#### VERIFICATION OF COMPLETION

Job Performance Measure No. SRO-A-5, Event Classification and NYS Part 1 Form

Examinee's Name:

Date Performed:

Facility Evaluator:

Number of Attempts:

Time to complete:

Question Documentation:

Question:

Response:

Result: SAT or UNSAT

Examiner's signature and date: \_\_\_\_\_

\_\_\_\_

**Initial Conditions:** 

~

o An event has occurred requiring Emergency classification

Initiating Cue:

- Classify the event just completed and provide a completed NYS Radiological Emergency Data Part 1 Form for the CCR Offsite Communicator
- If the EAL escalated during the scenario, classify the highest (most severe) EAL encountered.
- If multiple EAL entry criteria for the same classification occurred during the scenario, classify the event that occurred first.
- Complete the NYS Radiological Emergency Data Part 1 Form after classifying the event.