

neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;

- D. Pursuant to the Act and 10 CFR Parts 30, 40 and 70, to receive, possess, and use in amounts as required any byproduct, source, or special nuclear material without restriction to chemical or physical form for sample analysis or instrument and equipment calibration or associated with radioactive apparatus or components;
- E. Pursuant to the Act and 10 CFR Parts 30 and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by operation of the facility.

- 3. This renewed license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations: 10 CFR Part 20, Section 30.34 of 10 CFR Part 30, Section 40.41 of 10 CFR Part 40, Section 50.54 and 50.59 of 10 CFR Part 50, and Section 70.32 of 10 CFR Part 70; and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

- A. Maximum Power Level

The licensee is authorized to operate the facility at a steady state reactor core power level not in excess of 2339 megawatts thermal.

- B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 211 are hereby incorporated in the license.

The license shall operate the facility in accordance with the Technical Specifications.

- (1) For Surveillance Requirements (SRs) that are new in Amendment 176 to Final Operating License DPR-23, the first performance is due at the end of the first surveillance interval that begins at implementation of Amendment 176. For SRs that existed prior to Amendment 176, including SRs with modified acceptance criteria and SRs whose frequency of performance is being extended, the first performance is due at the end of the first surveillance interval that begins on the date the Surveillance was last performed prior to implementation of Amendment 176.

5.6 Reporting Requirements

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

15. "Safety Evaluation by the Office of Nuclear Reactor Regulation Related to Amendment No. 87 to Facility Operating License No. DPR-23, Carolina Power & Light Co., H. B. Robinson Steam Electric Plant, Unit No. 2, Docket No. 50-261," USNRC, Washington, DC 20555, 7 Nov. 84.
16. ANF-88-054(P), "PDC-3: Advanced Nuclear Fuels Corporation Power Distribution Control for Pressurized Water Reactors and Application of PDC-3 to H. B. Robinson Unit 2," approved version as specified in the COLR.
17. ANF-88-133 (P)(A), "Qualification of Advanced Nuclear Fuels' PWR Design Methodology for Rod Burnups of 62 Gwd/MTU," approved version as specified in the COLR.
18. ANF-89-151(A), "ANF-RELAP Methodology for Pressurized Water Reactors: Analysis of Non-LOCA Chapter 15 Events," approved version as specified in the COLR.
19. EMF-92-081(A), "Statistical Setpoint/Transient Methodology for Westinghouse Type Reactors," approved version as specified in the COLR.
20. EMF-92-153(P)(A), "HTP: Departure from Nucleate Boiling Correlation for High Thermal Performance Fuel," approved version as specified in the COLR.
21. XN-NF-85-92(P)(A), "Exxon Nuclear Uranium Dioxide/Gadolinia Irradiation Examination and Thermal Conductivity Results," approved version as specified in the COLR.
22. EMF-96-029(P)(A), "Reactor Analysis System for PWRs," approved version as specified in the COLR.
23. EMF-92-116, "Generic Mechanical Design Criteria for PWR Fuel Designs," approved version as specified in the COLR.
24. EMF-2103(P)(A), "Realistic Large Break LOCA Methodology for Pressurized Water Reactors," approved version as specified in the COLR.
25. EMF-2310(P)(A), "SRP Chapter 15 Non-LOCA Methodology for Pressurized Water Reactors," approved version as specified in the COLR.

(continued)