



RULES AND DIRECTIVES
UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

2006 DEC -7 PM 3: 20

RECEIVED

(18)

9/22/06

71 FR 55517

SUNSI Review Complete

Template = ADM-013

E-RIDS = ADM-03

Add: S. D'Connor (SCO)

J. Ridgely (JNR)

J. T. Yerokun (JTY)

T. Martinez - Navedo

(TXN2)

W.S. Raughtey (WSR)

Review of Draft Regulatory Guide DG-1155, "Maintenance, Testing and Replacement of Large Lead Storage Batteries for Nuclear Power Plants," by Richard T. Bolgeo, BSEE, Chairman of IEEE Standard 450-2002

COMMENT 3

DG-1155, Page 5, Item 3, Subsection 5.4.1 (d) states: "(d) For nuclear power generating station Class 1E batteries, the use of stabilized charging current to determine a fully charged condition should (1) be limited to lead-calcium batteries and (2) verified by measurements during charging. ..."

This statement recognizes the difference in technologies between lead-calcium batteries and other types and is technically accurate. Therefore, this recognition could be deemed to be prudent and would be acceptable.

<~><~><~><~><~><~><~>

COMMENT 4

DG-1155, Page 5, Item 5, states: "In Subsection 6.1, "Acceptance test," a second sentence should be added to state as follows: "However, a test of the battery's capability (see 7.5) shall be made upon initial installation.""

There is no technical basis for this change. IEEE Standard 450-1972,1975,1987,1995 and 2002 are all in agreement with this issue in that if an acceptance test is performed at the manufacturers, then it is not necessary to perform this test upon initial installation of the battery. See Section 6.1, paragraph 1 of IEEE Standard 450-2002.

The user has 2 years to test the newly installed battery by a Performance Test (or a Modified Performance Test) in accordance with section 6.2(a) of IEEE Standard 450-2002 after the battery has been installed.

Since the advent of IEEE Standard 450-1972, this has been the recommended method and through out the past 4 reviews, no changes have been approved in the IEEE Standard 450 documents. Numerous times when this issue was brought up by the NRC representative, we have asked for documented evidence from the committee as a whole that we can review, that would show where our recommendations in this case are lacking. **At no time has anyone presented any evidence to prove the case for the need to change this recommendation. This proposed requirement has not been shown that have any technical merit**

A review or DG-1155 shows no technical basis for this change for this recommendation presented in IEEE Standard 450-1972, 1975, 1987, 1995 and 2002. Also, for some nuclear plants that are limited on outage times, this change will cause a significant problem and could cause extended and unnecessary outages.

Therefore, I find this recommended change to be imprudent, not supported by engineering data and unacceptable.

<~><~><~><~><~><~><~>

Review of Draft Regulatory Guide DG-1155, "Maintenance, Testing and Replacement of Large Lead Storage Batteries for Nuclear Power Plants," by Richard T. Bolgeo, BSEE, Chairman of IEEE Standard 450-2002

COMMENT 5

DG-1155, Page 6, Item 7, states: "In Subsection 7.2.2, "Discharge Rate," the last paragraph allows users to transition from correcting for temperature *before* conducting the discharge test to correcting for temperature *after* conducting the discharge test. This statement should be supplemented with the following: "For nuclear power generating station Class 1E batteries, the preferred method is to adjust the discharge rate for the time-adjusted method for temperature before conducting the test.""


See the Comment 1 for the technical discussion.

DG-1155 is requiring a change to the test methodology of all types of capacity tests specified in IEEE Standard 450-2002 with out giving any technical reasons other than the incorrect assumption put forth in DG-1155, Page 4, Paragraph 4.

Therefore, I find this recommended change to be imprudent, not supported by engineering data and unacceptable.

<~><~><~><~><~><~><~><~>

In my review of this document I have tried to be objective and apply reasonable engineering principles to the information presented.



Richard T. Bolgeo
Chairman of IEEE Standard 450-2002
Vice Chairman and Task Leader of IEEE Standard 450-1997
Member of the IEEE Power Engineering Society Stationary Battery Committee
Member of the IEEE Stationary Battery Working Groups since 1982

Endorsed by:

Edward Stallings per email message
Vice Chairman of IEEE Standard 450-2002
Member of the IEEE Power Engineering Society Stationary Battery Committee
Member of the IEEE Stationary Battery Working Groups since 1982