

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Grand Gulf Early Site Permit Hearing

Docket Number: 52-009-ESP

DOCKETED
USNRC

December 7, 2006 (11:15am)

OFFICE OF SECRETARY
RULEMAKINGS AND
ADJUDICATIONS STAFF

Location: Rockville, Maryland

Date: Wednesday, November 29, 2006

Work Order No.: NRC-1345

Pages 52-312

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ATOMIC SAFETY AND LICENSING BOARD

5 + + + + +

6 HEARING

7 -----X

8 In the Matter of: :

9 SYSTEM ENERGY RESOURCES, INC.: Docket No. 52-009-ESP

10 (Early Site Permit for :)

11 Grand Gulf ESP Site) :

12 -----X

13 Third Floor Hearing Room

14 Two White Flint North

15 11555 Rockville Pike

16 Rockville, MD 20852-2738

17
18 Wednesday, November 29, 2006

19
20 The above-entitled matter came on for
21 hearing, pursuant to notice at 9:00 a.m.

22 BEFORE:

23 THE HONORABLE LAWRENCE G. McDADE, Chairman

24 THE HONORABLE NICHOLAS G. TRIKOUROS

25 THE HONORABLE RICHARD E. WARDWELL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 APPEARANCES:

2 On Behalf of the Applicant:

3 KATHRYN M. SUTTON, ESQ.

4 PAUL BESSETTE, ESQ.

5 MARTIN J. O'NEILL, ESQ.

6 Of: Morgan, Lewis & Bockius, LLP

7 1111 Pennsylvania Avenue, NW

8 Washington, DC 20004

9 (202) 739-5738

10
11 On Behalf of the NRC:

12 JONATHAN RUND, ESQ.

13 ANN HODGDON, ESQ.

14 PATRICK MOULDING, ESQ.

15 ROBERT WEISMAN, ESQ.

16 Office of the General Counsel

17 US Nuclear Regulatory Commission

18 Mail Stop 015 D21

19 Washington, DC 20555

20
21
22
23
24
25 **NEAL R. GROSS**COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

I-N-D-E-X

EXHIBITSMARK RECDNRC Staff

Pre-Filed Testimony on Issues A-I	78
Pre-Filed Testimony on Other Issues	79
Exhibit Nos. 1-45	83
Exhibit No. 46	271 274

SERI

Pre-Filed Testimony	86
Exhibit Nos. 1-30	87
Exhibit No. 31	273 273

HEARING ISSUES

Hearing Issue A	89
Hearing Issue B	228
Hearing Issue C	285
Hearing Issue D	293

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

P-R-O-C-E-E-D-I-N-G-S

9:04 a.m.

JUDGE MCDADE: This hearing will come to order. First, for the NRC staff, is everybody here that's going to be here?

MR. RUND: We have a few people that are just walking in now. They have the electronic versions the Board requested, so if we could request just a couple of minutes to just make sure we've got everything in order. We'll be ready to go in two minutes.

JUDGE MCDADE: Okay. Let me just note one thing. I notice there are people standing in the back. I just would note for you that in the ACRS room which is on the second floor of this building, right down one floor on the elevator, this proceeding is being broadcast. So from your standpoint if you get tired of standing, if a seat doesn't open up you can go down to the second floor to the ACRS room which is available just off the elevator and view the proceedings from there.

While the staff is getting ready, from the applicant are you all set to go?

MS. SUTTON: We're ready, Your Honor.

MR. RUND: Staff is ready.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE MCDADE: Okay. Before we get
2 started here, again let me remind everybody this is
3 being recorded. It's necessary for the court
4 reporter to take down what we're saying, so to the
5 degree that you can, please remember to talk into
6 the microphone, also to mention to your witnesses
7 that they should be talking into the microphone as
8 well so that we have a record of what it is that
9 they say.

10 Now, before we get started I want to do
11 a bit of introduction here, an introduction for
12 basically two purposes. One, to explain who we are
13 and what we're doing to any subsequent superior
14 tribunal that may be reviewing what we're doing, and
15 also to explain to the people who are here what it
16 is that we are doing. This is an adjudicatory
17 proceeding, but it's not an adversary proceeding and
18 in that sense it's a little bit different than what
19 probably most people think of by an adjudicative
20 proceeding. In most proceedings you have a
21 plaintiff and a defendant who are adversaries. The
22 plaintiff comes in, they present their evidence, the
23 defendant then raises any affirmative defenses they
24 may have and the judges decide whether or not - or a
25 jury decides whether or not they have met their

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 burden of proof. They serve basically as a referee
2 between the two parties and ultimately make a
3 determination as to whether or not the plaintiff has
4 met its burden of proof.

5 This is somewhat different in that it's
6 not an adversarial proceeding. We have two parties.
7 We have the NRC staff and we have the applicant, but
8 they have the same interest. They have the interest
9 in getting at this point the application approved.
10 The NRC staff has reviewed the application and they
11 have made a determination that the application, the
12 Early Site Permit, should be approved. So now we
13 have to do our job, and our job is to a very large
14 degree to review the staff's work. We are not doing
15 a de novo review of the application, but rather we
16 are starting from the work that the staff has done
17 in this particular case.

18 So what I want to do is just to take a
19 few minutes and to explain to you the procedure and
20 also to explain to you what it is we're going to be
21 doing during the course of the proceeding. Now,
22 System Energy Resources, Inc., has filed an
23 application. The application is for an Early Site
24 Permit. It is an Early Site Permit to allow the
25 construction, or the first stages going towards the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 construction of a nuclear electric power facility in
2 Grand Gulf, Mississippi, Clayborn County,
3 Mississippi. It is an Early Site Permit. Under the
4 Nuclear Regulatory Commission regulations, an Early
5 Site Permit is as a matter of law a construction
6 permit, and under the Atomic Energy Act in a
7 construction permit for a nuclear facility there
8 must be a hearing. Now, the hearings can take a
9 number of forms. First of all, once the application
10 is filed, once the staff takes certain preliminary
11 actions, parties who believe that they have an
12 interest can file a petition to intervene. They
13 have to demonstrate that they have standing and they
14 have to demonstrate that there is an issue that they
15 have identified that they have prepared to litigate
16 that is relevant to the decisions that the
17 Commission is going to have to make. In this
18 particular case there were various interveners who
19 filed petitions, but the Board determined that those
20 individuals had either not shown standing or had not
21 submitted an admissible contention, in other words
22 identified an issue that they were prepared to
23 litigate. So we are now left with what is referred
24 to as a mandatory hearing. It is a hearing before
25 this particular Board without an adversary party.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433--

www.nealrgross.com

1 Now, we have been instructed by the
2 Nuclear Regulatory Commission, we have been
3 delegated from the Nuclear Regulatory Commission the
4 authority and the responsibility to conduct this
5 particular hearing and we have been given specific
6 direction on what it is we are supposed to do and
7 what it is we are not supposed to do in conducting
8 these hearings for the Commission. Now first of
9 all, we're not to conduct a de novo review. We're
10 not starting at square one. The staff has conducted
11 a review and we are supposed to determine whether or
12 not, having reviewed the staff's work, that they
13 have adequately demonstrated, factually and
14 logically, that their conclusions are justified. So
15 effectively we are reviewing the staff's review of
16 SERI's application, specifically with regard to the
17 safety aspects of this particular application.

18 Now, the scope of the Board's review was
19 set out first of all in regulations promulgated by
20 the Nuclear Regulatory Commission at 10 C.F.R. §
21 2.104 and then subsequently in 1995 in response to a
22 request of certified questions the Nuclear
23 Regulatory Commission gave us more specific
24 directions on what it is we're supposed to do.
25 Specifically, we are to determine whether the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 performed an adequate review and made findings with
2 reasonable support in fact and logic. Now, in doing
3 this we have to answer various specific questions.
4 First of all, we have to determine, based on the
5 staff's review, whether or not we are satisfied that
6 in granting the license it would be harmful to the
7 common defense or security or to the health or the
8 public safety. We have to make sure that the
9 regulations promulgated by the Nuclear Regulatory
10 Commission have been followed, taking into
11 consideration site criteria contained in the Nuclear
12 Regulatory Commission regulations at 10 C.F.R. Part
13 100, whether a reactor can be constructed and
14 operated at the proposed site without undue risk to
15 the public health and safety. That's what we're
16 supposed to do with regard to the safety aspects.

17 We also have to make determinations with
18 regard to the environmental impact and potential
19 environmental impact of the proposed action, the
20 granting of this Early Site Permit. Our
21 responsibility for that first of all comes under the
22 National Environmental Policy Act. You're going to
23 hear it referred to by almost everybody during this
24 hearing as NEPA. And we have to make determinations
25 under NEPA. Again, it starts with the staff review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 They, based on the environmental reports submitted
2 by the applicant, have prepared an Environmental
3 Impact Statement, and much of what we have done is
4 to review the Environmental Impact Statement
5 submitted by the staff. We have to determine
6 whether or not the staff has complied with NEPA,
7 whether or not they have complied with the
8 regulations under NEPA and also whether or not they
9 have complied with the regulations issued by the
10 Nuclear Regulatory Commission which further
11 implement the provisions of the National
12 Environmental Policy Act. In addition to that, we
13 have to make a determination. After weighing the
14 alternatives, we have to determine whether or not
15 the Early Site Permit should be issued, whether it
16 should be denied, or if in issuing it, it should be
17 conditioned in certain ways in order to protect
18 significant environmental issues. Anyway, that is
19 basically what it is that we need to do and the
20 purpose behind this particular hearing.

21 Now, this particular hearing, if you
22 just came in, you're going to say we're starting in
23 the middle. And let me explain a little bit about
24 what has gone on before today. First of all, we
25 issued orders, a number of orders, asking for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 information from the staff and from the applicant.
2 Back in April we requested documents and briefing.
3 September 13 we issued specific questions to the
4 staff to which the applicant also had an opportunity
5 to respond relative to the Safety Evaluation Report.
6 We received answers from that. On October 3 we
7 issued another order having to do with the
8 Environmental Impact Statement, again asking very
9 specific questions about the review that led to the
10 creation of the Environmental Impact Statement.
11 Based on the responses to those questions, we then
12 issued another order identifying hearing issues.
13 And what we are going to be doing over the next few
14 days is going through those hearing issues. There
15 were nine that we identified. And we asked them to
16 provide first of all pre-filed testimony, which is
17 their direct testimony with regard to the questions
18 that we asked in our order of November 6. We have
19 received the pre-filed testimony. We are now going
20 to give them the opportunity to make additional
21 presentations and also to allow us to ask specific
22 questions based on the pre-filed testimony, based on
23 the question responses that we received to our
24 orders of September 13 and October 3. So there is a
25 significant record that has already been developed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 at this point in time that this hearing is the
2 culmination of the process rather than the beginning
3 of the process. It began with the submission of the
4 application by SERI. It was followed up by the
5 creation of documents such as the Environmental
6 Impact Statement and the Safety Evaluation Report of
7 the staff. It was followed up by requests for
8 information, documents and briefing by the Board,
9 followed with the specific questions on the
10 Environmental Impact Statement and the Safety
11 Evaluation Report by the Board, the responses to
12 those questions and then the identification of
13 hearing issues and the submission of pre-filed
14 direct testimony. So for the witnesses who come in
15 here today and tomorrow and the next day until we're
16 finished with this, they're not going to be starting
17 at square one. They're not going to be sitting down
18 explaining who they are and regurgitating everything
19 that they've said in their pre-filed testimony.
20 That's available, it's on the ADAMS for anybody who
21 wishes to view it, but we are going to be jumping in
22 kind of in the middle of their testimony. I think
23 that's by way of preliminary, sort of explains who
24 we are, what it is we view our responsibilities,
25 what directions we have been given by the Nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Regulatory Commission in conducting this hearing for
2 them, what has happened up until this point in the
3 proceeding and what we anticipate is going to be
4 happening over the next couple of days.

5 Before we proceed further, Judge
6 Trikouros wanted to ask some very specific
7 questions, but before I turn the floor over to him
8 let me ask of the staff, do you have any preliminary
9 matters to be taken up before Judge Trikouros'
10 question, and then we will be getting into Hearing
11 Issue A.

12 MR. RUND: I guess we'd like to start
13 off by introducing ourselves. My name's Jonathan
14 Rund. With me to my right is Ann Hodgdon. Robert
15 Weisman is immediately to my left, followed by Tison
16 Campbell and Patrick Moulding. Yesterday the Board
17 asked about supplemental testimony. Mr. Weisman
18 will explain what the purpose of that was.

19 JUDGE MCDADE: Okay. Right before we
20 begin with Hearing Issue A there will be a number of
21 preliminary matters. First of all, you know, we
22 have all of the pre-filed testimony that we want to
23 formally accept into the record. We also have a
24 number of pre-filed exhibits that we want to
25 formally accept into the record and admit so that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 won't have to be talking about them specifically
2 each time, you know, one of them comes up. So we'll
3 do that as a preliminary right before the beginning
4 of Hearing Issue A. While I'm on the subject just
5 let me mention to the degree practicable, and I
6 realize it may be difficult, but when you get a
7 chance to talk to your witnesses, when they refer to
8 a document, if it is an exhibit, if they can refer
9 to it by the exhibit number. I think all of us are
10 going to be pretty familiar with it, but again, you
11 know, any subsequent tribunal that reviews this may
12 not be as familiar with the documents and it's going
13 to be an awful lot easier if it's not only
14 identified as Figure 2-135 of the SSAR, but it's
15 also identified as SERI Exhibit 21 or Staff Exhibit
16 61 or whatever. So I realize that some of them may
17 not be familiar with that. To the degree that you
18 all can help them along when they refer to it you
19 can interrupt them and say, "And by that you mean
20 Exhibit," you know, and that way it'll be clear from
21 the record to anybody who's reviewing it. But
22 anyway, we'll take that up right before Hearing
23 Issue A.

24 Before we proceed further, does the
25 applicant have any preliminary matters?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SUTTON: By way of introduction,
2 Your Honor, I am Kathryn M. Sutton. I'm a partner
3 in the law firm of Morgan, Lewis & Bockius. With me
4 are two associates from the firm. On my left is
5 Paul Bessette. On my right is Martin O'Neill. We
6 represent the applicant System Energy Resource,
7 Inc., in this proceeding. It's commonly referred to
8 as SERI, S-E-R-I.

9 JUDGE MCDADE: Okay. And one of the
10 things I would also ask and you know relatively
11 early on, I went through what it is we think we're
12 supposed to be doing. If either the staff or the
13 applicant has an objection to that, you know, don't
14 be shy about stating it so that we can get that
15 resolved rather than our doing something that you
16 think is wrong and then we wind up at the end of the
17 hearing having to, you know. If by some odd chance
18 we actually were wrong, which is almost
19 inconceivable, to go back and retrace our steps.

20 MS. SUTTON: We have no objection at
21 this time and will not be shy.

22 JUDGE MCDADE: Thank you. Judge
23 Trikouros?

24 JUDGE TRIKOUROS: Thank you. Before we
25 get started on Hearing Issue A, I wanted to kick

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 this off with a question that has been plaguing me
2 that I'd like to get an answer to. I think the
3 answer would be very helpful to me and to the Board
4 in terms of some of the hearing issues that we're
5 going to be discussing today and tomorrow. And
6 specifically, my question is regarding the
7 components of an Early Site Permit. I do not have
8 any clear understanding of what those are. For
9 example, I'm assuming it will include plant
10 parameter envelope and permit conditions. However,
11 it's not clear to me what the statements will be
12 made. For example, will the Early Site Permit
13 specify a thermal megawatt power level that's been
14 approved for the site? Will the Early Site Permit
15 specify a megawatt electric limit for the site?
16 Will it specify both? So what exactly would an
17 Early Site Permit look like in terms of its
18 components, its contents so that as we begin to ask
19 questions down the road here, we can understand if
20 something important will not be included in the
21 permit or will be included in the permit which would
22 make it then less onerous to us if it were, you
23 know, not included in let's say the plant parameter
24 envelope. So I address this question to the staff.
25 However, the applicant is obviously free to chime

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 in.

2 MR. WEISMAN: This is Bob Weisman for
3 the NRC staff. And while I don't have a copy of the
4 form of an Early Site Permit with me, I can tell you
5 what it will contain at least to the best of my
6 recollection. And that is it will list the thermal
7 power level. The staff is planning on including
8 that in the Early Site Permit.

9 JUDGE TRIKOUROS: Not the megawatt
10 electric power level.

11 MR. WEISMAN: Not the megawatt electric.
12 I think in part because the thermal efficiency of a
13 particular plant could vary and with respect to
14 siting, the only thing that is important is the
15 thermal power level. It will have a list of site
16 characteristics that's incorporated into the permit.
17 That is in the SER and I believe it's in Appendix A.
18 It will have, if necessary it may have some bounding
19 site parameters necessary for the safety review. It
20 could also - on the environmental side it will have
21 a list of plant parameters, in this case a plant
22 parameter envelope that was used for the
23 environmental evaluation. It will also have, let's
24 see, I'm sorry I left out on the safety side a set
25 of COL action items. All of these will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 incorporated into the Early Site Permit.

2 JUDGE TRIKOUROS: Now I'm assuming that
3 when you say plant parameter envelope on the
4 environmental side, you mean the plant parameter
5 envelope period, which includes both the safety side
6 and the environmental side.

7 MR. WEISMAN: No, I don't mean that. I
8 do mean because the plant parameter envelope,
9 they're used for different purposes on the safety
10 side and on the environmental side, so the plant
11 parameter envelope on the environmental side is
12 necessary to define the staff's evaluation. If at
13 the COL stage a plant did not fall within those
14 parameters, that could be significant new
15 information, it could require additional
16 environmental evaluation. But if it - I'm seeing -
17 can I clarify something for you?

18 JUDGE TRIKOUROS: Yes, go ahead.

19 MR. WEISMAN: I saw a look of puzzlement
20 on your face and I wondered what your question was.

21 JUDGE TRIKOUROS: Well, I'm having a bit
22 of a problem with what you said. The plant
23 parameter envelope includes a number of important
24 design - it is, in fact, the surrogate plant which
25 has implications both in design and in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 environmental, in safety and in environmental. So
2 what you're telling me is the plant parameter
3 envelope that will be included in the Early Site
4 Permit will separate out only those parameters
5 associated with the environmental side and will not
6 include anything associated with the safety side?

7 MR. WEISMAN: To be clear, there will be
8 two separate tables in the ESP. There will be a
9 table that - incorporated into the ESP that has
10 certain plant parameters that are important for the
11 safety review to the extent that they're necessary
12 to consider to establish a site characteristic.
13 Those things will be in a separate table, but at the
14 COL stage all that is necessary on the safety side
15 is to assure that the plant falls within the site
16 characteristics, that the design of the actual
17 facility accounts for all of the site
18 characteristics.

19 The plant parameters on the safety side
20 considered at the ESP stage are, if you will, for
21 practicality. It's is this a reasonable design, a
22 reasonable - could a plant be put at this site with
23 its characteristics. So it's not necessary to put
24 all of those plant parameters on the safety side
25 into the permit. On the environmental side,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 however, the bounds of the analysis are where the
2 plant parameters interact with the environment what
3 effect will the plant have on the surrounding
4 environment. Those plant parameters are in a
5 different table and it is a complete set for the
6 environmental review.

7 JUDGE TRIKOUROS: So when we're at the
8 COL stage, the safety analyses that were done at the
9 ESP stage, will they have to be redone at the COL
10 stage or can the applicant just simply reference
11 certain analyses from the ESP stage that utilized
12 plant parameter envelope parameters.

13 MR. WEISMAN: At the ESP stage the
14 safety analysis all has to do with siting, whether
15 or not the site is acceptable. To the extent that a
16 design is considered in deciding that, and to my - I
17 would believe that the only area where that would
18 occur would be in the accident dose calculation.
19 That design could be set, the COL applicant could
20 rely on that at the ESP stage. Now, to the extent
21 that the site characteristics play into whether the
22 design is acceptable, those are going to be set in
23 the ESP and the applicant will be entitled to rely
24 on them at the COL stage. But the rest of the
25 design will have to meet all the independent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 requirements in Part 50 and its appendices, Part 20
2 and the other provisions of the Commission's
3 regulations.

4 JUDGE TRIKOUROS: Well okay. I could
5 debate this, and I will, but not right now. I think
6 we're going to be picking up on this in more detail
7 later in hearing issues and also in the
8 miscellaneous items at the back end, but I wanted to
9 get a good feel for the contents of the ESP and I
10 think you've helped me quite a bit. But let me ask
11 you one other question associated with that.
12 Thermal power level, would it be the site power
13 level or would it be the - would there be a site
14 power level and an upper limit specified for a given
15 plant size as well?

16 MR. WEISMAN: I believe that the way the
17 ESP would be currently structured is that it would
18 be a per-unit power level as well as a site overall
19 power level for any new units.

20 JUDGE TRIKOUROS: Okay, so a single unit
21 could not be greater than the specified value in the
22 Early Site Permit, but if it were less than that one
23 could produce - could build two units, for example,
24 as long as the two units were individually less than
25 the single unit value and that the sum of the two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 units was less than the site-approved value.

2 MR. WEISMAN: Yes. Yes. The ESP would
3 allow for modular construction, for example.

4 JUDGE TRIKOUROS: And there would be no
5 specification at all with respect to the number of
6 plants?

7 MR. WEISMAN: No, Your Honor.

8 JUDGE WARDWELL: And in all cases would
9 that - the site value that you're talking about
10 would not include the existing plant, or would there
11 be cases -

12 MR. WEISMAN: That is correct.

13 JUDGE WARDWELL: For instance, national
14 blowdown rate and those types of things that will be
15 part of what I believe would be the environmental
16 side of the bounding values, would those flow rates
17 be only the ESP site and not include the existing
18 plant that's there?

19 MR. WEISMAN: The ESP will only include
20 numbers, parameters, site characteristics for any
21 new plants. It will not include the existing
22 plants.

23 JUDGE WARDWELL: Thank you.

24 JUDGE MCDADE: Judge Trikouros, anything
25 further?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE TRIKOUROS: Yes, I have quite a
2 bit, but as I said I'm not -

3 JUDGE MCDADE: For now.

4 JUDGE TRIKOUROS: - going to address it
5 at this point. So I'm done with that here and now,
6 but I think this entire issue, we'll revisit a
7 number of times.

8 MS. SUTTON: Judge Trikouros, the
9 applicant will be addressing these questions in
10 great detail with respect to Hearing Issue G in
11 their presentation.

12 JUDGE TRIKOUROS: Thank you.

13 JUDGE MCDADE: Okay.

14 JUDGE WARDWELL: I have one other
15 question and that relates to, if I can remember what
16 it is now. I will remember it. If in fact we
17 wanted to - felt it was desirable to recommend that
18 additional tables of assumptions or commitments be
19 referenced or included in this permit, is there an
20 avenue and a mechanism to achieve that that would be
21 something that would seem reasonable to the staff?

22 MR. WEISMAN: If I could confer with my
23 colleagues for just a moment.

24 JUDGE WARDWELL: Sure.

25 MR. WEISMAN: Your Honor, I think the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Board clearly has the authority to impose permit
2 conditions in its decision and that that would be an
3 appropriate avenue for the Board to add any matters
4 such as you identified that the Board thought was
5 missing from what the staff proposed.

6 JUDGE WARDWELL: Thank you and one
7 second question, that's going to be my second last
8 question. That is you mentioned a form. Is there a
9 standard form for ESP permits?

10 MR. WEISMAN: Well, we are - the staff
11 is developing a form, but we haven't finally arrived
12 at what it would look like.

13 JUDGE WARDWELL: Okay, thank you.

14 JUDGE TRIKOUROS: Would it be
15 appropriate for us to - when do you think you're
16 going to complete this form?

17 MR. WEISMAN: It's difficult to
18 estimate, but I would think that it would be
19 developed very shortly, within a few days.

20 JUDGE MCDADE: Certainly before this one
21 is granted.

22 MR. WEISMAN: Yes, Your Honor.

23 JUDGE MCDADE: Okay. Could we ask, you
24 know, would it be possible for you to at some point
25 during the course of the proceeding to give us,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 stamp a draft, stamp a most recent draft, put the
2 date of the draft on it and just give us the - what
3 the current version looks like?

4 MR. WEISMAN: I think we could do that
5 for you, Your Honor.

6 JUDGE MCDADE: Okay, thank you.
7 Anything further from SERI before we proceed?

8 MS. SUTTON: No, Your Honor.

9 JUDGE MCDADE: Okay, thank you. At this
10 point let me just note that in response to our
11 request for pre-filed testimony we received from the
12 staff pre-filed testimony with regard to various
13 hearing issues. First, Hearing Issue A site
14 characterization, Hearing Issue B monitorability of
15 radiological releases, Hearing Issue C relating to
16 seismic issues, Hearing Issue D with regard to the
17 continuity between the ESP and the COL stage,
18 Hearing Issue E which is the alternative analysis,
19 Hearing Issue F cumulative site impacts, Hearing
20 Issue G evaluation of the plant parameter envelope,
21 Hearing Issue H continuity between the ESP stage, I
22 radiological reviews. Do you wish that we receive
23 those into the record?

24 MR. RUND: The staff wishes that those
25 be admitted into the record as if read, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE MCDADE: Okay. I understand that
2 you have also developed an errata sheet for some of
3 the ones that were submitted back on the 20th of
4 November, is that correct?

5 MR. RUND: That's correct.

6 JUDGE MCDADE: Okay. What I would ask
7 is if you could give to the court reporter at this
8 point the corrected copies of those documents that
9 we've made a permanent part of the record and also
10 hand up to us the errata sheet so that we can - just
11 as we are asking questions based on the copies that
12 we've been using as our working copies, we'll see
13 what the errata are.

14 Does SERI have any objection to our
15 receiving that testimony?

16 MS. SUTTON: No, Your Honor.

17 JUDGE MCDADE: Okay. And it will be
18 part of the record as if it were given here in
19 person by the witnesses. I'd note for the record
20 that we have received affidavits from each of the
21 individuals purporting to give testimony there,
22 indicating that they have made the statements under
23 penalty of perjury and that they attest that the
24 content of those documents is true and correct. And
25 they are received.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433 —

www.nealrgross.com

(Whereupon, the NRC staff's
Pre-Filed Testimony on
Hearing Issues and Errata
were admitted into
evidence.)

JUDGE MCDADE: I would also note that we
also received supplemental pre-filed testimony with
regard to geotechnical issues and concerning various
hydrology issues. Do you also wish that we receive
those into evidence at this time?

MR. RUND: Yes we do, Your Honor.

JUDGE MCDADE: Okay. Are there any
errata with regard to those documents?

MR. RUND: No, there aren't.

JUDGE MCDADE: Okay, and there's no
objection to our receiving the testimony?

MS. SUTTON: No.

JUDGE MCDADE: Okay. We will receive
that testimony as well. We also note that it is
made under oath subject to the penalties of perjury
and it is accepted into the record.

(Whereupon, the NRC staff's
Pre-Filed Testimony on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202)-234-4433

www.nealrgross.com

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)

SYSTEM ENERGY RESOURCES, INC.)

Docket No. 52-009-ESP

(Early Site Permit for Grand Gulf ESP Site))

CORRECTIONS TO THE NRC STAFF'S PREFILED TESTIMONY
ERRATA SHEET

Hearing Issue A

page 8: Replace "As a common engineering practice for determining the potential for a karst formation, the Applicant should search and investigate. . ." with "The Applicant should follow common engineering practice for determining the potential for a karst formation and should search and investigate. . ."

page 11: Replace: "grater" with "greater"

Hearing Issue B

page 3: Add the initials (GB) after "A.4"

Hearing Issue D

page 1: Replace the title: "CONTINUITY BETWEEN THE ESP STAGE AND COL STAGE" with "SLOPE AND FOUNDATION STABILITY"

Hearing Issue F

page 2: Replace "response to Q.5 in the testimony on Hearing Issue I" with "response to Q.3 in the testimony on Hearing Issue I."

page 5: Replace "ML" with "dADAMS Accession Number: ML062650312"

Hearing Issue I

page 6: Replace "Exhibit [I.A.3]" with "Staff Exhibit 10"

page 7: Replace "Exhibit [I.A.4]" with "Staff Exhibit 11"

page 7: Replace "Exhibit [I.A.4]" with "Staff Exhibit 11"

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE A:
SITE CHARACTERIZATION

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. (GB) Goutam Bagchi. I am employed as a Senior Advisor in the Office of Nuclear Reactor Regulation by the U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

A.1. (LV) Lance W. Vail. I am employed as a Senior Research Engineer II with the Hydrology Group at the Department of Energy's Pacific Northwest National Laboratory, operated by Battelle. I am providing testimony under a technical assistance contract with the staff of the U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

A.1. (TC) Thomas M. Cheng. I am employed as a Senior Structural/Geotechnical Engineer in the geosciences and Civil Engineering Branch A (EGCA), Division of Engineering (DE), Office of Reactor Regulation (NRR), NRC. A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit

("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. (GB) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in NUREG-1840, the "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site," April 2006 ("SER"), I reviewed the hydrology aspects of the Applicant's Site Safety Analysis Report. This review included evaluating the adequacy of hydrology-related site characterization data related to surface and subsurface hydrologic processes and the reliability of the safety-related conclusions that SERI made based on this characterization data.

A.2. (LV) As part of the NRC Staff's environmental review of SERI's ESP application, documented in the FSER, I assisted the NRC Staff in its analysis of the aspects of the Applicant's SSAR that concerned hydrology.

A.2. (TC) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in NUREG-1840, the "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"), I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned geotechnical engineering related issues.

TESTIMONY ON EXISTING SITE CHARACTERIZATION DATA

I. Hydrogeologic Characterization

Q.3. In its November 6, 2006, Order, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and discuss the existing site characterization data, and any additional data that will be needed at the COL stage relating to the hydrogeologic characterization of the shallow aquifers in the loess and alluvium and the deeper aquifers of the Catahoula/old alluvium that was used to estimate aquifer yield, water quality, and drawdown conditions for the purpose of (a) demonstrating that an adequately

designed ground water well system capable of withdrawing 3,570 gpm could be provided for the proposed plant(s) without impacting the water quality of the aquifer; and (b) defining construction dewatering requirements, and drawdown effects on existing structural support and lateral loads against finished foundation walls. Please address these issues.

A.3. (LV, GB) The Staff does not specify the specific methodologies or the specific data that an applicant utilizes in preparing an SSAR or an ER. However, the Staff does review the appropriateness of the methodologies and the completeness of the data used by the applicant. Limitations on available site characterization data and lack of specific plant design information may require the Staff to propose Permit Conditions or COL Action Items in the safety review and to not resolve specific issues in the environmental review.

In the Staff's safety review of SERI's ESP application for the Grand Gulf site, one Permit Condition (#2) and nine COL Action Items (2.4-1 through 2.4-9) related to hydrology were proposed by the Staff. In the Staff's environmental review the issue of impacts to the Catahoula aquifer was "unresolved."

The Staff was unable to determine that either the specific isotopes chosen by SERI or the distribution coefficients (K_d) of the chosen isotopes were appropriate. Information on both the chemistry of the radwaste system and the aquifer itself did not preclude the possibility that the radionuclides' mobility might be significantly increased through chemical chelation. Permit Condition #2, which precludes the release from the radwaste system, eliminated the necessity for further characterization information.

If SERI continues to propose to withdraw water from the Catahoula Formation for construction and operation of the ESP facility, the Staff will require further characterization of the Catahoula aquifer. The Staff will review the applicant's proposed aquifer characterization program based on: the location and depth of the proposed wells; the location and depth of existing and proposed subgrade plant structures; and the location and properties of existing and

proposed fill material. Since the construction of subgrade facilities would alter the subsurface environment and, thereby, could alter the geohydrologic characteristics of the Catahoula Formation, the determination of an appropriate aquifer characterization plan requires subgrade design information not available at the ESP stage. At the COL stage, a combination of pump tests, numerical modeling, boreholes, geophysical logging, and chemical characterization of groundwater may be used to develop an adequate understanding of the impacts of pumping on the Catahoula Formation. Since the Catahoula aquifer is designated as a sole-source aquifer by the EPA, the Staff will coordinate the aquifer characterization requirements with the EPA.

Listed below are the existing data supporting subsurface characterization of the ESP site:

1. geologic maps of site area (SSAR Figure 2.5-27)
2. description of regional geologic formations (SSAR Table 2.4-20)
3. hydrogeologic cross sections located in Mississippi River floodplain
(SSAR Figure 2.4-33/UFSAR Figure 2.4-27, SSAR Figure 2.4-36/UFSAR Figure 2.4-28,
and SSAR Figure 2.4-37/UFSAR Figure 2.4-28)
4. chemical analyses results of surface and ground water samples
(SSAR Table 2.4-23/UFSAR Table 2.4-21)
5. water quality sampling data from three ground water wells in the Catahoula formation
that are used to supply water for general site purposes of the existing plant (SSAR Table
2.4-25); sampled water quality parameters include pH, alkalinity, aluminum, chloride,
sulphate, fluoride, free carbon dioxide, iron, magnesium, manganese, calcium, sodium,
potassium, zinc, total dissolved residue, and hardness
6. ground water levels measured in piezometers (SSAR Table 2.4-30/UFSAR
Table 2.4-24; two piezometers in alluvium, five in terrace deposits, and eight in the
Catahoula formation), in observation wells (SSAR Table 2.4-31/UFSAR Table 2.4-25), in

- monitoring wells (SSAR Table 2.4-32/UFSAR Table 2.4-29), and in on-site wells (SSAR Table 2.4-33); hydrographs of piezometers and wells (SSAR Figure 2.4-39/UFSAR Table 2.4-32), construction observation wells (SSAR Figure 2.4-44/UFSAR Figure 2.4-36), and replacement observation wells (SSAR Figure 2.4-45/UFSAR Figure 2.4-36), and
7. location of perched water zones (SSAR Figure 2.4-33/UFSAR Figure 2.4-27)
 8. hydrogeologic properties of subsurface material (SSAR Table 2.4-34/UFSAR Table 2.4-26; hydraulic conductivity measured using pumping tests in seven wells in the terrace deposits, using variable head permeability tests in three wells in the terrace deposits and one in the Catahoula formation, and using laboratory consolidation tests at five locations in the Catahoula formation and two in the alluvium); hydraulic conductivity and transmissivity of the terrace deposits (SSAR Table 2.4-35/UFSAR Table 2.4-26a; 22 wells)
 9. projected ground water level contours under 8000 gpm of continuous pumping from all six radial collector wells (SSAR Figure 2.4-55/UFSAR Figure 2.4-44) -- only four of the radial collector wells were constructed for GGNS
 10. USGS water quality data for the Mississippi River at Vicksburg 1961 to 1999 (URL: http://nwis.waterdata.usgs.gov/nwis/qwdata?site_no=07289000)

Only limited site characterization data was obtained recently by the Applicant (items 1, 2, 5, and part of 6 (ground water levels in on-site wells), listed above). All other items listed above, except for item 10, were reported in the GGNS UFSAR.

GGNS UFSAR Figure 2.4-27 shows the locations of radial collector wells. The Applicant reported results from pumping tests conducted in collector wells # 3 and # 5. These were long term pumping tests lasting 134 days from August through December, 1979. The average pumping rates for these two collector wells were 8000 gpm and 7600 gpm, respectively. The

collector wells were installed to draw water indirectly from the Mississippi River through the alluvium.

Three wells that draw water from the Catahoula formation are used to provide water for general site purposes of the existing plant. These wells are rated at 513, 535, and 577 gpm, respectively.

The Staff reviewed the existing data to determine the groundwater characteristics near the ESP site. The radial collector wells can sustain pumping rates in excess of 7600 gpm for a sustained duration; the wells finished in the Catahoula formation can sustain pumping rates in excess of 500 gpm. Based on the available groundwater characterization data, the Staff determined that it is not unreasonable to expect that a suitable system of groundwater wells can be designed to extract water at a maximum rate of 3570 gpm from the Catahoula formation. The design of the groundwater well system will depend on the specific plant design chosen by the COL applicant and the layout of the plant infrastructure. The Staff will review the adequacy of the groundwater well system design at the COL stage, using appropriate NRC regulations and regulatory guidance.

The Applicant stated that dewatering will be required during construction of the ESP facility. The effects of any dewatering during construction of the ESP facility on existing structures will be reviewed at the COL stage under the requirements of 10 CFR Part 50 and 10 CFR Part 52. There are many engineered solutions to resolve specific conditions that can arise during the construction process; the Applicant has proposed a tried method of dewatering during construction. However, limited use of sheet piling, injection grouting, etc. can resolve construction circumstances in the future. Nevertheless, the maximum withdrawal rate is short-term and the safety-related SSCs of the existing plant are distant from the ESP site boundary. Therefore, it is expected that the potential for affecting the structural integrity of the safety-related SSCs of the existing plant from ground subsidence due to any dewatering activity at the

ESP site would be temporary and minimal. The Applicant stated that inspection and monitoring procedures will be developed for the construction phase of the ESP facility. Observation wells would be installed and monitored periodically throughout the construction of the ESP facility to measure ground water levels and to verify that ground water drawdown and the radius of influence evolve as predicted. The Staff concluded that it is feasible to conduct construction activities in a completely safe manner at the proposed ESP site and the site does not have any intrinsic characteristics that preclude its choice as a suitable site for locating future reactor or reactors, should a permit be granted. A dewatering system can be designed such that its effects on existing structures and systems are minimized, and existing regulatory criteria and review guidance will ensure a completely adequate review at the COL stage.

II. Fill Material Characterization

Q.4. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and discuss the existing site characterization data, and any additional data that will be needed at the COL stage relating to the characterization of the existing fill material for foundation design and to define construction conditions. Please address these issues.

A.4. (TC) The existing fill materials are located at an elevation approximately 130 ft (at planned plant grade) and were placed over time in an uncontrolled condition.¹ Therefore, there is no significant information on the strength and stiffness properties of the material, grain size distribution, and expected behavior under design load conditions. However, since the plant grade will be located at a depth of about 132.5 ft MSL, this fill material will have a negligible impact on the design of the facility. According to the Applicant's response to RAI 2.5.4-11, this

¹ An uncontrolled condition exists where the engineering properties do not need to be reasonably estimated.

fill material will be removed during plant construction and, where needed, new fill material will be placed under controlled conditions. Some minor impacts on construction may occur, although the Staff believes that any such impacts will be negligible.

III. Characterization Relating to Potential Karst Formation

Q.5. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and discuss the existing site characterization data, and any additional data that will be needed at the COL stage relating to deep explorations in the power block footprint to evaluate the potential for a karst formation. Please address these issues.

A.5. (TC) The issue of the potential for development of sinkholes, dissolution cavities or soft zones in calcareous clays and limestone below any nuclear sites, including the Grand Gulf site, needs to be evaluated. If such soft zones or voids exist in the soil/rock profile below the site, the potential for the collapse of these zones during and following a seismic event can lead to differential settlements of power block foundations and at the ground surface. Such effects are of serious concern at other sites housing critical facilities.

The geotechnical report, ER-02, indicates that materials below the plant are calcareous and therefore potentially susceptible to the effects of dissolution. The Staff believes that it is, however, most likely inappropriate to use deep borings or other such penetrations to investigate this potential at the Grand Gulf site. First, the fact that such penetrations do not encounter such a soft zone does not imply that such zones do not exist. Second, the number and spacing of such penetrations will depend on the estimated size of these features. The Applicant should follow common engineering practice for determining the potential for a karst formation and should search and investigate the available database of information for the known site materials, and determine the opinions of recognized geologic experts versed in the area. This

data would then be provided to the Staff. The Staff would also perform a chemical evaluation of available soil samples to support any of the conclusions drawn from the Applicant's study of the database. These evaluations should be performed prior to planning any deep boring program. During the COL stage, the Applicant will perform additional borings and laboratory testing as committed in the response to RAI 2.5.4-3. SER at 2-233. The Applicant's field exploration information and test results will be available to the Staff during its review of the COL Application.

IV. Characterization Relating to Effect of River Flooding on Bluff

Q.6. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and discuss the existing site characterization data, and any additional data that will be needed at the COL stage relating to the effect of river flooding on future erosion of the bluff and any retrogressive sloughs of the bluff. Please address these issues.

A.6. (TC, GB) The Staff notes that the levee systems and the revetments built on the banks of the Mississippi river by the Corps of Engineers focus on flooding on the west bank; on the east bank, protection is provided by revetments, which limit any erosion of the bank. The proposed ESP site is located on the east bank of the Mississippi River at an elevation of approximately 132.5 ft MSL. The ESP site is not subject to any significant flooding from the Mississippi River. The levees on the west bank of the river near the ESP site have a crest elevation between 101 and 103 ft MSL. If a future river flood overtops the levees on the west bank, the ESP site will still be above the river flood water elevation. During floods, the Mississippi River overtops the revetments on the east bank and flows through the floodplain located to the west of the bluffs. The Staff, in consultation with the U.S. Army Corps of Engineers, determined during its review of the design basis flood in the Mississippi River that the static flood water surface elevation would not be substantially greater than 103 ft MSL near

the GGNS site because of the large discharge capacity of the Mississippi River floodplain west of the levees. The bluff on the east bank, adjacent to the ESP site, is not protected from erosion from river flooding by engineered revetments. The bluff on the west of the ESP site area steeply falls from an approximate elevation of 160 ft MSL to 90 ft MSL. The bluff west of the foot of this steep portion then gradually slopes towards Gin and Hamilton Lakes. During the design basis flood, the static flood water surface elevation of 103 ft MSL will result in the inundation of the gradually sloping portion of the bluff and a smaller extent of the steeply sloping portion of the bluff.

(TC) The response to this question dealing with retrogressive sloughing is provided in the response to Hearing Issue D Question 7.

V. Mississippi River Sediment Characterization

Q.7. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and discuss the existing site characterization data, and any additional data that will be needed at the COL stage relating to Mississippi River sediment characterization for construction of the intake and discharge structures and operation of the water intake and treatment plant. Please address these issues.

A.7. (GB, TC) The Mississippi River intake and the discharge for the proposed ESP site are related to the normal operation of the plant, so they are not safety-related. The applicant has proposed the construction of a cooling tower with a water storage underneath, should there be a need for a water cooled ultimate heat sink. The Staff determined that it is not necessary to characterize the sediment deposition rate or associated data for the COL application. The Staff also determined that the Mississippi River is deep and has a very high continuous flow rate to allow the applicant to design a well engineered and satisfactory intake and discharge system for the normal cooling of a future plant.

VI. Characterization of the Loess

Q.8. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and discuss the existing site characterization data, and any additional data that will be needed at the COL stage relating to shear strength and creep characteristics of the loess for retrogressive slope deformations of the bluff that might impact the integrity of the proposed plant(s). Please address these issues.

A.8. (TC) The loess formation is an extensive formation that exists over large areas in this region of the country. The generic properties of the loess formation have been developed and studied for many years and a large database of information has been compiled. According to its response to RAI 2.5.4-11, the Applicant committed to locate the power block foundation on stiff and compact materials that are located well below the loess materials. SER at 2-243. The Applicant also noted that it modified the ESP site plan to restrict the location of the proposed power block area (PPBA) to a distance greater than 100 ft from the bluff area on the west side of the site. The Staff believes that the Applicant's commitment will eliminate the significant impacts of the loess material on the design of the plant structures.

VII. Surface and Ground Water Characterization

Q.9. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and discuss the existing site characterization data, and any additional data that will be needed at the COL stage relating to baseline surface and ground water quality to quantify potential impacts for the existing plant to assure sufficient data is available to discriminate between the existing plant and the proposed plant(s). Please address these issues.

A.9. (GB) Data available for characterization of the subsurface at and near the ESP site is discussed in response to Board's Hearing Issue A, Question 3. Data that would be needed in the future depend upon the monitoring system that will be put in place. The system selected would depend upon many different factors such as: the reactor, the design of its radwaste facility, radioisotope inventory, etc. The Staff believes that it would be speculative to make a list of any additional data that will be needed at the COL stage.

With regard to radiation levels in surface and ground water at and near the ESP site that may impact the existing plant, the Staff concluded that there will be no impact on the existing GGNS plant from accidental releases from the ESP facility. The Staff's proposed Permit Condition 2 requires that the ESP facility be designed such that any and all accidental releases of radionuclides into any potential liquid pathway are precluded. An overwhelming majority of evolutionary and advanced reactor designs employ the concept of a nuclear island or a power block that is buried into the ground at a depth of approximately 40 ft to 60 ft. In some advanced designs the radwaste facility is located on the nuclear island, which is protected from leakage by a stainless steel liner and leakage collection drains. The radwaste tank is also protected by high surrounding walls to contain any inadvertent spillage during radwaste handling or any unanticipated component failure. The Staff concluded that it is technically feasible to design engineered barriers and other hydraulic conditions to meet the requirements of Permit Condition 2.

With respect to normal releases, the Staff reviewed the Grand Gulf radiological environmental monitoring program (REMP). The requirements for the REMP are in 10 CFR 50.34a(a); 10 CFR 50.36a(a); SEC IV, B.2 of Appendix I in 10 CFR Part 50 and the REMP for the operating unit has been reviewed and approved by NRC Staff. Environmental monitoring has been performed around the Grand Gulf site since 1978. The REMP includes monitoring of the airborne exposure pathway, direct exposure pathway, water exposure

pathway, aquatic exposure pathway with control and indicator locations within a 29 km (18 mi) radius of the site. The pre-operational program included collection and analysis of samples of air particulates, precipitation, milk, crops, soil, well water, surface water, fish, and silt as well as measurement of ambient gamma radiation.

Related to surface and groundwater sampling, three surface water samples are taken, one upstream, one downstream and one downstream during a Liquid Radwaste Discharge. The surface water samples are taken at 92 day intervals and a gamma isotropic and tritium analysis are performed. The groundwater sample is taken at two wells once a year and a gamma isotropic and tritium analysis are also performed. Review of data from 2002 and 2003 showed no results above the lower limit of detection (LLD).

VIII. Aquifer Characterization

Q.10. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and discuss the existing site characterization data, and any additional data that will be needed at the COL stage relating to subsurface hydrological and chemical properties of the aquifer and definition of composition of the radwaste effluent. Please address these issues.

A.10. (GB) There is only limited data available regarding hydrological and chemical properties of the subsurface at and near the ESP site. At the ESP stage, the reactor type for the proposed facility has not been finalized and therefore the composition of the liquid radwaste effluent is not known.

The Staff's proposed Permit Condition 2 requires the ESP facility to be designed in such a way that any and all accidental releases of radionuclides are precluded. The Staff's proposed COL Action Item 2.4-9 addresses the need to obtain detailed groundwater characterization for dewatering system design.

The Staff requested that the Applicant provide more detailed data so the Staff could understand all the ground water pathways from points of release to the accessible environment. The Staff also requested that the applicant provide the chemical properties of the subsurface environment, since the mobility of radionuclides in the subsurface depends on the chemical properties of the subsurface media. Based on the Applicant's response, the Staff determined that, at the ESP stage, due to the incomplete characterization of subsurface hydrological and chemical properties in addition to the unknown composition of the liquid radwaste effluent of the proposed ESP facility, a comprehensive radionuclide migration analysis cannot be performed. The Staff determined that the proposed ESP site does not have any unique characteristics that could make a suitable system for monitoring or arresting radionuclide transmission through liquid pathway technically infeasible. The Staff imposed Permit Condition 2 to ensure that effective measures can be put in place during the COL stage. The Staff concluded, therefore, that further characterization of the composition of the liquid radwaste effluent and that of the subsurface hydrological and chemical properties was not needed, provided that Permit Condition 2 is not violated. As discussed in the Staff's response to the Board's Hearing Issue A, Question 9, the Staff concluded that it is technically feasible to design engineered barriers and other hydraulic conditions to meet the requirements of Permit Condition 2.

TESTIMONY ON LONG TERM STABILITY OF THE BLUFF

Q.11. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and explain the factual record concerning the long term stability of the bluff and its potential impact on the integrity of the proposed plant(s). Please address these issues.

A.11. (TC) The long term stability of the bluff can impact the evaluation of the plant design from several points of view. From a static perspective, the erosion of the bluff will reduce

confining pressures on soils underneath the toe of the foundation mat at the edge adjacent to the bluff. This reduction in confinement can reduce strength and stiffness of the toe soils needed to provide gross seismic overturning and sliding capacity for the plant. In response to RAI 2.4.5-11, the Applicant made a commitment to locate the foundation of seismic Category I structures at a depth where the minimum shear wave velocity is 1000 fps. SER at 2-236, A-17. Adherence to the minimum shear wave velocity would ensure that the foundation will be at a depth of between 120 and 140 ft below grade. Consequently, concerns related to seismic overturning and sliding will be resolved by such a deeply embedded foundation.

The impacts of erosion of the bluff on calculated seismic responses of the plant are more difficult to evaluate, since there is little to no experience with seismic response calculations for unbalanced site configurations. (All the current techniques used for seismic analyses are based on the assumption of uniform or balanced site conditions on all sides of the plant facility.) This behavior can potentially impact the computation of both seismic-induced element stresses (and therefore estimates of resulting demand/capacity ratios of structural plant elements) and the computation of in-structure floor response spectra.

**TESTIMONY ON SUBSURFACE HYDROLOGICAL AND
CHEMICAL PROPERTIES OF THE AQUIFER**

Q.12. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the site characterization, the Board asked that the NRC Staff summarize and explain the factual record concerning the sufficient knowledge of the subsurface hydrological and chemical properties of the aquifer and composition of the radwaste effluent to meet 10 C.F.R. § 100.20(c)(3) requirements for site suitability determination factors relating to accidental releases to the liquid pathway. Please address these issues.

A.12. (GB) Data available for characterization of the subsurface at and near the ESP site is discussed in response to Board's Hearing Issue A, Question 3.

There is only limited data available regarding hydrological and chemical properties of the subsurface at and near the ESP site. At the ESP stage, the reactor type for the proposed facility has not been finalized and therefore the composition of the liquid radwaste effluent is not known.

The Staff's proposed Permit Condition 2 requires the ESP facility to be designed in such a way that any and all accidental releases of radionuclides are precluded. The Staff's proposed COL Action Item 2.4-9 addresses the need to obtain detailed groundwater characterization for dewatering system design.

10 CFR Part 100.20(c)(3) requires that factors important to hydrological radionuclide transport be obtained from on-site measurements. These factors include subsurface soil characteristics, hydrological conditions, and pathways.

The Staff requested that the Applicant provide more detailed data so the Staff could understand all the ground water pathways from points of release to the accessible environment. However, the subsurface at the ESP site will be substantially disturbed during construction of the ESP facility. A COL recipient referencing a Grand Gulf ESP may be required to use an engineered fill to finish the grade at the ESP site. Underground portions of structures constructed as part of the ESP facility will act as barriers to regional groundwater flow and thus will modify flow pathways. The Staff concluded that a more useful and comprehensive analysis of subsurface pathways can only be carried out at the COL stage when the plant design including location and layout of ESP facility structures are known.

The Staff also requested that the Applicant provide chemical properties of the subsurface environment since the mobility of radionuclides in the subsurface depend on the chemical properties of the subsurface media. Based on the Applicant's response, the Staff

determined that, at the ESP stage, due to the incomplete characterization of subsurface hydrological and chemical properties and the unknown composition of the liquid radwaste effluent of the proposed ESP facility, a comprehensive radionuclide migration analysis cannot be undertaken. The Staff determined that the proposed ESP site does not have any unique characteristic that could make a suitable system for monitoring or arresting radionuclide transmission through liquid pathways technically infeasible. The Staff imposed Permit Condition 2 to ensure that effective measures can be put in place during the COL phase. The Staff concluded, therefore, that further characterization of the composition of the liquid radwaste effluent and that of the subsurface hydrological and chemical properties was not needed provided that Permit Condition 2 is not violated. As discussed in the Staff's response to the Board's Hearing Issue A, Question 9, the Staff concluded that it is technically feasible to design engineered barriers and other hydraulic conditions to meet the requirements of Permit Condition 2.

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)
)
SYSTEM ENERGY RESOURCES, INC.) Docket No. 52-009-ESP
)
(Early Site Permit for Grand Gulf ESP Site))

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE B:
MONITORABILITY OF INADVERTENT RADIOLOGICAL RELEASES

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. (GB) Goutam Bagchi. I am employed as a Senior Advisor in the Division of Engineering, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission. A statement of my professional qualifications is attached.

A.1. (SK) Stephen Klementowicz. I am employed as a Senior Health Physicist in the Division of License Renewal, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission. A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit ("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. (GB) As part of the NRC staff's health and safety review of the SERI ESP application, documented in NUREG-1840, the "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"), I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned hydrology.

A.2. (SK) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in the Grand Gulf Site SER, I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned the radioactive waste treatment system and the radiological impacts from routine operation to plant workers and members of the public. I was also part of the NRC Staff's environmental review of the SERI ESP application, documented in NUREG-1817, "Environmental Impact Statement for an Early Site Permit (ESP) at the Grand Gulf ESP Site: Final Report," April 2006 ("FEIS"). I reviewed the aspects of the Applicant's Environmental Report that concerned the radioactive waste treatment system and the radiological impacts from routine operation to plant workers, members of the public, and to the environment.

Q.3. In its November 6, 2006, Order, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the monitorability of inadvertent radiological releases, the Board stated its opinion that the suitability of the Grand Gulf site for the eventual construction of an additional plant(s) hinges, in part, on SERI's ability (1) to detect discharges from plant systems, structures, and components that have a potential for the inadvertent release of radioactivity into the site soils or into the surface and ground water, and (2) to determine whether future detections of radiation are the result of historic impacts from the existing facility, or are the result of new contamination from the proposed plant(s). Please address this statement.

A.3. (GB) A number of NRC regulations and guidance documents address monitoring of radioactive material in effluents from nuclear power reactors.¹

¹ 10 CFR Part 20, Standards for Protection Against Radiation; 10 CFR 50.34a, Design objectives for equipment to control releases of radioactive material in effluents - nuclear power reactors; 10 CFR 50.36a, Technical specifications on effluents from nuclear power reactors; 10 CFR 50.72, Immediate notification requirements for operating nuclear power reactors; 10 CFR 50.73, Licensee event report system; 10 CFR Part 50, Appendix A, Design Criterion 60, Control of Releases of Radioactive Materials to the Environment; 10 CFR Part 50, Appendix A, Design Criterion 64, Monitoring Radioactivity
(continued...)

As stated in responses to the Board's Hearing Issue A, Questions 9 and 10, accidental releases of radionuclides from the ESP facility are precluded by Permit Condition 2. The Staff concluded that it is technically feasible to design engineered barriers and other hydraulic conditions to meet the requirements of Permit Condition 2. Accordingly, monitoring of inadvertent radiological releases is not required or warranted.

Q.4. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the monitorability of inadvertent radiological releases, the Board asked that the Staff address site monitorability relating to surface water, ground water, and shallow soil impacts and sediments by presenting the existing knowledge base with detailed descriptions of the exploration program, aquifer testing, hydraulic modeling, and transport estimates used to characterize the site aquifer(s), and surface water courses. Please address these issues.

A.4. (GB) At the ESP stage, when the details of the reactor design, construction, and operating processes are not known, it is speculative and generally unproductive to investigate monitorability of the proposed ESP site. NRC's regulatory criteria and guidelines are in place to

¹(...continued)

Releases; 10 CFR Part 50, Appendix I, Numerical Guides for Design Objectives and Limiting Conditions for Operation to Meet the Criterion "As Low As Is Reasonably Achievable" for Radioactive Material in Light-Water-Cooled Nuclear Power Reactor Effluents; 40 FR 19439 (May 5, 1975; an immediately effective rule, using the terminology "as low as practicable"); Regulatory Guide 1.109, Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I (Rev. 1, 10/75); Regulatory Guide 1.21, Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants (Rev. 1, 6/74); Regulatory Guide 1.143, Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants (Rev. 2, 11/01); Regulatory Guide 4.1, Programs for Monitoring Radioactivity in the Environs of Nuclear Power Plants (1/73); Regulatory Guide 4.2, Preparation of Environmental Reports for Nuclear Power Stations (Rev. 2, 7/76); Regulatory Guide 4.8, Environmental Technical Specifications for Nuclear Power Plants (12/75) and Branch Technical Position (Rev. 1, 11/79, specific to environmental monitoring program); Regulatory Guide 4.15, Quality Assurance for Radiological Monitoring Program (Normal Operation) - Effluent Streams and the Environment; NUREG-0472, Radiological Effluent Technical Specifications for PWRs (2/80); NUREG-0473, Radiological Effluent Technical Specifications for BWRs (7/79).

ensure that a future COL review will require a full description of radioactive effluent monitoring systems and associated technical specification limits.

With regard to radioactive releases in ground water, it should be noted that the ESP site has a deep soil deposit. Consequently, the monitoring wells may need to be deep. On the other hand, predominantly clay soil at the site provides an advantage of relative impermeability.

Q.5. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the monitorability of inadvertent radiological releases, the Board asked that the Staff address site monitorability relating to surface water, ground water, and shallow soil impacts and sediments by describing and illustrating the extent of the existing radiological concentrations in the soil, sediment, surface water and ground water at the site, and the monitoring program used to quantify existing impacts. Please address these issues.

A.5. (SK) In addressing surface and groundwater radiologic impacts, the Staff relied on information from the radiological environmental monitoring program (REMP) currently in place at the Grand Gulf Nuclear Station. The REMP monitors the offsite environment outside the plant site. The NRC's requirements contained in Appendix A to 10 CFR Part 50, Criterion 64 - "Monitoring radioactivity releases," and its regulatory guidance in Branch Technical Position, Revision 1 (ML010710060), focus on the offsite environmental monitoring of soil, sediment, surface water, and ground water. However, the REMP does not focus on environmental monitoring within the plant site. The NRC requires that the REMP monitor the general offsite environment for the presence of radioactive material from the operating nuclear reactor. NRC's guidance describes the specified environmental monitoring program, which provides measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides that lead to the highest potential radiation exposure of individuals resulting from the station operation. Thus, there is no NRC requirement to have data for

radiological ground water or soil conditions at the site. The Staff did not receive any data in the SERI application on radiological conditions at the site.

Q.6. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the monitorability of inadvertent radiological releases, the Board asked that the Staff address site monitorability relating to surface water, ground water, and shallow soil impacts and sediments by summarizing meteorological, geologic, and hydrogeologic data that can be used to estimate migration pathways for future impacts from plant(s) at the site. Please address these issues.

A.6. (GB) The Staff has summarized the hydrologic characteristics of the ESP site in its response to the Board's Hearing Issue A, Question 3. As noted in the Staff's answer to Question 4 above, data available at the ESP stage do not allow a reliable estimate of migration pathways for future impacts from plant(s) at the site, since the reactor type, liquid radwaste inventory, location of radwaste facility, extent of site modification due to construction activities, and the extent of the use of engineered backfill are unknown. Permit Condition 2 precludes the inadvertent radiological releases to which this Board question refers and is sufficient to ensure that necessary and appropriate review will be undertaken at the time of the COL review.

Q.7. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the monitorability of inadvertent radiological releases, the Board asked that the Staff address site monitorability relating to surface water, ground water, and shallow soil impacts and sediments by explaining how the impact from a hypothetical release from the new plant could be separated from the historic impacts, and, as a corollary, if a future radiological release was detected, how it would be possible to determine which plant was the source of the impact. Please address these issues.

A.7. (SK) Hypothetical inadvertent radiological releases from the proposed new plant could be separated from historic impacts through a program of radiological surveys and specialized monitoring. The surveys and monitoring would have to trace the pathway of the residual radioactivity back to the source of the discharge in order to establish which plant was the source of the impact. As a practical matter, the NRC has experience with licensees who have performed such detailed, extensive surveys and monitoring of inadvertent liquid discharges at operating nuclear power reactor sites. However, as discussed in the Staff's response to Question 5, there are no NRC requirements to have such a detailed onsite monitoring program in order to detect inadvertent discharges. This is in contrast to routine radiological effluent discharges into the unrestricted area (public area). There is a requirement in Appendix A to 10 CFR Part 50, Criterion 64 - "Monitoring radioactivity releases," to monitor effluent discharge paths, and there is detailed regulatory guidance on the appropriate location, type, and sensitivity of monitoring equipment to be used. In addition, there is a requirement in 10 CFR 50.36a to submit an annual report that specifies the quantity of each of the principal radionuclides released to unrestricted areas in liquid and gaseous effluents. However, the regulation does not require the data to be reactor specific. As a matter of practice, licensees do a best effort to apportion the radioactive effluents to each reactor unit.

The NRC would not eliminate this site from future consideration because of the lack of a proposed radiological survey and monitoring program to monitor the onsite environment from potential inadvertent releases of radioactive material, because existing NRC requirements and guidance do not require such a program.

Q.8. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the monitorability of inadvertent radiological releases, the Board asked that the Staff address site monitorability relating to surface water, ground water, and shallow soil impacts and sediments by describing

the reasons why the potential un-monitorability of the site would or would not possibly eliminate this site from future consideration for a new plant.

A.8. (GB) The Staff imposed Permit Condition 2 to ensure that effective measures for precluding releases will be put in place during the COL phase. The Staff concluded, therefore, that further characterization of the composition of the radwaste effluent and that of the subsurface hydrological and chemical properties was not needed. As discussed in the Staff's response to the Board's Hearing Issue A, Question 9, the Staff concluded that it is technically feasible to design engineered barriers and other hydraulic conditions to meet the requirements of Permit Condition 2.

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE C:
SEISMIC IMPACTS

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. Yong Li (YL). I am employed as a Senior Geophysicist in the Division of Engineering, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit ("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. (YL) As part of the NRC staff's health and safety review of the SERI ESP application, documented in NUREG-1840, "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"), I reviewed the aspects of the Applicant's Site Safety Analysis Report ("SSAR") that concerned geology and seismology.

Q.3. In its November 6, 2006, Order, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to seismic impacts, the Board asked for a summary and discussion of the process that was utilized by the NRC staff to evaluate seismicity at the Grand Gulf site, including the specific steps used to evaluate the relevance, precision, and accuracy of analytical and digital models. Please address these issues.

A.3. (YL)

Regional and Site Geology

The Applicant described the regional geology, including the physiography, geological provinces, geologic history, stratigraphy, tectonic settings, and seismicity of the site region. SER at 2-144. The Applicant described these items in detail, including the geologic periods (era) in which they formed. SER at 2-144 through 2-159. The Applicant discussed each of the following seismic source zones and associated seismic activities surrounding the ESP site:

- Appalachian Mountains
- Ouachita Orogenic Belt
- Arkoma and Black Warrior Basins
- Reelfoot Rift
- New Madrid Seismic Zone (NMSZ)
- Gulf Coast Basin
- Pickens-Gilberttown and Southern Arkansas Fault Zones
- Saline River Source Zone (SRSZ)
- nontectonic structural features

The applicant fully considered the NMSZ in its investigation process because the NMSZ can contribute to the seismic hazard at the site, even though it is outside the 320 kilometer (200 mile) radius recommended by RG 1.165. SER at 2-151 through 2-159.

The Staff evaluated the geological and seismological information submitted by the Applicant in SSAR Section 2.5.1. as follows: The technical information presented in Section 2.5.1 of the application (SSAR) resulted from the Applicant's surface and subsurface geological and seismological investigations performed in progressively greater detail as these

investigations approached the site. SER at 2-162. Through its review, the Staff determined whether the Applicant complied with the applicable regulations and conducted its investigations with an appropriate level of thoroughness, as required by 10 C.F.R. § 100.23. SER at 2-162. SSAR Section 2.5.1 contains the geologic and seismic information gathered by the Applicant in support of the vibratory ground motion analysis; site SSE spectrum is provided in SSAR Section 2.5.2. SER at 2-163.

According to RG 1.165, applicants may develop the vibratory design ground motion for a new nuclear power plant using either the Electric Power Research Institute ("EPRI") or Lawrence Livermore National Laboratory ("LLNL") seismic source models for the Central and Eastern United States ("CEUS"). SER at 2-163. However, RG 1.165 recommends that applicants update the geological, seismological, and geophysical database and evaluate any new data to determine whether revisions to the EPRI or LLNL seismic source models are necessary. SER at 2-163. As a result, the Staff focused its review on geologic and seismic data published since the late 1980s that could indicate a need for changes to the EPRI or LLNL seismic source models. SER at 2-163. To thoroughly evaluate the geological and seismological information presented by the Applicant, the Staff obtained the assistance of the USGS.¹ SER at 2-163. In addition, the Staff and its USGS advisors visited the ESP site and surrounding area to evaluate and confirm the interpretations, assumptions, and conclusions presented by the Applicant concerning potential geologic and seismic hazards. SER at 2-163.

The Staff's review focused on the Applicant's characterization of the regional and local geologic structure and seismic potential. SER at 2-163. The Staff considered the Applicant's descriptions of physiographic provinces within the site region, the Mississippi embayment and

¹ One of the staff members from USGS was the key person to study and compile a database for Quaternary faults, liquefaction features and possible tectonic features in the CEUS, east of the Rock Mountain Front.

Gulf Coast Basin, tectonic evolution for major geologic features, and the stratigraphy of the site region. SER at 2-163. The Staff determined that these descriptions reflect well-documented geologic information, and concluded that they provide a relevant, accurate and thorough description of the regional site geology. SER at 2-163. Similarly, the Staff reviewed the Applicant's characterization of the tectonic features in the EPRI seismic source model from the late 1980's, focusing on two seismic zones: SRSZ and NMSZ. SER at 2-163. With the addition of these sources to the site seismic hazards estimate, which only enhanced the conservative estimate of ground motions for the ESP site, the Staff found that the Applicant accurately characterized the tectonic features and their correlations with the regional seismicity. SER at 2-164. Finally, the Staff considered a seismic catalog, which the Applicant revised in response to a Staff question, and determined that the Applicant had provided an accurate and thorough description of the regional seismicity. SER at 2-164.

With respect to site geology, the Applicant described the geologic information of both the site area (within an 8 kilometer radius [5 miles]) and the site location (within a 1 kilometer radius [~0.6 miles]) in terms of the (1) site physiography and geomorphology, (2) site geologic history, (3) site geologic conditions, (4) site structure, and (5) geotechnical properties of subsurface materials. SER at 2-159. The Applicant described these matters in detail. SER at 2-159 through 2-162. The Applicant did not identify any faults within the 8-kilometer radius of the site area. SER at 2-161.

The Staff found that the Applicant provided a thorough and accurate description of the surface features and characteristics for the ESP site. SER at 2-164. The Staff also found that the Applicant provided an accurate and thorough description of the site area stratigraphy, with emphasis on the younger layers of rock and soils. SER at 2-165. The Staff therefore found that the Applicant's description of the geological structures was complete and accurate. SER at 2-165. Nonetheless, the Staff stated that, based on RG 1.132, any excavation made during

construction will provide an opportunity to obtain additional geologic and geotechnical data. SER at 2-165. Therefore, the Staff found that the Applicant must perform geologic mapping of future excavation for safety-related structures, evaluate any unforeseen geologic features that are encountered, and notify the NRC no later than 30 days before any excavations for safety-related structures are opened. This is Permit Condition 3. SER at 2-165. In addition, the Staff also proposed COL Action Items 2.5-3 and 2.5-4 (Appendix A, A5). COL Action Item 2.5-3 requires the applicant to perform additional borings to confirm the current base case material properties and their variabilities throughout the site. COL Action Item 2.5-4 requires the applicant to provide information to correlate plot plans and profiles of each category I structure with subsurface profiles and materials properties to ascertain the sufficiency of selected borings to represent soil variations under each structure. Finally, the Staff found that the effects of human activity (e.g., ground water withdrawal or mining activity) have no potential to compromise the safety of the site. SER at 2-165.

Based on the facts and reasoning set forth above, the Staff concluded that the Applicant properly characterized the site lithology, stratigraphy, geological history, structural geology, and the characteristics of subsurface soils and rocks. SER at 2-165. Accordingly, the Staff concluded that the Applicant identified and appropriately characterized all the significant seismic sources for determining the safe-shutdown earthquake ("SSE") for the ESP site, in accordance with RG 1.165 and Section 2.5.1 of NUREG-0800, and therefore satisfied the associated requirements of 10 C.F.R. § 100.23(c) and GDC 2. Therefore, the Staff concluded that the proposed ESP site is acceptable from a geological and seismological standpoint and meets the requirements of 10 C.F.R. § 100.23. SER at 2-165.

Vibratory Ground Motion

The Applicant described the regional and local geology and structural background and outlined the major seismotectonic sources and materials in the site region. SER at 2-165. The Applicant described: (1) its determination of the ground motions at the ESP site resulting from possible earthquakes inside or outside the site region; (2) the characteristics of seismic sources used in the ESP site seismic hazard calculation; (3) the procedure for the probabilistic seismic hazard analysis ("PSHA") and its results; (4) site characteristics in seismic wave transmission; and (5) site responses at the ESP site. SER at 2-166. The Applicant then summarized the development of the SSE and operating-basis earthquake (OBE) ground motion for the ESP site. SER at 2-166.

With respect to seismic source characterization, the Applicant described the characteristics of all seismic sources in the ESP site region. SER at 2-166. The Applicant reviewed the original 1986 EPRI earthquake source model related to the ESP site and found that the model adequately captures the regional earthquake source characteristics and the uncertainty associated with the source model at the time the model was developed. SER at 2-166. The Applicant also addressed the SRSZ and updated NMSZ and their associated parameters resulting from the recent studies. SER at 2-166. The Applicant summarized the EPRI seismic source model, and the seismic source information for the seismic sources in the site region. SER at 2-166. This source information includes the maximum magnitude, closest distance to the ESP site, probability of activity, and an indication as to whether new information regarding the seismic source has been identified since the original EPRI seismic hazard analysis. SER at 2-166, 2-167. The Applicant presented detailed characterizations of the NMSZ and the SRSZ. SER at 2-167, 2-168. Finally, the Applicant described the effect of updating the earthquake catalog on the EPRI-Seismicity Owners Group ("SOG") seismicity parameters. SER at 2-169, 2-170.

In its review, the Staff considered the regulatory requirements of 10 C.F.R. § 52.17(a)(1)(vi) and 10 C.F.R. § 100.23(c) and (d), which require that an applicant for an ESP describe the seismic and geologic characteristics of the proposed site. SER at 2-180. In particular, 10 C.F.R. § 100.23(c) requires that an ESP applicant investigate the geological, seismological, and engineering characteristics of the proposed site and its environs with sufficient scope and detail to support estimates of the SSE and to permit adequate engineering solutions to actual or potential geologic and seismic effects at the proposed site. SER at 2-180. Section 100.23(d) states that the SSE for a site is characterized by both horizontal and vertical free-field ground motion response spectra at the free ground surface. Section 2.5.2 of NUREG-0800 provides guidance concerning the evaluation of the proposed SSE, and RG 1.165 provides guidance regarding the use of PSHA to address the uncertainties inherent in estimating ground motion at the ESP site.

First, the Staff found that the Applicant adequately characterized the overall seismic sources at the ESP site. SER at 2-183. The Staff also concluded that the Applicant's descriptions of the NMSZ and the SRSZ are accurate and sufficient to address the need for updated EPRI sources and to calculate the SSE for the ESP site. SER at 2-183. In addition, the Staff concurred with the Applicant's decision to use the original EPRI seismicity parameters based on its comparison of the updated seismic catalog to the original EPRI catalog. SER at 2-183.

Second, the Staff concluded that the Applicant's description of the PSHA parameters and procedures for the ESP site, as clarified through several RAI responses, is reasonably accurate and adequate. SER at 2-188. The Staff concurred with the Applicant on its conservative approaches in overlapping the new characteristic NMSZ onto the original EPRI source model, and in using only attenuation relationships for the mid-continent to estimate ground motion, although the ESP site is located in the extended Mississippi embayment. SER

at 2-188. In addition, the applicant also used point of closest approach, which assumes earthquakes along the three segments of the NMSZ as point sources at the southernmost end of each fault with the closest distance to the ESP site.

Third, the Staff concluded that the Applicant generally used an acceptable approach to characterize the site shear wave properties to the appropriate depth required by the reference rock used in the EPRI ground motion attenuation relationships in order to obtain the site-specific seismic wave responses. SER at 2-188.

Fourth, the Staff found that because of the narrow range in the magnitudes of the controlling earthquakes, it was appropriate to use the Applicant's chosen approach, the 2A approach described in NUREG/CR 6728, "Technical Basis for Revision of Regulatory Guidance on Design Ground Motions: Hazard- and Risk-consistent Ground Motion Spectra Guidelines". The Staff therefore concluded that SERI's description of the site responses and its approach in deriving the site soil response are reasonably accurate and adequate. SER at 2-188.

Finally, the Staff considered the SSE developed for the ESP site to be consistent with Appendix S to 10 C.F.R. Part 50, which defines the SSE as the "vibratory ground motion for which certain structures, systems and components must be designed to remain functional." The Staff concluded that the Applicant's approach to calculating the SSE for the ESP site is also consistent with the requirements of 10 C.F.R. §§ 100.23(c) and (d) and RG 1.165, and that the Applicant's description of the SSE and the subsequent operating-basis earthquake ("OBE") is accurate and adequate. SER at 2-189.

Based on the facts and reasoning set forth above with respect to vibratory ground motion, the Staff found that: (1) the Applicant provided a thorough characterization of the seismic sources surrounding the site, as required by 10 C.F.R. § 100.23; (2) the Applicant adequately addressed the uncertainties inherent in the characterization of these seismic sources through a PSHA, which follows the guidance provided in RG 1.165; (3) the controlling

earthquakes and associated ground motion derived from the Applicant's PSHA are generally consistent with the seismogenic region surrounding the ESP site; and (4) the Applicant's SSE was determined in accordance with RG 1.165 and Section 2.5.2 of NUREG-0800. SER at 2-189. Accordingly, the Staff concluded that the proposed ESP site is acceptable from a geological and seismological standpoint and meets the requirements of 10 C.F.R. § 100.23. SER at 2-189.

Surface Faulting

The Applicant described the potential for tectonic fault rupture at the ESP site. SER at 2-189. The Applicant performed the following investigations to assess the potential for surface faulting at and within an 8 kilometer (5-mile) radius of the ESP site:

- compilation and review of existing data
- interpretation of aerial photography
- discussions with current researchers in the area
- review of seismicity
- field reconnaissance

SER at 2-190. The Applicant stated that a wealth of information is available for the site regarding the surface faulting studies. The information comes from three primary sources: (1) previous research for the existing GGNS; (2) published and unpublished geologic maps from USGS, the State of Mississippi, and the University of Memphis; and (3) seismicity data compiled from published journal articles and evaluated as part of the Applicant's study. SER at 2-190. The Applicant performed field reconnaissance and interpreted aerial photography, which it used to produce an updated map of surficial deposits and geomorphology for the site location. SER at 2-190. The Applicant used the new map, in combination with other preexisting maps, to verify the absence of subsurface faulting or other forms of tectonic and nontectonic deformation by showing the surface of buried stratigraphic layers. SER at 2-190.

The Staff and its USGS advisors visited the ESP site and met with the Applicant to assist in confirming its interpretations, assumptions, and conclusions concerning potential surface

deformation. SER at 2-192. Specific areas of the Staff's review included the geological, seismological, and geophysical investigations, previous investigations, geological evidence or absence of evidence of surface deformation, correlation of an earthquake with capable tectonic sources, characterization of capable tectonic sources, zones of Quaternary deformation requiring detailed fault investigation, and the potential for surface tectonic deformation at the site. SER at 2-193.

The Staff focused its review on the adequacy of the Applicant's investigations to ascertain the potential for surface deformation that could affect the site. SER at 2-193. The Staff reviewed the Applicant's summary of previous site investigations recorded in the updated final safety analysis report ("UFSAR") along with the Applicant's recent investigations, and concluded that the Applicant adequately investigated the potential for surface deformation in the site area. SER at 2-193. The Staff and its USGS consultants also visited the site area and did not observe any evidence for Quaternary tectonic activity near the site. SER at 2-193. The Staff concluded that the Applicant adequately investigated the potential for surface deformation, as required by 10 C.F.R. § 100.23, and concurred with the Applicant's conclusion that no evidence of Quaternary folding or faulting can be associated with these local faults. SER at 2-193.

In its review of the geological and seismological aspects of the ESP site, the Staff considered the pertinent information gathered by the Applicant during the regional and site-specific geological, seismological, and geophysical investigations. SER at 2-193. The Staff concluded that the Applicant performed its investigations in accordance with 10 C.F.R. § 100.23 and RG 1.165 and provided an adequate basis to establish that no capable tectonic sources exist in the site vicinity that would cause surface deformation in the site area. SER at 2-193. The Staff concluded that the site is suitable from the perspective of tectonic surface deformation and meets the requirements of 10 C.F.R. § 100.23. In addition, the Staff found that the

Applicant appropriately considered the most severe surface deformation historically reported for the site and surrounding area, with sufficient margin for uncertainties, and that the application satisfies GDC 2 in that respect. SER at 2-193.

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE D:
SLOPE AND FOUNDATION STABILITY

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. (TC) Thomas M. Cheng. I am employed as a Senior Structural/Geotechnical Engineer in the geosciences and Civil Engineering Branch A (EGCA), Division of Engineering (DE), Office of Reactor Regulation (NRR), NRC. A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit ("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. (TC) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in NUREG-1840, the "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"), I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned geotechnical engineering related issues.

Q.3. In its November 6, 2006, Order, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to slope and foundation stability, the Board stated that it believed that the geotechnical stability

of the bearing strata and exterior earthen slopes (*i.e.*, bluff) is a fundamental site characteristic that could be quantified and addressed in this ESP application. Please address this comment.

A.3. (TC) The issues associated with both slope and foundation stability are not fundamental site characteristics since the importance of each of these site characteristics on plant behavior is directly a function of both soil properties and plant characteristics. The evaluation of foundation stability (or bearing capacity) is computed as the ratio of maximum demand (peak induced seismic toe pressure, for example) to available soil shear strength. The demand is directly related to characteristics of the plant, while the soil strength is directly related to the depth at which the plant foundation is to be located.

The evaluation of the effect of slope stability of the loess soils comprising the bluff is related not only to the strength parameters of the bluff material, but to the horizontal bluff standoff distance and depth of the foundation. Preliminary estimates made by SERI with the use of simplified slope stability evaluations and summarized in Section 2.5.5 of the SSAR indicated that, with stand-off distances of the order of 100 ft, potential failure surfaces through the bluff material would not intersect the plant cross-section.

The Staff believes that both of these issues can best be addressed at the COL stage, when specific plant geometries and locations are provided which can then be evaluated.

Q.4. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to slope and foundation stability, the Board requested that the Staff provide a comprehensive geologic description (*e.g.*, cross-sections, profiles, isopach maps, etc.) of site strata from beneath the ESP power block and extending to the Mississippi River, showing the location of the various strata at the site and using the most recent nomenclature that will be carried over to the COL stage. Please provide such a description and, in doing so, resolve any discrepancies between SSAR Figures 2.5-36, 2.5-37, and 2.5-75 to 2.5-77. Additionally, in this description, show (or eliminate as an

archaic term) the following: loess, upland complex, upland alluvium, new alluvium, young alluvium, old alluvium, clay-silt alluvium, sand-gravel alluvium, fill, Catahoula Formation.

A.4. (TC) A description of site soils is provided in SSAR section 2.5.4 and Entergy Grand Gulf ESP Engineering report ENTO002-ER-02 (ER-02). The figures in these documents show cross-sections of the site strata beneath and adjacent to the planned ESP power block location. The deposits were classified into four distinct layers based upon evaluation of sample texture, grain-size, estimated relative density (based on Standard Penetration Test [SPT] and Cone Penetrometer Test [CPT] measurements) and color. Stratigraphic profiles estimated from these identifications were developed and are shown in Figures ER-02-5 through 7. These are based on the few sample evaluations from the three ESP borings along with the borings available from the GGNS investigations. The primary soil layers are:

1. Loess - a medium stiff, slightly to moderately plastic, silt or clayey silt; average SPT blow counts between 5 and 13; shear wave velocities of 800 to 900 fps;
2. Upland Complex Alluvium - generally stiff interbedded sand, clayey sand, gravelly sand and sandy gravel with little fines content and little or no plasticity; SPT blow counts of 20 to 85; shear wave velocity of 800 to 1,800 fps;
3. Upland Complex Old Alluvium - interbedded clayey sands, silty sands and gravelly sands typically exhibiting poorer sorting than alluvium materials above; SPT blow counts of 33 to 85 bpf; shear wave velocity of 1,000 to 2,600 fps;
4. Catahoula Formation - a very stiff, hard clay to claystone material; one SPT sample with blow count of 82 bpf; shear wave velocity estimated from 1,600 to 2,800 fps;

Localized fill was placed at or near plant grade level to fill local swales that crossed the site. This fill was placed in a generally uncontrolled manner and consists of excavated loess materials. Since this material will be excavated during construction of any new facilities, its engineering significance is relatively minor except for the possible impact on surface facilities and/or

embedded components. The Staff will conduct an evaluation when the excavation information is available during the COL stage. The specific terminology used to characterize the alluvium does not impact the engineering properties of the site soils that control the assessments of suitability of the site for new plant construction. In some cases, the Staff may perform confirmatory analysis to support its conclusions.

SSAR Figures 2.5-75 through 2.5-77 present site cross-sections, which incorporate the material descriptions generated from the samples taken from the few available borings drilled for the ESP evaluation together with older borings taken for the construction of the currently operating GGNS. The layer interfaces are sketched thereon using the data available from the borings. Revision 1 of SSAR Figure 2.5-76 shows the cross-section of site strata beneath the planned ESP power block and the geotechnical information extended to the Mississippi River. In this cross-section, the boring log for Boring 3 is presented in Revision 1 of SSAR Figure 2.5-37. In Figure 2.5-77, the boring log for Boring-2A, the deepest available boring for this cross-section, is presented in Figure 2.5-36. The information presented on these logs includes the descriptors from the Unified Soil Classification System, which are descriptors based essentially on grain size distributions, measured in the laboratory or visually estimated from the sample inspections. These descriptors are used to estimate, along with sample SPT blow counts, potential engineering properties of the site soils.

The comparison of Revision 1 of SSAR Figures 2.5-36 and 2.5-37 with Revision 1 of SSAR Figures 2.5-75 through 2.5-77 indicates that a zone of filled material is noted at the top of Soil Boring WLA-3B (between Elevation 134 ft and Elevation 110 ft) in SSAR Figure 2.5-76. This zone of filled material is not shown in SSAR Figure 2.5-37. Based on the Applicant's commitment in its response to RAI 2.5.4-11, which states that soils at the plant foundation depth have a minimum shear wave velocity of 1000 fps (SER at 2-236), the soil material including the fill above Elevation minus 5 ft will potentially be removed for the construction of the plant

foundation mat as shown in Revision 1 of SSAR Figures 2.5-75 through 2.5-77 and Figure 2.5.5-1 (RAI Figure 2.5.5.1-1). SER at 2-244. Based on the above discussion, this discrepancy will not affect the construction of the plant foundation.

Q.5. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to slope and foundation stability, the Board requested that the Staff provide existing geotechnical information with specific emphasis on the shear strength, creep, and consolidation characteristics of the loess, alluvium, and Catahoula Formation. Please provide this information.

A.5. (TC) Existing geotechnical information for the significant layers of the site profile is presented in SSAR Section 2.5.4.1.1 and ER-02. SER at 2-194. The Catahoula formation, the deepest soil layer encountered in the ESP site investigation, is described as a rock-like formation with high shear strengths as indicated by the high SPT blow count shown for Boring 3 (Figure 2.5-36). The shear wave velocity measured is on average about 2,000 fps, generally considered acceptably stiff for nuclear facilities. The alluvium layers encountered higher up in the profile have blow counts of the order of 30 to 40 bpf with shear wave velocity of on average 1,000 to 1,500 fps. According SSAR Section 2.5.4.1, this material is to be the foundation soil on which the plant basemat will be located (SSAR Figures 2.5-76, -77). The SSAR Section 2.5.4.1 indicates that this material is at a depth of about 120 to 140 ft below the ground surface. The softer materials encountered in the borings, primarily the fill and loess soils, have lower recorded SPT blow counts and shear wave velocities that fall below 1,000 fps. Assuming that the foundation depth of the basemat is maintained at from 120 ft to 140 ft below grade, these loess soils will only impact the plant facility along the walls, but will not affect the foundation response. The stiffer soils providing support to the plant tend to be stiff and are generally not susceptible to liquefaction and creep. The upper loess soils, encountered at depths of about 70 ft, tend to be fine-grained, relatively soft and potentially susceptible to sloughing along the bluff; these soils

are not acceptable to provide primary support to the plant. The impact of potential slope erosion needs to be carefully evaluated during the COL stage since slope erosion, even though not influencing the primary support capacity of the stiffer soil layers, can have an impact on seismic stresses due to the unbalanced profile on both sides of the plant. However, since in the SSAR the Applicant restricts the location of the power block foundation to distances of greater than 100 ft from the bluff area on the west side of the plant site, the effect of slope erosion is insignificant. (SER at 2-243).

Q.6. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to slope and foundation stability, the Board requested that the Staff provide a discussion of the potential for slope deformations of the bluff due to creep and/or retrogressive movements. Please discuss the potential for slope deformations of the bluff due to creep and/or retrogressive movements.

A.6. (TC) As shown in SSAR Figure 2.5-76 (Revision 1), the fine-grained soils (colluvium and/or old landslide deposits derived from loess) along the bluff are known to be susceptible to sloughing and local slope failure over time. This behavior may also be influenced by flooding effects from the Mississippi due to undercutting of the slope face. These slope effects could result in unbalanced static and dynamic loads on the plant structures, which may not have been incorporated into the standard plant design. Such unbalanced forces can influence anticipated site settlements, calculated seismic induced stresses, and the design of plant structures. These responses are all related to both the horizontal standoff distance from the bluff and the foundation depth of the power block structures. In addition, all the current techniques used for seismic analyses are based on the assumption of uniform site conditions on all sides of the plant facility. If these unbalanced configurations occur at the site, the potential impact of the site condition on induced seismic stresses needs to be evaluated. Although the Staff believes that, based on its past review experience, these effects on seismic design forces

and plant floor response spectra will be small, the basis for this judgment needs to be verified at the COL stage, as described in COL Action Item 2.5-10. SER at 2-243.

Q.7. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to slope and foundation stability, the Board requested that the Staff provide a description of the impacts of flooding on erosion of the bluff and slough material on the bluff as it might affect the integrity of the plant. Please describe the impacts of flooding on erosion of the bluff and slough material on the bluff as it might affect the integrity of the plant.

A.7. (TC, GB) During its review of the design basis flood in the Mississippi River, the Staff, in consultation with the U.S. Army Corps of Engineers, determined that the static flood water surface elevation would not be substantially greater than 103 ft mean sea level (MSL), because of the large discharge capacity of the Mississippi River flood-plain west of the levees, once the levees are overtopped. The bluff on the east bank, adjacent to the ESP site, is not protected by engineered revetments from erosion due to river flooding. As a result of a design basis flood, the static flood water surface elevation of 103 ft MSL would result in the inundation of the gradually sloping portion of the bluff and, to a smaller extent, the steeply sloping portion of the bluff. In RAI 2.5.5-1, the Staff requested that the Applicant perform an evaluation to demonstrate the expected behavior of the loess escarpment (bluff) or the extent to which such movements will not occur. In its response, the Applicant noted that it modified the ESP site plan to restrict the location of the proposed power block area (PPBA) to a distance of over 100 ft from the bluff area on the west side of the site, and the foundation level will potentially be up to 130 ft below grade, which is in the zone of the old alluvium. SER at 2-243. The Applicant also stated that, based on a qualitative assessment of stability, the hazard to the ESP site from potential future movements of the loess soils is very low to none. The Staff concurs with this assessment.

Therefore, the impacts of flooding on erosion of the bluff and slough material on the bluff are not expected to affect the integrity of the plant.

Q.8. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to slope and foundation stability, the Board requested that the Staff provide technical analyses that support the opinions expressed in FSER §§ 2.5.4 and 2.5.5 including, but not limited to (i) stability analyses of existing bluff under varying conditions (including high water table conditions, plant setbacks, etc.) to indicate degree of safety; (ii) ground water flow estimates into excavation or measured values from previous construction for existing plant; (iii) bounding values of typical plant loads to verify no fatal flaw. Please provide these requested analyses.

A.8. (TC) The following evaluations were made to address the three items mentioned in this question.

- (i) To evaluate the potential effect of a slope failure through the loess material of the bluff on a proposed plant, a simple linear (plane) failure surface assumption was made. Using the estimated shear strength parameter indicated by the Applicant for the loess material, the potential horizontal extent of the failure surface (or break out point at plant grade) can be estimated. This calculation directly led to the conclusion that from a static point of view, a bluff stand-off distance of the order of 100 ft would minimize the potential effect of a slope failure on the plant.
- (ii) Ground water flow estimates into the excavation were not made for this evaluation since such inflows can be directly controlled during excavation and construction by means of dewatering schemes typically used during such heavy construction. Previous experience with similar construction of the GGNS indicates that no unusual ground water conditions would be encountered during this new construction.

- (iii) Presuming that the depth of the plant foundation will be located in the stiff old alluvium materials at a depth of up to 130 ft below grade (SSAR Figure 2.5-76), the loss of any passive pressure capacity on the west side of the plant by a slope failure through the loess material will not be a major loss since bottom friction as well as lateral capacity through the alluvium should provide enough total capacity required to overcome the lateral seismic demands on the plant. Since bounding calculations for these effects depend upon the specific plant footprint dimensions and depth, this analysis needs to be confirmed during the COL stage evaluations when the specific plant configuration is known.

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE E:
THE ALTERNATIVE ANALYSES FOR THE GRAND GULF ESP PROCEEDING

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. (JW) James H. Wilson. I am employed as a Senior Project Manager in the New Reactor Environmental Projects Branch, Division of New Reactor Licensing, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

A.1. (PH) Paul L. Hendrickson. I am employed as a Staff Scientist with the Engineered Systems Group at the Department of Energy's Pacific Northwest National Laboratory, operated by Battelle. I am providing testimony under a technical assistance contract with the staff of the U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

A.1. (LV) Lance W. Vail. I am employed as a Senior Research Engineer II with the Hydrology Group at the Department of Energy's Pacific Northwest National Laboratory, operated by Battelle. I am providing testimony under a technical assistance contract with the staff of the U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant"), pursuant to 10 C.F.R. Part 52, Subpart A, for an early site permit ("ESP") for a site within the existing site of the Grand Gulf Nuclear Station property.

A.2. (JW) I am the NRC Senior Project Manager for the environmental review of SERI's Grand Gulf ESP application. I was responsible for overseeing the preparation of NUREG-1817, the "Environmental Impact Statement for an Early Site Permit (ESP) at the Grand Gulf ESP Site: Final Report," April 2006 ("FEIS").

A.2. (PH) As part of the NRC staff's environmental review of SERI's ESP application, documented in the FEIS, I assisted the NRC staff in its analysis of the aspects of the Applicant's Environmental Report that concerned alternative power generation and alternative sites.

A.2. (LV) As part of the NRC staff's environmental review of SERI's ESP application, documented in the FEIS, I assisted the NRC staff in its analysis of the aspects of the Applicant's Environmental Report that concerned plant design alternatives.

Q.3. In its Order of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC staff's alternative analyses, the Board asked the NRC staff to "discuss why the alternative analyses included in the FEIS do or do not evaluate potential site impacts from the construction and operation of the proposed plant(s) and how future construction may affect the environmental factors that might conflict with the issuance of an ESP." Does the FEIS evaluate potential site impacts from the construction and operation of the proposed plant(s) and how future construction may affect the environmental factors that might conflict with the issuance of an ESP, and if so, why?

A.3. (JW) Yes. The alternative analyses included in the FEIS evaluated potential site impacts from the construction and operation of the proposed plant(s); in addition, Chapter 10 of

the FEIS discusses how future construction may affect the environmental factors that might conflict with the issuance of an ESP, one of the factors being consideration of alternatives to the proposed action. The alternative analyses include potential site impacts from the construction and operation of the proposed plant(s) based on the requirements of the National Environmental Policy Act (NEPA). NEPA requires that the NRC prepare a detailed statement on alternatives to the proposed action for every major Federal action significantly affecting the quality of the human environment. 42 USC § 4332(2)(C).

As the Board observed, if considered in isolation, the Grand Gulf ESP decision will not authorize any construction, and as a result, will not directly result in an environmental impact. However, in determining the "significance" of a Federal action, Council on Environmental Quality (CEQ) regulations state that an agency should consider "[w]hether the action is related to other actions with individually insignificant but cumulatively significant impacts. Significance exists if it is reasonable to anticipate a cumulatively significant impact on the environment. Significance cannot be avoided by terming an action temporary or by breaking it down into small component parts." 40 C.F.R. § 1508.27(b)(7). The fact that the licensing action concerning the Grand Gulf ESP is separate from any potential licensing action concerning the construction and operation of proposed plant(s) does not excuse the NRC from evaluating the potential site impacts from the construction and operation of proposed plant(s) and how future construction may affect the environmental factors that might conflict with the issuance of an ESP when the NRC performs its alternative analyses. It is for this reason that the NRC considered alternative power generating sources and plant design alternatives in addition to alternative sites.

I. Alternative Power Generating Sources

Q.4. In its Order of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC staff's alternative analyses, the Board asked for a discussion of the review of alternative power generation analysis. Would you address this issue?

A.4. (PH) Yes. The Staff addressed alternative power generating sources, including alternatives not requiring new generating capacity and alternatives that would require new generating capacity. In assessing these alternatives, the Staff used a target value of 2000 MW(e) for the electrical output of a new nuclear generating facility at the ESP site, which was also the value SERI used in its application. FEIS at 8-3.

The Staff considered four alternatives that would not involve new generating capacity. These consisted of purchase of the needed electric power from other suppliers, reactivation of retired power plants, extension of the operating life of existing power plants, and implementation of conservation or demand-side management programs. The Staff concluded that conservation or demand-side management was not a reasonable alternative to an ESP directed at base load electricity generation, and did not further consider this alternative. FEIS at 8-3.

Because of uncertainty concerning factors such as the timing for the construction of a new nuclear generating facility at the Grand Gulf ESP site and whether the plant would be a merchant or a regulated facility – factors which significantly impact the viability of options not involving new generating capacity – the Staff did not evaluate the remaining non-new-generating-capacity alternatives in great detail. With respect to the purchased power alternative, the Staff noted that the environmental impacts of power production would still occur, but would be located elsewhere within the region, nation, or in another country. FEIS at 8-4. The impacts would depend on the generation technology and location of the generation site

and, therefore, are unknown. FEIS at 8-4. Finally, depending on whether new transmission lines and rights-of-way are necessary to receive the purchased power, the Staff concluded that the local environmental impacts could range from SMALL to LARGE.¹ With respect to extension of the life of existing nuclear power plants, the Staff found that although the environmental impacts are significantly less than new construction, continued operation does not provide additional generation capacity. FEIS at 8-5. With respect to refurbishment, the Staff noted that most fossil plants available for refurbishment are older and would require extensive and expensive work to meet current environmental standards. FEIS at 8-5. The Staff concluded that these three alternatives are not reasonable alternatives to providing new base load power generation capacity, and noted that it would be unreasonable for an applicant to proceed with development of a nuclear power plant if the electrical power sought could be reasonably purchased, or could be obtained through reactivation or life extension of existing plants. FEIS at 8-5.

The Staff next considered alternatives involving new generating capacity. These consisted only of sources the Staff considered to be technically reasonable and commercially viable for base load power generation, which were limited to coal-fired and natural gas-fired generation. FEIS at 8-5.

The Applicant evaluated the construction of four 509 MW(e) coal-fired units at the Grand Gulf ESP site in its environmental report. In its evaluation, the Staff also used this assumption.

¹ To guide its assessment of environmental impacts of a proposed action or alternative actions, the NRC established a standard for quantifying environmental impacts using the Council on Environmental Quality guidance (40 C.F.R. § 1508.27). FEIS at 1-5, 1-6. Using this approach, the NRC established three significance levels -- SMALL, MODERATE, or LARGE -- that the Staff applied to its findings throughout the FEIS. The NRC Staff's definitions of these significance levels are as follows:

SMALL -- Environmental effects are not detectable or are so minor that they will neither destabilize nor noticeably alter any important attribute of the resource.

MODERATE -- Environmental effects are sufficient to alter noticeably, but not to destabilize, important attributes of the resource.

LARGE -- Environmental effects are clearly noticeable and are sufficient to destabilize important attributes of the resource.

FEIS at 8-7. The Applicant estimated that the coal-fired plant would consume approximately 6 million MT/yr (6.6 million tons/yr) of pulverized bituminous coal with an ash content of approximately 11.9 percent, and that approximately 223,000 MT (246,000 tons) of lime would be used annually for flue gas desulfurization. FEIS at 8-7.

In terms of air quality, the Applicant estimated the coal-fired plant's annual emissions, including those for sulfur oxides (SOx) (12,100 MT (13,340 tons)), nitrogen oxides (NOx) (11,600 MT (12,800 tons)), carbon monoxide (CO) (1500 MT (1650 tons)), and particulate matter (PM) (350 MT (390 tons)). FEIS at 8-7. A coal-fired plant would also have unregulated carbon dioxide emissions that could contribute to global warming. FEIS at 8-7. The plant would also be subject to emissions caps and the owner/operator would have to obtain pollution credits, certain permits pursuant to the Clean Air Act, and comply with other source performance and visibility standards. FEIS at 8-7, 8-8. The Staff concluded that air quality impacts from coal-fired generation would be MODERATE, noting the analysis in the GEIS on License Renewal (NUREG-1437) that implied substantial air quality impacts and global warming risks from coal-fired plants, as well as the human health effects associated with coal combustion. FEIS at 8-8.

In terms of waste management, the Applicant estimated that a 2000 MW(e) coal-fired plant would generate approximately 711,000 MT (784,000 tons) of ash and spent catalyst and an additional 660,000 MT (728,000 tons) of scrubber sludge annually. FEIS at 8-9. The Staff concluded that the impacts from waste generated at a coal-fired plant would be MODERATE, noting discussion in the GEIS of coal combustion waste products, recent EPA endorsement of regulations to address such products because of health concerns, and the potential land use and groundwater quality impacts of waste disposal. FEIS at 8-9.

With respect to human health impacts, the Staff noted that coal-fired power generation introduces risks from mining, transportation, waste, emissions, and in some circumstances

radiological doses. FEIS at 8-9. However, the Staff concluded that because of regulatory oversight exercised by the EPA and by State agencies, the human health impacts from radiological doses and inhaled toxins and particulates generated from coal-fired generation would be SMALL. FEIS at 8-9, 8-10.

In terms of other environmental impacts, the Applicant stated that a coal-fired plant would require approximately 1085 ha (2680 ac), including approximately 610 ha (1500 ac) to be converted to industrial use for the power block, infrastructure and support facilities, coal and limestone storage and handling, and landfill disposal of ash and scrubber sludge. FEIS at 8-10. Land use changes would also occur offsite in an undetermined coal-mining area to supply coal for the plant. The Staff concluded that the land-use impacts would be MODERATE. FEIS at 8-10. As a result of construction and operations, including coal and limestone mining, construction of a rail spur, and fly ash disposal, the Staff concluded that the ecological impacts could be MODERATE to LARGE. FEIS at 8-10. The Staff found that impacts on water use and quality would be SMALL and comparable to the impacts associated with a new nuclear facility, including the use of cooling water, cooling towers, blowdown, and waste discharge. FEIS at 8-10.

The Staff found that socioeconomic impacts from the coal-fired plant would be SMALL to MODERATE, based on the proximity to the surrounding population area and the relatively small number of workers (about 300) needed to operate the plant. FEIS at 8-11. The Staff also concluded that tax revenues would have a LARGE beneficial impact for Claiborne County. FEIS at 8-11. The Staff also concluded that the visual and aesthetic impacts of a coal-fired generation plant would be MODERATE, based on the presence of power block units and exhaust stacks visible offsite, cooling towers and associated plumes, and mechanical noise audible offsite (particularly rail delivery of fuel), though some of these impacts are intermittent or could be visually mitigated. FEIS at 8-11, 8-12. The Staff found that the historic and cultural

resource impacts would be SMALL (in light of the impacts from construction and operation of the existing GGNS), that environmental justice impacts would be LARGE and beneficial (given high property tax revenues), and that other construction and operation impacts would be SMALL. FEIS at 8-12.

The Applicant also evaluated natural gas-fired generation in its environmental report using combined-cycle combustion turbines and employing four units with a net capacity of 508 MW(e) per unit. In its evaluation, the Staff also used these assumptions. FEIS at 8-14.

In terms of air quality, the Staff found that compared with a coal-fired plant, a natural gas-fired plant would release similar types of emissions but in lower quantities. FEIS at 8-14. The Applicant estimated that a natural gas-fired plant equipped with appropriate pollution control technology would annually emit approximately 109 MT (120 tons) of SO_x, 417 MT (460 tons) of NO_x, 553 MT (610 tons) of CO, and 63 MT (70 tons) of PM₁₀ (particulate matter having an aerodynamic diameter less than or equal to 10 µm). FEIS at 8-15. The owner/operator would also have to obtain certain permits pursuant to the Clean Air Act, and comply with other stationary source and visibility standards. FEIS at 8-14. The Staff concluded that air quality impacts from new natural gas-fired power generation at the ESP site would be SMALL to MODERATE. FEIS at 8-15.

With respect to waste management, the Staff noted the finding in the GEIS that waste generation from natural gas is minimal; the Staff thus concluded that waste impacts from natural gas-fired power generation would be SMALL. FEIS at 8-15. With respect to human health risks, while the Staff noted its finding in the GEIS analysis that cancer and emphysema are potential health risks from natural gas-fired plants, it noted Mississippi Department of Environmental Quality (MDEQ) regulation of the ESP site and concluded that the impacts would be SMALL. FEIS at 8-15, 8-16.

In terms of other environmental impacts, the Applicant estimated that a natural gas plant would need approximately 91 ha (225 ac), including the power block and support facilities, cooling towers and support systems, and a natural gas pipeline. FEIS at 8-16. For any new natural gas-fired power plant, additional land would be necessary for natural gas wells and collection stations. FEIS at 8-16. In light of this relatively small land disturbance, the Staff concluded that land-use impacts from new natural gas-fired power generation would be SMALL, and ecological impacts would be SMALL to MODERATE. FEIS at 8-16. Based on the analysis in the GEIS, the Staff concluded that impacts on water use and quality would be SMALL. FEIS at 8-16.

With respect to socioeconomic impacts, the Staff concluded that based on the proximity to the surrounding population area and the relatively small number of workers (approximately 150) needed to construct and operate the plant in comparison to nuclear and coal-fired generation, the impacts would be SMALL. FEIS at 8-16, 8-17. The Staff concluded that the tax revenues would have a MODERATE beneficial impact on Claiborne County. FEIS at 8-17.

Although the turbine buildings, exhaust stacks (and emissions), cooling towers and associated plumes, and gas pipeline compressors would be visible offsite, and some noise would be audible offsite, the Staff concluded that the visual and aesthetic impacts of a natural gas-fired generation plant would be SMALL. FEIS at 8-17. Some of these impacts would be mitigated by the industrial and rural location and relatively smaller land use. FEIS at 8-17. The Staff found that the historic and cultural resource impacts would be SMALL (in light of the existing GGNS), that environmental justice impacts would be MODERATE and beneficial (given moderate property tax revenues), and that other construction and operation impacts would be SMALL. FEIS at 8-17.

SERI's application also identified other energy alternatives. However, as new nuclear units at the ESP site would constitute a base load generation plant, and the Applicant

determined that these alternatives either could not generate base load power or could not do so economically, it concluded that these alternatives were not reasonable. FEIS at 8-19. These alternatives included oil-fired generation, wind, solar, hydroelectric, geothermal, wood waste, municipal solid waste, biomass-derived fuels, and fuel cells. FEIS at 8-19 to 8-22. Based on its independent review (including, for some issues, reliance on the analysis in the GEIS), the Staff determined that SERI's conclusion – that these alternatives are not reasonable – is acceptable. FEIS at 8-19.

The Staff concluded that oil-fired generation has become more expensive than nuclear or coal-fired generation options and is likely to become even less economical in the future, particularly as a fuel source for a base load plant. FEIS at 8-19. The Staff found that Mississippi does not have sufficient wind resources to use large-scale wind turbines and that wind turbines typically do not operate at a capacity factor comparable to a base load plant, making them an uneconomical alternative. FEIS at 8-19, 8-20. With respect to solar power, the Staff found that it would be uneconomical because of solar power's higher capital cost per kilowatt of capacity, high energy storage requirements (limiting its use as a base load supply), and high land requirements. FEIS at 8-20.

Similarly, because of the relatively low amount of undeveloped hydropower resources in Mississippi and the large land and related environmental and ecological resource impacts (flooding, destruction of natural habitat, and alteration of natural river courses) associated with siting hydroelectric facilities large enough to produce 2000 MW(e), the Staff concluded that local hydropower was not a feasible alternative. FEIS at 8-20, 8-21. Although geothermal energy has an average capacity factor of 90 percent and can be used for base load power where available, the Staff found that no feasible eastern location for geothermal capacity can serve as an alternative to a base load nuclear power plant, making it an unreasonable alternative to the proposed ESP site. FEIS at 8-21.

Because of uncertainties associated with obtaining sufficient wood and wood waste to fuel a base load power plant (larger wood-waste power plants are typically only 40 to 50 MW(e) in size), the ecological impacts of large-scale timber cutting (for example, soil erosion and loss of wildlife habitat), and high inefficiency, the Staff concluded that wood waste is not a feasible alternative. FEIS at 8-21. Similarly, with respect to use of municipal solid waste, only about 89 waste-to-energy plants are operating in the United States, with an average output of approximately 28 MW(e) per plant; the Staff concluded that this would not constitute a feasible base load alternative to the proposed ESP site. FEIS at 8-22.

With respect to other biomass-derived fuels, including burning crops, converting crops to a liquid fuel such as ethanol, and gasifying crops (including wood waste), the Staff concluded, based on the analysis in the GEIS, that none of these technologies has progressed to the point of being competitive on a large scale or of being reliable enough to replace a large base load plant, and thus they do not represent reasonable alternatives. FEIS at 8-22. Finally, with respect to fuel cells, although significant efforts have been made to develop more practical and affordable fuel cell designs for stationary power applications, the Staff concluded that fuel cells currently are not economically or technologically competitive with other alternatives for base load electricity generation, and their future competitiveness compared to other fuels is speculative. FEIS at 8-22, 8-23. The Staff therefore concluded that fuel cells are not a reasonable alternative to nuclear generation at the proposed ESP site. FEIS at 8-23.

The Staff also considered the possibility that some combination of alternatives might be more economical than the construction of a new base load plant at the proposed ESP site. Of the many possible combinations, the Staff evaluated the environmental impacts of an assumed combination of three 508 MW(e) natural gas combined-cycle generating units at the Grand Gulf ESP site using closed-cycle cooling with cooling towers, 30 MW of wind energy, 30 MW of hydropower, 90 MW from biomass sources including municipal solid waste, and 326 MW from

conservation and demand-side management programs. FEIS at 8-23, 8-24. However, after comparing the environmental impacts with those assessed for the proposed plant at the ESP site, the Staff concluded that, from an environmental perspective, none of the viable energy alternatives were clearly preferable to construction of a new base load nuclear power generation plant. FEIS at 8-24 to 8-26.

II. Plant Design Alternatives

Q.5. In its Order of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC staff's alternative analyses, the Board asked for a summary of the plant design alternatives analysis. Would you address this issue?

A.5. (LV) Yes. In its environmental report, SERI described the process behind its decision to propose natural or mechanical draft cooling towers or both with a makeup water intake in the Mississippi River and a blowdown discharge outfall downstream of the intake. FEIS at 8-24. SERI considered seven heat-dissipation alternatives in its environmental report, including once-through cooling, wet mechanical draft cooling towers, wet natural draft cooling towers, wet-dry cooling towers, dry cooling towers, a cooling pond, and spray canals. FEIS at 8-26, 8-27. After ruling out other options for various reasons, SERI only included wet natural draft and wet mechanical draft cooling towers in its PPE. FEIS at 8-27. Based on its independent review - including a determination that the Mississippi River is not suited for once-through cooling, that land limitations make the site unsuitable for cooling pond or spray canal heat-dissipation designs, and that dry cooling technology has some detrimental effects on electricity production by reducing the energy efficiency of steam turbines - the Staff agreed that the other options were not suitable and concluded that wet mechanical draft cooling towers and wet natural draft cooling towers are suitable for the site. FEIS at 8-27, 8-28. However, system

design alternatives would be discussed at the CP or COL stage, because a specific cooling system design for the Grand Gulf ESP site has not been selected. FEIS at 8-28, 8-29.

For its intake system, SERI proposed to withdraw makeup water for the heat-dissipation system and the circulating water system directly from the Mississippi River through a shoreline embayment and intake constructed on the bank of the river. FEIS at 8-29. SERI considered two alternative types of water intake - either a direct intake from the river with a structure located on the riverbed and a pipeline connecting it to the bank, or a channel directing water to the intake structure on the shoreline - and the Staff found no basis to suggest that these alternatives would be environmentally preferable to SERI's proposed intake system. FEIS at 8-29.

For its discharge system, SERI stated that the thermal effluent from a new facility would also be released to the river through a new outfall structure that would be located downstream of the existing outfall. FEIS at 8-30. The Staff evaluated a shoreline diffuser outfall and a submerged single-point discharge, but it found no basis to suggest that the two discharge alternatives would be environmentally preferable to SERI's proposed discharge system. FEIS at 8-30.

In terms of water supply, the Staff did not identify any other water supply environmentally preferable to the Mississippi River and wells in the alluvial aquifer. FEIS at 8-30. Finally, with respect to water treatment, the Staff noted that although the water treatment requirements and water system effluents are not known, all chemical and thermal discharges would be regulated by the MDEQ through the National Pollutant Discharge Elimination System (NPDES) process. FEIS at 8-30.

III. Alternative Sites

Q.6. In its Order of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing.

With regard to the NRC staff's alternative analyses, the Board asked for a summary of the alternative sites analysis, including (i) site screening procedures; (ii) impact assessment for ESP's unresolved issues; and (iii) summary of alternative site comparison. Please address these issues.

A. Alternative Site Screening Selection Process

A.6. (PH) Regarding the site screening procedures, the Staff examined Entergy's region of interest ("ROI") for possible siting of a new nuclear power plant, as well as its alternative site selection process. (Entergy Nuclear, a division of Entergy Corporation, conducted the alternative site selection process for the Grand Gulf ESP application). FEIS at 8-31. Entergy Nuclear selected its ROI for examining potential ESP sites as the locations of seven existing Entergy sites with operating nuclear power plants licensed by the NRC at the time of its application for an ESP: Arkansas Nuclear One, Grand Gulf Nuclear Station, James A. FitzPatrick Nuclear Power Plant, Indian Point Energy Center, Pilgrim Nuclear Station, River Bend Station, and Waterford-3. FEIS at 8-31. The application explained that these sites were identified for several reasons. For example, NRC has approved the sites for nuclear plant construction and operation, site characterization data have been collected and are available, the operational impact of the existing nuclear plants is documented, and the sites and related facilities are controlled by Entergy. FEIS at 8-32. The Staff concluded that the criteria used to identify the ROI were reasonable for consideration and analysis of potential ESP sites. FEIS at 8-32.

The application next explained how Entergy Nuclear further screened its site list. It first removed Indian Point due to greater population density in the site vicinity. FEIS at 8-33. It then ranked the remaining sites with respect to 11 weighted screening criteria, including pricing, seismic evaluation, water availability, exclusion area, and spent fuel storage. FEIS at 8-33, 8-34. In the interest of regional and market diversity and to gain ESP experience in

different environments, Entergy removed Waterford and Arkansas-One (its 4th and 5th ranked sites), but retained Pilgrim for further evaluation, along with Grand Gulf, River Bend, and FitzPatrick, its top three sites. FEIS at 8-33. The Staff concluded this was a reasonable basis for narrowing the sites for examination. FEIS at 8-34.

To narrow its site selection to a final site, Entergy Nuclear ranked the sites using a final set of 34 weighted screening criteria, including flooding, accident effects, radionuclide pathways, socioeconomics, highway and rail access, and labor rates. FEIS at 8-35 to 8-37. This resulted in an ordered ranking of Grand Gulf, FitzPatrick, River Bend, and Pilgrim. The Staff concluded that the overall site selection process for alternative sites was reasonable and that the identification of the Grand Gulf ESP site was consistent with that approach. FEIS at 8-37.

B. Comparison of Impacts (Including Impacts for Unresolved Issues) for the Proposed and Alternative Sites

In its environmental report, the Applicant examined the River Bend, Pilgrim, and FitzPatrick alternative sites in detail. The Staff conducted its own independent examination, including visiting each of the three alternative sites to collect additional reconnaissance-level information. The Staff also visited the Grand Gulf ESP site. FEIS at 8-37, 8-38. The Staff found that SERI reasonably identified alternative sites, adequately evaluated the environmental impacts of construction and operation, and used a logical means of comparing sites. FEIS at 9-2. To compare the proposed action with the alternatives, the Staff weighed the impact significance levels (SMALL, MODERATE, or LARGE) it had determined with respect to the Grand Gulf ESP site for each major impact area with the corresponding levels for each of the three identified alternative sites. FEIS at 9-2. Where the Staff had been unable to reach a single determination level for the Grand Gulf ESP site due to insufficient information, the Staff

indicated a likely impact level for unresolved issues – so that a comparison could be made – based on professional judgment, experience, and consideration of controls likely to be imposed under required Federal, State, or local permits that would not be acquired until an application for a construction permit or combined license is underway. FEIS at 9-2. The Staff believes that the impact levels that were assigned in these areas are sufficiently defined for the purposes of comparison between the proposed and the alternative sites. The final impact assessment of construction and operation of new nuclear units at the Grand Gulf ESP site would be performed at the CP or COL stage for issues that were not resolved during the review of the ESP application. The alternative sites do not have unresolved impacts because impacts at alternative sites were evaluated using reconnaissance-level information.

The Staff determined that the impact level from construction would be SMALL for most of the environmental issues at each of the sites. See FEIS at Table 9-1. The Staff's issue-by-issue construction impact determinations are explained more fully in Chapter 4 of the FEIS for the Grand Gulf ESP site and in Chapter 8 for the alternative sites. The Staff found that construction of transmission corridors at the Pilgrim and FitzPatrick sites would have SMALL to MODERATE land use impacts. FEIS at 9-5. For terrestrial ecosystems, the Staff determined that impacts would likely be MODERATE at Grand Gulf and River Bend and as much as LARGE at FitzPatrick because of probable impacts to forests and wetlands and associated habitats. FEIS at 9-5. For threatened and endangered species, the Staff determined that impacts would likely be SMALL to MODERATE at River Bend and MODERATE TO LARGE at Pilgrim because of potential impacts to protected species. FEIS at 9-5. The Staff found socioeconomic and environmental justice impacts ranging from SMALL to MODERATE adverse impacts in some aspects, and up to LARGE beneficial impacts in other aspects, such as social and economic benefits because of tax revenue. FEIS at 9-5.

Similarly, the Staff determined that the impact level from operations would be SMALL for most of the environmental issues at each site. See FEIS Table 9-2. Once again, the Staff's issue-by-issue operational impact determinations are explained more fully in Chapter 5 of the FEIS for the Grand Gulf ESP site and in Chapter 8 for the alternative sites. Exceptions to the Staff's findings of SMALL impacts from operations included aquatic and terrestrial ecosystems and threatened and endangered species at the Pilgrim site, arising from potential impacts to the winter flounder larvae and on the redbelly turtle. FEIS at 9-5. Additionally, the Staff's findings concerning social and economic impacts in socioeconomics at the alternative sites included LARGE to SMALL beneficial impacts, principally due to added tax revenue and beneficial impacts on the local economy. FEIS at 9-5. The Staff determined that social and economic impacts at the Grand Gulf ESP site would be LARGE and beneficial, while impacts on infrastructure and community services would be MODERATE adverse at the Grand Gulf ESP site and SMALL to MODERATE adverse at the alternative sites. FEIS at 9-5. Finally, the Staff found that environmental justice impacts would be SMALL at the alternative sites, but up to LARGE and beneficial at the Grand Gulf ESP site. FEIS at 9-5, 9-6.

C. Summary of Alternative Site Comparison

The Staff then analyzed whether any of the alternative sites are environmentally preferable to the Grand Gulf site. First, with respect to construction impacts, while the Staff concluded that impacts were generally SMALL for all four analyzed sites, the Staff identified several differences between the environmental impacts of construction at the proposed and alternative ESP sites. FEIS at 9-6. However, while the Grand Gulf site had some higher adverse impacts with respect to demographics, terrestrial ecosystems and infrastructure and community services (as well as one area, social and economic benefits from tax revenues, of significantly higher beneficial impacts), the Staff found that each alternative site had higher adverse impacts for the same issues or in other respects. FEIS at 9-6. The Staff concluded that

none of the differences were sufficient to determine that any of the alternative sites is environmentally preferable to the Grand Gulf ESP site. FEIS at 9-6.

Second, with respect to operational impacts, the Staff again noted that impacts were generally SMALL for all four analyzed sites, and identified several differences between the environmental impacts at the proposed and alternative ESP sites. FEIS at 9-7. However, while the Grand Gulf site again had some higher adverse impacts with respect to demographics and infrastructure and community services (and also had significantly higher potential social and economic benefits), the Staff found that the alternative sites had, on the whole, either closely comparable impacts or slightly less beneficial impacts than the Grand Gulf site. FEIS at 9-7. The Staff again concluded that none of the differences were sufficient to determine that any of the alternative sites is environmentally preferable to the Grand Gulf ESP site. FEIS at 9-7.

Because the Staff determined that none of the alternative sites was environmentally preferable to the Grand Gulf ESP site, it concluded by extension that none of the alternative sites is obviously superior to the Grand Gulf ESP site. FEIS at 9-7.

Finally, the Staff compared the proposed action with the no-action alternative. The Staff noted that denial of the ESP application would prevent early resolution of safety and environmental issues for the site, and it further found that although SERI could follow any of several paths to satisfy its electric power needs, each of the paths would have associated environmental impacts. FEIS at 9-7, 9-8. The Staff additionally concluded that no significant environmental impacts would be avoided by the no-action alternative because no such impacts are caused by a site-suitability determination. FEIS at 9-8.

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE F:
CUMULATIVE SITE IMPACTS FOR THE GRAND GULF ESP PROCEEDING

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. (SK) Stephen Klementowicz. I am employed as a Senior Health Physicist in the Division of License Renewal, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission ("NRC").

A.1. (CB) Charles A. Brandt. I am employed as the Resource and Ecosystems Management Product Line Manager at the Pacific Northwest National Laboratory. I am providing testimony under a technical assistance contract with the staff of the NRC. A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant"), pursuant to 10 C.F.R. Part 52, Subpart A, for an early site permit ("ESP") for a site within the existing site of the Grand Gulf Nuclear Station ("GGNS") property.

A.2. (SK) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in NUREG-1840, "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"), I reviewed the aspects of the Applicant's Site Safety

Analysis Report that concerned the radioactive waste treatment system and the radiological impacts from routine operation to plant workers, members of the public, and to the environment. I was also part of the NRC Staff's environmental review of the SERI ESP application, documented in NUREG-1817, "Environmental Impact Statement for an Early Site Permit (ESP) at the Grand Gulf ESP Site: Final Report," April 2006 ("FEIS"). I reviewed the aspects of the Applicant's Environmental Report that concerned the radioactive waste treatment system and the radiological impacts from routine operation to plant workers, members of the public, and to the environment.

A.2. (CB) I was the Pacific Northwest National Laboratory Task Manager responsible for the Laboratory's environmental review of SERI's ESP application and preparation of NUREG-1817, the "Environmental Impact Statement for an Early Site Permit (ESP) at the Grand Gulf ESP Site: Final Report," April 2006 ("FEIS"). As part of this function, I assisted the NRC Staff in its analysis of the aspects of the Applicant's Environmental Report that concerned cumulative site impacts.

Q.3. In its November 6, 2006, Order, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC Staff's cumulative site impacts analysis, the Board stated its opinion that some issues will have an impact on the site which may be cumulative with respect to the number of plants, including any existing plants on the site. Would you please explain which parameters were, or should have been, evaluated in this regard?

A.3. (SK) The Staff presented information on its evaluation of the projected cumulative impacts of routine radiological discharges from a potential new reactor(s) and existing station to workers, members of the public, and to the environment in response to Q.3 in the testimony on Hearing Issue I.

A.3. (CB) In conducting the cumulative impacts evaluation for the environmental review of SERI's ESP application, the Staff considered the combined effects of the existing GGNS Unit 1 and the proposed GG ESP facility for all environmental issues that had been evaluated for construction, operation, fuel cycle, transportation, and decommissioning. This evaluation focused on issues where potential cumulative impacts could reasonably be expected to occur, including impacts of the existing GGNS Unit 1. Based on this analysis, the Staff identified the following impact issues and associated parameters as relevant to the cumulative impacts analysis:

- Land Use – land conversion to accommodate new workers and services for construction and operation; offsite land use changes resulting from transmission system improvements;
- Air Quality – pollutant emissions resulting from construction; pollutant emissions resulting from operation; heat, water vapor, and drift plumes from cooling tower operation;
- Water Use and Quality – surface water use (on site and from the Mississippi River); groundwater use; surface water quality (on site and in the Mississippi River); groundwater quality;
- Terrestrial Ecosystems – loss of important species and habitats due to construction; loss of important species and habitats from operation;
- Aquatic Ecosystems – loss of important species and habitats due to construction; loss of important species and habitats from operation;
- Socioeconomics – physical impacts; demography, social and economic impacts; infrastructure, and community services;
- Historic and Cultural Resources – cumulative impacts to historic and cultural resources;

- Environmental Justice – unusual resource dependencies or practices or environmental pathways; tax revenues; infrastructure and community services;
- Nonradiological Health – microbial organisms; occupational health; noise and dust emissions; chronic effects of electromagnetic fields;
- Radiological Impacts from Normal Operations – public and occupational radiological doses; radiological emissions;
- Fuel Cycle – fuel use for light-water reactor designs; fuel use for gas cooled designs;
- Transportation – radiological dose to public from unirradiated fuel, spent fuel, and radiological wastes from light-water reactor designs; radiological dose to public from unirradiated fuel, spent fuel, and radiological wastes from gas cooled reactor designs; and
- Decommissioning – radiological dose to workers and public; waste management; water quality; air quality; ecological resources; socioeconomics.

Q.4. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. The Board noted that in response to FSER Inquiry No. 2, the Staff indicated that in the FEIS it evaluated the impact of the combined radiological effluent discharges from the existing operating unit and the proposed plant(s). For both the FSER and the FEIS, please identify and discuss all of the issues that have or will contribute to cumulative effects.

A.4. (CB) In conducting the environmental review of SERI's ESP application, the Staff determined a cumulative impact level for each issue and associated parameter(s) (identified previously in response A.3) based upon an appropriate temporal and spatial context. The results of that analysis, including the relevant context for the analysis, are summarized in a table entitled "Summary of Issues for Which Cumulative Effects Were Analyzed," which accompanies this testimony.

Q.5. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC Staff's cumulative site impacts analysis the Board requested a discussion on whether the impacts of radiological effects should or should not be the only cumulative impact that needs to be considered in order to properly qualify the site. Please address this issue.

A.5. (SK) The only potential cumulative impact that was not required to be evaluated (as discussed in response to Q.5 in the testimony on Hearing Issue B) is the potential impact from inadvertent releases of radioactive liquid on the plant site. The Health Physics Branch of the Division of Inspection and Program Support within NRR is currently developing a plan and schedule to address the recommendations contained in the Lessons Learned Task Force Report (Adams Accession Number: ML062650312) on inadvertent radioactive liquid releases onto a plant site. The report contained several recommendations concerning the need to explore enhanced onsite environmental monitoring to detect the presence of radioactive material that originated from an inadvertent release. At this time, the Staff does not have any regulations and guidance to guide it in an evaluation of potential impacts from inadvertent releases of radioactive liquid on the plant site.

A.5. (CB) As just described in A.3 and A.4, and in the FEIS, radiological effects should not be (and were not) the only component of the cumulative impact analysis used to evaluate the Grand Gulf site. Consideration of only one potential impact (be it radiological effects or any other) would undermine the rigor and reliability of the qualification, because impacts not considered could potentially bias the Staff's analysis in favor of the site. Thus, the Staff considered in a cumulative sense all impacts that had the potential to affect the environment for the duration of the proposed action (construction period plus 40 years of operation). The impacts considered included all of those addressed in the analyses of construction, operation, fuel cycle, transportation, and decommissioning. As noted in the Staff

response to Board EIS Inquiry No. 5, the only impact issue that did not receive discussion in the cumulative impacts section of the FEIS was design basis accidents. This issue was not addressed cumulatively because (1) the purpose of the design basis accident analysis is to compare predicted dose consequences with regulatory limits and guidance pertaining to individual reactors (not collections of reactors), and (2) the likelihood of simultaneous design basis accidents is small.

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE G:
EVALUATION OF PLANT PARAMETER ENVELOPE

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. (GW) George F. Wunder. I am employed as a Project Manager in the ESBWR/ABWR Projects Branch 1, Division of Licensing Project Management, Office of New Reactors, U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

A.1. (JW) James H. Wilson. I am employed as a Senior Project Manager in the New Reactor Environmental Projects Branch, Division of New Reactor Licensing, Office of Nuclear Reactor Regulation, NRC. A statement of my professional qualifications is attached.

A.1. (BH) R. Brad Harvey. I am a Physical Scientist in the Nuclear Regulatory Commission's (NRC's) Office of Nuclear Reactor Regulation (NRR), Division of Risk Assessment (DRA). A statement of my professional qualifications is attached.

A.1. (SK) Stephen Klementowicz. I am a Senior Health Physicist in the Nuclear Regulatory Commission's (NRC's), Office of Nuclear Reactor Regulation (NRR), Division of License Renewal (DLR). A statement of my professional qualifications is attached.

A.1. (GB) Goutam Bagchi. I am a Senior Advisor in the Nuclear Regulatory Commission's (NRC's), Office of Nuclear Reactor Regulation (NRR), Division of Engineering (DE). A statement of my professional qualifications is attached.

A.1. (JR) James V. Ramsdell, Jr. I am employed as a Staff Scientist with the Atmospheric Chemistry & Meteorology Technical Group at the U. S. Department of Energy's Pacific Northwest National Laboratory operated by Battelle. I am providing testimony under a technical assistance contract with the staff of the U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit ("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. (GW) I took over Project Management responsibilities in May 2006, following issuance of NUREG-1840, the "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"). I have been responsible for project management activities with respect to the SER since that time.

A.2. (JW) I am the NRC Senior Project Manager for the environmental review of SERI's Grand Gulf ESP application. I was responsible for overseeing the preparation of NUREG-1817, the "Environmental Impact Statement for an Early Site Permit (ESP) at the Grand Gulf ESP Site: Final Report," April 2006 ("FEIS").

A.2. (BH) As part of the NRC staff's health and safety review of the SERI ESP application, documented in the Grand Gulf Site SER, I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned meteorology.

A.2. (SK) As part of the NRC staff's health and safety review of the SERI ESP application, documented in the Grand Gulf Site SER, I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned the radioactive waste treatment system and the radiological impacts of routine operation to plant workers and members of the public.

A.2. (GB) As part of the NRC staff's health and safety review of the SERI ESP application, documented in the Grand Gulf Site SER, I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned hydrology.

A.2. (JR) As part of the NRC staff's environmental review of the SERI ESP application, documented in the Grand Gulf FEIS, I assisted the NRC staff in its analysis of the aspects of the Applicant's Environmental Report that concerned Meteorology and Air Quality, and evaluation of Design Basis and Severe Accidents.

Q.3. In its November 6, 2006, Order, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC staff's evaluation of the plant parameter envelope ("PPE"), the Board stated that the list of PPE parameters provided in SERI's ESP application appears to be incomplete with respect to those identified in the Nuclear Energy Institute ("NEI") guidance. Please indicate any PPE parameters that are on the NEI list, but are not included in the PPE table for the Grand Gulf ESP.

A.3. (GW, JW) In response to the Board's question, the Applicant prepared a table identifying the NEI parameters and indicating whether each is included in the PPE table for the Grand Gulf ESP. That table is attached to this testimony as Table G-1. The Staff agrees with the Applicant's identification of which parameters from the NEI document were or were not used for the Grand Gulf application. The Staff takes no position concerning the Applicant's additional comments (column 3 of Table G-1) concerning the inclusion/exclusion of particular parameters.

Q.4. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC staff's evaluation of the PPE, the Board stated that the relationship between the PPE parameters provided in SERI's ESP application and the maximum MWt and MWe in the ESP analyses performed by the NRC staff was unclear to the Board. Please discuss how the staff's analyses that use the PPE parameters support the maximum site reactor power requested by the Applicant. Provide separate discussions for the FSER and the FEIS analyses.

A.4. (GW) With respect to the Staff's health and safety review and the analyses documented in the FSER, the Staff believes that the PPE parameters in the Grand Gulf ESP PPE that are directly related to the site power level are not inconsistent with the maximum site reactor power requested by the Applicant.

(GB) For example, the bounding parameter for maximum makeup water flow (78,000 gpm) is not inconsistent with the proposed maximum site reactor power.

(BH) Regarding the parameters related to Normal Plant Heat Sink Condenser and Normal Heat Sink (NHS) Cooling Towers in PPE Sections 2.3.2, 2.4.8, and 2.5.8, as well as the parameters related to the Unit Vent/Airborne Effluent Release Point in PPE Sections 9.4.2 Elevation (Normal), 9.4.3 Elevation (Post Accident), and 9.4.4 Minimal Distance to Site Boundary, these PPE parameters are not inconsistent with the Applicant's proposed maximum site reactor power.

(SK) Likewise, for the evaluation of the radiological impacts to plant workers, members of the public, and the environment, the Staff used SERI's bounding radiological routine effluent release source term. The source term was stated by SERI to be the maximum value for any of the plant design / number of unit combinations being considered for the site. This value is not inconsistent with the Applicant's proposed maximum site reactor power.

(GW) In summary, with respect to the Staff's health and safety review and the analyses documented in the FSER, the Staff believes that the PPE parameter values in the Grand Gulf ESP PPE that are directly related to the site power level are not inconsistent with the maximum site reactor power requested by the Applicant.

A.4. (JR) With respect to the Staff's environmental review and the analyses documented in the FEIS, the Staff believes that the PPE parameters in the Grand Gulf ESP PPE that are directly related to the site power level are not inconsistent with the maximum site reactor power requested by the Applicant.

The Staff's analyses in the FEIS are based on either 1) specific reactor designs (e.g., the ABWR and the AP1000), or 2) composite characteristics that are derived from consideration of the individual characteristics of each of the 7 reactor designs listed in the Application. The site goal is generation of about 2000 MWe. None of the reactors discussed in the Application is capable of generation of 2000 MWe. Therefore, at least two reactors would be necessary to meet that goal.

Of the reactors discussed, the ABWR is the largest, with a postulated rating of about 1500 MWe based on a design power level of 4300 MWt. Thus, the PPE (ER Table 3.0-1) lists 4300 MWt as a unit specific parameter. The corresponding site value (not included explicitly in the PPE) is 8600 MWt. The PPE contains several parameters that are directly related to the site power level. These parameters include normal heat sink blowdown flow rate, evaporation rate, and makeup water flow rate. The ABWR was considered in establishing these parameters. Consequently, the Staff assumes that the values given in the PPE encompass the heat rejection needs of two 4300 MWt ABWRs.

Normal heat sink blowdown flow rate, evaporation rate, and makeup water flow rate were considered in the evaluation of the impacts of plant operation on water use and quality. A similar set of parameters is associated with the ultimate heat sink. The ultimate heat sink would

have lesser impacts on the environment. Makeup water and blowdown flows were considered along with blowdown temperature (which is not likely to be related to power) in evaluation of the impacts of the postulated facility on aquatic ecology. Intake and outfall design characteristics not related to power level may have impacts on aquatic ecology that are as large as those related to power level.

Land use and terrestrial ecology impacts related to site power level are not likely to be particularly sensitive to the ultimate site power level, except to the extent that they will be impacted if the ESP site power level exceeds the capacity of the existing transmission system. If transmission capacity is exceeded and additional capacity installed, further increases in the size of the plant are not likely to have proportionately large increases in impacts.

Although radiological releases are affected somewhat by design power level, use of the PPE as implemented by SERI negated any effect that design power level might have. The radiological releases from plants are determined by plant systems and release paths as much as by the design power level.

SERI included tables of gaseous (Table 3.0-7) and liquid (Table 3.0-8) radiological releases expected during normal operations in its PPE. These tables are based on radionuclide-by-radionuclide comparison of projected releases from each of the 7 reactor designs being considered. For each radionuclide, the largest release from among the 7 designs was entered into the tables. Therefore, the PPE normal-operations source terms in these tables bound the source terms for all 7 reactor designs, including the ABWR. The source term for any other reactor design should be compared against the source terms in the tables on an isotopic basis to determine if the source terms are bounded by the FEIS analysis. Reactor power rating is not an appropriate basis for making this determination.

Comparisons of isotopic release rates and doses are more appropriate means of establishing whether a reactor design is within the bounds of the Staff's analysis than is reactor

design power. Design basis accidents and severe accidents were evaluated for both the ABWR and AP1000 reactor designs. The ABWR has a higher thermal power than the AP1000. However, the consequences of ABWR design basis accidents are not necessarily greater than those of AP1000 design basis accidents.

In summary, with respect to the Staff's environmental review and the analyses documented in the FEIS, the Staff believes that the PPE parameter values in the Grand Gulf ESP PPE that are directly related to the site power level are not inconsistent with the maximum site reactor power requested by the Applicant.

Q.5. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC staff's evaluation of the PPE, the Board requested that the staff identify and discuss any differences or inconsistencies in the treatment of the PPE between the FSER and the FEIS.

A.5. (GW, JW) The Staff does not believe that there are "inconsistencies" in the FSER and FEIS treatment of the PPE. However, in general terms, there are some fundamental differences between the approaches used for the FSER and the FEIS; these differences influence, among other things, why the Staff analyzes the PPE values for a particular component of its review. The sources of these differences are the statutory and regulatory requirements for each review. The Staff's safety review is performed under the Atomic Energy Act and in accordance with the regulations in 10 C.F.R. Part 52. The environmental review is performed under NEPA as implemented in NRC regulations at 10 C.F.R. Part 51. Whereas the safety review is focused primarily on protecting the health and safety of the public, the environmental review considers a much broader range of impacts to the environment as a whole. This broader range of impacts is reflected in the longer set of PPE values relevant to the environmental review.

Appendix I of the FEIS presents the PPE submitted by the Applicant in its ER. The listing is not a complete listing of plant parameters, but is a listing of the plant parameters that the Applicant considered relevant to the environmental review (ER page 3.1-1). Similarly, the PPE listing in the SSAR includes only those plant parameters relevant to the site-suitability evaluation (SSAR page 1.3-5). The PPE tables in the SER and EIS agree for those parameters that are found in both.

In its safety review, the Staff reviewed the Applicant's PPE parameters to evaluate site-related aspects of plant design, in order to determine whether the site characteristics would be consistent with a design that might be described in an eventual COL application. Consequently, the Staff's safety analysis focused on how the site would meet the functional or operational needs of a potential future unit (or units), as well as the capability of the facility to withstand any site environmental hazards (natural and man-made). In contrast, the Staff's environmental review focused on evaluating the environmental impacts of construction and operation of a nuclear unit or units at the proposed site if the characteristics of those units were within the parameter values defined in the PPE. The intent of the Staff's environmental review is to provide a bounding estimate of the environmental impacts that might occur at the Grand Gulf ESP site.

In other words, an important reason for the differences in approach between the FEIS and the FSER is the matter of perspective. For example, both the FEIS and the FSER consider impacts related to hydrology. But in these two documents, the Staff is looking at hydrology for very different reasons. In the FEIS, the Staff is evaluating the impacts on the hydrology of the surrounding area of constructing and operating a nuclear plant (or plants). In the FSER, in contrast, the Staff is evaluating the potential impacts of local hydrology on the plant. Thus, in one case the Staff is looking from the inside out, and in the other case it is looking from the outside in. This difference in perspective leads to very different evaluations in relation to the

same resource. Specifically, the analyses in the FSER address, for example, concerns related to the probable maximum flood, an issue unrelated to the environmental review. On the other hand, the analyses in the FEIS address concerns related to issues such as reduced streamflow downstream of the plant.

More generally, for an environmental review under NEPA and Part 51 the Staff evaluates the reasonably foreseeable impacts. In addition, the Staff has the latitude, if numerical data are not available, to qualitatively evaluate the impacts.¹ In contrast, the safety review generally focuses on the results of conservative analyses. As an example, in considering χ/Q values the Staff used "typical" meteorological conditions in the FEIS (see FEIS at 5-63). "Typical" is defined as those conditions that give atmospheric dispersion factors that are exceeded [i.e., dispersion is less and dose is higher] 50 percent of the time. In contrast, for the Chapter 15 analyses in the FSER, the Staff used values for χ/Q associated with "adverse" meteorological conditions (defined as those conditions that give atmospheric dispersion factors that are exceeded no more than 5 percent of the time).

In summary, because of the differences in the basic goals of the analyses in the FEIS and the FSER, there are differences not only in the data used and the approaches applied by the Staff in the analyses, but also in the significance of particular PPE values to those analyses. Based upon the reasoning described above, these differences are to be expected between the FEIS and FSER reviews, including in the Staff's analyses of the particular PPE parameter values and their relevance to the respective safety and environmental conclusions.

Q.6. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the NRC staff's evaluation

¹ As stated in 10 C.F.R. § 51.71(d), "The analysis for all draft environmental impact statements will, to the fullest extent practicable, quantify the various factors considered. To the extent that there are important qualitative considerations or factors that cannot be quantified, these considerations or factors will be discussed in qualitative terms."

of the PPE, the Board requested that the staff discuss the completeness of the PPE parameters for the Grand Gulf ESP and why it is acceptable for the Grand Gulf PPE to provide only a subset of the parameters identified in NEI 01-02.

A.6. (GW) The Staff determined that all of the parameters necessary for the health and safety evaluation of the Grand Gulf ESP PPE were included in the Application and, based on its experience and judgment, including extensive experience with the characteristics of operating reactors, the Staff determined that the values selected for those parameters were not unreasonable.

(JW) The Staff determined that all of the PPE parameters necessary for the Staff's independent evaluation of the Environmental Report for the Grand Gulf ESP were included in the Application or were obtained from reconnaissance-level information gathered in the course of the Staff's environmental review. Based on its experience and judgment, including extensive experience with the characteristics of operating reactors, the Staff determined that the values selected for those parameters were not unreasonable.

(GW, JW) The Staff notes that it has not formally endorsed NEI-01-02, and thus the set of parameters identified in that document is not binding on the Staff in its review of PPEs, including the PPE for the Grand Gulf ESP. In any event, the NEI-01-02 PPE is not intended to represent any specific site or design. Individual PPEs are based on the unique analysis of data needed to support a particular ESP. Although NEI-01-02 identifies other parameters that could be used in generating a PPE, the Staff does not agree that an ESP applicant's PPE must address all the NEI-01-02 parameters to be complete. Indeed, NEI, in correspondence with the NRC concerning the refinement of a PPE worksheet based on the guidance of NEI-01-02, agreed that an applicant should evaluate which parameter values would be necessary for its particular application; that correspondence also noted that the completeness of the industry parameter list would continue to be assessed to identify new or unnecessary parameters. See

Letter from Ronald Simard (NEI) to James Lyons, dated February 7, 2003, ADAMS Accession No. ML030420321.

With respect to the Grand Gulf ESP, the Applicant explained (SSAR Page 1.3-3) that its PPE was derived from a PPE worksheet that was, in turn, based on the guidance of NEI-01-02. The Applicant also explained that the PPE worksheet was refined through work with the NEI ESP Task Force. Because the PPE in the Grand Gulf application is site-specific, it is expected that it would differ from the NEI sample PPE as well as from PPEs developed for other specific sites. For example, some parameters on the NEI list (such as those concerning once-through cooling or cooling ponds) were not relevant to the Grand Gulf ESP application because of the plant design features that the Applicant chose to consider.

In summary, for the Grand Gulf ESP Application, the Staff reviewed the PPE selected by the Applicant and found that the included parameters and parameter values were complete. The Staff agreed that the Applicant's PPE was not unreasonable and was, therefore, acceptable.

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)
)
SYSTEM ENERGY RESOURCES, INC.) Docket No. 52-009-ESP
)
(Early Site Permit for Grand Gulf ESP Site))

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE H:
CONTINUITY BETWEEN THE ESP STAGE AND COL STAGE

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. (GW) George F. Wunder. I am employed as a Project Manager in the ESBWR/ABWR Projects Branch 1, Division of Licensing Project Management, Office of New Reactors, U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

A.1. (JW) James H. Wilson. I am employed as a Senior Project Manager in the New Reactor Environmental Projects Branch, Division of New Reactor Licensing, Office of Nuclear Reactor Regulation, NRC. A statement of my professional qualifications is attached.

A.1. (TC) Thomas Cheng. I am employed as a Geotechnical Engineer in the Division of Engineering, Office of Nuclear Reactor Regulation, NRC. A statement of my professional qualifications is attached.

A.1. (GB) Goutam Bagchi. I am employed as a Senior Advisor in the Division of Engineering, Office of Nuclear Reactor Regulation, NRC. A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit ("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. (GW) I took over Project Management responsibilities in May 2006, following issuance of NUREG-1840, the "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"). I have been responsible for project management activities with respect to the SER since that time.

A.2. (JW) I am the NRC Senior Project Manager for the environmental review of SERI's Grand Gulf ESP application. I was responsible for overseeing the preparation of NUREG-1817, the "Environmental Impact Statement for an Early Site Permit (ESP) at the Grand Gulf ESP Site: Final Report," April 2006 ("FEIS").

A.2. (TC) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in the Grand Gulf Site SER, I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned geotechnical engineering.

A.2. (GB) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in the Grand Gulf SER, I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned hydrology.

Q.3. In its November 6, 2006, Order, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the continuity between the ESP stage and the combined license ("COL") stage, the Board stated that numerous unresolved items, Applicant commitments, NRC Staff assumptions, deferred issues, COL Action Items, and permit conditions, not currently on any list, should be formally captured for transition to the COL stage. Further, the Board stated that it is not clear how these unresolved items, commitments, assumptions, and deferred issues will be tracked

between the ESP and the COL stage, and then subsequently managed (*i.e.*, discovered, implemented, reviewed, and approved), so as to assure that they are satisfactorily completed at the COL stage. In view of the foregoing, please first summarize how reviews were conducted and what steps were taken to assure consistency among the Staff reviewers and contractors.

A.3. (GW) With respect to how reviews were conducted, and the consistency of those reviews, the Staff prepared its Safety Evaluation Report (SER) in accordance with the guidance of RS-002, the Review Standard for "Processing Applications for Early Site Permits," (RS-002). The purpose of RS-002 is to ensure, in part, that evaluations across the spectrum of technical disciplines meet a consistent standard. In addition, RS-002 contains regulatory guidance derived from NUREG-0800, Revision 3, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants" (hereinafter referred to as the Standard Review Plan or SRP). The Standard Review Plan reflects the NRC Staff's historical experience in establishing and promulgating guidance concerning the safety of nuclear facilities, as well as in evaluating safety assessments.

Each section of RS-002 provides specific guidance on how to prepare the corresponding section of the SER. The sections of RS-002 contain subsections defining 1) the specific areas to be reviewed, 2) the acceptance criteria as contained in the relevant section of the Code of Federal Regulations, 3) the review procedures, and 4) guidance on documenting the review findings. In addition to the section-specific guidance, RS-002 states that "[r]eviewers will ensure that the safety case in all assigned sections is adequately supported by clearly identified references as needed." However, because not all portions of the SRP are within the scope of an early site permit (ESP) proceeding, some sections of those guidance documents are not addressed in RS-002 and/or the SER. These issues would be addressed, as appropriate, in the review of a combined license (COL) application that referenced the Grand Gulf ESP.

After the individual sections of the SER are completed, the technical branches submit them to the safety project manager. The safety project manager is tasked by RS-002 to ensure that the facts stated in the Staff's SER are internally consistent as well as consistent with the statements set forth in the applicant's site safety assessment.

After all sections of the SER are completed and the document is compiled, it is again reviewed for consistency by the project manager, project branch chief, and individual technical branches. The project manager is also tasked with obtaining review by and concurrence from Staff counsel to ensure that the SER is defensible and that counsel has no legal objection to the document.

The Staff does employ contractors from outside the NRC as consultants to work on certain areas of the SER; however, the Staff technical branches retain responsibility for the content of their respective sections. All SER input from outside contractors is submitted through the appropriate technical branch. Many outside contractors are familiar with the guidance of RS-002; however, in any event, the individual Staff technical branches are responsible for ensuring that their respective sections of the SER conform to that guidance.

The Staff employs detailed guidance on preparation of the SER as well as a regimen of peer, supervisory, and legal review. Combined, these features ensure consistency across the entire spectrum of the Staff safety review.

A.3. (JW) The NRC standards for review of an ESP application are outlined in 10 C.F.R. § 52.18. The NRC Staff conducts its environmental reviews of ESP applications in accordance with guidance set forth in review standard RS-002. That review standard draws from the previously published NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," as well as from NUREG-1555, "Standard Review Plans for Environmental Reviews for Nuclear Power Plants" (ESRP). As provided in 10 C.F.R. Part 51, Subpart A, Appendix A, the techniques of tiering and incorporation by reference were used to

aid in the presentation of issues, eliminate repetition, and reduce the size of the environmental impact statement (EIS); for example, the Staff also considered the information and analyses provided in NUREG-1437, the "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" in its review.

Each section of RS-002 provides specific guidance on how to prepare the corresponding section of the EIS. The sections of RS-002 contain subsections defining 1) the specific areas to be reviewed, 2) the acceptance criteria as contained in the relevant section of the Code of Federal Regulations, 3) the review procedures, and 4) guidance on documenting the review findings. However, because not all portions of the SRP are within the scope of an early site permit (ESP) proceeding, some sections of those guidance documents are not addressed in RS-002 or the EIS (e.g., the final balancing of the environmental costs and benefits of construction and operation of a nuclear power plant). These issues would be addressed, as appropriate, in the review of a combined license (COL) application that referenced the Grand Gulf ESP.

After the individual sections of the EIS are completed, the technical branches submit them to the environmental project manager. The environmental project manager is tasked by RS-002 to ensure that the facts stated in the Staff's EIS are internally consistent as well as consistent with the statements set forth in the applicant's environmental report.

After all sections of the EIS are completed and the document is compiled, it is again reviewed for consistency by the project manager, project branch chief, and individual technical branches. The project manager is also tasked with obtaining review by and concurrence from Staff counsel to ensure that the EIS is defensible and that counsel has no legal objection to the document.

The Staff does employ contractors from outside the NRC as consultants to work on certain areas of the EIS; however, the Staff technical branches retain responsibility for the

content of their respective sections. All EIS input from outside contractors is submitted through the appropriate technical branch. The contractors from Pacific Northwest National Laboratory are familiar with the guidance of RS-002; however, in any event, the individual Staff technical branches are responsible for ensuring that their respective sections of the EIS conform to that guidance.

The Staff employs detailed guidance on preparation of the EIS as well as a regimen of peer, supervisory, and legal review. Combined, these features ensure consistency across the entire spectrum of the Staff environmental review.

Q.4. With respect to the Board's concerns identified in the previous question, please address whether the Staff is utilizing a consistent approach for formally characterizing the conclusions and limitations of the ESP for unambiguous transition to the COL stage. In doing so, please describe the progression from the ESP to the COL stage in terms of the use of formal lists such as Applicant commitments, Staff assumptions, COL Action Items, etc., and demonstrate that these list(s) are sufficiently comprehensive. Please also discuss the logic behind how the Staff chose which transition items would be formally documented and which would not.

A.4. (GW) With respect to the relationship between the ESP and COL reviews, and the consistency of the Staff's approach to the two reviews, the Board expressed concern about Staff assumptions and applicant commitments and the assurance that these will be tracked so as to be addressed at the COL stage.

In its ESP reviews, the Staff ensures that assumptions and commitments on which an ESP SER relies will be addressed by documenting such assumptions or commitments, either in the SSAR or as Permit Conditions. A Permit Condition is established when 1) the Staff's evaluation in the SER rests on an assumption that is not currently supported; 2) a site physical

attribute is not acceptable, standing alone, for the design of structures, systems, or components important to safety; or 3) the Staff's evaluation depends on some future action.

In addition, in instances where the Staff identifies design information that should be provided by any future applicant referencing the ESP at the COL stage, the Staff generates COL Action Items and includes them as an Appendix to the ESP. COL Action Items identify certain design matters that any future applicant referencing the ESP shall address in the site-specific section of the Final Safety Analysis Report (FSAR). These COL Action Items call for a set of design information to be provided by any future applicant referencing the ESP, but this list is not exhaustive; that is, they do not constitute the complete set of information that must be provided by any future applicant. For example, a COL application referencing a Grand Gulf ESP would still need to meet the requirements of 10 CFR Part 52, Subpart C, and the Staff would review the COL application in accordance with the Standard Review Plan.

There are no other lists of commitments or assumptions on which the Staff bases its SER. If a particular assumption, commitment, or COL-stage information need does not rise to the level of a Permit Condition or COL Action Item, the Staff determines that no further formal documentation is necessary beyond the discussion or reference in the SER.

Consequently, in the course of developing the Grand Gulf SER, the Staff created a list of Permit Conditions. These Permit Conditions become a part of any Early Site Permit (ESP) that may be issued. Also in the course of developing the Grand Gulf SER, the Staff also created a list of COL Action Items. The COL Action Items will be listed in an Appendix to any ESP that may be issued. Finally, the Staff notes that while the Staff had identified a set of Open Items in its Draft SER, all of these Open Items were subsequently resolved and their resolution documented in the Staff's Final SER.

The Staff considers its list of Permit Conditions to be comprehensive because the Staff has determined that the Permit Conditions identified are the only ones necessary to ensure that

10 CFR Part 100 is satisfied. The Staff's list of COL Action Items is not comprehensive in the sense of covering all items needing to be reviewed at the COL stage; in that sense, only the Standard Review Plan would be comprehensive. However, the list of COL Action Items is comprehensive with respect to the Staff having exercised its judgment in identifying site-specific issues relating to design that would need special attention at the COL stage.

The Staff believes that its approach to reviewing the health and safety aspects of the Grand Gulf ESP application and documenting the conclusions and limitations of the ESP has been consistent and comprehensive, and that all relevant conditions and future action items are appropriately presented to facilitate the review of any COL application referencing a Grand Gulf ESP.

A.4 (JW) With respect to the relationship between the ESP and COL reviews, and the consistency of the Staff's approach to the two reviews, the Board expressed concern about Staff assumptions and applicant commitments and the assurance that these will be tracked so as to be addressed at the COL stage.

In the course of developing the Grand Gulf FEIS, the Staff created a list of key assumptions, found in Appendix J to the FEIS. An assumption was considered "key" if the assumption was necessary to determine the magnitude of impact for a particular resource at the proposed site. Therefore, while some assumptions, including certain Applicant commitments, were important enough to be considered key assumptions and documented in Appendix J, the Staff did not prepare a list of all commitments or assumptions. The Staff considers Appendix J to be a sufficiently comprehensive list for the purpose of facilitating a future COL environmental review.

The Staff identified COL Action Items in the Grand Gulf SER for specific design matters that the Staff concluded that a future COL applicant should address in a facility Final Safety Analysis Report. As COL Action Items concern the adequacy of the proposed design, and the

environmental review does not consider the adequacy of the design, the environmental Staff did not identify COL Action Items. While Appendix J of the FEIS presents assumptions and commitments that the Staff intends to verify at the COL stage, the listing of these assumptions and commitments (unlike COL Action Items) does not necessarily reflect the need for new or additional information from the COL applicant at that time.

Issues were deferred in the Grand Gulf FEIS if the ESP application did not address the issue (e.g., the benefits assessment) or if the issue could not be resolved because 1) the ESP application did not provide sufficient information and 2) other information was not then reasonably available to allow the Staff to reach a conclusion on the impacts. However, the Staff was able to resolve or address all environmental issues required for reaching its conclusion with respect to the ESP; no issues were deferred that were necessary for the Staff to make its determination with respect to whether an environmentally preferable or obviously superior site had been identified.

As just stated, the Staff believes that its approach to reviewing the environmental aspects of the Grand Gulf ESP application and documenting the conclusions and limitations of the ESP has been consistent and comprehensive, and that all relevant conditions and future action items are appropriately presented to facilitate the review of any COL application referencing a Grand Gulf ESP.

However, with that in mind, because the Board's question reflects its concern about the broader relationship between an ESP review and the review of a COL referencing an ESP, it may be helpful at this time to note briefly the process and scope of any COL-stage environmental review that would reference an ESP.

For an early site permit, the NRC prepares an EIS that resolves numerous issues within certain bounding conditions. These issues have issue preclusion at the COL or CP stage, provided certain conditions are met. If the issue (e.g., the benefits assessment) could be

deferred and the ESP applicant elected to do so, then the COL applicant would be required to address the issue in its COL or CP application. A COL or CP application must also demonstrate that the design of the facility falls within the parameters specified in the ESP. In addition, the application should indicate whether the site is in compliance with the terms of the ESP. The applicant should maintain, in auditable form, information supporting such a conclusion that the site is in compliance with the ESP. While the NRC is ultimately responsible for completing any required NEPA review -- for example, to ensure that the conclusions for a resolved ESP environmental issue remain valid for a COL action -- the COL applicant must identify whether there is new and significant information¹ on any resolved issue. A COL applicant should have a reasonable process to ensure that it becomes aware of new and significant information that may have a bearing on the earlier NRC conclusion, and should document the results of this process in an auditable form even for issues for which the COL applicant does not identify any new and significant information.

Pursuant to 10 CFR 51.70(b), the NRC is required to independently evaluate and be responsible for the reliability of all information used in the EIS, including an EIS prepared for a COL. In carrying out its responsibilities under 10 CFR 50.70(b), the staff may (1) inquire into the continued validity of the information disclosed in an EIS for an ESP that is referenced in a COL application and (2) look for any new information that may affect the assumptions, analysis, or conclusions reached in the ESP EIS.

The initial burden to assess newly identified information and those issues that were deferred to the COL or CP application falls to the applicant. The applicant is required to provide

¹ The Staff, in the context of a COL application that references an ESP, defines "new" in the phrase "new and significant information" as any information that was not considered in preparing the environmental report included in the ESP application or in the ESP EIS, and that was not generally known or publicly available during the preparation of the ESP EIS. This new information may include (but is not limited to) specific design information that was not contained in the application, but has changed by the time of the COL application. Such new information may or may not be significant.

information sufficient to resolve any other significant environmental issue not considered in the ESP proceeding, either for the site or design, and the information contained in the application should be sufficient to aid the Commission in its development of an independent analysis (see 10 CFR 51.45). Therefore, the environmental report must contain new and significant information identified by the COL applicant.

In the NRC environmental review process for a COL application, the COL EIS brings forward the Commission's earlier conclusions from the ESP EIS and articulates the activities undertaken by the NRC staff to ensure that an issue that was resolved need not be reconsidered. If there is new and significant information on a previously resolved issue, then the staff will limit its inquiry to determine whether such information changes the Commission's earlier conclusion. Environmental matters subject to litigation in a COL proceeding mainly include (1) those issues that were not considered or not resolved in the previous proceeding on the site or the design, (2) those issues for which there is new and significant information, and (3) those issues subject to the change or waiver process in 10 CFR Part 52.

Issuance of a COL is a major Federal Action and, in accordance with 10 CFR 51.20, the NRC must prepare an EIS on that action. If there is no new or significant information on an issue resolved at the ESP stage, then the Staff will tier off from the ESP EIS and disclose the NRC conclusion.

As previously stated, the Staff believes that its environmental review of the Grand Gulf ESP application has resolved all matters necessary for the issuance of an ESP and that the Staff's documentation of its ESP review would support the necessary review process for any COL application referencing a Grand Gulf ESP.

Q.5. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the continuity between the ESP stage and the COL stage, the Board stated that there are several Staff proposed

conditions to the ESP that appear to be difficult, if not impossible, to achieve during the COL stage due to the absolute nature of the requirements. Specifically the Board identified the site characteristic for stability of subsurface materials and foundation, which is defined as minimum shear wave velocity of soil at the proposed foundation level as 1000 feet per second (fps), as such a condition. Please explain in detail how this can be achieved at the COL stage and whether it will be verified.

A.5. (TC) As indicated in SSAR Figures 2.5-75 through 2.5-77 (Rev. 1), the foundation for a reactor referencing the ESP site would be about 140 ft below the grade (Elevation -5 ft), which is in the old alluvium zone. In Revision 1 of SSAR Figures 2.5-36 and 2.5-37, the shear wave velocity of the old alluvium at Elevation -5 ft is greater than 1000 fps. During the COL stage, the soil above Elevation -5 ft needs to be removed to allow the construction of the proposed powerblock area (PPBA) foundation mat. On this basis, the site characteristic of "shear wave velocity of 1000 fps or greater for the foundation of the power block" can be achieved at the COL stage.

Q.6. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the continuity between the ESP stage and the COL stage, the Board stated that there are several Staff proposed conditions to the ESP that appear to be difficult, if not impossible, to achieve during the COL stage due to the absolute nature of the requirements. Please explain in detail how proposed Permit Condition No. 2 (which requires that an applicant referencing the Grand Gulf ESP design any new unit's radwaste systems with features to preclude any and all accidental releases of radionuclides into any potential liquid pathway) can be achieved at the COL stage:

A.6. (GB) Consistent with 10 CFR Part 52, a specific plant design evaluation was not conducted in this ESP review. The Staff's sole conclusion at the ESP stage is that the requirements postulated in the proposed Permit Condition 2 are not technically unreasonable.

The Staff based this conclusion on recent certified designs and on an understanding of historic inadvertent releases at various nuclear facilities. The Staff concluded that engineering solutions did exist that could have precluded these past releases. The proposed Permit Condition 2 can be met through the use of radwaste facility designs that are already incorporated in some certified designs. These certified designs of advanced and passive reactors locate the radwaste facility on the nuclear island, protected from leakage by stainless steel liner and leakage collection drains. These designs are also provided with high surrounding walls to contain any inadvertent spillage during radwaste handling or any unanticipated component failure. The Staff concluded that preclusion of accidental releases, including inadvertent releases, is technically feasible as in the examples cited above.

November 20, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF PRE-FILED TESTIMONY CONCERNING HEARING ISSUE I
RADIOLOGICAL REVIEWS AND CONFIRMATORY ANALYSES

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. (JL) Jay Y. Lee. I am employed as a Senior Health Physicist in the Division of Risk Assessment, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission ("NRC").

A.1. (SK) Stephen Klementowicz. I am employed as a Senior Health Physicist in the Division of License Renewal, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission ("NRC")

A.1. (EH) Eva Eckert Hickey. I am employed as a Staff Scientist with the Radiological Science and Engineering Group, Pacific Northwest National Laboratory operated by Battelle. I am providing testimony under a technical assistance contract with the staff of the U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

A.1. (JR) James V. Ramsdell, Jr. I am employed as a Staff Scientist with the Atmospheric Chemistry & Meteorology Technical Group at the U. S. Department of Energy's Pacific Northwest National Laboratory operated by Battelle. I am providing testimony under a

technical assistance contract with the staff of the U.S. Nuclear Regulatory Commission ("NRC"). A statement of my professional qualifications is attached.

A.1. (GB) Goutam Bagchi. I am employed as a Senior Advisor in the Division of Engineering, Office of Nuclear Reactor Regulation, NRC. A statement of my professional qualifications is attached.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit ("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. (JL) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in NUREG-1840, "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"), I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned geography and demography, and the radiological consequences of design basis accidents ("DBAs").

A.2. (SK) As part of the NRC Staff's health and safety review of the SERI ESP application, documented in NUREG-1840, "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"), I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned the radioactive waste treatment system and the radiological impacts from routine operation to plant workers, members of the public, and to the environment. I was also part of the NRC Staff's environmental review of the SERI ESP application, documented in NUREG-1817, "Environmental Impact Statement for an Early Site Permit (ESP) at the Grand Gulf ESP Site: Final Report," April 2006 ("FEIS"). I reviewed the aspects of the Applicant's Environmental Report that concerned the radioactive waste treatment system and the radiological impacts from routine operation to plant workers, members of the public, and to the environment.

A.2. (EH) As part of the NRC Staff's environmental review of the SERI ESP application, documented in NUREG-1817, "Environmental Impact Statement for an Early Site Permit (ESP) at the Grand Gulf ESP Site: Final Report," April 2006 ("FEIS"), I assisted the NRC staff in its analysis of the aspects of the Applicant's Environmental Report that concerned health effects from radiological and non-radiological impacts, uranium fuel cycle impacts and decommissioning.

A.2. (JR) As part of the NRC staff's environmental review of the SERI ESP application, documented in the Grand Gulf FEIS, I assisted the NRC staff in its analysis of the aspects of the Applicant's Environmental Report that concerned meteorology, air quality, and the impact of postulated accidents.

A.2. (GB) As part of the NRC staff's health and safety review of the SERI ESP application, documented in the Grand Gulf SER, I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned hydrology.

Q.3. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the Staff's radiological reviews and confirmatory analyses, the Board requested an overview of the radiological analyses performed by SERI and the NRC Staff's review of these analyses, including details regarding the nature of confirmatory analyses performed (or not performed) by the NRC Staff or its contractors. For normal releases, please provide an overview of the radiological analyses and results, and discuss the Staff review that was performed including the method and results of the confirmatory analyses.

A.3. (EH, SK) With respect to the radiological environment, the Staff reviewed annual radioactive effluent release reports for calendar years 2001, 2002, and 2003, (see ADAMS Accession Nos. ML021200537, ML031120162, and ML041260549, respectively) and found that doses to the maximally exposed individuals around GGNS Unit 1 were a small fraction of the

limits specified in Federal environmental radiation standards, 10 C.F.R. Part 20; 10 C.F.R. Part 50, Appendix I; and 40 C.F.R. Part 190. FEIS at 2-19.

The Staff reviewed the documentation for SERI's proposed radiological environmental monitoring program ("REMP"). The Staff found the proposed REMP to be adequate, noting that SERI will provide an annual Radiological Environmental Operating Report for the entire site (including both GGNS Unit 1 and the new nuclear unit(s)) to compare data with those for previous years; that the REMP would utilize the sampling locations used by the GGNS Unit 1; and that SERI will implement a quality assurance program for the REMP. Both surface and groundwater are monitored under the Radiological Environmental Monitoring Program (REMP). The REMP includes 3 samples of surface water (1 upstream, 1 downstream, and 1 downstream during a liquid radwaste discharge) and 2 samples of groundwater taken at two different wells on an annual basis. All five of these samples are submitted for gamma isotopic and tritium analyses. This monitoring is an operational program, and the results are reported annually in the Grand Gulf Nuclear Station Annual Radiological Environmental Monitoring Program Summary. For the purposes of the ESP analysis, the Staff determined that the REMP for the operation of Unit 1 was also adequate for determining the baseline for comparison with the expected impacts to the environment related to construction and operation of any proposed new unit(s). FEIS at 5-61 to 5-62.

With respect to radiological health impacts, after reviewing SERI's estimate of dose to site preparation workers during construction activities (from direct radiation as well as from gaseous and liquid effluents), the Staff found the doses to be well within NRC exposure limits designed to protect the public health. The Applicant's evaluation included an annual dose estimate for the site preparation workers of approximately 0.36 mSv (36 mrem), which is less than the 1 mSv (100 mrem) annual dose limit to an individual member of the public found in

10 C.F.R. § 20.1301. Therefore, assuming the location of the proposed new nuclear unit does not change, the Staff concluded that the impacts of radiological exposures to site preparation workers would be SMALL. FEIS at 4-56.

The Staff evaluated the health impacts from routine gaseous and liquid radiological effluent releases from a new nuclear unit at the Grand Gulf ESP site. After independently evaluating SERI's assessment of likely exposure pathways and its use of the LADTAP II and GASPAR II modeling programs to calculate the dose to a maximally exposed individual and a collective whole body dose for the population within 80 km (50 mi) of the Grand Gulf ESP site, and comparing the calculated doses to regulatory design objectives, the Staff concluded that there would be no observable health impacts to the public from normal operation of a new nuclear unit, and therefore the health impacts would be SMALL. FEIS at 5-51 to 5-58.

Furthermore, the Staff concluded that the health impacts from occupational radiation exposure would be SMALL. This conclusion is based on the determination that: the occupational exposures for the new nuclear unit would likely be bounded by occupational exposures from currently operating LWRs and the licensee of a new plant will need to apply the ALARA process to maintain individual doses to workers as low as reasonably achievable below the 0.05 Sv (5 rem) annual limit, as specified in 10 C.F.R. § 20.1201. FEIS at 5-58.

The Staff examined the Applicant's estimated doses to surrogate biota species for both liquid and gaseous effluent pathways. FEIS at 5-59. The Staff's independent evaluation of biota doses produced results similar to those generated by the Applicant. FEIS at 5-60. As stated in Appendix H, the Staff used the LADTAP II code, GASPAR II code, and input parameters supplied by SERI in its ER to calculate doses to the biota. As part of its independent review, the Staff requested SERI's input values for these codes, and reviewed them for reasonableness. It then ran the codes using SERI's input and default values from Regulatory Guide 1.109 (when input values were not provided) to verify the results of SERI's

dose assessment. The Staff concluded that there was sufficient protection because the cumulative effects of the GGNS unit 1 and the new nuclear unit(s) would result in dose rates significantly less than those noted in studies by the National Council on Radiation Protection and Measurements ("NCRP") and International Atomic Energy Agency ("IAEA"), both of which found adequate protection for biota. Therefore, the Staff concluded that the radiological impact on biota) other than members of the public from routine operation would be SMALL. FEIS at 5-59 to 5-61.

Q.4. In its November 6, 2006, Order, the Atomic Safety and Licensing Board ("Board") identified certain issues to be addressed in connection with the mandatory hearing. With regard to the Staff's radiological reviews and confirmatory analyses, the Board requested an overview of the radiological analyses performed by SERI and the NRC Staff's review of these analyses, including details regarding the nature of confirmatory analyses performed (or not performed) by the NRC Staff or its contractors. Please discuss the selection of the design basis accidents and explain the difficulties associated with event names that appear in the SSAR, FSER, and FEIS.

A.4. (JL) The Staff used the design basis accidents ("DBAs") that are listed and analyzed in: (1) RG 1.183, "Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors"; (2) NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Report for Nuclear Power Plants," Section 15.0.1, "Radiological Consequence Analyses Using Alternative Source Terms"; and (3) NUREG-1555, "Standard Review Plan for Environmental Reviews for Nuclear Power Plants." The DBA event names, which appear in the SSAR, FSER, and FEIS, are reconciled and summarized in Staff Exhibit 10.

Q.5. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the Staff's radiological reviews and confirmatory analyses, the Board requested an overview of the radiological analyses performed by SERI and the NRC Staff's review of these analyses, including details

regarding the nature of confirmatory analyses performed (or not performed) by the NRC Staff or its contractors. For accidental releases, please provide an overview of the radiological analyses and results for the design basis events (including the key input, assumptions, and methodology) and discuss the Staff review that was performed, including the method and results of any confirmatory analyses.

A.5. (JL) The Applicant did not select a particular reactor design, but instead used surrogate reactor designs (ABWR and AP1000) to demonstrate the site suitability of the proposed ESP site. Therefore, as stated in the FSER, Section 15.3.4 (page 15-8), the Staff did not perform independent confirmatory radiological consequence analysis reviews of the Grand Gulf ESP application, because the Applicant based its radiological analyses and design basis events on the AP1000 and ABWR designs.

The Staff did, however, perform an independent confirmatory review at the time of the design certifications of the AP1000 and ABWR. The Applicant did not perform a new radiological consequence analysis, but instead directly extracted the radiological consequence analysis results from design certification documentation previously submitted to and reviewed by the NRC in connection with the design certification applications.

The Applicant used either: (1) the ratio of the site-specific atmospheric dispersion factors (χ/Q values) to the postulated design χ/Q values along with the calculated doses in the certification document to assess the suitability of the proposed ESP site for the AP1000 DBAs and ABWR Loss of Coolant Accident (LOCA) (see Staff Exhibit 11] for the methodology used by the Applicant - Case 1); or (2) calculated a site-specific dose using the source term releases in the certified ABWR Design Control Document (DCD) for ABWR DBAs other than LOCA (see Staff Exhibit 11 for the methodology used by the Applicant - Case 2).

The Commission approved the key input, assumptions, and methodology used by the Applicant, and the Staff in its review, for each DBA, including the results of the Staff's

confirmatory radiological consequence analyses for the referenced standard reactor design certifications (ABWR and AP1000). This information is documented in NUREG-1503, "Final Safety Evaluation Report Related to the Certification of the Advanced Boiling Water Reactor Design," and NUREG-1793, "Final Safety Evaluation Report Related to the Certification of the AP1000 Standard Design."

A.5. (JR) In the SSAR, ER, FSER, and FEIS, the Applicant and the Staff considered a range of design basis accidents for the ABWR and AP1000 reactor designs and a loss-of-coolant accident for the ACR-700 reactor design. The Staff has evaluated design basis accidents for the ABWR and AP1000 reactors at length as part of the design certification process for those reactors. As a result of this process, appropriate design basis accidents and source terms for each accident have been established. In addition, a design dispersion factor has been established for each design. This dispersion factor is a metric, which characterizes how good the atmospheric dispersion has to be at a site to ensure that doses resulting from design basis accidents will fall below regulatory evaluation criteria. This dispersion factor is a design characteristic, not a site characteristic.

The Staff assumes that information related to the ABWR and AP1000 designs from the design certification process is an appropriate starting point for review of design basis accidents related to the SERI application for the Grand Gulf site. The Staff compared the selection of accidents for these designs with accidents evaluated in the design certification process and with accidents listed in various guidance documents such as standard review plans (e.g. RS-002, NUREG-0800, and NUREG-1555) and in Regulatory Guides (e.g., Regulatory Guides 1.3 and 1.183) and determined that the set of design basis accidents considered in the SSAR and ER is appropriate. The Staff also determined that the design basis accident source terms and evaluation methods used by the Applicant were generally appropriate.

The Staff also evaluated the Applicant's site-specific information (i.e., meteorological data and distances to the exclusion area boundary and outer boundary of the low population zone) to ensure that the information was appropriate for estimating the potential consequences of design basis accidents. This information was found to be acceptable with the exception of the atmospheric dispersion factors used to evaluate the consequences of design basis accidents in the Environmental Report (ER).

Having reviewed the selection of DBAs, the calculational methods, and the input to the DBA calculation, Staff concludes that the Applicant's DBA analysis presented in the SSAR are acceptable for the safety review of the ESP application.

The atmospheric dispersion factors used in the ER are the same as those used in the SSAR. This is inconsistent with NRC guidance and with the intent of NEPA. The atmospheric dispersion factors used in safety analyses are for adverse meteorological conditions, while those used in environmental reviews are for typical meteorological conditions. Adverse meteorological conditions are those conditions that result in doses that are exceeded no more than about 5% of the time; typical meteorological conditions are those conditions that are exceeded 50% of the time. NEPA reviews are focused on realistic estimates of impacts, not worst-case estimates.

The Staff extracted realistic site-specific atmospheric dispersion factors from data provided by the Applicant and used those factors in its DBA review in the FEIS. With this exception, the DBA analyses performed for the FEIS were identical to those performed for the FSER. The results of the Staff's DBA analyses are presented in the FEIS. On the basis of the Staff's results, the Staff concludes that the environmental impacts of postulated DBAs would be of small significance at the Grand Gulf ESP site.

The Staff also reviewed the potential consequences of an ACR-700 loss-of-coolant accident. The ACR-700 design has not been submitted for design certification. However, the Staff notes that given the information provided by the Applicant, the consequences of a

postulated loss-of-coolant accident for the ACR-700 reactor design are smaller than those of an AP1000 design.

Q.6. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the Staff's radiological reviews and confirmatory analyses, the Board requested an overview of the radiological analyses performed by SERI and the NRC Staff's review of these analyses, including details regarding the nature of confirmatory analyses performed (or not performed) by the NRC Staff or its contractors. For the severe accidents discussed in the FEIS, please provide an overview of the MACCS2 analyses, results, and the nature of the NRC Staff's review, including the results of any confirmatory analyses for the air and water ingestion pathways. In addition, for the non-MACCS2 severe accident effects, such as groundwater release, please elaborate further on the basis for the conclusion that the risks for these pathways are acceptably small.

A.6. (JR) The potential impacts of severe accidents are evaluated as part of the environmental review of an ESP application. In its application, SERI evaluated the potential impacts of severe accidents using general correlations between severe accidents and impacts presented in NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants." The Staff believes that a site-specific evaluation of these potential impacts is more appropriate. Consequently, the Staff requested that SERI provide such evaluations; SERI complied with this request and provided the Staff with input to and output from the MACCS2 computer code for postulated severe accidents for both ABWR and AP1000 reactor designs at the Grand Gulf ESP site. The Staff reviewed SERI's input to the MACCS2 code and then used the input to rerun the code. When the results of the SERI and Staff code runs were compared, there were no differences in the output. In addition to providing the Staff with code input and output, SERI provided its summarized results, which the Staff reviewed. Ultimately, the Staff

extracted pertinent results from the computer code output for the evaluation presented in the FEIS rather than using the information in the SERI summary.

The MACCS2 computer code is a second generation code used for assessing the environmental consequences of severe accidents. It was developed by Sandia National Laboratory for both the U.S. Nuclear Regulatory Commission and the U.S. Department of Energy. It uses time-varying site-specific meteorology to evaluate transport, dispersion, and deposition of radionuclides, which might be released to the atmosphere during a severe accident. Other input to the code includes land use patterns and population distributions. Given this input, MACCS2 estimates probability distributions for health and economic impacts of these releases and accounts for short- and long-term mitigative actions.

MACCS2 deals with the atmospheric pathway and, to the extent that surface water is contaminated by the deposition of radionuclides, the surface water pathway. MACCS2 does not deal with the contamination of surface water due to liquid spills or due to the contamination of ground water as a result of core damage followed by basemat melt-through.

The FEIS presents a limited discussion of the groundwater pathway, based on the NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants," evaluation of the groundwater pathway for severe accidents at current generation nuclear power plants. This NUREG discusses the probability of a severe accident followed by basemat melt through, which was assumed to be 1×10^{-4} Ryr⁻¹. Using this assumption, NUREG-1437 estimates, based on the Liquid Pathway Generic Study (NUREG-0440), that for large river sites (e.g. Grand Gulf) the population risk is approximately 12 person-rem per reactor year, but notes that interdiction can reduce the risk by an order of magnitude.

The basemat melt-through assumed in NUREG-1437 is unrealistically conservative for the ABWR and AP1000 reactor designs. The total core damage frequencies from internal events for the ABWR and AP1000 reactor designs are about 2×10^{-7} Ryr⁻¹. It is unrealistic to

assume that the probability of basemat melt-through is greater than the core damage frequency. The Staff believes that for advanced light water reactors, a basemat melt-through probability of 1×10^{-6} Ryr⁻¹ would be bounding and a probability of 1×10^{-7} Ryr⁻¹ would be reasonable because 1) not all core damage events lead to basemat melt-through, and 2) advanced light-water reactors have design features intended to prevent melt-through (e.g., systems to flood the reactor cavity). Thus, the Staff believes that the risks associated with the groundwater pathway are acceptably small.

Q.7. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the Staff's radiological reviews and confirmatory analyses, the Board requested an overview of the radiological analyses performed by SERI and the NRC Staff's review of these analyses, including details regarding the nature of confirmatory analyses performed (or not performed) by the NRC Staff or its contractors. Please explain why the contribution of external events was not specifically factored into the core damage frequencies used in the presentation of the analysis results.

A.7. (JR) The Staff has considered external initiating events for severe accidents. NUREG-1742, "Perspectives Gained From the Individual Plant Examination of External Events (IPEEE) Program," presents a detailed discussion of external initiating events at current power plants. It shows that core damage frequencies from external events are, in general, not significantly larger than those from internally initiated events, and in many cases are smaller.

In the design certification process, the Staff considered external initiating events for ABWR and AP1000 severe accidents. Specifically, Chapter 19 of the ABWR design control document and Chapter 19 of the AP1000 FSER consider seismic events, internal fires, and internal floods; the ABWR DCD also considers tornadoes. The AP1000 FSER has some numerical core damage frequency values supplied by the vendor. In contrast, the ABWR DCD

does not include core damage frequency values; instead, it makes qualitative statements related to CDFs such as "extremely small."

The AP1000 FSER has some numerical core damage frequency values supplied by the vendor. However, the Staff did not adopt these values because it believes that such conclusions are not possible without a detailed PRA. Rather, the FSER makes qualitative statements related to CDFs, as in the case of internal fires where it states: "the AP1000 design is capable of withstanding severe accident challenges from internal fires in a manner superior to most, if not all, operating plant designs." Section 19.1.5.2.1 of the FSER, page 19-83.

Finally, the Staff compared the risks from internally initiated severe accidents with the Commission's safety goals and determined that those risks are significantly below the risks set forth in the goals.

For these reasons, the Staff concluded that an attempt at detailed consideration of external initiating events would not contribute significantly to the purposes of the FEIS or NEPA.

Q.8. In its November 6, 2006, Order, the Board identified certain issues to be addressed in connection with the mandatory hearing. With regard to the Staff's radiological reviews and confirmatory analyses, the Board requested an overview of the radiological analyses performed by SERI and the NRC Staff's review of these analyses, including details regarding the nature of confirmatory analyses performed (or not performed) by the NRC Staff or its contractors. Please address whether or not ESP Permit Condition 2 (FSER, App. A, Table A.1) precludes the need to perform an analysis of the liquid radwaste tank failure event at the COL stage, or to what extent it impacts the assumptions associated with the analysis of such an event.

A.8. (GB) The Staff's proposed Permit Condition 2 requires the preclusion of any and all accidental releases of radionuclides to any potential liquid pathway. Permit Condition 2 does not address the analysis of radwaste tank failure events or the design of the tank itself. No radwaste tank failure analysis is needed at the COL stage for reactor designs that incorporate the same

design criteria as the entire seismic Category I structures, systems and components for the selected reactor design, and that incorporate features, such as suitable barriers, to contain any accidental spillage of radioactive liquid effluents due to random component failure. Therefore, Permit Condition 2 does not impact the need to perform an analysis of the tank failure event at the COL stage. The preclusion of accidental spillage of liquid radwaste effluents is achievable by design, it has already been incorporated into some certified designs. There is therefore no need to use a COL Action Item to require a review of a postulated radwaste tank failure.

1 Geotechnical and Hydrology
2 Issues and Errata were
3 admitted into evidence.)

4 JUDGE MCDADE: Let me let you take care
5 of certain of the administrative things because I
6 have certain questions with regard to those latter
7 two. The latter two appeared to be a follow-up on
8 the proposed findings of fact and conclusions of law
9 that the staff submitted and I just want to make
10 sure that we are correctly viewing these. So I've
11 got a couple of questions about them for the staff
12 before we proceed further.

13 MR. RUND: Yes, Your Honor.

14 JUDGE MCDADE: But I don't want you to
15 be doing three things at once, so.

16 MR. WEISMAN: I can address those
17 questions, Your Honor.

18 JUDGE MCDADE: Okay, specifically with
19 regard to the hydrology supplemental testimony. Can
20 you describe the purpose of that?

21 MR. WEISMAN: Yes, Your Honor. In our
22 proposed findings of fact that we filed on August
23 11, 2006, we identified in footnotes several matters
24 that the staff felt the SER needed clarification.
25 And in those footnotes, which are Footnotes 6 - 12

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

November 22, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF SUPPLEMENTAL PRE-FILED TESTIMONY
CONCERNING HYDROLOGY

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. Goutam Bagchi. I am a Senior Advisor in the Nuclear Regulatory Commission's (NRCs), Office of Nuclear Reactor Regulation (NRR), Division of Engineering (DE). A statement of my professional qualifications was attached to the NRC Staff's pre-filed testimony submitted on November 20, 2006, in response to hearing issues identified by the Board.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit ("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. As part of the NRC staff's health and safety review of the SERI ESP application, documented in NUREG-1840, the "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site," April 2006 ("SER"), I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned hydrology.

Q.3. In the "NRC Staff's Proposed Findings of Fact and Conclusions of Law in the Mandatory Hearing," filed with the Board on August 11, 2006, the Staff indicated that it intended to clarify certain points in NUREG-1840 in pre-filed testimony. With respect to section 2.4.2.3 of NUREG-1840, please explain the difference between the effects of intense precipitation in the local site area and that in site region that leads to a probable maximum flood ("PMF").

A.3. In Section 2.4.2.3 of NUREG-1840, the Staff described how it used the National Oceanic and Atmospheric Administration ("NOAA") Hydrometeorological Report ("HMR") 52 guidelines to estimate the 1-hour 1-mi² probable maximum precipitation depth for the ESP site. However, the Staff did not explain the difference between the effects of intense precipitation in the local site area and those in the site region that lead to a probable maximum flood ("PMF").

Flooding can occur at a site through different mechanisms, two of which are the PMF and local intense precipitation. Local intense precipitation is a measure of the extreme amount of water falling in the immediate vicinity of the site no more than one square mile in area that is considered in the engineering design of local site drainage. In response to local intense precipitation, immediate flooding by ponding at the site may occur due to inadequate infiltration capacity and a lack of an efficient drainage system. The difference between the floods caused by local intense precipitation and PMF is that the former occurs at an immediate site, whereas PMF is the routed discharge from a probable maximum precipitation ("PMP") event occurring over an entire watershed within which a site is located.

PMF is derived by routing a PMP event through the watershed. NOAA Hydrometeorological Reports provide methods for estimation of PMP in watersheds of ten to 20,000 square miles for several durations (six to 72 hours). HMRs also provide methods for estimation of so-called "point" PMP of one-hour duration. NOAA recommends that a "point" be interpreted as a one square-mile area. HMRs provide maps to determine PMP values for

durations less than one hour for a point (one square-mile area); this PMP is the local intense precipitation (SER Tables 2.4-2 and 2.4-2a).

Q.4. Please clarify how mitigation measures for these two flooding mechanisms are different.

A.4. Protection from PMF may be provided by siting the plant above the PMF flood elevation, but flooding from local intense precipitation cannot be controlled by siting. Rather, flooding from local intense precipitation must be mitigated by an effective and efficient site drainage system.

Q.5. Please clarify what guidance the Staff used for estimating the design-basis flooding considering the worst single phenomenon, as well as combinations of less severe phenomena.

A.5. The Staff used RG 1.59, Rev. 2, "Design Basis Floods for Nuclear Power Plants," August 1977, and ANSI/ANS-2.8-1992, "Determining Design Basis Flooding at Power Reactor Sites," July 1992, for estimating the design-basis flooding considering the worst single phenomenon, as well as combinations of less severe phenomena. SER at 2-85. The Staff also used USGS, NOAA, Natural Resources Conservation Service (formerly the Soil Conservation Service), USACE, and applicable State and river basin authority publications to verify the Applicant's data relating to extreme events in the region. SER at 2-85.

Q.6. Please clarify the Staff's analysis of the Applicant's PMP depth estimates and of flooding effects of local intense precipitation for the Grand Gulf ESP site.

A.6. With respect to the Applicant's revised estimates of PMP depth, the Staff determined that these conformed to the latest HMR-52 criteria. SER at 2-88. The Staff also prepared its own estimates of PMP depths, and the Applicant's estimates closely matched those of the Staff. SER at 2-88. Therefore, the Staff concluded that the Applicant's PMP depth estimates were acceptable. SER at 2-88. Accordingly, the Staff established a site

characteristic for local intense precipitation, or PMP, of 19.2 inches per hour, of which 6.2 inches falls during the first 5 minutes. SER Table 2.4.14-1 at 2-141. This PMP is for a one square mile area, and is considered as local intense precipitation that would fall on the Grand Gulf ESP site rather than a PMF in the Mississippi River near the site caused by a PMP event in the Mississippi River Basin. The local intense precipitation will also be used to determine the flooding elevation in Streams A and B (located on the site, see SER at 2-74) and to design the site grading as described below.

The Staff noted that the area of Basin A (located on the site, see SER at 2-72) is 2.94 square miles, and that there is no guidance for determination of PMP values for areas that are larger than one square mile but smaller than ten square miles. Nonetheless, the PMP value for an area exceeding one square mile in size will be less than that for a one square-mile area (a point), and greater than that for a ten square-mile area. Therefore, one-square mile PMP (point PMP or local intense precipitation) is a conservative estimate (greater than the true value) for the PMP value for Basin A. Accordingly, flooding resulting from local intense precipitation based on a one-square mile PMP value for Basin A will also be conservative (more severe than the true value).

Based on the physical site topography and the location of the proposed powerblock area (PPBA) to the west of the site access road and downstream of existing culverts, the Staff found that it is reasonable to expect that flood water elevation in Streams A and B adjacent to the PPBA would be substantially less than that of the proposed ESP site grade. SER at 2-79.

While a comprehensive flood water elevation analysis for the site cannot now be carried out, the

Staff found further that, given the topographic location of the ESP site in relation to Streams A

and B, an effective drainage system can be designed when a COL application is filed that

references any ESP that might be issued. SER at 2-79, 2-80. Accordingly, the Staff

established COL Action Item 2.4-3, which relates to the design of site grading. SER at 2-80.

The design of this grading will afford flood protection to safety-related structures for any new unit at the ESP site based on a comprehensive flood water routing analysis for a local PMP (local intense precipitation) event. SER at 2-80. Similarly, since the maximum water surface elevation depends on the site grade and locations of safety-related structures, as well as local intense precipitation, the Staff established COL Action Item 2.4-5, which relates to plant grade and drainage system design based on the maximum water surface elevation on the site. SER at 2-89. COL Action Item 2.4-5 provides that a COL or construction permit applicant should demonstrate that the ESP plant grade is safe from the flooding effects of maximum water surface elevation during local intense precipitation without relying on any active surface drainage systems that may be blocked during this event. SER at 2-89; SER Appendix A.2, Action Item No. 2.4-5.

Q.7: Please clarify the Staff's analysis with respect to the PMF from the Mississippi River.

A.7. In analyzing the PMF from the Mississippi River, the Staff determined a maximum wave height of 10.9 feet, and added this to the Mississippi River DPF to arrive at maximum water surface elevation. SER at 2-96. The Staff also agreed that the water surface elevation at peak PMF discharge will not be appreciably higher than 103 feet above MSL, the top surface elevation of the levee on the west bank of the Mississippi River. SER at 2-89. In this regard, the Staff established a site grade of 132.5 feet above MSL as a characteristic of the ESP site. SER at A-16. In view of the above, the Staff estimated that the highest water surface elevation in the Mississippi River as a result of the DPF, wind setup, and wave runup will not impact the ESP site since the maximum water surface elevation is significantly below the ESP site grade. SER at 2-87; SER § 2.4.3. Accordingly, a PMF on the Mississippi River will not cause flooding of the proposed Grand Gulf ESP site.

Based on the facts and reasoning documented in the SER, as well as those just mentioned, the Staff found that the Applicant provided sufficient information pertaining to floods.

November 22, 2006

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	

NRC STAFF SUPPLEMENTAL PRE-FILED TESTIMONY
CONCERNING GEOTECHNICAL ISSUES

Q.1. Please state your name, occupation, by whom you are employed and your professional qualifications.

A.1. Thomas M. Cheng. I am employed as a Senior Structural/Geotechnical Engineer in Geosciences and Civil Engineering Branch A (EGCA), Division of Engineering (DE), Office of Reactor Regulation (NRR), Nuclear Regulatory Commission (NRC). A statement of my professional qualifications was attached to the NRC Staff's pre-filed testimony submitted on November 20, 2006, in response to hearing issues identified by the Board.

Q.2. Please describe your professional responsibilities with regard to the review of the application by System Energy Resources, Inc. ("SERI" or "Applicant") for an early site permit ("ESP") for a new nuclear power plant or plants to be located on the existing Grand Gulf Nuclear Station ("GGNS") site near Port Gibson, Mississippi.

A.2. As part of the NRC Staff's health and safety review of the SERI ESP application, documented in NUREG-1840, the "Safety Evaluation Report for an Early Site Permit (ESP) at the Grand Gulf Site" ("SER"), I reviewed the aspects of the Applicant's Site Safety Analysis Report that concerned geotechnical engineering related issues.

Q.3. In the "NRC Staff's Proposed Findings of Fact and Conclusions of Law in the Mandatory Hearing," filed with the Board on August 11, 2006, the Staff indicated that it intended to clarify certain points in NUREG-1840 in pre-filed testimony. Please clarify the Staff's discussion in NUREG-1840 with respect to stability of subsurface materials and foundations.

A.3. With respect to stability of subsurface materials and foundations overall, the Staff concluded that the Applicant adequately determined the engineering properties of the soil encountered during its field and laboratory investigations, and that the Applicant provided sufficient technical information in the geotechnical area to demonstrate the suitability of the ESP site for building a new nuclear power plant. SER at 2-241. The Staff found that the Applicant used the latest field and laboratory methods, in accordance with RGs 1.132, 1.138, and 1.198, "Procedures and Criteria for Assessing Seismic Soil Liquefaction at Nuclear Power Plant Sites," issued November 2003, to determine these properties. SER at 2-241. With respect to field investigations and laboratory testing necessary for the design of safety-related structures, however, the Staff also concluded that the Applicant did not perform activities sufficient to adequately define the overall subsurface profile, as well as the potential variability of the properties of the soil underlying the ESP site; the Staff therefore noted the Applicant's commitment to perform additional field investigations, once it has selected the locations and facilities for safety-related structures at the COL stage. SER at 2-241. In this regard, the COL action items included in SER Appendix A that relate to the stability of subsurface materials and foundations will prompt an applicant for a COL or CP to address the adequacy of the design of structures that would be built if a COL or CP were later granted.

Q.4. Please clarify the Staff's discussion in NUREG-1840 with respect to embankments and dams.

A.4. The Staff found that no impoundment structures lie within the ESP area. SER at 2-246. The Staff also found that the Applicant provided sufficient descriptions of the

embankments and dams in the site vicinity to support its ESP application. SER at 2-246. The Staff, in SER §§ 2.4.4 and 2.5.5, discussed all other issues relevant to dams and embankments, respectively. Since the Applicant did not evaluate the effect of potential flooding of the Mississippi River and possible future erosion of the bluff, as discussed in SER Section 2.5.5.1 (SER at 2-242), the Staff established COL Action Item 2.5-11, which provides that a COL or CP applicant should evaluate the effect of potential flooding of the Mississippi River and possible future erosion of the bluff, including their impacts on soil-structure interaction (SSI) effects of the plant. SER at 2-246, A-8. On this basis, the Staff concluded that the assessment of embankments and dams presented in this SSAR section is acceptable for the ESP application. SER at 2-246.

1 in the staff proposed findings, we included
2 testimony in the NRC staff supplemental pre-filed
3 testimony concerning hydrology to address those
4 matters. They're simply to clarify the SER and make
5 sure that the staff's position is well understood.

6 JUDGE MCDADE: Okay. And also just to
7 note that in those proposed findings of fact and
8 conclusions of law, when you originally submitted it
9 you indicated in those footnotes, those several
10 footnotes, that you would be submitting the
11 supplemental testimony, and this is the follow-up on
12 that.

13 MR. WEISMAN: Yes, Your Honor.

14 JUDGE MCDADE: Okay. And then with
15 regard to the next one on geotechnical issues, that
16 basically is the same thing -

17 MR. WEISMAN: Yes.

18 JUDGE MCDADE: - except with regard to
19 different issues and different footnotes.

20 MR. WEISMAN: Yes, Footnotes 14 and 15
21 in the proposed findings.

22 JUDGE MCDADE: Okay. Does SERI need any
23 further clarification on that?

24 MS. SUTTON: No, Your Honor.

25 JUDGE MCDADE: Okay. Now, also the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 staff submitted various exhibits. The exhibits, we
2 had directed that they be pre-marked and pre-filed.
3 Do you have at this point a full index of the
4 proposed staff exhibits and a copy of those exhibits
5 that can be furnished to the court reporter?

6 MR. RUND: We have all but the exhibits
7 from the engineering report that's mentioned I
8 believe in the staff's testimony on Hearing Issue D.

9 JUDGE MCDADE: Okay, that was
10 specifically SERI Engineering Report 02, is that
11 correct?

12 MR. RUND: That's correct.

13 JUDGE MCDADE: Okay.

14 MR. RUND: We're in the process of
15 getting copies of the figures or tables I believe
16 that are mentioned in that testimony, and we should
17 be able to have them to you hopefully by -
18 definitely by the end of the hearing, probably by
19 the end of the day.

20 JUDGE MCDADE: Okay, that's fine. What
21 exhibit number will that be? Is it listed on your
22 current index?

23 MR. RUND: It's not currently listed,
24 but it would just follow. I believe it would be the
25 next three, and then I think the Board also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 requested the draft ESP template. That would just
2 follow after those three.

3 JUDGE MCDADE: Okay. Can you hand up
4 the exhibits and the index for the exhibits?

5 MR. RUND: Yes.

6 JUDGE MCDADE: Okay. And SERI, you have
7 had an opportunity to review these exhibits?

8 MS. SUTTON: No, Your Honor.

9 JUDGE MCDADE: Okay. What I'd do then,
10 before you hand them up to us, just to make sure
11 that SERI sees them and before I accept them into
12 evidence here I just want to make sure that SERI
13 does not have any objections, and if they do we can
14 resolve those objections before they're admitted
15 rather than after.

16 MS. SUTTON: One point of clarification
17 while we're getting the documentation. The cover
18 page to ER 02 per your instruction yesterday is
19 included in our exhibits as SERI Exhibit 8 which you
20 will see later when that's entered into evidence.
21 And in addition we will provide the figures
22 referenced by Mr. Rund this morning.

23 JUDGE MCDADE: Thank you. Let me note
24 for the record that we have received Staff Exhibits
25 1 through 45 and we would be predisposed to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 admitting those into evidence at this point absent
2 any objection from SERI. So take your time and let
3 us know.

4 MS. SUTTON: Your Honor, at this time we
5 have no objection. However, we note that Staff
6 Exhibits 15 through 19 include the presentation
7 slides for Hearing Issues E through I. To the
8 extent that we have any objections we'll make them
9 during the presentations or prior thereto.

10 JUDGE MCDADE: Okay.

11 MS. SUTTON: Once we've had an
12 opportunity to review the slides.

13 JUDGE MCDADE: Okay, what I will do is
14 this then. I will admit at this point Staff
15 Exhibits 1 through 45. They are admitted into
16 evidence.

17
18 (Whereupon, the documents
19 marked as Staff Exhibit Nos.
20 1-45 for identification were
21 admitted into evidence.)

22 JUDGE MCDADE: If during the course of
23 the hearing the applicant has an objection to any
24 one of those and asks that it be withdrawn from
25 evidence they can make that objection and we can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 rule on it at that point in time. If there is any
2 objection. So we can move forward, accept them and
3 absent further objection ruling they are admitted
4 into evidence.

5 MS. SUTTON: Thank you, Your Honor.

6 JUDGE MCDADE: Okay. Does the staff
7 have anything further preliminarily before we begin
8 with Hearing Issue A?

9 MR. CAMPBELL: Yes, Your Honor. The
10 staff would like to note that on the -

11 JUDGE MCDADE: One thing, please, if you
12 could just state your name so that the court
13 reporter has it.

14 MR. CAMPBELL: Tison Campbell for the
15 staff.

16 JUDGE MCDADE: Thank you.

17 MR. CAMPBELL: We would like to note
18 that on the CD which was provided to the Board and
19 the applicant, Exhibit 18 appears as
20 HearingIssueH.pdf.

21 JUDGE MCDADE: I'm sorry, H-?

22 MR. CAMPBELL: ".pdf".

23 JUDGE MCDADE: Oh, okay. Thank you.

24 Again, anything preliminary from the staff before we
25 begin with Issue A?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. RUND: We have nothing further.
2 We're just sorting through the exhibits. We had
3 quite a few that were added at the last minute so it
4 will take us some time.

5 JUDGE MCDADE: Okay. Can you do that
6 while I sort of address the same questions that I
7 just had to you I can address to SERI and get their
8 testimony in and their exhibits in while you're
9 doing that?

10 MR. RUND: That'd be fine. I think that
11 might move things along.

12 JUDGE MCDADE: Okay. Again, with regard
13 to the various hearing issues A through I we
14 received pre-filed testimony from SERI. Do you have
15 any changes to that testimony that was submitted?

16 MS. SUTTON: We do, Your Honor. Mr.
17 O'Neill will bring you a copy of the errata sheet
18 and clean copies per your instruction yesterday of
19 all pre-filed testimony on those issues.

20 JUDGE MCDADE: Okay. And at this point
21 do you move the admission of those statements?

22 MS. SUTTON: We do, Your Honor.

23 JUDGE MCDADE: Okay. And are those
24 statements at this point all sworn to that they are
25 made subject to the penalties of perjury and are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 true and correct?

2 MS. SUTTON: That is correct, Your
3 Honor. We have affidavits from each of our
4 witnesses appended to the testimony Mr. O'Neill will
5 give you.

6 JUDGE MCDADE: Does the staff have any
7 objection to our receiving that testimony from the
8 applicant?

9 MS. HODGDON: No objection.

10 JUDGE MCDADE: Okay. Then the pre-filed
11 testimony on Hearing Issues A through I submitted by
12 SERI is received.

13
14 (Whereupon, SERI's Pre-Filed
15 Testimony on Hearing Issues
16 and Errata were admitted
17 into evidence.)

18 JUDGE MCDADE: The next is with regard
19 to exhibits. Do you have pre-marked exhibits from
20 SERI?

21 MS. SUTTON: We do, Your Honor. We have
22 SERI Exhibits 1 through 30.

23 JUDGE MCDADE: Okay. And if at this
24 point you could hand up the pre-marked exhibits and
25 the index for Exhibits 1 through 30 and I would do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**


BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

ERRATA NOTICE

System Energy Resources, Inc., ("SERI"), Applicant in the above-captioned matter, has made the following changes to its November 22, 2006, filing relating to pre-filed testimony on Hearing Issues A, D, E, F, G, and H; Exhibit 1 (Statements of Professional Qualifications of SERI Witnesses); and the accompanying list of SERI pre-filed hearing exhibits.

Respectfully submitted,



Kathryn M. Sutton

Paul M. Bessette

MORGAN, LEWIS & BOCKIUS, LLP

1111 Pennsylvania Ave., NW

Washington, DC 20004

Telephone: (202) 739-5738

Facsimile: (202) 739-3001

COUNSEL FOR SYSTEM
ENERGY RESOURCES, INC.

Dated at Washington, District of Columbia,
this 29th day of November, 2006

1. PRE-FILED TESTIMONY OF LORI M. EVANS, WILLIAM R. LETTIS, AND JEFFREY L. BACHHUBER ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE A (SITE CHARACTERIZATION)

- Page 3, second sentence of fourth paragraph, A4 (JLB),

Change:

“...cone penetrometer soundings, borehole P-S velocity surveys and SASW surface surveys.”

to:

“...cone penetrometer soundings, and borehole P-S velocity surveys.”

- Page 8, last sentence of first paragraph, A8 (WRL,JLB),

Change:

“Upland Complex alluvium at, or below, the bottom of loess deposits at approximately elevation 97 feet MSL (depth of 36 feet) or lower where the average shear wave velocity exceeds 1,000 feet per second and materials consist of dense alluvium”

to:

“Upland Complex alluvium at, or below, the bottom of loess deposits at approximately elevation 97 feet MSL (depth of 36 feet) or lower.”

- Page 8, last paragraph, A8 (WRL, JLB),

Change:

“Plant basemat (foundation) elevations above this level would require overexcavation of soils down to material exhibiting an average shear wave velocity of 1,000 fps, or alternatively, in-situ improvement (*e.g.* grouting). Excavated soils would be replaced by engineered-fill (*e.g.* lean concrete) that exhibits a Vs of 1,000 fps or greater”

to:

“The minimum shear wave velocity exceeds 1,000 fps at, and below, approximately elevation -7 feet MSL (depth of about 140 feet below assumed finished plant grade). Plant basemat (foundation) elevations above this level would require overexcavation and replacement of soils down to material exhibiting a minimum shear wave velocity of 1,000 fps, or alternatively, in-situ ground improvement (*e.g.* grouting) and/or further engineering design analyses.”

- Page 9, first sentence, A8 (WRL, JLB): Delete entire sentence.

2 PRE-FILED TESTIMONY OF WILLIAM R. LETTIS AND JEFFREY L. BACHHUBER ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE D (SLOPE AND FOUNDATION STABILITY)

- Page 3, first paragraph, A4 (JLB),

Change:

"...cone penetrometer soundings, borehole P-S velocity surveys and SASW surface surveys."

to:

"...cone penetrometer soundings, and borehole P-S velocity surveys."

- Page 7, first paragraph, A9 (JLB),

Change:

"Upland Complex alluvium at, or below, the bottom of loess deposits at approximately elevation 97 feet MSL (depth of 36 feet) or lower where the average shear wave velocity exceeds 1,000 feet per second and materials consist of dense alluvium"

to:

"Upland Complex alluvium at, or below, the bottom of loess deposits at approximately elevation 97 feet MSL (depth of 36 feet) or lower."

- Page 7, last paragraph, A9 (JLB),

Change:

"Plant basemat (foundation) elevations above this level would require overexcavation of soils down to material exhibiting an average shear wave velocity of 1,000 fps, or alternatively, in-situ improvement (*e.g.* grouting). Excavated soils would be replaced by engineered fill (*e.g.* lean concrete) that exhibits a V_{sof} of 1,000 fps or greater"

to:

"The minimum shear wave velocity exceeds 1,000 fps at, and below, approximately elevation -7 feet MSL (depth of about 140 feet below assumed finished plant grade). Plant basemat (foundation) elevations above this level would require overexcavation and replacement of soils down to material exhibiting a minimum shear wave velocity of 1,000 fps, or alternatively, in-situ ground improvement (*e.g.* grouting) and/or further engineering design analyses."

- Page 8, first sentence, A9 (JLB): Delete entire sentence.

3. PRE-FILED TESTIMONY OF JOHN G. CESARE, GEORGE A. ZINKE, KYLE H. TURNER, AND MICHAEL D. BOURGEOIS ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE E (ALTERNATIVE ANALYSES)

- Page 2, second paragraph, A3 (GAZ),

Change:

“I have over 30 years of technical and management experience in the commercial nuclear power industry. Since joining Entergy Nuclear, Inc., as a project manager in 1997, I have focused principally on business development matters involving the company’s GGNS Early Site Permit and COL Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility operation and decommissioning.”

to:

“I have 30 years of technical and management experience in the commercial nuclear power industry. Since 2001, as a Project Manager with Entergy Nuclear, Inc., I have focused principally on licensing matters involving the company’s Grand Gulf Nuclear Station (“GGNS”) ESP and combined operating license (“COL”) Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee, River Bend, and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility construction, operation, and decommissioning.”

4. PRE-FILED TESTIMONY OF JOHN CESARE, DAVID J. BEAN, AND MARVIN MORRIS ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE F (EVALUATION OF CUMULATIVE SITE IMPACTS)

- Page 1 of Exhibit, change title of exhibit from “SERI EXHIBIT xx” to “SERI EXHIBIT 2.”

5. PRE-FILED TESTIMONY OF JOHN CESARE, AL SCHNEIDER, AND GEORGE ZINKE ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE G (EVALUATION OF PLANT PARAMETER ENVELOPE)

- Page 2, last paragraph, A3 (GAZ),

Change:

“Since joining Entergy Nuclear, Inc., as a project manager in 1997, I have focused principally on business development matters involving the company’s GGNS Early Site Permit and COL Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility operation and decommissioning.”

to:

“Since 2001, as a Project Manager with Entergy Nuclear, Inc., I have focused principally on licensing matters involving the company’s Grand Gulf Nuclear Station (“GGNS”) ESP and combined operating license (“COL”) Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee, River Bend, and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility construction, operation, and decommissioning.”

- Page 5, last paragraph, second sentence, A6 (JGC, AJS, GAZ):

Change “Hearing Issue F” to “Hearing Issue G.”

6. PRE-FILED TESTIMONY OF GEORGE A. ZINKE, MARVIN MORRIS, JOHN G. CESARE, WILLIAM R. LETTIS, AND JEFFREY L. BACHHUBER ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE H (CONTINUITY BETWEEN THE ESP STAGE AND COL STAGE)

- Page 2, last paragraph, A3 (GAZ),

Change:

“I have over 30 years of technical and management experience in the commercial nuclear power industry. Since joining Entergy Nuclear, Inc., as a project manager in 1997, I have focused principally on business development matters involving the company’s GGNS Early Site Permit and COL Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee and GGNS facilities, where I was

responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility operation and decommissioning.”

to:

“I have 30 years of technical and management experience in the commercial nuclear power industry. Since 2001, as a Project Manager with Entergy Nuclear, Inc., I have focused principally on licensing matters involving the company’s Grand Gulf Nuclear Station (“GGNS”) ESP and combined operating license (“COL”) Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee, River Bend, and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility construction, operation, and decommissioning.”

7. EXHIBIT 1 (STATEMENTS OF PROFESSIONAL QUALIFICATIONS OF SERI WITNESSES)

- Added resume of George A. Zinke.
- Added supporting expert witness affidavits

8. SERI PRE-FILED HEARING EXHIBITS

- Updated SERI Pre-filed Hearing Exhibits to include Exhibits 6 through 30.

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

**PRE-FILED TESTIMONY OF LORI M. EVANS, WILLIAM R. LETTIS, AND
JEFFREY L. BACHHUBER ON BEHALF OF APPLICANT CONCERNING HEARING
ISSUE A
(SITE CHARACTERIZATION)**

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is Lori M. Evans ("LME"). I am employed as Senior Project Manager for ENERCON Services, Inc.

A1. My name is William R. Lettis ("WRL"). I am employed as the President and Principal Geologist of William Lettis & Associates, Inc.

A1. My name is Jeffrey L. Bachhuber ("JLB"). I am employed as the Vice President, Senior Principal Engineering Geologist of William Lettis & Associates, Inc.

Q2. On whose behalf will are you testifying in this proceeding?

A2. (LME, WRL, JLB) We are providing testimony on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (LME) I hold a B.S. degree in Geology from Tennessee Technological University. I have over fourteen years of experience that includes project management, a varied technical background, and environmental risk analysis. I have acted as task leader for hydrologic analyses

for a proposed expansion of an existing nuclear power plant, have assisted in development of new bank environmental policy guidance documents, and have been responsible for managing multiple-site Phase I environmental site assessment projects. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (WRL) I hold a Ph.D. and an M.S degree in Geology from the University of California, Berkeley, and a B.S. degree in Geology and a B.S. degree in Forestry from Humboldt State University. I have over 20 years experience performing regional and site investigations to assess geologic and seismic hazards for large engineered facilities, including bridges, dams, nuclear and fossil fuel plants, pipelines, and liquid natural gas ("LNG") terminals. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (JLB) I hold M.S. and B.A. degrees in Geology from San Jose State University. I am a Certified Engineering Geologist in California with over 20 years of professional experience performing geologic/geotechnical studies for nuclear and other critical facilities throughout the United States, Peru, Dominican Republic, Puerto Rico, Korea, Indonesia, Japan, and Turkey. I have performed detailed site investigations in a variety of geologic settings, in addition to regional hazard mapping and facility siting and routing studies. These projects involved assessment of earthquake hazard and sources, fault rupture and ground failure analysis, slope stability analysis and mitigation design, karst and void identification and treatment, foundation characterization with borings and geophysical techniques, laboratory testing, failure mode assessment, and development of foundation criteria for detailed static and dynamic stability and site response analyses (including soil-structure interaction) A full statement of my professional qualifications is contained in SERI Exhibit 1.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf ESP application, including the basis for your familiarity with that application.

A4. (LME) I am task leader for the hydrologic analysis sections of the Grand Gulf ESP application. As task leader, I was responsible for assessing the potential impacts on the surface water and groundwater of constructing and operating a nuclear power generating facility at the Grand Gulf site.

A4. (WRL) As Project Manager for the seismic and geotechnical work in support of the Entergy Grand Gulf Nuclear Station ("GGNS") ESP, my responsibilities include preparation of Sections of 2.5.1 through 2.5.6 of the SSAR, including seismic source characterization and probabilistic seismic hazard analysis to develop the safe shutdown earthquake ("SSE") design ground motion in compliance with Regulatory Guide 1.165, and, geotechnical characterization of the site in partial compliance with Regulatory Guides 1.138 and 1.132.

A4. (JLB) I was responsible for developing detailed site geotechnical characterization for the Grand Gulf ESP site. My work regarding the Grand Gulf ESP included developing quality assurance/quality control ("QA/QC") technical procedures and workplans to guide all field and laboratory activities, directing field investigations consisting of geologic mapping, deep mud rotary borings, cone penetrometer soundings, and borehole P-S velocity surveys. I also prepared Sections 2.5.4 to 2.5.6 for the site safety analysis report ("SSAR"), responded to Nuclear Regulatory Commission ("NRC") requests for additional information ("RAIs"), and presented the project to the Advisory Committee on Reactor Safeguards ("ACRS") in a formal meeting.

Q5. In an Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of

November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the NRC Staff. The Staff submitted its pre-filed testimony on November 20, 2006. *See* NRC Staff Pre-Filed Testimony Concerning Hearing Issue A: "Site Characterization" (Nov. 20, 2006). Have you reviewed the Staff's testimony on Hearing Issue A?

A5. (LME, WRL, JLB) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental pre-filed testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31, 2006, Prehearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (WRL, JLB) Yes. We are offering supplemental testimony with respect to Answers 5 and 11 of the NRC Staff's pre-filed testimony.

A6. (LME) Yes. I am offering supplemental testimony with respect to Answer 3 of the NRC Staff's pre-filed testimony.

Q7. Turning to Answer 5 of the Staff's pre-filed testimony, please provide any additional information that you believe is necessary.

A7. (WRL, JLB) In Answer 5 of its pre-filed testimony (under the section entitled "Characterization Relating to Potential Karst Formation,") the NRC Staff states that "materials below the plant are calcareous and therefore potentially susceptible to the effects of dissolution." Staff Issue A Testimony, A.5 at 8. Although SERI agrees with this general comment, it warrants mention that these calcareous deposits beneath the site occur at a minimum

depth of 390 feet below the surface, over 200 feet below the maximum embedment depth for any reactor considered in the ESP application.

The Staff further indicates that deep borings are "most likely inappropriate" to investigate the potential for dissolution or karst formation within these calcareous materials at the site, and that the "Applicant should search and investigate the available data base of information for the known site materials, and determine the opinions of recognized geologic experts versed in the area" Staff Issue A Testimony, A.5 at 8. SERI concurs with the Staff position. In fact, in response to Staff RAI 2.5.4-9, SERI performed a three-part investigation of the potential for karst formation at the site. That investigation included: (1) evaluating and documenting the presence or absence of karst features in the Site Area; (2) evaluating and documenting the presence or absence of karst features in outcrop areas of the Vicksburg Group in the Site Area and Site Region, including discussions with recognized geologic experts; and (3) evaluating the zone of influence of any new proposed foundation on the Vicksburg Group strata, assuming that dissolution might occur. Each of these evaluations showed that karst development is not present in the site area; that the Glendon Limestone within the Vicksburg Group is not susceptible to dissolution; and that even if dissolution were to occur within the Glendon Limestone at a depth of 390 feet or more, it would be below the zone of foundation influence at the site. Nevertheless, as discussed in the FSER at 2-236 (Section 2.5.4.3.6), and as required by COL Action Item 2.5-8, a deep boring program will be implemented during the COL geotechnical program to evaluate the potential for karst formation and dissolution within the Glendon Limestone beneath the site.

As a final clarification regarding the Staff's testimony on karst formation, SERI is unaware of any Staff requirement to perform chemical evaluations of available soil samples prior

to planning any deep boring program during the COL site investigation. *See Staff Issue A Testimony, A.5 at 9.* Consistent with COL Action Items 2.5-3 and 2.5-4, SERI will undertake additional borings, laboratory testing, geophysical surveys, and geotechnical investigations during the COL phase.

Q.8 Turning to Answer 11 of the Staff's pre-filed testimony, please provide any additional information that you believe is necessary.

A.8 (WRL, JLB) In Hearing Issue A, Answer A.11 of the NRC Staff pre-filed testimony, the Staff discussed issues related to stability of the river bluff, plant foundation embedment depth, and minimum required shear wave velocity. This testimony provides additional clarification of these issues.

Setback from River Bluff

SERI Exhibit 3 provides a graphic representation of the relationships between the river bluff slope and ESP proposed plant reactor building envelope. This figure shows that the ESP setback distance provides a sufficient safety buffer against any reasonable potential failure surfaces from intersection of the proposed plant envelope. In order to reach the proposed plant envelope area, a failure plane extending from the river bluff would have an inclination significantly less than 15 degrees (above horizontal), which is far below typical estimated residual angles of internal friction (angle of repose) for the loess soil that forms the river bluff and typically stands vertically in excavated cuts.

Existing Fill

Existing fill underlying the ESP proposed reactor building envelope is localized and shallow (depth of fill above approximate elevation 100 feet; SERI Exhibit 3), and does not extend to the foundation depth ranges of planned power plants.

Foundation Depth

The Environmental Report plant parameters envelope (PPE; Table 3.0-1) lists the ESP bounding foundation embedment depth as 140 feet. This depth is the maximum depth of the bottom of the foundation basemat, as measured from the finished plant grade (assumed at approximately elevation 133 feet above mean sea level ("MSL")) for any reactor design considered in the ESP Application. The relative location and elevation of this bounding depth with respect to the existing ground surface is shown on SSAR Figures 2.5-75 through 2.5-77 (geologic cross sections A-A', B-B', and C-C'), and labeled as "likely maximum foundation depth range within Proposed PPBA" (Proposed Power Block Area). The corresponding elevation of this maximum bounding embedment depth is approximately elevation (-)7 feet MSL.

Other plant technologies considered in the ESP Application have basemat elevations that are shallower than the bounding embedment depth, typically within the range of about 30 to 70 feet below finished plant grade. The stability and foundation suitability of subsurface materials that occur between assumed finished plant grade and the bounding maximum foundation depth range (and below this depth range throughout the likely range of foundation influence) were specifically evaluated with respect to the varying technologies and possible embedment depths. This evaluation included compilation and review of about twenty existing borings from the Unit 1 Updated Final Safety Analysis Report ("UFSAR") that are within and adjacent to the ESP reactor building envelope (See SERI Exhibit 3; SSAR Figure 2.5-69), drilling and sampling of three ESP borings, four ESP cone penetrometer soundings, seismic velocity surveys in the ESP borings, and laboratory static and dynamic testing of ESP borehole samples. On the basis of this evaluation, Section 2.5.4.6 of the SSAR recommends that the plant foundations be founded in

Upland Complex alluvium at, or below, the bottom of loess deposits at approximately elevation 97 feet MSL (depth of 36 feet) or lower.

Responses provided by NRC Staff in pre-filed testimony reference foundation embedment depths of between 120 and 140 feet (average depth of 130 feet). This depth correlates to the PPE bounding embedment depth for ESP foundations, rather than a minimum or design depth that could be at shallower depths according to the ESP evaluation.

Shear Wave Velocity

Some plant designs considered in the ESP Application reference a minimum 1,000 feet-per-second ("fps") shear wave velocity ("Vs") requirement for soils below the safety-related plant foundation basemat. Shear wave measurements of site subsurface materials were obtained by borehole P-S suspension surveys in each of the three ESP borings distributed within the proposed reactor building envelope (SSAR Figure 2.5-80). Based on the results from the ESP velocity surveys, Section 2.5.4.6 of the SSAR states that the average Vs exceeds 1,000 fps (in Upland Complex Alluvium) at, and below, approximately elevation 97 feet MSL (depth of about 36 feet below assumed finished plant grade elevation 133 feet MSL). The minimum shear wave velocity exceeds 1,000 fps at, and below, approximately elevation -7 feet MSL (depth of about 140 feet below assumed finished plant grade). Plant basemat (foundation) elevations above this level would require overexcavation and replacement of soils down to material exhibiting a minimum shear wave velocity of 1,000 fps, or alternatively, in-situ ground improvement (*e.g.* grouting) and/or further engineering design analyses.

Q9. Turning to Answer 3 of the Staff's pre-filed testimony, please provide any additional information that you believe is necessary.

A9. (LME) In Answer 3 of the Staff's pre-filed testimony, the Staff refers in several instances to three ground water wells in the Catahoula formation that are used to supply water for general site purposes of the existing plant, referencing SSAR Table 2.4-25. The Staff further states that based on available groundwater characterization data, the Staff determined that it is not unreasonable to expect that a suitable system of groundwater wells can be designed to extract water at a maximum rate of 3570 gpm from the Catahoula formation. The Staff further states in Answer 3 that impacts to the Catahoula aquifer was "unresolved" and if SERI continues to propose to withdraw water from the Catahoula Formation for construction and operation of the ESP facility, the Staff will require further characterization of the Catahoula aquifer.

Regarding the location of the three GGNS ground water wells currently in service, SERI provides the following correction based on current information and recent site investigations conducted as part of the ongoing COLA activities at the GGNS site. The withdrawal permit for two of three wells (TW-1A and TW-1B) referenced by the Staff was renewed in 1996, and the renewal application lists the source as the Catahoula aquifer. The withdrawal permit for the two wells that are currently in routine use was renewed in 2006, and the renewal application lists the source as the Miocene aquifer system (which includes the Catahoula Formation). The ESP application consistently references the source of potable water as the Catahoula formation, based on the information provided in these recent withdrawal permits. Soil characterization results from recent COLA site investigations, however, in the general area of the location of these wells and review of historical well installation records for the wells, indicate that the wells are in fact screened in terrace materials overlying the Catahoula Formation.

COL Action Item 2.4-8 in FSER Appendix A requires that the COL applicant referencing the GGNS ESP demonstrate that an adequately designed ground water well system is provided for the ESP facility. Regardless of the source of the ground water, *i.e.*, Catahoula or terrace deposits, this COL Action Item still requires satisfactory resolution. Construction and operational impacts on water use and water quality are unresolved in the Environmental Impact Statement ("EIS"); thus, additional characterization of ground water will be required for a COL application, regardless of the eventual source of ground water to provide plant potable water and other possible needs.

Q10. Does this conclude your testimony?

A10. (LME, WRL, JLB) Yes.

I-WA/2661766.2

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

**PRE-FILED TESTIMONY OF LORI M. EVANS, WILLIAM R. LETTIS, AND MARVIN
MORRIS ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE B
(MONITORABILITY OF INADVERTENT RADIOLOGICAL RELEASES)**

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is Lori M. Evans ("LME"). I am employed as Senior Project Manager for ENERCON Services, Inc.

A1. My name is William R. Lettis ("WRL"). I am employed as the President and Principal Geologist of William Lettis & Associates, Inc.

A1. My name is Marvin Morris ("MM"). I am employed as a consulting engineer and analyst for ENERCON Services, Inc..

Q2. On whose behalf are you testifying in this proceeding?

A2. (LME, WRL, MM) We are testifying on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (LME) I hold a B.S. degree in Geology from Tennessee Technological University. I have over fourteen years of experience that include project management, a varied technical background, and environmental risk analysis. I have acted as task leader for hydrologic

analyses for a proposed expansion of an existing nuclear power plant, have assisted in development of new bank environmental policy guidance documents, and have been responsible for managing multiple-site Phase I environmental site assessment projects. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (WRL) I hold a Ph.D. and an M.S degree in Geology from the University of California, Berkeley, and a B.S. degree in Geology and a B.S. in Forestry from Humboldt State University. I have over 20 years experience performing regional and site investigations to assess geologic and seismic hazards for large engineered facilities, including bridges, dams, nuclear and fossil fuel plants, pipelines, and Liquid Natural Gas ("LNG") terminals. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (MM) I hold a B.S. degree in Mathematics from the University of Texas, Pan American, and an M.S. degree in Physics from Sam Houston State University. I have over 30 years of experience in the nuclear industry in areas of design, analysis, licensing and operations support. A full statement of my professional qualifications is contained in SERI Exhibit 1.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf ESP application, including the basis for your familiarity with that application.

A4. (LME) I am task leader for the hydrologic analysis sections of the Grand Gulf ESP application. As task leader, I was responsible for assessing the potential impacts on the surface water and groundwater of constructing and operating a nuclear power generating facility at the Grand Gulf site.

A4. (WRL) As Project Manager for the seismic and geotechnical work in support of the Entergy Grand Gulf Nuclear Station ("GGNS") ESP, my responsibilities include Sections of 2.5.1 through 2.5.6 of the Site Safety Analysis Report ("SSAR"), including seismic source

characterization and probabilistic seismic hazard analysis to develop the Safe Shutdown Earthquake ("SSE") design ground motion in compliance with Regulatory Guide 1.165, and geotechnical characterization of the site in partial compliance with Regulatory Guides 1.138 and 1.132.

A4. (MM) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As a senior engineer, I was responsible for analyses supporting the application in the areas of offsite hazards, atmospheric dispersion, design basis accidents, and severe accidents. My responsibilities included Sections 2.3, 3.2, and 3.3 of the SSAR and Sections 2.7, 5.4, and 7.1 of the Environmental Report ("ER").

Q5. In its Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the Nuclear Regulatory Commission ("NRC") Staff. The Staff submitted its pre-filed testimony on November 20, 2006. *See* NRC Staff Pre-Filed Testimony Concerning Hearing Issue B: "Monitorability of Inadvertent Radiological Releases" (Nov. 20, 2006) ("Staff Issue B Testimony"). Have you reviewed the Staff's testimony on Hearing Issue B?

A5. (LME, WRL, MM) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental pre-filed testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31,

2006, Pre-hearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (LME, MM) Yes. We are offering supplemental testimony with respect to Answers 5 and 6 of the Staff's pre-filed testimony.

A6. (WRL) No. I will be available, however, to respond to any questions that the Board might pose to the Applicant during the evidentiary hearing that relate specifically to geologic data for the Grand Gulf ESP site, as referred to in Hearing Issue B(3).

Q7. Turning to Answer 5 of the Staff's pre-filed testimony, please provide any additional information or clarification that you believe is necessary.

A7. (LME, MM) The last sentence of Answer 5 of the NRC Staff's pre-filed testimony states that "[t]he Staff did not receive any data in the SERI application on radiological conditions at the site." Staff Issue B Testimony, A.5 at 5. As a clarification, SERI notes that one of the wells that is routinely sampled as part of the current GGNS radiological environmental monitoring plan ("REMP") is located on the ESP site, near the ESP power block area. SSAR Table 2.4-36 (and ER Table 6.2-1) provides a list of REMP sampling locations, sampling parameters, sample frequency and types of analyses performed. ER Table 6.2-2 provides REMP sampling results for years 2002 and 2003.

Q7. Turning next to Answer 6 of the Staff's pre-filed testimony, please provide any additional information or clarification that you believe is necessary.

A7. (MM) As Question 6 of the Staff's pre-filed testimony reflects, in Hearing Issue B(3), the Board inquired about "meteorological, geologic, and hydrogeologic data than can be used to estimate migration pathways for future impact from plant(s) at the site." The Staff's response to this question did not explicitly address meteorological data that could be used to

evaluate the consequences of inadvertent radiological releases, presumably because the Board's question appears to contemplate a potential liquid radionuclide release to "surface water, ground water, and shallow soil and sediments." See Staff Issue B Testimony, A.6 at 5. SERI notes that site meteorological data could be used to assess the offsite consequences of a potential normal or inadvertent gaseous radionuclide release in accordance with the Technical Specifications and the Offsite Dose Calculation Manual for the new plant.

Q7. Does this conclude your pre-filed testimony on Hearing Issue B?

A7. (LME, WRL, MM) Yes.

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

PRE-FILED TESTIMONY OF WILLIAM R. LETTIS AND JEFFREY L. BACHHÜBER
ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE C
(SEISMIC IMPACTS)

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is William R. Lettis ("WRL"). I am employed as the President and Principal Geologist of William Lettis & Associates, Inc.

A1. My name is Jeffrey L. Bachhuber ("JLB"). I am employed as the Vice President, Senior Principal Engineering Geologist of William Lettis & Associates, Inc.

Q2. On whose behalf are you testifying in this proceeding?

A2. (WRL, JLB) We are providing testimony on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (WRL) I hold a Ph.D. and an M.S degree in Geology from the University of California, Berkeley, and a B.S. degree in Geology and a B.S. degree in Forestry from Humboldt State University. I have over 20 years of experience performing regional and site investigations to assess geologic and seismic hazards for large engineered facilities, including bridges, dams, nuclear and fossil fuel plants, pipelines, and Liquid Natural Gas ("LNG") terminals. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (JLB) I hold an M.S. and B.A. degrees in Geology from San Jose State University. I am a Certified Engineering Geologist in California with over 20 years of professional experience performing geologic/geotechnical studies for nuclear and other critical facilities throughout the United States, Peru, Dominican Republic, Puerto Rico, Korea, Indonesia, Japan, and Turkey. I have performed detailed site investigations in a variety of geologic settings, in addition to regional hazard mapping and facility siting and routing studies. These projects involved assessment of earthquake hazard and sources, fault rupture and ground failure analysis, slope stability analysis and mitigation design, karst and void identification and treatment, foundation characterization with borings and geophysical techniques, laboratory testing, failure mode assessment, and development of foundation criteria for detailed static and dynamic stability and site response analyses (including soil-structure interaction) A full statement of my professional qualifications is contained in SERI Exhibit 1.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf Nuclear Station ("GGNS") ESP application, including the basis for your familiarity with that application.

A4. (WRL) As Project Manager for the seismic and geotechnical work in support of the GGNS ESP, my responsibilities included preparation of Sections of 2.5.1 through 2.5.6 of the Site Safety Analysis Report ("SSAR"), including seismic source characterization and probabilistic seismic hazard analysis used to develop the Safe Shutdown Earthquake ("SSE") design ground motion in compliance with Regulatory Guide 1.165, and geotechnical characterization of the site in partial compliance with Regulatory Guides 1.138 and 1.132.

A4. (JLB) I was responsible for developing detailed site geotechnical characterization for the Grand Gulf ESP site. My work regarding the Grand Gulf ESP included

developing Quality Assurance/Quality Control ("QA/QC") technical procedures and workplans to guide all field and laboratory activities, directing field investigations consisting of geologic mapping, deep mud rotary borings, cone penetrometer test ("CPT") soundings, borehole compression wave/shear wave ("P-S") velocity surveys, and spectral analysis of surface waves ("SASW") surface surveys. I also prepared Sections 2.5.4 to 2.5.6 for the Safety Analysis Report ("SAR"), responded to Nuclear Regulatory Commission ("NRC") requests for additional information ("RAIs"), and presented the project to the Advisory Committee on Reactor Safeguards ("ACRS") in a formal meeting.

Q5. In an Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the NRC Staff. The Staff submitted its pre-filed testimony on November 20, 2006. *See* NRC Staff Pre-Filed Testimony Concerning Hearing Issue C: "Seismic Impacts" (Nov. 20, 2006). Have you reviewed the Staff's testimony on Hearing Issue C?

A5. (WRL, JLB) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental pre-filed testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31, 2006, Pre-hearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (WRL, JLB) No. We are prepared, however, to respond orally to any questions germane to Hearing Issue C that the Board may ask of us during the evidentiary hearing.

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

PRE-FILED TESTIMONY OF WILLIAM R. LETTIS AND JEFFREY L. BACHHUBER
ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE D
(SLOPE AND FOUNDATION STABILITY)

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is William R. Lettis ("WRL"). I am employed as the President and Principal Geologist of William Lettis & Associates, Inc.

A1. My name is Jeffrey L. Bachhuber ("JLB"). I am employed as the Vice President, Senior Principal Engineering Geologist of William Lettis & Associates, Inc.

Q2. On whose behalf are you testifying in this proceeding?

A2. (WRL, JLB) We are providing testimony on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (WRL) I hold a Ph.D. and an M.S degree in Geology from the University of California, Berkeley, and a B.S. degree in Geology and a B.S. degree in Forestry from Humboldt State University. I have over 20 years of experience performing regional and site investigations to assess geologic and seismic hazards for large engineered facilities, including bridges, dams, nuclear and fossil fuel plants, pipelines, and Liquid Natural Gas ("LNG") terminals. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (JLB) I hold M.S. and B.A. degrees in Geology from San Jose State University. I am a Certified Engineering Geologist in California with over 20 years of professional experience performing geologic/geotechnical studies for nuclear and other critical facilities throughout the United States, Peru, Dominican Republic, Puerto Rico, Korea, Indonesia, Japan, and Turkey. I have performed detailed site investigations in a variety of geologic settings, in addition to regional hazard mapping and facility siting and routing studies. These projects involved assessment of earthquake hazard and sources, fault rupture and ground failure analysis, slope stability analysis and mitigation design, karst and void identification and treatment, foundation characterization with borings and geophysical techniques, laboratory testing, failure mode assessment, and development of foundation criteria for detailed static and dynamic stability and site response analyses (including soil-structure interaction) A full statement of my professional qualifications is contained in SERI Exhibit 1.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf ESP application, including the basis for your familiarity with that application.

A4. (WRL) As Project Manager for the seismic and geotechnical work in support of the Entergy Grand Gulf Nuclear Station ("GGNS") ESP, my responsibilities included preparation of Sections of 2.5.1 through 2.5.6 of the Site Safety Analysis Report ("SSAR"), including seismic source characterization and probabilistic seismic hazard analysis used to develop the Safe Shutdown Earthquake ("SSE") design ground motion in compliance with Regulatory Guide 1.165, and geotechnical characterization of the site in partial compliance with Regulatory Guides 1.138 and 1.132.

A4. (JLB) I was responsible for developing detailed site geotechnical characterization for the Grand Gulf ESP site. My work regarding the Grand Gulf ESP included

developing Quality Assurance/Quality Control ("QA/QC") technical procedures and workplans to guide all field and laboratory activities, as well as directing field investigations consisting of geologic mapping, deep mud rotary borings, cone penetrometer test ("CPT") soundings, and borehole P-S velocity surveys. I also prepared Sections 2.5.4 to 2.5.6 for the Safety Analysis Report ("SAR"), responded to Nuclear Regulatory Commission ("NRC") Staff requests for additional information ("RAIs"), and presented the project to the Advisory Committee on Reactor Safeguards ("ACRS") in a formal meeting.

Q5. In an Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the NRC Staff. The Staff submitted its pre-filed testimony on November 20, 2006. *See* NRC Staff Pre-Filed Testimony Concerning Hearing Issue D: "Slope and Foundation Stability" (Nov. 20, 2006). Have you reviewed the Staff's testimony on Hearing Issue D?

A5. (WRL, JLB) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental pre-filed testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31, 2006, Pre-hearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (WRL, JLB) Yes. We are offering supplemental testimony with respect to the following issues: river bluff stability, geologic nomenclature, foundation embedment depth, and shear wave velocity.

Q7. With respect to river bluff stability, please provide any additional information that you believe is necessary to address that issue.

A7. (JLB) In Hearing Issue D, Question Q.3 of the NRC Staff pre-filed testimony, the Board requested additional clarification regarding the geotechnical stability of the bearing strata and exterior earthen slopes (*i.e.*, bluff). The staff response discussed that the ESP setback ("stand-off") distance of 100 feet prevents potential failure surfaces through the bluff material from intersecting the plant cross-section. SERI Exhibits 3 and 5 provide a graphic representation of the relationships between the river bluff slope and ESP proposed plant reactor building envelope. This figure shows that the ESP setback distance provides a sufficient safety buffer against any reasonable potential failure surfaces from intersection of the proposed plant envelope. In order to reach the proposed plant envelope area, a failure plane extending from the river bluff would have an inclination significantly less than 15 degrees (above horizontal), which is far below typical estimated residual angles of internal friction (angle of repose) for the loess soil that forms the river bluff and typically stands vertically in excavated cuts.

Q8. With respect to geologic nomenclature, please provide any additional information that you believe is necessary to address that issue.

A8. (WRL) In Hearing Issue D, Question Q.4 of the NRC Staff pre-filed testimony, the Board requested additional clarification of the stratigraphic nomenclature used to describe the site geologic and hydrogeologic units. The Staff response provides clarification of the geologic stratigraphic nomenclature used in Section 2.5 of the SSAR, but does not provide clarification of

the hydrogeologic nomenclature provided in Section 2.4 of the SSAR. The Staff's focus on the geologic unit nomenclature is appropriate, because Hearing Issue D relates to stability of the Mississippi River bluff, which is a geologic issue. However, to provide additional clarification, SERI Exhibit 4 provides a chart showing the correlation of geologic and hydrogeologic units used in the original site Updated Final Safety Analysis Report ("UFSAR") (in which some terms are now archaic), and those used in Section 2.4 (hydrogeologic units), and Section 2.5 (geologic units) of the ESP SSAR. The term "New Alluvium" cited in the Board question was not used in the ESP SSAR. It should be noted that the hydrogeologic nomenclature used in the original site UFSAR was adopted without change in the ESP. However, the geologic nomenclature used in the UFSAR was modified and updated in the ESP SSAR Section 2.5 to reflect more recent understanding of the geology in the Site Area.

Q9. With respect to plant foundation embedment depth and shear wave velocity, please provide any additional information that you believe is necessary to address that issue.

A9. (JLB) In Hearing Issue D, Questions Q.4, Q.5, Q.7, and Q.8 of the NRC Staff pre-filed testimony, the Staff discussed issues related to the depth of existing fill, plant foundation embedment depths, and minimum shear wave velocity requirements for plant foundation basemats. This response provides additional clarification regarding these issues.

Existing Fill

Existing fill underlying the ESP proposed reactor building envelope is localized and shallow (depth of fill above approximate elevation 100 feet; SERI Exhibit 3), and does not extend to the foundation depth ranges of planned power plants.

Foundation Depth

The Environmental Report plant parameters envelope (PPE; Table 3.0-1) lists the ESP bounding foundation embedment depth as 140 feet. This depth is the maximum depth of the bottom of the foundation basemat, as measured from the finished plant grade (assumed at approximately elevation 133 feet above mean sea level (MSL)) for any reactor design considered in the ESP Application. The relative location and elevation of this bounding depth with respect to the existing ground surface is shown on SSAR Figures 2.5-75 through 2.5-77 (See SERI Exhibit 3 for location of geologic cross sections A-A', B-B', and C-C'), and labeled as "likely maximum foundation depth range within Proposed PPBA" (Proposed Power Block Area). The corresponding elevation of this maximum bounding embedment depth is approximately elevation (-)7 feet MSL.

Other plant technologies considered in the ESP Application have basemat elevations that are shallower than the bounding embedment depth, typically within the range of about 30 to 70 feet below finished plant grade. The stability and foundation suitability of subsurface materials that occur between assumed finished plant grade and the bounding maximum foundation depth range (and below this depth range throughout the likely range of foundation influence) were specifically evaluated with respect to the varying technologies and possible embedment depths. This evaluation included compilation and review of about twenty existing borings from the Unit 1 UFSAR that are within and adjacent to the ESP reactor building envelope (See SERI Exhibit 3; SSAR Figure 2.5-69), drilling and sampling of three ESP borings, four ESP cone penetrometer soundings, seismic velocity surveys in the ESP borings, and laboratory static and dynamic testing of ESP borehole samples. On the basis of this evaluation, Section 2.5.4.6 of the SSAR

recommends that the plant foundations be founded in Upland Complex alluvium at, or below, the bottom of loess deposits at approximately elevation 97 feet MSL (depth of 36 feet) or lower.

Responses provided by NRC Staff in pre-filed testimony reference foundation embedment depths of between 120 and 140 feet (average depth of 130 feet). This depth correlates to the PPE bounding embedment depth for ESP foundations, rather than a minimum or design depth that could be at shallower depths according to the ESP evaluation.

Shear Wave Velocity

Some plant designs considered in the ESP Application reference a minimum 1,000 feet-per-second ("fps") shear wave velocity ("Vs") requirement for soils below the safety-related plant foundation basemat. Shear wave measurements of site subsurface materials were obtained by borehole P-S suspension surveys in each of the three ESP borings distributed within the proposed reactor building envelope (SSAR Figure 2.5-80). Based on the results from the ESP velocity surveys, Section 2.5.4.6 of the SSAR states that the average Vs exceeds 1,000 fps (in Upland Complex Alluvium) at, and below, approximately elevation 97 feet MSL (depth of about 36 feet below assumed finished plant grade elevation 133 feet MSL). The minimum shear wave velocity exceeds 1,000 fps at, and below, approximately elevation -7 feet MSL (depth of about 140 feet below assumed finished plant grade). Plant basemat (foundation) elevations above this level would require overexcavation and replacement of soils down to material exhibiting a minimum shear wave velocity of 1,000 fps, or alternatively, in-situ ground improvement (e.g. grouting) and/or further engineering design analyses.

Q10. Does this conclude your testimony?

A10. (WRL, JLB) Yes.

1-WA/2661770.2

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

**PRE-FILED TESTIMONY OF JOHN G. CESARE, GEORGE A. ZINKE, KYLE H.
TURNER, AND MICHAEL D. BOURGEOIS ON BEHALF OF APPLICANT
CONCERNING HEARING ISSUE E
(ALTERNATIVE ANALYSES)**

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is John G. Cesare ("JGC"). I am employed as Lead Licensing Project Engineer for ENERCON Services, Inc.

A1. My name is George A. Zinke ("GAZ"). I am employed as the Project Manager, Business Development, for Entergy Nuclear, Inc.

A1. My name is Kyle H. Turner ("KHT"). I am employed as the Chief Executive Officer of McCallum-Turner, Inc.

A1. My name is Michael D. Bourgeois ("MDB"). I am employed as the Manager of Project Management for Entergy Nuclear, Inc.

Q2. On whose behalf are you testifying in this proceeding?

A2. (JGC, GAZ, KHT, MDB) We are providing testimony on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (JGC) I hold a B.S. degree in Chemical Engineering and an M.S. degree in Nuclear Engineering from Mississippi State University. I have over 24 years of experience in the nuclear power industry, including experience in the areas of new reactor, operational and decommissioning licensing; special projects; organizational assessment; and management support. This includes ten years of supervisory and management experience at a boiling water reactor ("BWR") facility. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (GAZ) I hold a B.S. degree in Electrical Engineering from Wichita State University. I have 30 years of technical and management experience in the commercial nuclear power industry. Since 2001, as a Project Manager with Entergy Nuclear, Inc., I have focused principally on licensing matters involving the company's Grand Gulf Nuclear Station ("GGNS") ESP and combined operating license ("COL") Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee, River Bend, and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility construction, operation, and decommissioning. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (KHT) I hold a B.S. degree in Electrical Engineering for the Georgia Institute of Technology, as well as Ph. D. and M.S. degrees in Nuclear Engineering, also from the Georgia Institute of Technology. I have more than 30 years experience providing technical, business, and management consulting services to commercial industry and government. My management responsibilities have ranged in budget up to \$16 million and 200 professional staff. I am Principal author for the industry ESP Siting Guide, ESP Model Program Plan and COL Model Program Plan

for nuclear power plants, and am currently managing an Electric Power Research Institute ("EPRI") project to develop a model Program Plan for overall nuclear power plant development under Part 52 regulations. Since 2001, I have directed site selection studies for ten nuclear power plant sites for COL and ESP applications (Duke Power, Entergy Nuclear, Florida Power & Light, Progress Energy (2), NuStart, South Carolina Electric & Gas, and two confidential clients). A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (MDB) I hold a B.S. degree in Nuclear Engineering Technology from Thomas Edison State College. I have over forty years of commercial and military nuclear experience. My experience includes project and outage management, nuclear reactor operation, and work control.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf ESP application, including the basis for your familiarity with that application.

A4. (JGC) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As the lead licensing project engineer, I coordinated and supported the development of the safety analyses, environmental report, and emergency planning assessment for the ESP application. I also participated in site safety and environmental visits, the development of applicant responses to Nuclear Regulatory Commission ("NRC") Staff requests for additional information ("RAIs"), and the Advisory Committee on Reactor Safeguards ("ACRS") review process. My work also involved active participation in the industry ESP task force and numerous licensing-related interactions with the NRC Staff.

A4. (GAZ) As the Project Manager, Business Development, for Entergy Nuclear, Inc., I have two different but complementary roles. Namely, I am both the NuStart Licensing Lead

and the Entergy Nuclear New Plant Licensing Lead. In the former capacity, I am responsible for regulatory affairs associated with the NuStart COL Development Project. Entergy is a member of NuStart Energy Development, LLC, a consortium formed in 2004 that is seeking to facilitate the licensing, construction, and operation of new, advanced nuclear power plants in the United States. In the latter capacity, I am responsible for regulatory affairs and quality assurance associated with the Entergy COL Development Process. The acquisition of an ESP for the GGNS site is a preliminary and integral step in the Entergy COL Development Process. As such, I have overall responsibility for regulatory and engineering matters related to the Grand Gulf ESP application.

A4. (KHT) I was the Principal in charge of work performed by McCallum-Turner to support SERI in the site selection study for the Grand Gulf ESP. McCallum-Turner developed site evaluation criteria and worked with Entergy staff to evaluate the Entergy existing nuclear power plant sites in the Northeast and in the Southeast for potential location of a new nuclear power plant; this work involved performing and reviewing site evaluations, development of criterion weight factors and developing composite site suitability evaluations for use in comparing sites. McCallum-Turner applied the site selection criteria established in the EPRI siting guide to information gathered from existing data sources for the proposed sites. McCallum-Turner then facilitated overall ranking of the candidate sites to identify a preferred site (GGN) for the ESP.

A4. (MDB) As ESP Project Manager, I was the project lead for the GGNS ESP site selection process.

Q5. In an Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of

November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the NRC Staff. The Staff submitted its prefiled testimony on November 20, 2006. *See* NRC Staff Pre-Filed Testimony Concerning Hearing Issue E: "Alternative Analyses" (Nov. 20, 2006). Have you reviewed the Staff's testimony on Hearing Issue E?

A5. (JGC, GAZ, KHT, MDB) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental pre-filed testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31, 2006, Prehearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (MDB) Yes. I am offering supplemental testimony with respect to Answer 6 of the Staff's pre-filed testimony.

A6. (JGC, GAZ, KHT) No. We are prepared, however, to respond orally to any questions germane to Hearing Issue E that the Board may ask of us during the mandatory hearing.

Q7. Turning to Answer 6 of the Staff's pre-filed testimony, in narrowing the sites down to Grand Gulf, did Entergy Nuclear eliminate Fitzpatrick, River Bend, and Pilgrim from all future consideration for possible ESP purposes outside the scope of this proceeding?

A7. (MDB) No. By way of clarification, in conducting its alternative site screening process, Entergy Nuclear excluded those sites from further consideration as part of this ESP effort, but not from all possible future consideration for additional ESPs.

Q7. Does this conclude your prefiled testimony on Hearing Issue E?

A7. (MDB) Yes.

1-WA/2661774.2

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

**PRE-FILED TESTIMONY OF JOHN CESARE, DAVID J. BEAN, AND MARVIN
MORRIS ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE F
(EVALUATION OF CUMULATIVE SITE IMPACTS)**

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is John G. Cesare ("JGC"). I am employed as the Lead Licensing Project Engineer for ENERCON Services, Inc.

A1. My name is David J. Bean ("DJB"). I am employed as a Senior Environmental Scientist for ENERCON Services, Inc.

A1. My name is Marvin Morris ("MM"). I am employed as a consulting engineer and analyst for ENERCON Services, Inc.

Q2. On whose behalf are you testifying in this proceeding?

A2. (JGC, DJB, MM) We are providing testimony on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (JGC) I hold a B.S. degree in Chemical Engineering and an M.S. degree in Nuclear Engineering from Mississippi State University. I have over 24 years of experience in

the nuclear power industry, including experience in the areas of new reactor, operational and decommissioning licensing; special projects; organizational assessment; and management support. This includes ten years of supervisory and management experience at a boiling water reactor ("BWR") facility. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (DJB) I hold an M.S. degree in Zoology from the Ohio State University, and a B.A. degree in Biology from the State University of New York at Oswego. I have over 30 years of experience in the Environmental Industry, and am well-versed in environmental impact analysis/assessment, the National Environmental Policy Act ("NEPA"), and Strategic Environmental Management. I have extensive experience performing environmental safety and health ("ES&H") compliance strategy development, site evaluation and selection planning, risk assessment/analysis, and waste management. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (MM) I hold a B.S. degree in Mathematics from the University of Texas, Pan American, and an M.S. degree in Physics from Sam Houston State University. I have over 30 years of experience in the nuclear industry in areas of design, analysis, licensing, and operations support. A full statement of my professional qualifications is contained in SERI Exhibit 1.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf ESP application, including the basis for your familiarity with that application.

A4. (JGC) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the Grand Gulf Nuclear Station ("GGNS") site. As the lead licensing project engineer, I coordinated and supported the development of the safety

analyses, environmental report, and emergency planning assessment for the ESP application. I also participated in site safety and environmental visits, the development of applicant responses to Nuclear Regulatory Commission ("NRC") Staff requests for additional information ("RAIs"), and the Advisory Committee on Reactor Safeguards ("ACRS") review process. My work also involved active participation in the industry ESP task force and numerous licensing-related interactions with the NRC Staff.

A4. (DJB) As Senior Environmental Scientist, I coordinated the preparation of the environmental sections for the Grand Gulf ESP application. I was responsible for budget and schedule control, and technical review of sections of the Site Safety Analysis Report ("SSAR") and Environmental Report ("ER"). The evaluation included an assessment of the potential impacts on the terrestrial and aquatic environment of constructing and operating a new nuclear power generating facility at the proposed site.

A4. (MM) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As a senior engineer, I was responsible for analyses supporting the application in the areas of offsite hazards, atmospheric dispersion, design basis accidents, and severe accidents. My responsibilities included Sections 2.3, 3.2, and 3.3 of the SSAR and Sections 2.7, 5.4, and 7.1 of the ER.

Q5. In an Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the NRC Staff. The Staff submitted its prefiled testimony on November 20, 2006. *See* NRC Staff Pre-Filed

Testimony Concerning Hearing Issue F: "Evaluation Of Cumulative Site Impacts" (Nov. 20, 2006). Have you reviewed the Staff's testimony on Hearing Issue F?

A5. (JGC, DJB, MM) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental pre-filed testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31, 2006, Pre-hearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (JGC, MM) No. We are prepared, however, to respond orally to any questions germane to Hearing Issue F that the Board may ask of us during the evidentiary hearing.

A6. (DJB) Yes. I am offering supplemental testimony with respect to Exhibit 3 of the Staff's pre-filed testimony.

Q7. Turning to Exhibit 3 of the Staff's pre-filed testimony, please provide any additional information or clarification that you believe is necessary.

A8. (DJB) Staff Exhibit 3 is a table of resolved and unresolved safety and environmental issues identified by the Staff with respect to the GGNS ESP. For most resolved issues, the Staff provides clarifying assumptions and comments. SERI's Exhibit 2, which is attached to this testimony, includes additional clarifying comments to Staff Exhibit 3, with supporting references where appropriate. SERI's clarifying comments on Staff Exhibit 3 are noted in bold in SERI's Exhibit 2.

Q8. Does this conclude your testimony?

A8. (DJB) Yes.

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

**PRE-FILED TESTIMONY OF JOHN CESARE, AL SCHNEIDER, AND GEORGE
ZINKE ON BEHALF OF APPLICANT CONCERNING HEARING ISSUE G
(EVALUATION OF PLANT PARAMETER ENVELOPE)**

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is John G. Cesare ("JGC"). I am employed as Lead Licensing Project Engineer for ENERCON Services, Inc.

A1. My name is Al J. Schneider ("AJS"). I am employed as the Manager of Projects for the New Plant Services Division of ENERCON Services, Inc.

A1. My name is George A. Zinke ("GAZ"). I am employed as the Project Manager, Business Development, for Entergy Nuclear, Inc.

Q2. On whose behalf will you testify in this proceeding?

A2. (JGC, AJS, GAZ) We are providing testimony on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (JGC) I hold a B.S. degree in Chemical Engineering and an M.S. degree in Nuclear Engineering from Mississippi State University. I have over 24 years of experience in

the nuclear power industry, including experience in the areas of new reactor, operational and decommissioning licensing; special projects; organizational assessment; and management support. This includes ten years of supervisory and management experience at a Boiling Water Reactor ("BWR") facility. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (AJS) I hold B.S. and M.S. degrees in Mechanical Engineering from the University of Arkansas. I have over 33 years of technical and management experience in the commercial nuclear power industry. This experience encompasses numerous lead and supervisory assignments in engineering, projects, technical support, preoperational and start-up testing programs, procedure upgrade and development, licensing, and outage planning and scheduling. As noted above, I have provided project management and technical expertise to the Grand Gulf Nuclear Station ("GGNS") ESP project. I also have provided project management services in connection with NuStart's initiation of its combined operating license application ("COLA") preparation project, the ENERCON/NuStart Economic Simplified Boiling Water Reactor ("ESBWR") COLA preparation project, the design of BWR/6 Emergency Core Cooling System ("ECCS") Suction Strainers for three BWR/6 plants, Technical Specification Surveillance Test Procedure Upgrade Projects, system design criteria review and development, comprehensive in-service testing ("IST") program reviews, and a ten-year IST program update. A full statement of my professional qualifications is contained in SERI Exhibit 1

A3. (GAZ) I hold a B.S. degree in Electrical Engineering from Wichita State University. I have 30 years of technical and management experience in the commercial nuclear power industry. Since 2001, as a Project Manager with Entergy Nuclear, Inc., I have focused principally on licensing matters involving the company's Grand Gulf Nuclear Station ("GGNS")

ESP and combined operating license ("COL") Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee, River Bend, and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility construction, operation, and decommissioning. A full statement of my professional qualifications is contained in SERI Exhibit 1.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf ESP application, including the basis for your familiarity with that application.

A4. (JGC) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As the lead licensing project engineer, I coordinated and supported the development of the safety analyses, environmental report, and emergency planning assessment for the ESP application. I also participated in site safety and environmental visits, the development of applicant responses to Nuclear Regulatory Commission ("NRC") Staff requests for additional information ("RAIs"), and the Advisory Committee on Reactor Safeguards ("ACRS") review process. My work also involved active participation in the industry ESP task force and numerous licensing-related interactions with the NRC Staff.

A4. (AJS) As Project Manager for ENERCON for the Entergy Grand Gulf early site permit application development, I was responsible for overall management of all of ENERCON's work related to development of the ESP application, including budget, resources and schedule, and was responsible for implementation of the Quality Assurance program for the application development project. I was responsible for integrating the input from other contractors (*i.e.*, William Lettis & Associates, Inc.) into the safety analysis report for the

application. I participated in the development and technical review of the environmental report and the safety analysis report parts of the application. I also participated in site safety and environmental visits to the site by the NRC, the development of applicant responses to Nuclear Regulatory Commission ("NRC") Staff requests for additional information ("RAIs") and DSER Open Items, and the Advisory Committee on Reactor Safeguards ("ACRS") review process.

A4. (GAZ) As the Project Manager, Business Development, for Entergy Nuclear, Inc., I have two different but complementary roles. Namely, I am both the NuStart Licensing Lead and the Entergy Nuclear New Plant Licensing Lead. In the former capacity, I am responsible for regulatory affairs associated with the NuStart COL Development Project. Entergy is a member of NuStart Energy Development, LLC, a consortium formed in 2004 that is seeking to facilitate the licensing, construction, and operation of new, advanced nuclear power plants in the United States. In the latter capacity, I am responsible for regulatory affairs and quality assurance associated with the Entergy COL Development Process. The acquisition of an ESP for the GGNS site is a preliminary and integral step in the Entergy COL Development Process. As such, I have overall responsibility for regulatory and engineering matters related to the Grand Gulf ESP application.

Q5. In its Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the NRC Staff. The Staff submitted its pre-filed testimony on November 20, 2006. *See* NRC Staff Pre-Filed Testimony Concerning Hearing Issue G: Evaluation of Plant Parameter Envelope" (Nov. 20, 2006). Have you reviewed the Staff's testimony on Hearing Issue G?

A5. (JGC, AJS, GAZ) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental prefiled testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31, 2006, Pre-hearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (JGC, AJS, GAZ) No. We will be available, however, to respond orally to any questions germane to Hearing Issue G that the Board may pose to the Applicant during the forthcoming evidentiary hearing.

I-WA/2661430.2

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

**PRE-FILED TESTIMONY OF GEORGE A. ZINKE, MARVIN MORRIS, JOHN G.
CESARE, WILLIAM R. LETTIS, AND JEFFREY L. BACHHUBER ON BEHALF OF
APPLICANT CONCERNING HEARING ISSUE H
(CONTINUITY BETWEEN THE ESP STAGE AND COL STAGE)**

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is George A. Zinke ("GAZ"). I am employed as the Project Manager, Business Development, for Entergy Nuclear, Inc.

A1. My name is Marvin Morris ("MM"). I am employed as a consulting engineer and analyst for ENERCON Services, Inc.

A1. My name is John G. Cesare ("JGC"). I am employed as Lead Licensing Project Engineer for ENERCON Services, Inc.

A1. My name is William R. Lettis ("WRL"). I am employed as the President and Principal Geologist of William Lettis & Associates, Inc.

A1. My name is Jeffrey L. Bachhuber ("JLB"). I am employed as the Vice President, Senior Principal Engineering Geologist of William Lettis & Associates, Inc.

Q2. On whose behalf are you testifying in this proceeding?

A2. (GAZ, MM, JGC, WRL, JLB) We are providing testimony on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (GAZ) I hold a B.S. degree in Electrical Engineering from Wichita State University. I have 30 years of technical and management experience in the commercial nuclear power industry. Since 2001, as a Project Manager with Entergy Nuclear, Inc., I have focused principally on licensing matters involving the company's Grand Gulf Nuclear Station ("GGNS") ESP and combined operating license ("COL") Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee, River Bend, and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility construction, operation, and decommissioning. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (MM) I hold a B.S. degree in Mathematics from the University of Texas, Pan American, and an M.S. degree in Physics from Sam Houston State University. I have over 30 years of experience in the nuclear industry in areas of design, analysis, licensing and operations support. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (JGC) I hold a B.S. degree in Chemical Engineering and an M.S. degree in Nuclear Engineering from Mississippi State University. I have over 24 years of experience in the nuclear power industry, including experience in the areas of new reactor, operational and decommissioning licensing; special projects; organizational assessment; and management support. This includes ten years of supervisory and management experience at a Boiling Water

Reactor ("BWR") facility. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (WRL) I hold a Ph.D. and an M.S degree in Geology from the University of California, Berkeley, and a B.S. degree in Geology and a B.S. degree in Forestry from Humboldt State University. I have over 20 of years experience performing regional and site investigations to assess geologic and seismic hazards for large engineered facilities, including bridges, dams, nuclear and fossil fuel plants, pipelines, and Liquid Natural Gas ("LNG") terminals. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (JLB) I hold an M.S. and B.A. degrees in Geology from San Jose State University. I am a Certified Engineering Geologist in California with over 20 years of professional experience performing geologic/geotechnical studies for nuclear and other critical facilities throughout the United States, Peru, Dominican Republic, Puerto Rico, Korea, Indonesia, Japan, and Turkey. I have performed detailed site investigations in a variety of geologic settings, in addition to regional hazard mapping and facility siting and routing studies. These projects involved assessment of earthquake hazard and sources, fault rupture and ground failure analysis, slope stability analysis and mitigation design, karst and void identification and treatment, foundation characterization with borings and geophysical techniques, laboratory testing, failure mode assessment, and development of foundation criteria for detailed static and dynamic stability and site response analyses (including soil-structure interaction) A full statement of my professional qualifications is contained in SERI Exhibit 1.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf ESP application, including the basis for your familiarity with that application.

A4. (GAZ) As the Project Manager, Business Development, for Entergy Nuclear, Inc., I have two different but complementary roles. Namely, I am both the NuStart Licensing Lead and the Entergy Nuclear New Plant Licensing Lead. In the former capacity, I am responsible for regulatory affairs associated with the NuStart COL Development Project. Entergy is a member of NuStart Energy Development, LLC, a consortium formed in 2004 that is seeking to facilitate the licensing, construction, and operation of new, advanced nuclear power plants in the United States. In the latter capacity, I am responsible for regulatory affairs and quality assurance associated with the Entergy COL Development Process. The acquisition of an ESP for the GGNS site is a preliminary and integral step in the Entergy COL Development Process. As such, I have overall responsibility for regulatory and engineering matters related to the Grand Gulf ESP application.

A4. (MM) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As a senior engineer, I was responsible for analyses supporting the application in the areas of offsite hazards, atmospheric dispersion, design basis accidents, and severe accidents. My responsibilities included Sections 2.3, 3.2, and 3.3 of the SSAR and Sections 2.7, 5.4, and 7.1 of the ER.

A4. (JGC) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As the lead licensing project engineer, I coordinated and supported the development of the safety analyses, environmental report, and emergency planning assessment for the ESP application. I also participated in site safety and environmental visits, the development of applicant responses to Nuclear Regulatory Commission

("NRC") Staff requests for additional information ("RAIs"), and the Advisory Committee on Reactor Safeguards ("ACRS") review process. My work also involved active participation in the industry ESP task force and numerous licensing-related interactions with the NRC Staff.

A4. (WRL) As Project Manager for the seismic and geotechnical work in support of the Entergy Grand Gulf ESP, my responsibilities included preparation of Sections of 2.5.1 through 2.5.6 of the Site Safety Analysis Report ("SSAR"), including seismic source characterization and probabilistic seismic hazard analysis used to develop the Safe Shutdown Earthquake ("SSE") design ground motion in compliance with Regulatory Guide 1.165, and geotechnical characterization of the site in partial compliance with Regulatory Guides 1.138 and 1.132.

A4. (JLB) I was responsible for developing detailed site geotechnical characterization for the Grand Gulf ESP site. My work regarding the Grand Gulf ESP included developing Quality Assurance/Quality Control ("QA/QC") technical procedures and workplans to guide all field and laboratory activities, directing field investigations consisting of geologic mapping, deep mud rotary borings, Cone Penetrometer Test ("CPT") soundings, and borehole P-S velocity surveys. I also prepared Sections 2.5.4 to 2.5.6 for the SAR, responded to NRC RAIs, and presented the project to the ACRS in a formal meeting.

Q5. In an Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the NRC Staff. The Staff submitted its pre-filed testimony on November 20, 2006. See NRC Staff Pre-Filed

Testimony Concerning Hearing Issue H: "Continuity Between The Esp Stage And Col Stage" (Nov. 20, 2006). Have you reviewed the Staff's testimony on Hearing Issue H?

A5. (GAZ, MM, JGC, WRL, JLB) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental pre-filed testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31, 2006, Pre-hearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (JGC) Yes. I am offering supplemental testimony with respect to Answer 4 and Exhibit 8 of the Staff's pre-filed testimony.

A6. (WRL, JLB) Yes. We are offering supplemental testimony with respect to Answer 5 of the Staff's pre-filed testimony.

A6. (GAZ, MM) No. We are prepared, however, to respond orally to any questions germane to Hearing Issue H that the Board may ask of us during the evidentiary hearing.

Q7. Turning to Answer 4 and Exhibit 8 of the Staff's pre-filed testimony, please provide any additional information that you believe is necessary.

A7. (JGC) In Answer 4 and Exhibit 8, the Staff states that COL Action Items "call for a set of design information to be provided by any future applicant referencing the ESP." By way of clarification, COL Action Items directly or indirectly deal with design-related issues and information. Some COL Action Items call for obtaining site characterization information at COL that would subsequently be used to confirm the adequacy of design or used in an analysis of a design related matter. For example, COL Action Item 2.3-2 requires the applicant to

evaluate dispersion of airborne radioactive materials to the control room. Control room X/Q is a site characteristic, but is dependent on design information and site meteorological information (FSER 2.3.4.3 at 2-57). Moreover, these items constitute information requirements only and an applicant may depart from or omit COL Action Items, provided that the departure or omission is identified and justified in the FSAR. *See* FSER at A-4.

Q8. Turning to Answer 5 of the Staff's pre-filed testimony, please provide any additional information that you believe is necessary.

A8. (JLB, WRL) In Answer 5 of the Staff's pre-filed testimony, the Staff states that a reactor referencing the ESP would be about 140 ft. below grade (Elevation -5 feet), and that soil above Elevation -5 ft. needs to be removed to allow the construction of the foundation mat. This response provides additional clarification of this statement.

Foundation Depth

The Environmental Report plant parameters envelope (PPE; Table 3.0-1) lists the ESP bounding foundation embedment depth as 140 feet. This depth is the maximum depth of the bottom of the foundation basemat, as measured from the finished plant grade (assumed at approximately elevation 133 feet above mean sea level (MSL)) for any reactor design considered in the ESP Application. The relative location and elevation of this bounding depth with respect to the existing ground surface is shown on SSAR Figures 2.5-75 through 2.5-77 (geologic cross sections A-A', B-B', and C-C'), and labeled as "likely maximum foundation depth range within Proposed PPBA" (Proposed Power Block Area). The corresponding elevation of this maximum bounding embedment depth is approximately elevation (-)7 feet MSL.

Other plant technologies considered in the ESP Application have basemat elevations that are shallower than the bounding embedment depth, typically within the range of about 30 to 70

feet below finished plant grade. The stability and foundation suitability of subsurface materials that occur between assumed finished plant grade and the bounding maximum foundation depth range (and below this depth range throughout the likely range of foundation influence) were specifically evaluated with respect to the varying technologies and possible embedment depths. This evaluation included compilation and review of about twenty existing borings from the Unit 1 Updated Final Safety Analysis Report ("UFSAR") that are within and adjacent to the ESP reactor building envelope (See SERI Exhibit 3; SSAR Figure 2.5-69), drilling and sampling of three ESP borings, four ESP cone penetrometer soundings, seismic velocity surveys in the ESP borings, and laboratory static and dynamic testing of ESP borehole samples. On the basis of this evaluation, Section 2.5.4.6 of the SSAR recommends that the plant foundations be founded in Upland Complex alluvium at, or below, the bottom of loess deposits at approximately elevation 97 feet MSL (depth of 36 feet) or lower.

Responses provided by the NRC staff in pre-filed testimony on this hearing issue reference foundation embedment depths of between 120 and 140 feet (average depth of 130 feet). This depth correlates to the PPE bounding embedment depth for ESP foundations, rather than a minimum or design depth that could be at shallower depths according to the ESP evaluation.

Shear Wave Velocity

Some plant designs considered in the ESP Application reference a minimum 1,000 feet-per-second ("fps") shear wave velocity ("Vs") requirement for soils below the safety-related plant foundation basemat. Shear wave measurements of site subsurface materials were obtained by borehole P-S suspension surveys in each of the three ESP borings distributed within the proposed reactor building envelope (SSAR Figure 2.5-80). Based on the results from the ESP

velocity surveys, Section 2.5.4.6 of the SSAR states that the average Vs exceeds 1,000 fps (in Upland Complex Alluvium) at, and below, approximately elevation 97 feet MSL (depth of about 36 feet below assumed finished plant grade elevation 133 feet MSL). Plant basemat (foundation) elevations above this level would require overexcavation and replacement of soils down to material exhibiting a minimum shear wave velocity of 1,000 fps, or alternatively, in-situ ground improvement (*e.g.* grouting) and/or further engineering design analyses.

Q.9 Does this conclude your testimony?

A.9 (JGC, WRL, JLB) Yes.

I-WA/2661778.2

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	
	)	
SYSTEM ENERGY RESOURCES, INC.	)	Docket No. 52-009-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	ASLBP No. 04-823-03-ESP

**PRE-FILED TESTIMONY OF MARVIN MORRIS AND JOHN CESARE ON BEHALF
OF APPLICANT CONCERNING HEARING ISSUE I
(RADIOLOGICAL REVIEWS AND CONFIRMATORY ANALYSES)**

Q1. Please state your name, current position, and by whom you are employed.

A1. My name is Marvin Morris ("MM"). I am employed as a consulting engineer and analyst for ENERCON Services, Inc.

A.1 My name is John G. Cesare ("JGC"). I am employed as Lead Licensing Project Engineer for ENERCON Services, Inc.

Q2. On whose behalf are you testifying in this proceeding?

A2. (MM, JGC) We are providing testimony on behalf of the applicant in this early site permit ("ESP") proceeding, System Energy Resources, Inc. ("SERI" or the "Applicant").

Q3. Please describe your professional qualifications.

A3. (MM) I hold a B.S. degree in Mathematics from the University of Texas, Pan American, and an M.S. degree in Physics from Sam Houston State University. I have over 30 years of experience in the nuclear industry in areas of design, analysis, licensing and operations support. A full statement of my professional qualifications is contained in SERI Exhibit 1.

A3. (JGC) I hold a B.S. degree in Chemical Engineering and an M.S. degree in Nuclear Engineering from Mississippi State University. I have over 24 years of experience in the nuclear power industry, including experience in the areas of new reactor, operational and decommissioning licensing; special projects; organizational assessment; and management support. This includes ten years of supervisory and management experience at a Boiling Water Reactor ("BWR") facility. A full statement of my professional qualifications is contained in SERI Exhibit 1.

Q4. Please describe your professional responsibilities with regard to the Grand Gulf Nuclear Station ("GGNS") ESP application, including the basis for your familiarity with that application.

A4. (MM) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As a senior engineer, I was responsible for analyses supporting the application in the areas of offsite hazards, atmospheric dispersion, design basis accidents, and severe accidents. My responsibilities included Sections 2.3, 3.2, and 3.3 of the SSAR and Sections 2.7, 5.4, and 7.1 of the ER.

A4. (JGC) As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As the lead licensing project engineer, I coordinated and supported the development of the safety analyses, environmental report ("ER"), and emergency planning assessment for the ESP application. I also participated in site safety and environmental visits, the development of applicant responses to Nuclear Regulatory Commission ("NRC") Staff requests for additional information ("RAIs"), and the Advisory Committee on

Reactor Safeguards ("ACRS") review process. My work also involved active participation in the industry ESP task force and numerous licensing-related interactions with the NRC Staff.

Q5. In its Order (Requesting Specific Summary Exhibits and Supplemental Briefs; Identifying Hearing Issues and Requesting Evidentiary Presentations on Specific Issues) of November 6, 2006, the Atomic Safety and Licensing Board ("Board") identified a series of hearing issues on which the Board has required testimony and presentations from the NRC Staff. The Staff submitted its pre-filed testimony on November 20, 2006. *See* NRC Staff Pre-Filed Testimony Concerning Hearing Issue I: "Radiological Reviews And Confirmatory Analyses" (Nov. 20, 2006). Have you reviewed the Staff's testimony on Hearing Issue I?

A5. (MM, JGC) Yes.

Q6. During the October 31, 2006, pre-hearing conference, the Board expressly authorized the Applicant, as appropriate, to submit supplemental pre-filed testimony for the limited purpose of clarifying and/or providing additional factual information that may inform the Board's mandatory hearing review and decision-making process. *See* Transcript of October 31, 2006, Pre-hearing Conference at 8. Do you wish to provide any such supplemental testimony at this time?

A6. (MM, JGC) Yes. We are offering supplemental testimony with respect to Answer 3 of the Staff's pre-filed testimony. Specifically, we have augmented the discussion of the Applicant's and the Staff's radiological analyses of normal gaseous and liquid effluent releases.

Q7. Please describe the Applicant's and the Staff's analyses with respect to gaseous radiological effluent releases.

A7. (MM, JGC) For the gaseous release pathway, SERI and the Staff calculated annual radiation exposures for the population within a 80-km (50-mi) radius of the site and for hypothetical individuals of various ages, by using the GASPAR II code and assuming the following pathways:

- direct radiation from immersion in the gaseous effluent cloud and from particulates deposited on the ground;
- inhalation of gases and particulates;
- ingestion of milk contaminated through the grass-cow-milk pathway;
- ingestion of vegetables contaminated by particulates; and
- ingestion of meat from animals grazing on contaminated pasture.

The methodology contained in the GASPAR II program, which is described in NUREG/CR-4653, "GASPAR II – Technical Reference and User Guide" (Mar. 1987), was used to determine the gaseous pathway doses. This program implements the radiological exposure models described in Regulatory Guide 1.109, Revision 1, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 C.F.R. Part 50, Appendix I" (Oct. 1977) for radioactivity releases in gaseous effluents.

Three types of doses were calculated by the Staff and compared with SERI's calculations.

Those doses include:

- doses to an individual located at the exclusion area boundary of 0.93 km (0.58 mi) north of the site as a result of gamma air dose, beta air dose, total body dose and skin dose;
- doses to hypothetical individuals (maximally exposed individual) of various ages that are exposed to gaseous radioactive effluents via the pathways listed above; and
- doses to the population residing within an 80-km (50-mi) radius of the site.

The input data for the dose analysis are summarized in the table below.

Input Description	Location of Data (SSAR)	Data Source
Source Term Population Data	Table 1.3-2 Section 2.1	Composite release Projected population at the end of plant life – i.e., 2070
Meteorological Data	Section 2.3	GGNS site data
Consumption Factors	Table 3.2-2	Regulatory Guide 1.109, Table E-5.
Milk Production within 5 miles	Table 3.2-6	Land use survey
Meat Production within 5 miles	Table 3.2-7	Land use survey
Vegetable Production within 5 miles	Table 3.2-8	Land use survey

For parameters that are not site-specific, the Applicant used default values from Regulatory Guide 1.109

The results of the Applicant's dose analysis are provided in Site Safety Analysis Report ("SSAR") Table 3.2-3A, "ANNUAL DOSE TO A MAXIMALLY EXPOSED INDIVIDUAL FROM GASEOUS EFFLUENTS (Per Unit)", and SSAR Table 3.2-4, "ANNUAL POPULATION DOSES - GASEOUS PATHWAY." These results are within the regulatory design objectives. The Staff concluded that there would be no observable health impacts due to normal gaseous releases from a new nuclear plant and, therefore, that the health impacts would be SMALL. See FEIS at 5-58.

Q8. Please describe the Applicant's and the Staff's evaluations with respect to liquid radiological effluent releases.

A8. The release of small amounts of radioactive liquid effluents currently is permitted at GGNS, and would be expected to be permitted for the new facility at the GGNS ESP Site, as

long as releases comply with the requirements specified in 10 C.F.R. Part 20. The important exposure pathways include:

- internal exposure from ingestion of water or contaminated food chain components;
- external exposure from the surface of contaminated water or from shoreline sediment; and
- external exposure from immersion in contaminated water.

The LADTAP II computer program, as described in NUREG/CR-4013, "LADTAP II—Technical Reference and User Guide" (Apr. 1986), and the liquid pathway parameters presented in ER Table 5.4-1, were used by the Staff and SERI to calculate the maximally exposed individual dose from this pathway. The LADTAP II program implements the radiological exposure models described in Regulatory Guide 1.109, Revision 1, for radioactivity releases in liquid effluents. The input parameters used are listed below:

LIQUID PATHWAY PARAMETERS⁴

Description	Parameter
Effluent Discharge ¹	12,800 gpm
Source Term ²	Isotope Maximum Composite Release
Commercial Fish Catch ³	446,467 kg
Invertebrate Harvest ³	3,511 kg

NOTES:

1. ER Table 3.0-1.
2. ER Table 3.0-8.
3. GGNS Unit 1 FER.
4. ER Table 5.4-1.

Consumption Factors were obtained from NRC Regulatory Guide 1.109, Table E-5.

The results of this analysis are given in ER Table 5.4-8, "Liquid Pathway Comparison of Maximum Individual Dose to 10 Cfr 50, Appendix I Criteria" and ER Table 5.4-10, "Estimated Population Dose from Liquid Effluents via the Aquatic Food Pathway." These results are within the regulatory design objectives. The Staff concluded that there would be no observable health impacts due to normal liquid releases from a new nuclear plant and therefore the health impacts would be SMALL. See FEIS at 5-58.

Q9. Does this conclude your prefiled testimony on Hearing Issue I?

A9. (MM, JGC) Yes.

I-WA/2661933.1

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

AFFIDAVIT OF JEFFREY L. BACHHUBER

I, Jeffrey L. Bachhuber, do hereby state as follows:

1. I am employed as the Vice President, Senior Principal Engineering Geologist of William Lettis & Associates, Inc.
2. I hold M.S. and B.A. degrees in Geology from San Jose State University. I am a Certified Engineering Geologist in California with over 20 years of professional experience performing geologic/geotechnical studies for nuclear and other critical facilities throughout the United States, Peru, Dominican Republic, Puerto Rico, Korea, Indonesia, Japan, and Turkey. I have performed detailed site investigations in a variety of geologic settings, in addition to regional hazard mapping and facility siting and routing studies. These projects involved assessment of earthquake hazard and sources, fault rupture and ground failure analysis, slope stability analysis and mitigation design, karst and void identification and treatment, foundation characterization with borings and geophysical techniques, laboratory testing, failure mode assessment, and development of foundation criteria for detailed static and dynamic stability and site response analyses (including soil-structure interaction). A full statement of my professional qualifications is contained in SERI Exhibit 1.

3. I was responsible for developing detailed site geotechnical characterization for the Grand Gulf ESP site. My work regarding the Grand Gulf ESP included developing quality assurance/quality control ("QA/QC") technical procedures and workplans to guide all field and laboratory activities, directing field investigations consisting of geologic mapping, deep mud rotary borings, cone penetrometer soundings and borehole P-S velocity surveys. I also prepared Sections 2.5.4 to 2.5.6 for the site safety analysis report ("SSAR"), responded to Nuclear Regulatory Commission ("NRC") requests for additional information ("RAIs"), and presented the project to the Advisory Committee on Reactor Safeguards ("ACRS") in a formal meeting.
4. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issues A, C, D, and H marked with my initials ("JLB").
5. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.



Jeffrey L. Bachhuber

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD


In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

AFFIDAVIT OF DAVID J. BEAN

I, David J. Bean, do hereby state as follows:

1. I am employed as a Senior Environmental Scientist for ENERCON Services, Inc.
2. I hold an M.S. degree in Zoology from the Ohio State University, and a B.A. degree in Biology from the State University of New York at Oswego. I have over 30 years of experience in the Environmental Industry, and am well-versed in environmental impact analysis/assessment, the National Environmental Policy Act ("NEPA"), and Strategic Environmental Management. I have extensive experience performing environmental safety and health ("ES&H") compliance strategy development, site evaluation and selection planning, risk assessment/analysis, and waste management. A full statement of my professional qualifications is contained in SERI Exhibit 1.
3. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issue F marked with my initials ("DJB").
4. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my

statements in this affidavit, are true and correct to the best of my knowledge, information,
and belief.


David J. Bean

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**


BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

AFFIDAVIT OF MICHAEL D. BOURGEOIS

I, Michael D. Bourgeois, do hereby state as follows:

1. I am employed as the Manager of Project Management for Entergy Nuclear, Inc.
2. I hold a B.S. degree in Nuclear Engineering Technology from Thomas Edison State College. I have over 37 years of commercial and military nuclear experience. My experience includes project and outage management, nuclear reactor operation, and work control. A full statement of my professional qualifications is contained in SERI Exhibit 1.
3. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issues E and G marked with my initials ("MDB").
4. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.


Michael D. Bourgeois

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006


AFFIDAVIT OF JOHN G. CESARE

I, John G. Cesare, do hereby state as follows:

1. I am employed as Senior Licensing Consultant for ENERCON Services, Inc.
2. I hold a B.S. degree in Chemical Engineering and an M.S. and B.S. degree in Nuclear Engineering from Mississippi State University. I have over 24 years of experience in the nuclear power industry, including experience in the areas of new reactor, operational and decommissioning licensing; special projects; organizational assessment; and management support. This includes ten years of supervisory and management experience at a boiling water reactor ("BWR") facility. A full statement of my professional qualifications is contained in SERI Exhibit 1.
3. As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. As the Lead Licensing Project Engineer, I coordinated and supported the development of the safety analyses, environmental report, and emergency planning assessment for the ESP application. I also participated in site safety and environmental visits, the development of applicant responses to Nuclear Regulatory Commission ("NRC") Staff requests for additional information ("RAIs"), and the Advisory Committee on Reactor Safeguards ("ACRS") review process.

My work also involved active participation in the industry ESP task force and numerous licensing-related interactions with the NRC Staff.

4. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issues E, F, G, H, and I, that are marked with my initials ("JGC").
5. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.



John G. Cesare

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD


In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

AFFIDAVIT OF LORI M. EVANS

I, Lori M. Evans, do hereby state as follows:

1. I am employed as Senior Project Manager for ENERCON Services, Inc. I hold a B.S. degree in Geology from Tennessee Technological University. I have over 14 years of experience that includes project management, a varied technical background, and environmental risk analysis. I have acted as task leader for hydrologic analyses for a proposed expansion of an existing nuclear power plant, have assisted in development of new bank environmental policy guidance documents, and have been responsible for managing multiple-site Phase I environmental site assessment projects. A full statement of my professional qualifications is contained in SERI Exhibit 1.
2. I am task leader for the hydrologic analysis sections of the Grand Gulf ESP application. As task leader, I was responsible for assessing the potential impacts on the surface water and groundwater of constructing and operating a nuclear power generating facility at the Grand Gulf site.
3. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issues A and B marked with my initials ("LME").
4. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with

28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.

A handwritten signature in cursive script, appearing to read "Lori M. Evans", written over a horizontal line.

Lori M. Evans

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

AFFIDAVIT OF WILLIAM LETTIS

I, William R. Lettis, do hereby state as follows:

1. I hold a Ph.D. and an M.S degree in Geology from the University of California, Berkeley, and a B.S. degree in Geology and a B.S. degree in Forestry from Humboldt State University. I have over 20 years experience performing regional and site investigations to assess geologic and seismic hazards for large engineered facilities, including bridges, dams, nuclear and fossil fuel plants, pipelines, and liquid natural gas ("LNG") terminals. A full statement of my professional qualifications is contained in SERI Exhibit 1.
2. I am Project Manager for the seismic and geotechnical work in support of the Entergy Grand Gulf Nuclear Station ("GGNS") ESP. My responsibilities included preparation of Sections of 2.5.1 through 2.5.6 of the SSAR, including seismic source characterization and probabilistic seismic hazard analysis to develop the safe shutdown earthquake ("SSE") design ground motion in compliance with Regulatory Guide 1.165, and, geotechnical characterization of the site in partial compliance with Regulatory Guides 1.138 and 1.132..
3. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issues A, B, and H marked with my initials ("WRL").

4. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.



William R. Lettis

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD


In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

AFFIDAVIT OF MARVIN MORRIS

I, Marvin Morris, do hereby state as follows:

1. I am employed as a consulting engineer and analyst for ENERCON Services, Inc.
2. I hold a B.S. degree in Mathematics from the University of Texas, Pan American, and an M.S. degree in Physics from Sam Houston State University. I have over 30 years of experience in the nuclear industry in areas of design, analysis, licensing and operations support. A full statement of my professional qualifications is contained in SERI Exhibit 1.
3. As part of a larger ENERCON team, I served as a consultant to SERI and supported the development of the ESP application that seeks to demonstrate site suitability for a new commercial nuclear power plant at the GGNS site. I was responsible for analyses supporting the application in the areas of offsite hazards, atmospheric dispersion, design basis accidents, and severe accidents. My responsibilities included Sections 2.3, 3.2, and 3.3 of the SSAR and Sections 2.7, 5.4, and 7.1 of the Environmental Report ("ER").
4. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issues B, F, H, and I, that are marked with my initials ("MM").

5. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.



Marvin Morris

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

AFFIDAVIT OF AL J. SCHNEIDER

I, Alcuin J. Schneider, do hereby state as follows:

1. I am employed as the Manager of Projects for the New Plant Services Division of ENERCON Services, Inc.
2. I hold B.S. and M.S. degrees in Mechanical Engineering from the University of Arkansas. I have over 33 years of technical and management experience in the commercial nuclear power industry. This experience encompasses numerous lead and supervisory assignments in engineering, projects, technical support, preoperational and start-up testing programs, procedure upgrade and development, licensing, and outage planning and scheduling. I have provided project management and technical expertise to the Grand Gulf Nuclear Station ("GGNS") ESP project. I also have provided project management services in connection with NuStart's combined license application ("COLA") preparation project, and the NuStart Economic Simplified Boiling Water Reactor ("ESBWR") COLA preparation project. A full statement of my professional qualifications is contained in SERI Exhibit 1
3. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issue G marked with my initials ("AJS").

4. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.



Alcuin J. Schneider

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD


In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006

AFFIDAVIT OF KYLE H. TURNER

I, Kyle H. Turner, do hereby state as follows:

1. I am employed as the Chief Executive Officer of McCallum-Turner, Inc.
2. I hold a B.S. degree in Electrical Engineering for the Georgia Institute of Technology, as well as Ph. D. and M.S. degrees in Nuclear Engineering, also from the Georgia Institute of Technology. I have more than 30 years experience providing technical, business, and management consulting services to commercial industry and government. My management responsibilities have ranged in budget up to \$16 million and 200 professional staff. I am Principal author for the industry ESP Siting Guide, ESP Model Program Plan and COL Model Program Plan for nuclear power plants ,and am currently managing an Electric Power Research Institute ("EPRI") project to develop a model Program Plan for overall nuclear power plant development under Part 52 regulations. Since 2001, I have directed site selection studies for ten nuclear power plant sites for COL and ESP applications (Duke Power, Entergy Nuclear, Florida Power & Light, Progress Energy (2), NuStart, South Carolina Electric & Gas, and two confidential clients). A full statement of my professional qualifications is contained in SERI Exhibit 1.
3. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issue E marked with my initials ("KHT").

4. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.



Kyle H. Turner

**UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION**

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the matter of	)	Docket No. 52-009-ESP
	)	
SYSTEM ENERGY RESOURCES, INC.	)	ASLBP No. 04-823-03-ESP
	)	
(Early Site Permit for Grand Gulf ESP Site)	)	November 28, 2006


AFFIDAVIT OF GEORGE A. ZINKE

I, George A. Zinke, do hereby state as follows:

1. I am employed as Project Manager, Business Development, for Entergy Nuclear, Inc.
2. I hold a B.S. degree in Electrical Engineering from Wichita State University. I have 30 years of technical and management experience in the commercial nuclear power industry. Since 2001; as a Project Manager with Entergy Nuclear, Inc., I have focused principally on licensing matters involving the company's Grand Gulf Nuclear Station ("GGNS") Early Site Permit and Combined Operating License ("COL") Development projects, as well as the NuStart COL Development Project. Prior to that, I held various managerial and supervisory positions at the Maine Yankee, River Bend, and GGNS facilities, where I was responsible for overseeing various licensing, system engineering, quality assurance, worker concerns, emergency preparedness, and environmental programs related to facility construction, operation, and decommissioning. A full statement of my professional qualifications is contained in SERI Exhibit 1.
3. As Project Manager, Business Development, for Entergy Nuclear, Inc., I have two different but complementary roles. Namely, I am both the NuStart Licensing Lead and the Entergy Nuclear New Plant Licensing Lead. In the former capacity, I am responsible for regulatory affairs associated with the NuStart COL Development Project. Entergy is

a member of NuStart Energy Development, LLC, a consortium formed in 2004 that is seeking to facilitate the licensing, construction, and operation of new, advanced nuclear power plants in the United States. In the latter capacity, I am responsible for regulatory affairs and quality assurance associated with the Entergy COL and ESP Development Processes. The acquisition of an ESP for the GGNS site is a preliminary and integral step in the Entergy COL Development Process. As such, I have overall responsibility for regulatory and engineering matters related to the Grand Gulf ESP application.

4. I have primary technical responsibility for those portions of the Applicant's Prefiled Direct Testimony on Hearing Issues E, G, and H, which are marked with my initials ("GAZ").
5. I attest to the accuracy of these statements, support them as my own, and endorse their introduction into the record of the above-captioned proceeding. In accordance with 28 U.S.C. §1746, I declare under penalty of perjury that those statements, and my statements in this affidavit, are true and correct to the best of my knowledge, information, and belief.


George A. Zinke

1 the same thing at this point in time. I would admit
2 those into evidence. If during the course of the
3 proceeding the staff has an objection they can raise
4 the objection at that time and if the objection were
5 upheld we would then withdraw it from evidence. But
6 for the purposes right now they are received, they
7 are part of the record subsequent to a further order
8 by the Board.

9
10 (Whereupon, the documents
11 marked as SERI Exhibit Nos...
12 1-30 for identification were
13 admitted into evidence.)

14 MS. SUTTON: Yes, Your Honor.

15 JUDGE MCDADE: Thank you. Okay, we are
16 ready to proceed with Hearing Issue A. A question:
17 do we need to take a short recess prior to that for
18 you to just handle the administrative matters, and
19 if so how long would you suggest? If it's only
20 going to be a couple of minutes we might as well
21 just stay here in place and be ready.

22 MS. HODGDON: Ten minutes?

23 JUDGE MCDADE: From the staff. Is that
24 sufficient?

25 MS. SUTTON: Ten minutes would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 sufficient.

2 JUDGE MCDADE: Judge Trikouros, before
3 we do that, do you have anything further?

4 JUDGE TRIKOUROS: Yes, just a point of
5 clarification. You were going to submit that ESP
6 form into the record. When would that happen?
7 Sooner would be better than later.

8 MS. HODGDON: Mr. Weisman said within
9 the next couple of days, before the hearing is over.
10 He didn't give you an exact time.

11 JUDGE TRIKOUROS: All right. Well, the
12 sooner the better. It'd be helpful to me to have
13 it.

14 MS. HODGDON: Well, we don't know - the
15 answer is we don't know exactly. As soon as we
16 know, we will tell you.

17 JUDGE MCDADE: Okay. Rather than just
18 sort of everybody sit here and stare at each other
19 for 10 minutes, why don't we take a 10-minute
20 recess. It is now, at least according to my watch,
21 quarter of 10:00. We'll come back at five minutes
22 of 10:00. Thank you. We are in recess.

23 (Whereupon, the foregoing matter went
24 off the record at 9:47 a.m. and went back on the
25 record at 10:04 a.m.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE MCDADE: The hearing will come to
2 order. Let me just note for the record that we had
3 a recess. The recess was originally scheduled to go
4 until 9:55. We were advised that they would need an
5 additional five minutes so we extended it to 10:00.
6 We're now advised that we're going to be needing an
7 additional 10 minutes to sort of get the paperwork
8 together. I just wanted to note for the people who
9 are here that we are going to go back into recess
10 and will come back in at 10 minutes past 10:00 so
11 that if anybody has any other business to take care
12 of we're going to be in recess until 10 minutes past
13 10:00. If you believe that you are going to need
14 any additional time, just tell Ms. Wolf so that we
15 can extend the recess. But hopefully we can get
16 started promptly at 10 past 10:00. We are in
17 recess.

18 (Whereupon, the foregoing matter went
19 off the record at 10:05 a.m. and went back on the
20 record at 10:17 a.m.)

21 JUDGE MCDADE: The hearing will come to
22 order. The first order of business at this point
23 would be beginning with Hearing Issue A. We had
24 advised in our preliminary hearings that prior to
25 the presentation of the testimony if the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 wished to make a brief opening statement what they
2 would be presenting they would be allowed to do so,
3 and then the applicant would have an opportunity to
4 do so as well either directly after the staff or at
5 the conclusion. Do you wish to make an opening with
6 regard to Hearing Issue A?

7 MR. RUND: We have no opening statement,
8 but we'd like to introduce who's up there. I
9 believe the applicant's witnesses on Hearing Issue A
10 are also sitting with us. So after I introduce our
11 witnesses I'd like to hand it over to the applicant.

12 JUDGE MCDADE: That's fine.

13 MR. RUND: The staff's panel for Hearing
14 Issue A which deals with site characterization
15 consists of Lance Vail, Goutam Bagchi and Thomas
16 Cheng. Also with us is Carl Constantino who
17 assisted Dr. Cheng in preparing his testimony.

18 JUDGE MCDADE: Okay, thank you. From
19 the standpoint of SERI, do you have any opening
20 statement to make?

21 MS. SUTTON: Your Honor, we have called
22 as witnesses by way of background Lori Evans,
23 William Lettis and Jeffrey Bachhuber. We don't - I
24 just have some preliminary administrative matters if
25 you would like to run through to introduce them as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 witnesses, but no, we have no opening statement on
2 this.

3 JUDGE MCDADE: Why don't you go ahead
4 and do that at this point.

5 MS. SUTTON: All right. Would you just
6 briefly introduce yourselves to the Board?

7 WITNESS EVANS: My name is Lori Evans.
8 I work for Enercon Services and I'm here on behalf
9 of SERI.

10 WITNESS LETTIS: I'm William Lettis. I
11 work with William Lettis & Associates, principal
12 geologist and I'm here on behalf of SERI.

13 WITNESS BACHHUBER: I'm Jeff Bachhuber
14 with William Lettis & Associates, principal
15 engineering geologist, representing SERI.

16 JUDGE MCDADE: Okay. We have received
17 the pre-filed testimony of each of these
18 individuals. We have also received curriculum vitae
19 with regard to each of these individuals. There
20 being no objection from either side we will
21 recognize and accept them as experts in the field
22 for which they are offered and will accept opinion
23 testimony from them as experts. There's no
24 objection from the staff?

25 MR. RUND: No. I would like to point

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 out though, all of our statements of professional
2 qualifications are in one document labeled Staff 13.
3 Dr. Constantino's statement of professional
4 qualifications is separately in Staff 14. Also,
5 since we - it slipped my mind, I think we'd like to
6 have all of our witnesses introduce ourselves for
7 the court reporter.

8 JUDGE MCDADE: Well, we would also ask
9 not only to introduce yourself initially for the
10 court reporter, but when you do make a statement,
11 assuming that you're familiar with your name, you've
12 used it a long time, the court reporter may not be,
13 even though you've introduced yourself. So if you
14 could, just preface your statement by giving your
15 name to make sure that the statement you give is
16 attributed to you. You may want to do that because
17 you may disagree with the statement of one of your
18 colleagues and not want to have it attributed to
19 you. So please, when you do make a statement, just
20 preface it by your name and then go ahead. But
21 gentlemen representing the staff, if you could
22 identify yourselves?

23 WITNESS CONSTANTINO: I'm Carl
24 Constantino, a professor at City University of New
25 York and consultant to Brook Haven National

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Laboratory.

2 WITNESS CHENG: My name is Thomas Cheng,
3 senior structural engineer in the Geosciences Center
4 in civil engineering branch.

5 WITNESS BAGCHI: My name is Goutam
6 Bagchi. I'm a senior level advisor in Division of
7 Engineering and I was responsible for the review in
8 the hydrology area.

9 WITNESS VAIL: My name is Lance Vail.
10 I'm a senior research engineer at Pacific Northwest
11 National Laboratory in the hydrology group.

12 JUDGE MCDADE: Okay, thank you. At this
13 point, could all seven of you please stand to be
14 sworn? And we will do this just once for all seven
15 of you and basically what I'm going to be asking you
16 is do you state under penalty of perjury that the
17 testimony you give will be true and correct?

18 WHEREUPON,

19

20 LANCE VAIL
21 CARL CONSTANTINO
22 GOUTAM BAGCHI
23 LORI EVANS
24 WILLIAM LETTIS
25 JEFF BACHHUBER
26

27 were duly sworn and assumed the witness
28 stand.

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE MCDADE: Okay, please be seated,
2 you are under oath. Is the staff ready to proceed?

3 MR. RUND: Yes, we are.

4 JUDGE MCDADE: Judge Wardwell is going
5 to be beginning with the questioning of the Board on
6 Hearing Issue A.

7 JUDGE WARDWELL: I have a number of
8 things and I thought the best way to focus it was to
9 create hypothetical hypotheses that I think need to
10 be refuted in order to comfort myself in regards to
11 some concerns I have in regards to the site
12 characterization. I will present those to you when
13 the time's appropriate so that you can tailor any
14 response that you have in accordance with those
15 hypotheses under each section that we're dealing
16 with, but I thought it might be useful to start off
17 with, to just have anyone who wishes to to start off
18 by just describing the various geologic strata that
19 exist between the Mississippi River and the power
20 block area extending all the way to the existing
21 plant for that matter, naming the various layers,
22 referencing whatever exhibit is best for us to
23 follow along with and hopefully we'll be able to
24 pull it up or you can pull it up on your computer
25 also if you want to hook that up. And just step us

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 through what's there, what depths they're at, how
2 does that relate to the PPE for any foundation
3 exploration or foundation depth, just any background
4 information to get everyone oriented to some of the
5 site characteristics in the geologic end.

6 WITNESS CHENG: Your Honor, may I ask my
7 consultant Dr. Constantino to respond to this
8 question?

9 JUDGE WARDWELL: Make sure you - I can
10 hear you, but I want to make sure everyone else can
11 hear you, so pull that mic real close and talk into
12 it in good shape, so.

13 JUDGE MCDADE: And also again, let me
14 reiterate, when you are making a statement to state
15 your name first. That statement was made by Dr.
16 Cheng and he is now referring the matter to his
17 colleague. Sir?

18 WITNESS CONSTANTINO: I'm Carl
19 Constantino. The issue of description of the site
20 is provided in the various engineering reports.
21 Basically there's a surficial layer if I recall of
22 loess, followed by a series of alluvium layers,
23 followed by a very much stiffer Catahoula formation.
24 The extent of the site to hard rock conditions is -
25 I should say hard rock conditions are very deep so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you have this generic site which extends to
2 thousands of feet.

3 JUDGE WARDWELL: Is there a good cross-
4 section we should be looking at that would assist us
5 in this description?

6 WITNESS CONSTANTINO: Yes. I think if
7 you look at Figure 25.

8 JUDGE WARDWELL: And it'd be best if you
9 could -

10 WITNESS CONSTANTINO: 2576 and -7 have
11 generic profiles that were generated from the ESP.

12 MR. RUND: Just for clarification, 25-75
13 is labeled as Staff Exhibit 40. 2.5-76 is Staff 41.

14 JUDGE MCDADE: Thank you.

15 WITNESS CONSTANTINO: Following these
16 cross-sections that were provided, these cross-
17 sections were built up from the ESP borings that
18 were - and cone penetrometers that were generated at
19 the site together with a significant amount of data
20 from the previous explorations that were done for
21 the existing plant. As you can see from those
22 figures, the upper surface elevation is at
23 approximately Elevation 130, 135. And that loess
24 material which is shown on 2.5-76 in yellow extends
25 down to Elevation 60 or so, and then followed by a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 series of alluvium layers of various
2 characterizations. Some are fine grain, some are
3 fine grain intermixed with gravels.

4 JUDGE MCDADE: Actually, sorry, if I
5 could interrupt you for just a second, just an
6 administrative question I have. We received an
7 electronic copy of it that we can look at
8 electronically here. We can't send it out to the
9 well. We've also got paper copies. I know you all,
10 you know, were going to bring laptops. If it is
11 possible for you to flip that up so that the people
12 present could see these figures as well and do it
13 relatively easily. I don't want to interrupt the
14 testimony or delay the testimony, but if it's
15 readily available that you can hook it in so that
16 it's available to the people in the audience I would
17 appreciate it. As I've said, we've got it up here
18 but we can't send it out to the audience.

19 MR. RUND: We have a laptop with that
20 electronically. I think it'll just take a minute if
21 we - are you suggesting we plug it in?

22 JUDGE MCDADE: Yes. Why don't we keep
23 going with the testimony and just if you could be
24 plugging it in and that way, you know, at the
25 earliest possibility without delaying things, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 know, the people in the back who are here, it's an
2 awful lot easier to follow the testimony if you're
3 also looking at the exhibit as well. So as I said,
4 we can proceed because the members of the Board and
5 you all have copies of it, but if we can send it out
6 to the audience as well conveniently.

7 MR. RUND: We'll start on that.

8 JUDGE MCDADE: I'm sorry for the
9 interruption.

10 WITNESS CONSTANTINO: Should I continue?
11 Okay.

12 JUDGE MCDADE: If it's not going to
13 disturb you to have them fiddling with the computer.

14 WITNESS CONSTANTINO: Very little
15 disturbs me.

16 JUDGE MCDADE: Okay.

17 WITNESS CONSTANTINO: In any case, the
18 interesting part of this figure is not only the
19 description of the site profiles in the upper
20 echelon of the - the soil layering in the upper
21 echelons of the site profile, which is, this is only
22 the top several hundred feet of profile which
23 extends, as I said, to thousands of feet to hard
24 rock. The interesting part of the figure is the
25 sketch of an intended depth of the foundation for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 any new plant, approximate depth of the foundation
2 of any new plant that would be sited. And it's
3 indicated that any new plant would be sited well
4 below the loess material.

5 Of the generic three profiles we have,
6 the loess, the alluvium and the Catahoula, the loess
7 is the most problematic from a design perspective
8 since it tends to be the softest, the finest
9 material and one which would have difficulty in
10 providing adequate foundation capacity to any plant
11 situated basically on the loess. When you get to
12 alluvium strengths tend to be higher and the
13 Catahoula has much higher strength. So the only
14 additional material at the site which is indicated
15 on this figure are the fill materials, which are
16 indicated to be in the upper echelons, the upper
17 parts of the site. Those were placed in - based on
18 the SERI descriptions in an uncontrolled manner.
19 Their properties are not well known, but they would
20 have - judged to have little impact on any
21 foundation designs since they're so high in the
22 profile.

23 JUDGE WARDWELL: On that cross-section
24 which I assume will have a profile I guess it is,
25 there are various numbers listed there as opposed to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the actual formation and they refer to descriptions
2 down below.

3 WITNESS CONSTANTINO: Right.

4 JUDGE WARDWELL: Could you go through
5 which numbers relate to what and what it's called
6 now and what it will be called in the future?

7 WITNESS CONSTANTINO: I'll try as best I
8 could. Zone Material 1 is this uncontrolled fill
9 material which is at near-surface in the profile.
10 Zone Number 2 is the loess material which extends to
11 depth or elevations of about Elevation 70 which
12 approximately then with the surface at 130,
13 approximately 60 or 70 feet of loess material, which
14 is just Aeolian material, windblown, relatively
15 uniform across the site. The Material 3 is the
16 colluvium or alluvium deposits which are located
17 across the site. The additional layers shown on
18 this Figure 2b and 2c are off to the side of the
19 site and would not have a direct impact on any plant
20 location since they are under the Mississippi River.
21 And Zone 4 is the old alluvium, the Upland Complex,
22 very stiff material. You could tell that from the
23 measured blow counts, SPT blow counts as well as
24 velocity measurements. And below that is the
25 Catahoula formation which is very stiff. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Catahoula is in fact not shown on Figure 76.

2 JUDGE WARDWELL: At about what elevation
3 and ranges do - is the Catahoula encountered?

4 WITNESS CONSTANTINO: The Catahoula,
5 there was only one location encountered from the ESP
6 borings that I recall, and the Catahoula is of the
7 order of 140 feet below grade I think is the number.
8 And that was, as I say, encountered in only one
9 boring taken for the ESP profile. There was one SPT
10 sample if I recall that encountered the Catahoula
11 and it was very high blow count. Catahoula is
12 generally characterized as a silt stone/clay stone
13 material, very stiff, very dense.

14 JUDGE WARDWELL: So at 140 feet below
15 the grade, the existing grade that the boring was
16 made was anywhere between what, 130 to 140?

17 WITNESS CONSTANTINO: One hundred thirty
18 to 140 was the deepest investigation.

19 JUDGE WARDWELL: I'm trying to get how -
20 what's the elevation of that level.

21 WITNESS CONSTANTINO: Well, if the grade
22 is at 135 and I go down 140, it's somewhere of the
23 order of zero if my arithmetic works.

24 WITNESS LETTIS: Excuse me.

25 JUDGE WARDWELL: Zero to -5 or -10.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 WITNESS LETTIS: This is William Lettis.
2 If I could add a point of -

3 JUDGE WARDWELL: Could you also add that
4 you are with the applicant when you do that? And I
5 don't mind, at least in regards to my questions in
6 this particular area. There may be some times I'll
7 want the staff to only answer, but I think in this
8 introductory thing I appreciate any -

9 WITNESS LETTIS: I'm sorry.

10 JUDGE WARDWELL: - amplification that
11 you do make on it. So please feel free to do that
12 but make sure you identify yourself as with the
13 applicant.

14 WITNESS LETTIS: Okay. I'm William
15 Lettis with the applicant and I apologize for
16 interjecting here, but just a point of
17 clarification. On Staff Exhibit 41 I believe which
18 they have entered shows the Catahoula at depth. It
19 would have been Figure 2.5-77. And it is located in
20 the boring that encountered the Catahoula at an
21 elevation of approximately -70 feet or so, -70
22 elevation.

23 JUDGE WARDWELL: And to be clear that's
24 Number 5 on your profile sheet. That's Numeral 5 is
25 the Catahoula. Correct?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS LETTIS: Yes, and it's
2 identified as Number 5. And so it's at
3 approximately a depth of 200 to 225 feet below the
4 site from the ground surface to the site. So it's a
5 bit deeper than what Dr. Constantino is mentioning.

6 WITNESS CONSTANTINO: Yes, I agree with
7 that. I have those figures in front of me.

8 JUDGE WARDWELL: Yes, go ahead if you
9 have more to say.

10 WITNESS CONSTANTINO: So again, from a
11 siting perspective all of these layers are of
12 interest, but the primary layers of concern from a
13 foundation perspective would be the alluvium, the
14 Upland alluvium, the old alluvium or the new
15 alluvium, whatever term you want to associate with
16 it.

17 JUDGE WARDWELL: That's one of the
18 things we need to resolve now. We have to define
19 which - what are these alluviums we're talking about
20 because in various documents we have Upland Complex,
21 we have Upland alluvium, we have new alluvium, we
22 have young alluvium, we have old alluvium, we have
23 clay/silt alluvium, sand/gravel alluvium, fill and
24 the Catahoula formation.

25 WITNESS CONSTANTINO: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: And depending upon
2 where you are those are intermixed and I'd like to
3 clarify are all of those separate ones, or is there
4 some duplication and renaming of some of those? And
5 how does it interrelate to what we've got for a
6 strata here?

7 WITNESS CONSTANTINO: Yes. My
8 interpretation of what we have, names have changed
9 over the course of time by various people. The
10 issues, the alluvium layers are really relatively
11 thin layers of various characteristics so it's
12 difficult to say what an alluvium is. In the
13 characterization the primary interest is the
14 engineering properties of those layers and they vary
15 with fineness of the material and as you go down the
16 profile, the fineness, grain size distribution
17 changes from small layer to small layer to small
18 layer, from fine grain to fine grain with some
19 gravel interspersed to coarse grain material back to
20 fine grain. In the profile, I think the engineering
21 properties are relatively consistent from sublayer
22 to sublayer to sublayer. That is, we know the
23 velocities are relatively consistent with depth.
24 The grain size may change, but the strength
25 parameters don't seem to change that much. If we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 encounter more gravel than fines, then basically we
2 would expect that to be a better foundation material
3 than the fine grain. But I think the alluvium,
4 colluvium, Upland Complex all refer to the series of
5 layers.

6 JUDGE WARDWELL: Okay, let me - I'm
7 sorry if I do interrupt, and I will interrupt
8 occasionally if I feel we're getting more depth than
9 we really need just for brevity. It's not to be
10 rude or anything, but I do want to continue to move
11 this along and when I feel we've gotten sufficient
12 here, or if the question that's being asked is not
13 really clear and being responded to appropriately
14 I'll rephrase the question. The 3, Number 3 on
15 Staff Exhibit 41 is labeled on this sheet Upland
16 Complex alluvium, if I interpret it correctly. And
17 again, either of you can respond to that. Is that
18 going to be the best nomenclature to move forward to
19 the COL stage in regards to that upper layer of
20 alluvium that exists beneath the loess?

21 WITNESS LETTIS: This is William Lettis
22 with the applicant. I might offer a point of
23 clarification that might help move forward with the
24 nomenclature issue. If I could refer to SERI
25 Exhibit 4. SERI Exhibit 4 is a correlation chart

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that we put together to illustrate sort of the
2 evolution of geologic terms used to describe the
3 materials at the site. We can begin with the
4 existing UFSAR. They established a site
5 nomenclature at the site at the time of their
6 license process. They described units both for
7 geotechnical purposes and for hydrologic purposes.
8 The hydrological, the geohydrological or
9 hydrogeological terminology is different than the
10 geotechnical terminology. Or there's greater
11 definition of subunits within the hydrogeologic
12 nomenclature. And so what this chart shows is what
13 was used in the original UFSAR classification, what
14 terms are now archaic, if you will, or no longer
15 going to be used especially in the geotechnical
16 area, and how the terms are now being defined for
17 the ESP classification. And this is the terminology
18 that we intend to move forward with to the COL
19 process.

20 The geotechnical classification, we have
21 the artificial fill as Dr. Constantino described.
22 There's the Mississippi River alluvium that is
23 located out on the Mississippi River flood plain and
24 does not underlie the site itself. There's the
25 loess deposits which are the highest or youngest

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 unit underlying the site itself is the loess. Then
2 there's the Upland Complex which has been divided
3 into two units, the alluvium and the old alluvium.
4 The term "young alluvium" is also used for this
5 Upland Complex alluvium just to differentiate from
6 old alluvium, the underlying. The term "new
7 alluvium" as far as we can search through the
8 documents we did not use in any of the materials, so
9 the term "new" has sort of been introduced to this
10 process inadvertently. But I tried to capture all
11 the different terms in this correlation chart.

12 JUDGE WARDWELL: I assume the same with
13 "young." "Young" was also encountered at one point.

14 WITNESS LETTIS: Yes, "young alluvium"
15 would refer to the upper alluvium in the Upland
16 Complex. And then the Upland Complex alluvial
17 deposits, the young and the old, are underlain by
18 the Catahoula formation at a depth of about 200 -
19 225 feet beneath the site. And then we can describe
20 other terms.

21 JUDGE WARDWELL: And what's that
22 elevation-wise again?

23 WITNESS LETTIS: It would be about -70
24 elevation. Once again, the surface of the Catahoula
25 we believe has been eroded by the - during

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 deposition of the alluvium above it, so it has an
2 erosional relief on it. So the exact depth of the
3 Catahoula will vary, but it's approximately a -70
4 elevation beneath the site. And for the hydrology
5 units, because we're attempting to correlate
6 hydrologic data from the ESP site with the existing
7 information from the site, we've retained the same
8 nomenclature from the UFSAR to the ESP. So we did
9 not revise the nomenclature for the hydrogeologic
10 units.

11 JUDGE MCDADE: If I could just interject
12 something here to make sure that I'm following it
13 and I have very limited geologic background. I took
14 a rocks for jocks class back in the 1960s so bear
15 with me here. Am I following it correctly that
16 basically we've got three kinds of strata here.
17 We've got the loess, we've got the alluvium and then
18 we've got the old Catahoula. And that each of those
19 - what did I say wrong?

20 JUDGE WARDWELL: You just added another.
21 You said the old - just the Catahoulas, not the old
22 Catahoula.

23 JUDGE MCDADE: Okay. Well, I don't know
24 it's the old Mississippi so it's the old Catahoula.
25 That each of those have certain strength parameters,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 but the alluvium basically, whatever we call it,
2 there are variances in it, but for the purposes of
3 an engineering structure on it they have basically
4 similar strength parameters and that as long as the
5 foundations of the facility are done below the loess
6 and in the alluvium that it is going to have
7 basically similar strength parameters regardless of
8 which alluvium it is. Am I correct in that?

9 WITNESS CONSTANTINO: With one
10 clarification I would suggest. Basically you're
11 right, there are basically three zones of material
12 we're interested in. The alluvium properties
13 actually vary with depth, so the deeper you go, the
14 better that you are. One of the issues is how deep
15 you really have to go to get to the minimum
16 characteristics you would accept, and that's an
17 issue that has to be defined here.

18 JUDGE MCDADE: Okay, and how will that
19 be defined and when?

20 WITNESS CONSTANTINO: I presume it'll be
21 defined at COL stage by a number of borings which
22 penetrate to depths of interest. Because you want -
23 the primary characteristic we're interested in is
24 the minimum sheer wave velocity of 1,000 feet a
25 second so you want to get down to depths which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 consistently give you numbers like that. The
2 alluvium seems to indicate velocities based on the
3 data we have already less than 1,000 feet a second
4 higher up in the alluvium.

5 JUDGE WARDWELL: And I think the better
6 way to address that question is what did the
7 applicant commit to in the ESP stage in regards to
8 following forward in the COL stage based on the
9 staff's review.

10 WITNESS CONSTANTINO: Well, the table -
11 you want to answer that?

12 WITNESS CHENG: This is Tom Cheng. In
13 the SSAR Section 2.5.6 the zone criteria, the
14 applicant committed to use the - to satisfy the
15 1,000 feet per second of sheer wave velocity for the
16 foundation level.

17 JUDGE WARDWELL: So it's not committing
18 to - it's not relying on - to achieve that
19 particular commitment, is that based on new
20 information that they will take at the COL stage
21 prior to any construction? Is it a commitment based
22 on information they'll take during actual
23 construction? Is it based on the data that's
24 available now defining whatever information there is
25 in regards to sheer wave velocity or is it a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 combination of all of those or some of those?

2 WITNESS CHENG: During our review of the
3 SSAR we issued RAI to question the minimum sheer
4 wave velocity and the staff position is 1,000 feet
5 per second minimum. So in response to the staff's
6 RAI that's how the applicant made that commitment.

7 JUDGE WARDWELL: But there is
8 information available now, albeit maybe not
9 extensive enough, that shows the difference in sheer
10 velocities with depth. Would the staff be satisfied
11 at the COL stage if in fact the applicant comes in
12 and says I can put the foundation as shallow as 40
13 feet below the ground because see, here's some
14 borings I took that showed 1,000 feet per second.
15 Would that be adequate for the staff in regards to
16 meeting the ESP requirements?

17 WITNESS CHENG: As shown in Exhibit 40
18 through 42, which is the SSAR Figure 2.5-75 through
19 77, indicate the sheer wave velocity in the old
20 alluvium region or zone has the sheer wave velocity
21 higher than - equal or higher than 1,000 feet per
22 second. And that this is - it's possible foundation
23 of the power block will be located in that elevation
24 which is elevation based on my scale from the
25 figure, the elevation -5 feet, which is about 130 -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 140 feet under - the under-grade, below grade.

2 JUDGE WARDWELL: Let me try to rephrase
3 my question. Is it acceptable at the COL stage for
4 an applicant to base their foundation grade on the
5 information that exists at this present time and
6 only on that information and no other?

7 WITNESS CHENG: May I ask my consultant
8 to address your question?

9 WITNESS CONSTANTINO: I think the answer
10 is no. They only have three pieces of information.

11 JUDGE WARDWELL: Can I just quickly
12 interrupt? I just - I want to get a clarification
13 then. When your contractor speaks, he's speaking on
14 - in representing the staff, correct? I want to
15 just clarify that.

16 MR. RUND: That's correct.

17 JUDGE WARDWELL: There were times in the
18 documents where it seemed to kind of say that, well,
19 contractor said this and in actuality whenever
20 either in the documentation or in this hearing if
21 your contractor is saying it, staff does agree that
22 it represents staff's position, is that correct?

23 MR. RUND: Yes, that's correct.

24 JUDGE WARDWELL: Good. Sorry to
25 interrupt you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS CONSTANTINO: Okay. My
2 recommendation carries no weight. I would recommend
3 to the staff that the answer would be no.

4 JUDGE WARDWELL: But see, we've just
5 gotten - we've gotten carte blanche approval for you
6 to knock your socks off. You've got, oh boy, here's
7 your time to - maybe you can get a raise out of
8 this. Just ask for - say you will have a raise.

9 WITNESS CONSTANTINO: The issue is the
10 minimum velocity. We have only three borings, three
11 cone penetrometers with three velocity measurements
12 which show variability in the velocity through those
13 kind of depths. We need many more. "Many" is
14 subjective, but certainly you need a greater site
15 investigation program to make assessments of the
16 minimum velocity and at depths, if you wish to go to
17 that minimum velocity of 1,000 feet a second that's
18 one option. If you wish to locate higher, you then
19 must address the minimum and its variability impact
20 on the design. So I think the program must define
21 the minimum. Anything which goes beyond that has to
22 come at COL stage. So I think the answer to the
23 first question is the data available now is not
24 sufficient to make those definitions.

25 JUDGE WARDWELL: Okay, but in your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 response you've raised a couple of other questions.
2 It seems that you just said that if in fact it's
3 less than that, they could then do an analysis that
4 showed that based on the variability that you could
5 in fact place part of the, I don't know the
6 appropriate word, foundation for the plant on
7 material less than 1,000 feet per second?

8 WITNESS CONSTANTINO: Well, you have
9 various options. One is yes, you could do that and
10 try to assess the impact on the plant. The other is
11 you could remove the material and replace it with
12 something. What something is is open to question.
13 And go through a verification program for what you
14 replace it with to show that that replacement meets
15 1,000 feet a second. So there are various options
16 available for any applicant to place anything.

17 JUDGE WARDWELL: I'd just like to
18 clarify something, probably from Dr. Cheng, is that
19 correct? In the staff's review, in my review of the
20 documentation I never saw any suggestion that the
21 power block would be placed on anything less than
22 1,000 feet per second of existing sheer velocity, or
23 the material would be enhanced as you suggest to get
24 it up to the equivalence of that. And that there
25 was no suggestion that in fact if there were parts

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the plant that were less than that, an analysis
2 could be done to show that it's still adequate
3 support. Which is the - if it's different, I think
4 we should know that as we move forward. You could
5 speak right into the mic if you want. Unless you
6 want to caucus to make sure. Okay.

7 JUDGE MCDADE: But just as an aside, I
8 mean if a question comes up that you want to discuss
9 among yourselves before you make an answer, you want
10 to check with your colleague because you're not
11 certain of it because remember, you are testifying
12 under oath and an answer 'I don't know' is often the
13 only truthful answer. So if you want to discuss it
14 with a colleague beforehand just do so.

15 JUDGE WARDWELL: And trust us, we
16 recognize that with various individuals, especially
17 if some may be contractors, that people will provide
18 engineering solutions that are perfectly adequate
19 but not necessarily in the documentation. So I'll
20 just be asking clarifications for that, and it's
21 nothing against anyone's particular opinion of how
22 you could actually achieve a certain design. I just
23 want to make sure we're clear on what it is that the
24 applicant is proposing in the ESP and then what's
25 going to be moved forward and at least as we stand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 now in the COL stage knowing that of course it can
2 change at the COL stage with the right appropriate
3 recommendations and design details. Go ahead.

4 WITNESS CHENG: This is Tom Cheng. To
5 answer your question, the staff did not make any
6 recommendation or suggestion in the SER to meet the
7 1,000 feet per second requirement. They just
8 repeated based on the staff position used for the
9 review of the design certification for advanced
10 reactors. And indeed this deposition will be
11 incorporated in the future revision of the SRP.

12 May I just - I was talking about the
13 improvement of the site condition. Would you please
14 allow me to read one paragraph I quoted from the
15 SSAR?

16 JUDGE TRIKOUROS: You're reading from
17 the Grand Gulf UFSAR?

18 WITNESS CHENG: Yes. Not UFSAR, it's
19 the ESP SSAR.

20 JUDGE TRIKOUROS: Okay, I just wanted to
21 make that clear.

22 WITNESS CHENG: In Section 2.5.4.6
23 design criteria, at end of the paragraph it states
24 that the soil underlying the elevation of the
25 selected plant foundation that are found to have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 shear wave velocity below the design requirement,
2 which is 1,000 feet per second, will require removal
3 or recompaction with or without additive and/or in
4 situ improvement using method such as cellular deep
5 soil mixing or consolidation grouting to achieve the
6 required shear wave velocity. That's a commitment
7 made by the applicants.

8 JUDGE WARDWELL: Okay. And that says to
9 me that in fact no portion of the foundation grade
10 can have a shear wave velocity less than 1,000
11 unless it has been improved by some fashion like you
12 just described.

13 WITNESS CHENG: That's correct.

14 JUDGE WARDWELL: Or a similar
15 alternative.

16 WITNESS CHENG: For the safety-related
17 structure, yes.

18 JUDGE WARDWELL: And do you agree with
19 that as the applicant's commitment?

20 WITNESS LETTIS: This is William Lettis
21 with the applicant. With one additional caveat that
22 depending on which vendor is selected for the site,
23 the vendor may choose to do additional engineering
24 analysis to confirm that their design meets a lower
25 velocity and/or they may make design improvements,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

-- (202) 234-4433

www.nealrgross.com

1 strengthen their foundation or whatever might be
2 required to meet a lower minimum threshold velocity.
3 Well, a higher threshold velocity.

4 JUDGE MCDADE: But if that were the
5 case, under this Early Site Permit you would have to
6 ask for a variance, correct? Under this site permit
7 it has to be 1,000 feet per second sheer wave.

8 WITNESS LETTIS: Yes, that would be
9 correct.

10 JUDGE TRIKOUROS: Where does that show
11 up? If I look at the plant parameter envelope I see
12 a foundation embedment of 140 feet, but I don't see,
13 and it may be elsewhere that I'm not seeing, a sheer
14 wave velocity design requirement of 1,000 feet per
15 second.

16 WITNESS CHENG: If you look at the SSAR
17 Figure 2.5-36 -

18 JUDGE WARDWELL: Is that an exhibit?

19 WITNESS CHENG: 36.

20 JUDGE WARDWELL: Is that an exhibit?

21 JUDGE TRIKOUROS: I understand that it's
22 in the SSAR. What I'm saying is, is it in either
23 the site characteristic table or the plant parameter
24 envelope which identifies site and reactor design
25 requirements?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS CHENG: No, in the SER, Section
2 2.5.5 there's a table to list as a site
3 characteristic requirement. In the final SER.

4 JUDGE WARDWELL: And the 140-foot depth
5 in the PPE was strictly the maximum that was
6 evaluated, is that correct? That's the deepest
7 anticipated?

8 WITNESS CHENG: I think that this - I
9 would suggest to ask the applicant to address this
10 because based on my interpretation of the figure
11 2.5-75 through 77 that's the lowest they will go.

12 JUDGE TRIKOUROS: And it is identified
13 as maximum in Exhibit 46 or 43.

14 WITNESS LETTIS: This is William Lettis
15 with the applicant. Yes, that's correct, that's the
16 maximum possible embedment depth for a reactor
17 considering all reactor technologies that we were
18 considering at the time that we would put the base
19 mount of the reactor. Other technologies have
20 shallower embedment depth requirements so we would
21 consider shallower embedment depths.

22 JUDGE MCDADE: And within the proposal,
23 within the application, what we would need are two
24 things. One, it's going to be 140 feet or less and
25 it's going to be 1,000 feet per second sheer wave

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 velocity. It has to meet both of those
2 requirements. If it doesn't, then a variance would
3 be requested. Is that correct?

4 WITNESS LETTIS: This is William Lettis.
5 Yes, that's correct, unless as stated in the
6 documents we may over-excavate and backfill or
7 improve the ground to achieve the minimum 1,000 feet
8 per second. So it may not be the native soil that
9 gives us the 1,000 feet per second, but we may
10 improve the ground to achieve 1,000 feet per second.

11 JUDGE MCDADE: I understand. Thank you.

12 JUDGE TRIKOUROS: And we will be
13 exploring the issue of what is, again, what is in
14 your Early Site Permit. Is it arbitrary, is it to
15 say anything that's in the SSAR is considered a
16 design requirement in the Early Site Permit, or is
17 it specifically going to be listed as a plant
18 parameter envelope item, or a site characteristic
19 item, or both, which in some cases site
20 characteristics are part of the plant parameter
21 envelope.

22 WITNESS BAGCHI: Your Honor, this is
23 Goutam Bagchi of the staff. I'm covering hydrology
24 area, but I just respectfully want to point out the
25 site characteristic has the minimum sheer wave

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 velocity stability of subsurface to geo-foundations.
2 It is a site characteristic.

3 JUDGE TRIKOUROS: Right. So this
4 currently is a site characteristic and the only
5 thing in the PPE is a foundation embedment of 140
6 feet. So what Judge McDade indicated is then
7 correct. You have two criteria.

8 WITNESS BAGCHI: As I understand it the
9 Early Site Permit would incorporate the site
10 characteristics in the permit itself. Therefore, it
11 will be binding. That's my belief.

12 JUDGE TRIKOUROS: Right. But what you
13 have not established is whether it will include the
14 entire plant parameter envelope, at least not as of
15 this conversation this morning.

16 JUDGE WARDWELL: But even if it did and
17 it included this 140, that 140 is just the maximum
18 depth. It could be anywhere less than 140, correct?
19 As long as it meets the 1,000 shear wave velocity.

20 WITNESS CHENG: Yes, it could be less
21 than 140. However, if the soil shear wave velocity
22 is less than 1,000, they'll either remove and refill
23 or improve the site.

24 JUDGE WARDWELL: How is that 1,000 feet
25 per second of shear velocity going to be verified at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the COL stage? And based on your review, how do you
2 anticipate that being done by the applicant, any
3 applicant that would come in under this?

4 WITNESS CHENG: In the SER - this is Tom
5 Cheng again. In the SER the staff asked the
6 applicant to perform additional boring to collect
7 more data. And during that time the staff had a
8 chance to review the information profiled by the
9 applicant and to make the final decision.

10 JUDGE WARDWELL: Wouldn't you - go
11 ahead. Someone else.

12 WITNESS LETTIS: This is William Lettis
13 with the applicant. If I could just amplify on
14 that. There's very good and very clear guidance
15 provided by Regulatory Guide 1.132 and Regulatory
16 Guide 1.138 which governed the level of
17 investigation required for siting a nuclear power
18 plant once you've selected your design or your
19 vendor and the footprint and that requires borings
20 spaced at approximately every 100 feet. It provides
21 guidance on the depth of those borings. It would be
22 related to the embedment depth of the reactor,
23 obviously. The deeper the reactor, the deeper your
24 borings would go. It has recommendations for types
25 of data that will be collected, including sheer wave

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 velocity, other static and dynamic property data.
2 So there's very clear guidance on what will be
3 performed during a COL phase. There is a COL action
4 item attached to this ESP, Action Item 2.5.3 or -3.

5 MS. SUTTON: 2.5-3.

6 WITNESS LETTIS: And that requires us to
7 perform those additional investigations at the COL
8 phase and it will be based on those data that we
9 will ultimately design the final foundation depth
10 and a final footprint location and other design
11 features such as that.

12 JUDGE WARDWELL: Would you anticipate
13 any confirmation testing during actual construction
14 of those velocities or is that pretty much
15 impossible to do once you've reached a grade that's
16 desired?

17 WITNESS CONSTANTINO: I'm Carl
18 Constantino again. The decision on the depth really
19 has to come before you get down to construction
20 stage. So there's a geophysical testing program,
21 relatively extensive, various methods used for
22 confirmation, which indicate what that depth is
23 going to be for the design stage. Then once
24 construction starts there are programs you could put
25 in place. That is, after excavation you could do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 some geophysical testing locally to ensure. That's
2 not part of the requirement.

3 WITNESS LETTIS: This is William Lettis
4 with the applicant. During construction there is a
5 permit condition on the ESP that we will perform
6 logging of all the excavations and cut slopes during
7 construction to confirm that we're meeting the
8 anticipated foundation conditions. There's no
9 requirement -

10 JUDGE WARDWELL: That's just a visual
11 observation?

12 WITNESS LETTIS: That's visual
13 observations. There's no requirement for performing
14 additional subsurface investigation either through
15 borings or geophysical techniques during
16 construction. During construction and also post-
17 construction there's an instrumentation phase where
18 we will be putting in monuments to monitor for
19 settlements or stress relief issues. So there's an
20 instrumentation phase of work and then there's also
21 the logging of existing exposures, visual
22 examination of existing exposures. We may also
23 take, during that process take samples of the
24 exposed soil for further lab testing. That's not
25 required but it may be part of the due diligence or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the normal standard of practice for engineering.
2 But we do not at this time plan to do any additional
3 subsurface investigations during construction.

4 JUDGE WARDWELL: Back, Mr. Lettis, to
5 your geologic unit correlation table, your Exhibit 4
6 I believe. Did I get that right? Yes.

7 WITNESS LETTIS: Yes.

8 JUDGE WARDWELL: SERI Exhibit 4. Under
9 the hydrologic sections, looking at the alluvium
10 beneath the Mississippi River we have several
11 descriptions of alluvium. Are those separate layers
12 and zones, or are those other names for the same
13 deposit?

14 WITNESS EVANS: This is Lori Evans for
15 the applicant. The first three terms, Mississippi
16 River alluvium, Holocene alluvium and flood plain
17 alluvium are essentially all the same, can be used
18 pretty much interchangeably. The clay/silt alluvium
19 and sand/gravel alluvium are subdivisions within
20 that. You have thicker deposits near the base.

21 JUDGE WARDWELL: And where do you find
22 the clay/silt alluvium and the sand/gravel alluvium
23 in the profile section? Can you define it spatially
24 in regards to certain depths that you generally have
25 as far as a range of values?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS EVANS: There was a lot of
2 variability as is typical with flood plain deposits.
3 I can't give you an exact depth at this time.

4 JUDGE WARDWELL: But they are - those
5 zones are spatially defined, we can't put the exact
6 number on it because of the variability -

7 WITNESS EVANS: Correct.

8 JUDGE WARDWELL: - but they are
9 spatially defined in a vertical sense. They're not
10 scattered in lenses or are they both in regards to
11 how - well, how is it used during the hydrologic ESP
12 classification? Why did you break those two out and
13 how were they incorporated into whatever you did
14 that made you want to divide those up into those
15 zones?

16 WITNESS EVANS: This relates more
17 directly to the radial wells that are used for the
18 water supply, the service water supply for Unit 1.
19 And we did sort of a cursory evaluation of whether
20 that could also potentially be used for any
21 potential new units at the site.

22 JUDGE WARDWELL: And is the clay/silt
23 above the sand/gravel generally, or is it?

24 WITNESS EVANS: Generally, yes.

25 JUDGE WARDWELL: Okay. That's what I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 interested in. I should have asked my question much
2 better and we could have saved three or four minutes
3 there.

4 WITNESS EVANS: Okay.

5 JUDGE WARDWELL: Back to Staff Exhibit
6 41. And I think I'll stay with the applicant for
7 awhile because they prepared this profile. One,
8 Zone 1 is fill. I was - well, let me just ask the
9 question. Did you really mean to have that upper
10 layer that's the higher elevation area where the
11 power block will be to mean that that was fill
12 material? I didn't realize that was fill material
13 that now exists out on the site as you go up that
14 bank. I thought that bank was a cut slope and not a
15 fill slope, and you're saying here as I interpret
16 this profile that that's a fill slope and not a cut
17 slope, if in fact 1 represents fill material. That
18 shaded zone that you now are saying is going to be a
19 potential cut area for the ESP plant, are you saying
20 material was brought in to bring that elevation up?

21 WITNESS LETTIS: On Staff Exhibit 41
22 that you're referring to

23 WITNESS BACHHUBER: This is Jeff
24 Bachhuber with SERI. On Staff Exhibit 41 the area
25 of fill is shown ingrating with the Number 1

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

- (202) 234-4433

www.nealrgross.com

1 designation. It occurs in two locations on that
2 exhibit cross-section. One of them is within the
3 zone that is shaded or hatched as a potential
4 excavation area. The current plant grade is shown
5 by the top line on the cross-section. And there is
6 about a 25-foot cut slope between what we call the
7 lower pad and the upper pad that is spanned by the
8 proposed plant envelope. The upper portion -

9 JUDGE WARDWELL: You've answered my
10 question. Thank you very much.

11 WITNESS BACHHUBER: Okay.

12 JUDGE WARDWELL: The 1 refers only to
13 the little valley that's filled in there. I didn't
14 have a colored sheet. Now I understand what it was.

15 WITNESS BACHHUBER: That's good. Jeff
16 Bachhuber -

17 JUDGE WARDWELL: I thought it was
18 referring to that whole flat path before. But now I
19 see that dashed line and the difference in grading.

20 WITNESS BACHHUBER: Jeff Bachhuber,
21 applicant. One more point of clarification. The
22 SERI Exhibit 3 shows the extent of former swales
23 that existed at the site before any development
24 occurred. And the fill that is defined occurs
25 within those swales. And so it's part of the plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 preparation for the existing power plant and which
2 extends over our proposed ESP area, they in-filled
3 those swales to create a level grade.

4 JUDGE WARDWELL: And that fill is to be
5 removed as far as your proposal is that the staff
6 reviewed?

7 WITNESS BACHHUBER: Jeff Bachhuber,
8 applicant. The fill will be removed from below the
9 footprint areas of safety-related facilities. It is
10 possible that non-safety facilities, parking areas,
11 warehouses, could potentially be constructed over
12 some remaining fill. In the ESP SSAR, it's defined
13 that the fill will be further evaluated for
14 suitability for that use. But for safety-related
15 facilities it will be completely removed from the
16 footprint zones.

17 JUDGE WARDWELL: That's exactly what I
18 meant by my question. Thank you. Staying with that
19 exhibit, you show a zone called 2A. Could either
20 the staff for the applicant - and let's stay with
21 the applicant. It's their cross-section, their
22 profile. Could you elaborate more on what that zone
23 is?

24 WITNESS BACHHUBER: Jeff Bachhuber with
25 the applicant. Zone 2A is colluvium and/or old

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 landslide deposits. The colluvium is a soil that
2 has accumulated on the existing Mississippi River
3 bluff and it has accumulated by long-term erosion
4 and soil creep. It's typically on the order of
5 several feet to perhaps 10 feet thick and it's
6 comprised of loess soils but they have been
7 transported and now are sitting on the surface of
8 this slope. In the case of ancient landslide
9 deposits, we identified a couple potential landslide
10 areas during the ESP investigation. And these are
11 shown on SERI Exhibit 3 and they're labeled QLSO
12 with a question mark. And that designation
13 indicates a possible shallow soil slump. These
14 features were identified on the basis of examining
15 existing topographic maps and brief site
16 reconnaissance. These features, it actually turns
17 out with further studies, post-ESP studies that they
18 indeed are not ancient landslides, but rather are
19 related to either surficial erosion or poor control
20 in the topography. We have since obtained a higher
21 quality topographic map that does not show one of
22 the features that's shown on this ESP figure,
23 Exhibit 3.

24 JUDGE WARDWELL: Your Exhibit 3 doesn't
25 cover the entire bank surrounding the power block

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 area, correct? Or does it?

2 WITNESS BACHHUBER: Jeff Bachhuber,
3 applicant. Exhibit 3 shows a portion of the river
4 bluff where it encroaches closest to the ESP. The
5 areas where the river bluff is shown on this Exhibit
6 3 occur in the lower left-hand area near WLA CPT-3
7 and then also on the upper part of the figure near
8 B-19. It's a boring designation. Now, that upper
9 slope, you could see by the contours, there are
10 closely spaced topographic lines indicating a slope
11 in that area. And that actually is a slope related
12 to a tributary creek that drains into the
13 Mississippi River. And so that slope shown on the
14 north side of Exhibit 3 is the slope going down into
15 a tributary drainage.

16 JUDGE WARDWELL: Was that drainage Basin
17 A, do you remember?

18 WITNESS BACHHUBER: Yes, that's correct.
19 The slope shown in the lower left-hand area is the
20 actual Mississippi River bluff, and it extends
21 further to the northwest off the map and further to
22 the south off the map.

23 JUDGE WARDWELL: And do you have mapping
24 of that that shows those other - or were there any
25 other areas in that portion of the bluff that's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 shown on this figure?

2 WITNESS BACHHUBER: There are other
3 figures in the SSAR that show a more general
4 geologic maps that extend well beyond the ESP area.
5 And those do include the area of the Mississippi
6 River slope. Similar features that are shown on
7 Exhibit 3 as the ancient slumps, the QLSO question
8 mark, are not shown on those figures because of the
9 scale of the mapping.

10 JUDGE WARDWELL: Okay. On Figures 2.4-
11 36 and 37 of the SSAR which are Staff Exhibits what?
12 Do you know?

13 JUDGE MCDADE: 2.4-36 is Staff Exhibit
14 32. What was the other one?

15 JUDGE WARDWELL: 37 it should be. I
16 hope 33.

17 JUDGE MCDADE: 33 is Staff Exhibit 34.

18 MR. RUND: Did you mean 2.5-36 and 37?

19 JUDGE WARDWELL: Probably could be,
20 probably.

21 JUDGE MCDADE: Okay, 2.5-36, Staff
22 Exhibit 38. 2.5-37 is Staff Exhibit 39. Am I
23 correct?

24 MR. RUND: That's correct.

25 JUDGE WARDWELL: On those exhibits,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 which are similar profiles if my memory serves me
2 correctly, not taking the time to pull those up
3 right here at this moment, that show the same thing
4 that's shown on Staff Exhibit 41, but it uses
5 different nomenclature including the term "terrace
6 deposit" or "terrace" I guess it's just called. Is
7 that correct?

8 WITNESS LETTIS: Could you please
9 clarify where it says terrace deposit?

10 JUDGE WARDWELL: Well it may not. I'm
11 trying to refresh my memory and I haven't pulled it
12 out in front of me. Because of the late submittal
13 of it I don't have that nicely organized so that I
14 can grab that.

15 JUDGE MCDADE: Which one, Staff Exhibit?

16 JUDGE WARDWELL: 38 and 39. 2.5-36 and
17 37 aren't the ones that I am interested in. I'm
18 interested in the SSAR Figures 2.4-36 and 37.

19 WITNESS LETTIS: This is William Lettis
20 with the applicant. I believe you're correct.
21 You're referring back to cross-sections Figure 2.4-
22 37 as opposed to Figure 2.5.

23 JUDGE WARDWELL: Right. And that's the
24 one I'm interested in. Right.

25 WITNESS LETTIS: And the Figures 2.4-37,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 36 and 37 are taken from the UFSAR for the existing
2 site. And they use the old archaic nomenclature of
3 terrace deposits. On our figures we're using the
4 more current nomenclature of the Upland Complex to
5 describe the alluvium. The terrace deposits are
6 basically the alluvial units.

7 JUDGE WARDWELL: That's what I wanted
8 confirmation of. Thank you.

9 MR. RUND: Just for clarification, those
10 are Staff Exhibits -

11 JUDGE WARDWELL: 24 is the one we're
12 looking at. That's the one that has the terrace
13 deposits listed on there and I wanted to confirm
14 that in fact. And let me ask this. Those terrace
15 deposits are in fact - the best way to interpret
16 those terrace deposits would be if you were using
17 current nomenclature, one of the two zones of the
18 Upland Complex, either the Upland Complex alluvium
19 and the old Upland Complex alluvium together.

20 WITNESS LETTIS: That's correct. It's
21 the terrace deposits referred to in the UFSAR
22 primarily are the Upland Complex younger alluvium,
23 the upper alluvium. The older alluvium extends part
24 way into what they defined as the Catahoula
25 formation. The uppermost part of the Catahoula

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
— WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 formation is a gravel, or an alluvium as opposed to
2 a stiff clay, as described in the UFSAR. We have
3 interpreted those gravels in the upper part of the
4 old Catahoula description as the Upland Complex
5 older alluvium. So we've redefined the UFSAR's
6 stratigraphy and the terms to more accurately
7 reflect the true depositional environments of these
8 units. The Catahoula is strictly confined to the
9 stiff clay under the site. The alluvium, river-
10 deposited alluvium, has been defined as the Upland
11 Complex, both the younger alluvium and the older
12 alluvium. And then we have the overlying windblown
13 loess.

14 JUDGE WARDWELL: I just wanted to note
15 that the record will reflect that I wasn't the only
16 person to use the term "old Catahoula." Revenge is
17 sweet.

18 On Page 7 of the pre-filed testimony -
19 oh, let me interrupt quickly before I go to that
20 question. Staff, in your review, is there anything
21 that's been said by the applicant that you would
22 contradict or amplify, wish to amplify in regards to
23 the last dialogue that we've had on that cross-
24 section? Is everything consistent with what you
25 interpreted during your review?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS CHENG: Staff don't have any -
2 yes.

3 JUDGE MCDADE: Okay, and that was Dr.
4 Cheng who made that statement. Just so the record
5 reflects who's responding.

6 WITNESS CHENG: Tom Cheng. The answer
7 is no.

8 JUDGE WARDWELL: That's young Dr. Cheng.

9 JUDGE MCDADE: You are back on Page 7?

10 JUDGE WARDWELL: Page 7 of the pre-filed
11 testimony under Answer 4, second to the last line it
12 said the plant grade will be located at a depth of
13 about 132.5 mean sea level. I don't - could you
14 clarify that?

15 WITNESS BAGCHI: Well perhaps - this is
16 Goutam Bagchi of the staff. Perhaps the word
17 "depth" is a little bit misleading. We have a site
18 parameter of planned grade to 132.5 feet mean sea
19 level. That's what we mean here.

20 JUDGE WARDWELL: So that was meant to
21 convey the top elevation of the plant, not the
22 foundation grade whatsoever?

23 WITNESS BAGCHI: Yes, Your Honor.

24 JUDGE WARDWELL: Okay. Which finally
25 moves us into my first, what I call fake hypotheses.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 To my first question, my fake hypotheses, ones that
2 I don't necessarily believe in, but I want to make
3 sure that we have enough information to refute them.
4 And so I think it helps focus the discussion. And
5 we've already answered many of the questions I had
6 on this. Here's where the next line of questionings
7 will be geared towards and in fact we've already
8 answered the question, as I said, on some of the
9 points that I wanted to raise in this hypothesis to
10 be able to refute it.

11 But the hypothesis someone could take is
12 that the site is inherently unsuitable for the
13 placement of another plant due to several basic
14 factors, including but not limited to excessive
15 differential settlements caused by residual fills,
16 the inability to assure a sheer wave velocity of
17 1,000 feet per second, extensive Karst formation and
18 blast-induced liquefaction from a river barge
19 accident or premeditated activity. That's the
20 hypothesis that we want to now talk about to make
21 sure we got enough information to say no, that can't
22 happen. I think we've already discussed the fills
23 so we don't need to spend any more time on that.
24 I'm satisfied that we do have that information.
25 Same thing with the sheer wave velocity. I think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we've covered that in depth. Could you elaborate
2 more on the Karst formation and the potential for
3 that at the site and what will take place to address
4 that particular issue at the site?

5 JUDGE MCDADE: Actually, before you do,
6 think about it for a second. I just want to raise
7 one administrative matter. We would anticipate
8 going through and breaking at the first reasonable
9 breaking point after 12:00 for lunch. With that in
10 mind, does anybody need a break before that, or is
11 everybody good to keep going through until a little
12 bit after 12:00, about another 40 minutes or so?

13 MS. SUTTON: We would like to proceed.
14 We need no break.

15 MR. RUND: Staff is fine, we're ready to
16 proceed.

17 JUDGE MCDADE: Okay. The witnesses feel
18 the same? You're the more important people. Okay,
19 because as I said, if we took a break now then we'd
20 go longer before lunch, but we'll probably look for
21 a breaking point after 12:00, somewhere between
22 12:00 and 12:15. So if everybody thinks they can go
23 through, let's get started answering the straw man
24 hypothetical posed by my colleague.

25 JUDGE WARDWELL: That's an excellent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 description. I'm going to use that from now on in
2 regards to my hypotheses. A straw man hypotheses.
3 SMH.

4 WITNESS CONSTANTINO: This is Carl
5 Constantino again. The issue of Karst formation
6 came up in reviewing the SSAR words. And that issue
7 is a generic issue that I think shows up anytime you
8 see in the site profile words like limestone or
9 carbonate materials, things which are essentially
10 susceptible to solutioning processes.

11 JUDGE WARDWELL: Could you make sure -
12 you probably were going to, but for the benefit of
13 the panel, just describe that potential problem as
14 it exists in the country?

15 JUDGE MCDADE: And when he says for the
16 benefit of the panel, he means me. Because he
17 already knows, but he assumes I don't, with some
18 basis.

19 WITNESS CONSTANTINO: At many sites that
20 I'm involved with, for example Savannah River site
21 or the Oak Ridge site or, well, Hanford site, all
22 those sites do have voids that have been encountered
23 over the years of exploration. And those voids, the
24 collapse of those voids lead to serious concern with
25 the design process of the facilities placed on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 top. So anything which potentially impacts the
2 creation of voids below the power block has a
3 potential impact on the design of the power block, a
4 serious impact. So for example, the Oak Ridge site,
5 many of the rocks encountered at the Oak Ridge site
6 are very similar to the ones encountered here,
7 except these are very much deeper than they are
8 further north. But the potential for solutioning is
9 the issue. There's no indication of anything I've
10 read that in fact sinkholes or soft zones are
11 existing under the site. I have not seen that. But
12 the process going forward into the COL stage would
13 have to be to make sure that the exploration program
14 is detailed enough to be able to make an assessment
15 of what that potential is. And if there is a
16 potential, then how that potential would be
17 incorporated into the design. I think that's the
18 whole issue of our question, or my question. And it
19 really came from the descriptions that were provided
20 in the SSAR of the materials that you would expect
21 to be encountered.

22 JUDGE WARDWELL: Are those materials
23 only in the Catahoula, or are they in the alluvium
24 also? Are they mostly Catahoula or deeper rock
25 zones?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS CONSTANTINO: They're certainly
2 deeper than the Catahoula. I don't recall any
3 concern with materials in the alluvium or the Upland
4 Complex, although there may be some carbonate
5 materials described in that description higher up in
6 the profile. The deeper the potential for such soft
7 zones, the less the potential impact on the design.
8 No matter how deep, I think the issue of voids or
9 holes below a power block is of interest in the
10 design.

11 JUDGE WARDWELL: How are these - how is
12 this determined? It hasn't been defined at the ESP
13 stage correctly.

14 WITNESS CONSTANTINO: No. No. There's
15 not enough information presented at the ESP stage to
16 make any determination one way or the other.

17 JUDGE WARDWELL: Couldn't someone take
18 the position that in fact it's a basic site
19 characteristic that ought to be discovered now
20 because it could preclude the site from moving
21 forward with a plant design?

22 WITNESS CONSTANTINO: My response to
23 that I think is there is nothing that has been
24 presented which indicates in fact that's a problem.
25 There is an existing plant there which did go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 through a detailed evaluation, so I don't think
2 that's a serious issue at this site, but I think
3 that's one that has to be addressed, usually not by
4 borings or deep sampling, but just by investigation,
5 investigations and studies that are available from
6 the geologic communities over the years. And those
7 kind of assessments I think are relatively easy to
8 address. It's a matter of going back and looking
9 through the technical literature that's available
10 and talking to people in the area. I don't think
11 that's a showstopper at the current time.

12 JUDGE WARDWELL: Any of the other
13 witnesses in their review, did - were there any
14 other things that led you to be comforted that more
15 than likely Karst formation is not a critical issue
16 at this site? Yes, we still need to look at it as
17 we move forward at the COL stage, but at this point
18 you have sufficient observations that lead you to
19 believe that it's not a problem. What are those
20 items that other people might have, other witnesses
21 might have used to comfort themselves that it's not
22 anything that needs to be addressed at this point?
23 Any further than what already is.

24 WITNESS CHENG: Tom Cheng. Based on my
25 understanding of the site, because the limestone

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 kind of formation would be several feet below the
2 grade which is very far from the foundation,
3 potential foundation level I believe the fact that,
4 because of the sinkhole and the soft zone has any
5 significant impact on the construction.

6 JUDGE WARDWELL: If the site was - on
7 sites where this is a problem, what would you likely
8 - would you see anything necessarily on sites where
9 this might be a problem which would certainly raise
10 a flag and say, gee, we ought to cover it at the ESP
11 stage?

12 WITNESS CONSTANTINO: Yes, at sites
13 where this is known to be a problem the
14 investigation programs are very extensive. And
15 trying to locate a sinkhole requires an extensive
16 boring, cone penetrometer, any type of penetration
17 program. And they're difficult to find and they're
18 even more difficult to incorporate within the design
19 to ensure that the facilities could bridge over it.
20 So I think where those - at the sites I'm familiar
21 with where that has been a problem, the programs are
22 very extensive to address those issues.

23 WITNESS LETTIS: This is William Lettis
24 with the applicant. I'd like to add some additional
25 comments regarding Karst. The first comment is that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the shallowest carbonate horizon beneath the site is
2 at approximately a depth of 400 feet. So it's well
3 below the - any proposed embedment depth of the
4 foundation. In response to an RAI from the staff,
5 RAI 2.5.4-9, we performed a fairly extensive
6 investigation as Dr. Constantino mentioned to search
7 for evidence and more importantly negative evidence
8 showing that Karst is not present in the site area.

9 We did a threefold investigation. One
10 was to look in the 5-mile radius area around the
11 site through aerial photography, available maps,
12 looking for any potential evidence that Karst-type
13 phenomena might have occurred, any evidence of
14 sinkhole, deformation of the ground surface,
15 circular features on the ground surface and there
16 are none. We also looked in areas throughout the
17 State of Mississippi where this unit beneath the
18 site called the Glendon limestone comes to the
19 ground surface to see if there's Karst associated
20 with this unit where it's exposed or in the shallow
21 subsurface. And we looked all through the State of
22 Mississippi and throughout the central and western
23 parts of Mississippi there are no known Karst
24 features associated with the Glendon limestone, or
25 more importantly the Vicksburg group, which is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 more extensive body of carbonate rock including the
2 Glendon limestone.

3 So we looked throughout Mississippi. We
4 also contacted local researchers in Mississippi, in
5 particular Professor Millroy from Mississippi State
6 who is - he's a cave specialist I believe. Karst
7 commonly will form caves, so there's the National
8 Spelunking Society which we also contacted about
9 where there are caves in Mississippi. There is
10 nothing associated with the Glendon limestone
11 throughout central and eastern Mississippi - or
12 western Mississippi. The limestone in this area
13 appears to be too dirty. As you progressively go
14 east into eastern-most Mississippi and on into
15 Alabama and on into Florida the limestone becomes
16 pure and pure limestone is more susceptible to
17 dissolution and Karst formation than what you might
18 call dirty limestone or limestone that contains a
19 lot of terrogenous material like clays and silts and
20 things. And so that's the second part.

21 Third part we looked at the foundation
22 depth relative to the location of where this
23 material is in the subsurface at 400 feet or more
24 and even if we had dissolution cavities, which would
25 still be of concern as Carl mentions, but it would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have little influence on the foundation at a depth
2 of somewhere between 100 and 140 feet in terms of
3 the foundation bulb of influence at that depth.

4 Lastly, I'll mention for the existing
5 UFSAR we reviewed the site data. They had several
6 boreholes that penetrated the Glendon limestone.
7 There was no evidence in those boreholes of any
8 dissolution phenomena at all. They also performed
9 for the existing site seismic refraction surveys,
10 and none of those seismic refraction surveys show
11 any type of collapse features or anything in the
12 shallower subsurface that might reflect deeper Karst
13 formation. So through reviewing the existing site
14 information that gives us information on the Glendon
15 limestone, looking in the site area for evidence of
16 Karst, of which there is none, looking at areas
17 where the Glendon limestone reaches the ground
18 surface for evidence of Karst, of which there is
19 none, contacting researchers in the State of
20 Mississippi for Karst phenomena associated with the
21 Glendon limestone or Vicksburg group in this part of
22 Mississippi and there is none, and then looking at
23 the site information there is no evidence of Karst.
24 So that was all contained in a response to a staff
25 RAI and we spent a considerable amount of time

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

—(202) 234-4433

www.nealrgross.com

1 responding to that RAI and doing this research.

2 JUDGE WARDWELL: On Page 8 of the pre-
3 filed testimony by the staff in regards to Hearing
4 Issue A, the last - starting four lines up with the
5 sentence, 'As a common engineering practice for
6 determining the potential for Karst formation, the
7 applicant should search and investigate the
8 available database for information for the known
9 site materials and determine the opinions of
10 recognized geologic experts versed in this area and
11 provide that to the staff.' Based on your
12 discussion in your pre-filed testimony from - you
13 being SERI - you feel you have done that as you just
14 described to us in response to that RAI, is that
15 correct?

16 WITNESS LETTIS: Yes, Your Honor, that
17 RAI described more or less that scope of work that
18 the staff suggests should be done.

19 JUDGE WARDWELL: Is there anything else
20 that needs to be done at the COL stage beyond what
21 you've done, considering this is what the staff says
22 should be done at the COL stage then?

23 WITNESS LETTIS: What we have agreed to
24 do is in response to a COL action item is to do a
25 deeper borehole into the Glendon limestone in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 response to a COL Action Item 2.5-8 which will
2 search for evidence of dissolution in the Glendon
3 limestone. We will sample the Glendon limestone and
4 look to see the purity of the carbonate, whether
5 it's susceptible to dissolution or not, but other
6 than that we don't plan to do any additional work on
7 Karst at the site.

8 JUDGE MCDADE: When you say you don't
9 plan to, that's what in response to RAI 2.5.4-3
10 you're committing to do, correct? I mean, you've
11 made a commitment to do that, what you've just said,
12 and that's going to be a COL action item.

13 WITNESS LETTIS: Yes.

14 JUDGE MCDADE: Okay.

15 JUDGE WARDWELL: Staff, do you agree
16 with their interpretation in fact they have
17 accomplished lots of what you had suggested in the
18 bottom of Page 8 has already been performed, and
19 that only a boring is needed, or would you still
20 stand by your writeup in your pre-filed testimony at
21 the bottom of Page 8 and the top of Page 9?

22 WITNESS CONSTANTINO: Carl Constantino
23 again. In response to what Dr. Lettis said, I only
24 have one problem. The potential dissolutioning
25 extends from depths on the order of 400 feet or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 more. If the plant power block is located at a
2 depth of 130 feet, that leaves of the order of 200-
3 some odd feet to this zone of potential carbonates.
4 The typical advanced reactor systems that we've
5 looked at have power blocks which are dimensioned as
6 much as 400 feet. So if there are materials down
7 there in this carbonate material which could be
8 subjected to dissolution, they would impact the
9 design. So the program not only of the looking at
10 samples of limestone, but looking at samples of
11 these carbonates and see how susceptible they are to
12 any dissolutioning would be something that you would
13 do during COL stage, I would suggest.

14 JUDGE WARDWELL: And is that what you're
15 talking about on the top of Page 9 where you stated
16 that the staff would also perform a chemical
17 evaluation of available soil samples to support any
18 of the conclusions -

19 WITNESS CONSTANTINO: Yes, that's -

20 JUDGE WARDWELL: - drawn from.

21 WITNESS CONSTANTINO: I think that's
22 what -

23 JUDGE WARDWELL: But you agree that the
24 applicant has studied the database?

25 WITNESS CONSTANTINO: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: In regards to their
2 response and refreshing your memory in regards to
3 what was in the RAI response?

4 WITNESS CONSTANTINO: Yes. No, I think
5 searching the database I think was fine. I think
6 the commitment to take samples through these
7 potential materials and as part of the testing
8 program, incorporate that into the testing program.
9 They're very simple tests.

10 JUDGE WARDWELL: But what you're
11 referring to here on the top of Page 9 is really
12 taking available soil samples prior to the boring
13 program I believe, isn't it? As I interpret it?

14 WITNESS CONSTANTINO: No. As part of
15 boring program you will be taking samples to depths
16 which extend into these carbonate materials because
17 -

18 JUDGE WARDWELL: I understand that, but
19 the sentence at the top of Page 9 says, "The staff
20 would also perform a chemical evaluation of
21 available soil samples to support any conclusions
22 drawn from the applicant's study of the database.
23 These evaluations should be performed prior to
24 planning any deep boring program." So I assume what
25 you're referring to here is you're going to test the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 existing soil samples that are available, and I
2 assume still kept, so that you could help guide the
3 boring program into those areas for the best
4 location is what I interpreted that to mean.

5 WITNESS CONSTANTINO: I'm not sure that
6 sentence captures your description. The intent was
7 as part of the boring program to be done, which
8 extends to those depths. There are really not many
9 samples available now.

10 JUDGE WARDWELL: That's where I was
11 going with this question.

12 WITNESS CONSTANTINO: Okay. So I think

13 -

14 JUDGE WARDWELL: So really, the
15 sentence, the third line down, these evaluations
16 should be performed prior to the deep boring program
17 should really be ahead of the previous sentence and
18 then we'd all be pretty much copacetic, is that
19 fair?

20 WITNESS CONSTANTINO: That's fair.

21 JUDGE WARDWELL: Fine. Any comments on
22 what's been said by the staff from the applicant?
23 Dr. Lettis?

24 JUDGE MCDADE: Well actually, beforehand
25 if I could just ask a question by way of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 clarification with regard to the testimony. There
2 was a request for additional information. As a
3 result of that request for additional information
4 there was a commitment made by the staff. That
5 commitment, or a commitment has been documented in
6 the Safety Evaluation Report as COL Action Item
7 Number 2.5-3. And one thing I want to clarify is,
8 is there anything in addition to what is specified
9 in that COL action item that you believe is
10 necessary prior to moving forward. Is there
11 anything that should be added to that commitment at
12 this point in time?

13 JUDGE WARDWELL: What's that number
14 again?

15 JUDGE MCDADE: I believe it's Action
16 Item Number 2.5-3. It's on Page - Appendix A-7. Is
17 that? Dr. Lettis, that is the commitment that you
18 were referring to?

19 JUDGE WARDWELL: No, it was 2.5-8.

20 WITNESS LETTIS: This is Dr. Lettis.
21 COL Action Item 2.5-8 requires us to perform a deep
22 boring to investigate the Glendon limestone.

23 JUDGE MCDADE: Okay, and that's the
24 commitment you were referring to?

25 WITNESS LETTIS: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: Any other comments on
2 what the staff said in regards to any discrepancies
3 that you feel you'd like to clarify or amplify non-
4 discrepancies?

5 WITNESS LETTIS: No Your Honor, that's
6 fine.

7 JUDGE WARDWELL: Okay.

8 JUDGE MCDADE: And again, I'm not sure
9 that - if I got an answer, it went over my head. Is
10 there anything in addition to that COL action item
11 that you feel should be added in order to determine
12 the suitability here?

13 WITNESS CONSTANTINO: I'd like to just
14 look at that.

15 JUDGE MCDADE: Please. And I misstated,
16 it's actually on Page A-8, not A-7.

17 WITNESS CONSTANTINO: I don't think we -
18 Carl Constantino again. I don't think there's any
19 disagreement with that statement as it sits. That
20 statement does not imply to me that the
21 investigation would only be restricted to the
22 limestone.

23 JUDGE MCDADE: Okay, well here's my
24 point. It will extend to whatever we say it has to
25 extend to, and I'm just asking you in your expert

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 opinion are there additional conditions that we
2 should require here, additional things that we
3 should require them to do.

4 JUDGE WARDWELL: Related to Karst
5 formation.

6 JUDGE MCDADE: Yes.

7 WITNESS CONSTANTINO: I'm interpreting
8 this response to say that part of this is to
9 evaluate the soil samples taken below the power
10 block from the deep borings and evaluate their
11 potential for dissolution, not only the limestone.
12 That's what I'm interpreting this statement to say.

13 JUDGE WARDWELL: I think that's a
14 logical interpretation. However, reading Page 9
15 tells me that you're going to be doing that. That's
16 what - that was my next round of questions. The
17 staff would also perform a chemical evaluation of
18 the available soil samples to support any
19 conclusions drawn from the applicant's. Is that
20 correct?

21 WITNESS CHENG: This is Tom Cheng.
22 Sometimes the staff likes to perform the
23 confirmatory evaluation to support its staff
24 conclusion. That's why the statement is made there.

25 JUDGE WARDWELL: So would you anticipate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the applicant to also be performing these same
2 similar analyses on the soil samples? That you'd
3 split the samples and they would perform some?

4 WITNESS CHENG: Yes.

5 MS. STEPHENS: Is that your
6 understanding as the applicant that you would be
7 performing these types of chemical evaluations on
8 any samples? Forget what's written on Page 9. Do
9 you agree as the applicant that you would perform
10 chemical evaluations of any samples, I guess we
11 shouldn't really call them soil samples, retrieved
12 from your Karst deep boring that you're going to
13 perform as part of the COL action item?

14 WITNESS LETTIS: This is Dr. Lettis.
15 The intent of the deep boring is to look for any
16 potential calcareous units at depth. If we identify
17 any calcareous units we will sample them and perform
18 chemical analyses to look and see what their
19 carbonate content is, what their potential for
20 dissolution might be. Also, as we go into the
21 carbonate-rich zone such as the Glendon limestone,
22 we'll look for evidence has there been any
23 dissolution that has occurred just physically in the
24 core sample itself. As I mentioned, the several
25 borings that have gone through the Glendon limestone

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 at the site have shown no evidence of any
2 dissolution in the Glendon limestone. And the
3 boring work performed to date do not show any other
4 shallow or calcareous units at the site.

5 Obviously as we move forward through the
6 boring program for the COL phase we'll be looking
7 for calcareous units shallower than the Glendon
8 limestone. I don't expect to encounter any based on
9 what we know about the site, but that's part of just
10 the due diligence of performing a geotechnical site
11 investigation is to look for those types of
12 phenomena.

13 JUDGE WARDWELL: Based on the responses
14 I've heard to these questions, I think there's
15 agreement between the staff and the applicant. Does
16 the staff agree with that? Is there any
17 misunderstandings in regards to that?

18 WITNESS CHENG: This is Tom Cheng. The
19 staff agrees with it.

20 JUDGE WARDWELL: I guess that's all.
21 Well, let me just summarize. As far as a Karst
22 formation is concerned that in fact many of the
23 things that would be desirable to be done to try to
24 do the research of existing databases, see what's
25 there, talk to some people has been done. A good

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 faith effort has been accomplished in regards to
2 defining that, whether or not that's a potential
3 significant problem. There's a commitment to do
4 additional work and to further define the potential
5 for this formation, and that the applicant and the
6 staff are in agreement of what that work's going to
7 be, and the straw man disappears. Fair to say?

8 JUDGE MCDADE: Just so when we get the
9 transcript of it there will be something on the
10 record other than a nod, would somebody speak out so
11 that the court reporter can write it down? Say yes?

12 WITNESS CHENG: Tom Cheng, yes.

13 WITNESS LETTIS: Dr. Lettis, yes.

14 JUDGE MCDADE: Thank you.

15 JUDGE TRIKOUROS: I have a question
16 regarding pre-filed testimony on Page 3. The - I'll
17 read the preamble to it. It says, 'The staff was
18 unable to determine that either the specific
19 isotopes chosen by SERI or the distribution
20 coefficients of the chosen isotopes were
21 appropriate. Information on both the chemistry of
22 the radwaste system and the aquifer itself did not
23 preclude the possibility that the radionuclides'
24 mobility might be significantly increased through
25 chemical matriculation.' It says, 'Permit Condition

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Number 2 which precludes the release from the
2 radwaste system eliminated the necessity for further
3 characterization information.' I'd like to get a
4 further explanation -

5 JUDGE WARDWELL: Can we wait on that?
6 I've got quite a few questions that deals with this
7 later on.

8 JUDGE TRIKOUROS: I do, I have a number
9 of additional questions regarding Permit Condition
10 2.

11 JUDGE WARDWELL: Yes, well I do too, but
12 can?

13 JUDGE TRIKOUROS: On this particular
14 subject?

15 JUDGE WARDWELL: Yes. I'd like to stay
16 with this subject and get through my first straw man
17 hypotheses if we could before we get to that because
18 we've got a lot - we had to spend quite a bit of
19 time on this.

20 JUDGE TRIKOUROS: That's okay, I'll wait
21 till you're ready.

22 JUDGE WARDWELL: We'll never get it done
23 before noon if we jump to this.

24 JUDGE TRIKOUROS: I know that.

25 JUDGE WARDWELL: In fact that's what I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was going - I was just pausing and that's what
2 allowed you the opportunity to leap into this. And
3 the reason I was pausing is because whether or not
4 we want to break now or get into the next smaller
5 subject area which I think will take about 20 - 30
6 minutes. Seems like it's break.

7 JUDGE MCDADE: Well, we have one vote
8 for break. I don't really care one way or the
9 other.

10 JUDGE WARDWELL: I think it's a good
11 time.

12 JUDGE MCDADE: So why don't we take a
13 break at this point in time. It's now about five
14 minutes of 12:00. Just so we have a nice round
15 figure to shoot at do you want to come back at 1
16 o'clock? Is that going to be enough time or does
17 anybody need additional time?

18 MS. SUTTON: That will be sufficient.

19 MR. RUND: That's fine with the staff.

20 JUDGE WARDWELL: And it's 12:02 by the
21 computer. Not that there's anything wrong with his
22 watch, but there is.

23 JUDGE MCDADE: But one other thing that
24 I would - one of the things we had asked before is
25 that you have people available for Hearing Issue 2

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 while Hearing Issue 1 was here. I think we're going
2 to be going awhile on Hearing Issue A so you may
3 want to be able to tell the people for B that they
4 don't necessarily have to be readily available at 1
5 o'clock. If they, you know, wander back within your
6 control by 2:00 or 2:30 that is probably going to be
7 adequate. Do you think I'm safe in that assumption?

8 JUDGE WARDWELL: Yes.

9 JUDGE MCDADE: Okay. That said, we will
10 be in recess until 1 o'clock. Thank you.

11 (Whereupon, the foregoing matter went
12 off the record at 11:58 a.m. and went back on the
13 record at 1:05 p.m.)

14 JUDGE MCDADE: Before we get started
15 back with the testimony I just wanted to take care
16 of a couple of administrative matters. The first
17 administrative matter is how late we're going to run
18 through till tonight. What we proposed to do is to
19 break sometime between 5:00 and 6:00, not to break
20 under any circumstances before 5:00. That we would
21 break sometime between 5:00 and 6:00 at a reasonable
22 break time, you know, given the questioning. Does
23 that pose a problem for any of the parties, or do
24 you anticipate for any of your witnesses? From the
25 staff?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. RUND: We're okay with that.

2 MS. SUTTON: No problem.

3 JUDGE MCDADE: Okay. We'll probably
4 take at least one break probably for 15 minutes in
5 about an hour and a half, again depending on what
6 looks like a good time to break here this afternoon.
7 With regard to tomorrow we would anticipate or
8 propose to start at about 9 o'clock and let me
9 rephrase that, not about 9 o'clock, at 9 o'clock
10 tomorrow. Does that pose a problem for the staff or
11 your witnesses?

12 MR. RUND: That's fine.

13 MS. SUTTON: That's fine.

14 JUDGE MCDADE: Okay. And specifically
15 if you think there are going to be administrative
16 matters that you are going to need some more time to
17 take care of in the morning let us know because
18 there's no point of getting everybody here ready to
19 go at 9 o'clock if it's then going to be delayed
20 while certain administrative matters get taken care
21 of. So when we break today I'll ask the question
22 again and absent some statement from one of the
23 parties we'll just set it for 9 o'clock tomorrow
24 morning.

25 Anything that we should take up before

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we get started again with the witnesses? From the
2 staff?

3 MR. RUND: The staff has two points we'd
4 like to make now. The first regards a question
5 which I think is coming regarding the barge
6 accident. Our witness is not available today but
7 will be here tomorrow. So I'd like to request that
8 we could put that off until tomorrow.

9 JUDGE MCDADE: And again, we're talking
10 here a hypothetical barge accident.

11 MR. RUND: Absolutely.

12 JUDGE MCDADE: Okay. You're not
13 actually going to blow one.

14 MR. RUND: I hope not.

15 JUDGE MCDADE: Okay.

16 MR. RUND: And secondly the Board seemed
17 to have interest in radiological releases. There
18 seemed to be some questions that might be going down
19 that direction, so we brought up our experiment on
20 that, Steve Klementowicz. He's currently on the
21 panel and if the Board would like to swear him in
22 now just in case some of those questions come down
23 the pike. I think that might be a good idea.

24 JUDGE MCDADE: Okay, do we already have
25 pre-filed testimony from him?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. RUND: Yes, we do. We also have his
2 qualification.

3 JUDGE WARDWELL: Were you motivated by
4 one of the questions we had near the end of the
5 morning session that led you to believe we may start
6 in on that?

7 MR. RUND: It seemed like that so I
8 thought the efficient thing would be to go ahead and
9 just get him sworn in.

10 JUDGE WARDWELL: I think we're going to
11 try to reserve that till we get into Issue B which I
12 anticipate we should be able to do today, this
13 afternoon. So I think we can get through into that,
14 but it's fine he's here, I just wanted to know your
15 motivation. Thanks.

16 JUDGE MCDADE: And since we might bounce
17 around and it may come up, sir, could you please
18 rise?

19 MS. SUTTON: Your Honor, we also have
20 our radiological expert available who also has filed
21 pre-filed testimony who we would like to also
22 introduce at this time. Mr. Marvin Morris.

23 JUDGE MCDADE: And do we have his CV?

24 MS. SUTTON: Yes, you do.

25 JUDGE MCDADE: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SUTTON: It's in SERI Exhibit 1,
2 Your Honor.

3 JUDGE WARDWELL: Did both these
4 witnesses provide pre-filed testimony in regards to
5 Issue B?

6 MS. SUTTON: Yes, Your Honor.

7 MR. RUND: Yes, Your Honor.

8 JUDGE WARDWELL: Okay, that's what I
9 thought.

10 JUDGE MCDADE: And from the staff's
11 standpoint you have no objection to the
12 qualification of the applicant's witness as an
13 expert?

14 MR. RUND: We do not.

15 JUDGE MCDADE: And you have no
16 objections to the staff's expert as a witness?

17 MS. SUTTON: Your Honor, we would also
18 like to have Mr. George Zinke sworn at this time.
19 He also is knowledgeable about Permit Condition 2
20 that you questioned previously and have him
21 available for purposes of expediency. And we have
22 no objections to the qualifications of the staff's
23 witness.

24 JUDGE MCDADE: Okay. And again, we
25 already have his CV?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SUTTON: Correct, in SERI Exhibit 1
2 and his pre-filed testimony as well.

3 JUDGE MCDADE: Okay. Would you also
4 stand? I thought we were going to do a two-fer and
5 now we're going to do a three-fer as far as the
6 swearing. Will you state under penalty of perjury
7 that any testimony you give here will be true and
8 correct?

9 WHEREUPON,
10

11 STEVE KLEMENTOWICZ
12 MARVIN MORRIS
13 GEORGE ZINKE

14 were duly sworn and assumed the witness stand.

15 JUDGE MCDADE: Okay, you are under oath.
16 Please be seated and let's get started.

17 JUDGE WARDWELL: To refresh everyone's
18 memory where we were, we were dealing with the first
19 straw man hypothesis saying that the site is
20 inherently unsuitable, and we were dealing with the
21 first issue that I raised with that being excessive
22 differential settlements caused by any number of
23 four different topics. We've covered residual
24 fills, sheer velocity, the Karst formation and then
25 the last one was blast-induced liquefaction and
26 hearing that the potential for a barge accident

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 would not be till later I think we'll just go ahead
2 and defer all of that discussion till later. While
3 I hear some murmurings over on the staff's corner,
4 I'll explain where we're going with that. I'd like
5 to hear what the liquefaction potential of the soils
6 are at the site and I'll lead you through a series
7 of questions with that, and then talk about whether
8 or not there is a potential for enough of a driving
9 force to cause that liquefaction if in fact the
10 liquefaction potential is not well-defined or there
11 is some indication that it could be, and then relate
12 that to would a blast from the river provide enough
13 force to cause that problem. I think we might as
14 well do that all together once your other witness is
15 available. And you said that he or she would be
16 available when?

17 MR. RUND: Tomorrow morning.

18 JUDGE WARDWELL: Okay. Shall we just
19 delay that till then, that part of it?

20 JUDGE MCDADE: Let me just posit a
21 question here. You got a general overview of the
22 questions that Judge Wardwell wants to ask in that
23 particular area. If we have the individuals here
24 now who are going to be responsible for answering
25 most of those questions, but they would not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 otherwise be back here tomorrow morning, rather than
2 require them to be here the rest of this afternoon
3 and then be here again tomorrow, do you think it
4 would be helpful, and you may want to consult with
5 your witnesses on this, but do you think it would be
6 helpful to have these individuals answer questions
7 on that, or would you prefer to defer until
8 tomorrow?

9 MR. RUND: I believe everybody is going
10 to be here. I see Mr. Bagchi raising his hand. Is
11 that fine to wait until tomorrow?

12 WITNESS BAGCHI: I would have liked to
13 propose respectfully that liquefaction issue is
14 related to geotechnical and Dr. Constantino is the
15 expert on this and I believe that vibratory motion
16 is necessary for liquefaction that could lead to a
17 safety-related structural concern. So I think even
18 without the characterization of the blast load from
19 a postulated barge accident, potential for
20 liquefaction can be discussed and disassociate that
21 from the amplitude of the load.

22 JUDGE WARDWELL: Okay, and that's fair,
23 so we will move forward because what I hear you
24 saying, Mr. Bagchi, if that's correct, Dr. Bagchi,
25 that -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS BAGCHI: I'm a simple mister,
2 sir. My CV is there.

3 JUDGE WARDWELL: That's not simple.
4 That's with experience as good as any, so. You've
5 just been conveyed an honorary doctor by this panel.
6 What I heard you say is that you might have the
7 potential to eliminate liquefaction as a potential
8 from happening regardless of what the driving force
9 is such that we may even not necessitate any
10 testimony from the blast person, although I think I
11 still would like to hear about that anyhow, but
12 we'll decide that after we go through with the line
13 of questioning.

14 WITNESS BAGCHI: Forgive me Judge. I
15 wanted to say vibratory motion is necessary of the
16 kind that comes from an earthquake.

17 JUDGE WARDWELL: Well, we'll talk about
18 that in my line of questioning. So let's proceed
19 with the panel here to talk strictly about the
20 liquefaction potential at the site now.

21 MS. SUTTON: Your Honor? Our panel that
22 is currently empaneled can address that issue. Our
23 expert on the blast zone is here as well if you
24 would like him to be sworn, but he is currently not
25 sworn. He will also be here tomorrow.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: We will wait tomorrow
2 on that if and when we do cover the blast portion.
3 As I read the pre-filed testimony and the SER, it
4 seemed to me that the small liquefaction potential
5 to a certain degree was based on the over-
6 consolidated nature of the loess, the alluvium and
7 the Catahoula formation. Would one of the members
8 of the panel describe what your knowledge base is on
9 the over-consolidated nature of these soils? Or
10 strata?

11 WITNESS CONSTANTINO: Carl Constantino
12 again. Based on information provided in the SSAR,
13 over-consolidation ratios that were encountered in
14 the UFSAR are of the order of 1 and a half, 2, which
15 is reasonably high. The issue of liquefaction
16 potential is a function of two things. Not only is
17 it a function of the characteristics so the soil,
18 the strength of the soil, as well as the demand. So
19 both sides - if I talk about liquefaction, I have to
20 look at two sides. If I talk about over-
21 consolidation I'm only looking at one piece of that.
22 So I think the indication that over-consolidation
23 ratios are relatively high for these soils goes to
24 speaking to the fact that those materials would
25 probably be expected to have high strength against

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 liquefaction.

2 On the other side, the demands for this
3 site, or seismic demands for this site are very low.
4 So the demands you would expect for the magnitude of
5 the seismic-induced sheer strains would lead to
6 small demands. We would expect for materials at
7 depth which have significant over-consolidation
8 ratios, their characteristic strength would be very
9 high so we would - the implication is safety factors
10 against potential liquefaction over broad areas
11 which would impact the power block, the safety
12 factors would be very large. So liquefaction in
13 general from a vibratory demand would be expected to
14 be not an issue, not a serious issue.

15 On top of that, if the power block is
16 situated low, the foundation of the power block is
17 situated low in the soil profile, there are
18 essentially no indications under any kind of seismic
19 load of liquefaction-induced failures for depths
20 below 50 feet. That is, 50 feet is a normally
21 considered cutoff. Below that depth the general
22 subjective assumption is nothing's going to happen.
23 And that's really confirmed when we do site response
24 analysis to look at the demand and we look at
25 laboratory testing to look at the capacity. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701 ...

(202) 234-4433

www.nealrgross.com

1 liquefaction from vibratory effects are expected to
2 be not an issue.

3 Liquefaction from potential blast
4 effects are also expected to not be an issue because
5 of several reasons. Blast loadings tend to be
6 single cycle loadings and to get liquefaction-
7 induced development of pore pressures you need many
8 cycles. The classic is 15 cycles for a large
9 magnitude event. And the smaller the number of
10 cycles induced by the, whatever the causative event
11 is, seismic or blast, the smaller the number of
12 cycles, the lower the potential for liquefaction.
13 In addition, blast tends to give you - if
14 liquefaction does occur on the blast, it would be a
15 very restricted zone because of the rate of change
16 of the induced stresses are very heavily dependent
17 on distance from the blast point which are very
18 close by. So there are great changes in the induced
19 stresses. Those stresses tend to be not sheer kind
20 of stresses, but hydrostatic kind of stresses. So
21 they are not inducing high pore pressures which
22 would lead to liquefaction. So on both those terms
23 then, liquefaction due to vibratory and liquefaction
24 due to blast, both of those potential effects are in
25 my opinion negligent.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: But in hearing your
2 testimony then you do agree that there's a potential
3 for excess pore water pressures to develop under a
4 blast loading?

5 WITNESS CONSTANTINO: Yes, and they
6 would be very restricted and close to the blast.
7 Yes.

8 JUDGE WARDWELL: And that would have a
9 potential of creating excessive uplift for anything
10 buried beneath the water table of those particular
11 strata that this occurs.

12 WITNESS CONSTANTINO: Locally, if the
13 blast is big enough and close enough to the point of
14 the blast you could say that's a potential issue for
15 plants of this size. I would say again that that's
16 not a problem.

17 JUDGE WARDWELL: The over-consolidation
18 ratio that you've quoted, that you indicated that
19 you reviewed, did you review the laboratory data
20 from that, or did you just review that that
21 statement that that is the over-consolidation ratio?
22 Did you confirm that over-consolidation ratio?

23 WITNESS CONSTANTINO: No. Well, no.
24 The only thing I personally did was review the
25 statements. There was no, as far as I recall, no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 consolidation laboratory test performed as part of
2 this cycle of testing.

3 JUDGE WARDWELL: Do you know what their
4 basis was for making that statement?

5 WITNESS CONSTANTINO: Yes, the primary
6 basis I recall was the information provided from the
7 UFSAR. That in those consolidation tests, the over-
8 consolidation ratios were physically measured
9 primarily in the loess material which are most
10 susceptible, but down below they also indicate
11 there's some information about over-consolidation
12 ratios. I personally did not review the laboratory
13 data to confirm this.

14 JUDGE WARDWELL: Would SERI like to
15 comment?

16 WITNESS BACHHUBER: Jeff Bachhuber for
17 SERI and I'd like to add to Carl's information here.
18 For the ESP we looked at several data sets to
19 evaluate over-consolidation ratio and one of the
20 data sets we looked at was the UFSAR where they had
21 reported calculated over-consolidation ratios or OCR
22 based on consolidation tests in the Catahoula
23 formation, which is the bearing formation for the
24 existing plant, Unit 1.

25 In addition to that we performed a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 couple of analyses for the ESP. One was based on
2 the cone penetrometer test. We performed four cone
3 penetrometer soundings throughout the ESP site and
4 we used correlations that compare the CPT results
5 with estimates of over-consolidation. And based on
6 that assessment we were predicting over-
7 consolidation ratios of about 1.5 to 5 and that was
8 consistent with what was reported in the UFSAR.

9 In addition to that, we evaluated the
10 results from the dynamic testing that we performed
11 on samples obtained from the ESP borings. And those
12 included resonant column and torsional shear tests
13 performed by the University of Texas at Austin. And
14 based on the behavior of those soils, they show that
15 they are significantly over-consolidated, likely in
16 the range again of about 2 to 5. And so we had
17 several independent data sets that we looked at.

18 As for the geologic setting, the Upland
19 Complex alluvium, which are the bearing strata for
20 the foundation, whether we look at shallow levels or
21 deeper levels all the way to the 140-foot depth,
22 those materials show a history of geologic past
23 higher loading. And we know that from the profile,
24 the way the strata currently occur at the site. The
25 different layers within the Upland Complex, they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 have substantial relief. And so separate layers
2 within that Upland Complex alluvium have undergone
3 past significant erosion, indicating that there were
4 thicker deposits overlying those sediments previous.

5 The entire region shows evidence of
6 substantial incision of rivers which has left a
7 number of terraces on the landscape. And it looks
8 like that river incision has removed tens to perhaps
9 hundreds of feet of sediment that previously
10 existed. And that caused a consolidation or
11 compression of the deposits and now those soils have
12 been removed, leaving the soils in an over-
13 consolidated state.

14 JUDGE WARDWELL: What data did you have
15 - did they have in the UFSAR relating to the loess
16 formation?

17 WITNESS BACHHUBER: I don't recall for
18 the loess. For the Catahoula formation I think they
19 had on the order of 10 or 15 consolidation tests.
20 So they had a fairly significant amount of lab
21 testing. For the loess I don't recall any testing
22 on those materials. But the foundations for the
23 plants will be below any loess soils and so over-
24 consolidation of the loess does not really have a
25 connection with liquefaction at the foundation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 levels.

2 JUDGE WARDWELL: But it would have in
3 regards to the pure development of excess pore water
4 pressures that could lead to uplift. It's not
5 necessarily a sheer strength problem, but an excess
6 pore water pressure problem. Isn't that fair to say
7 as a straw man hypothesis?

8 WITNESS BACHHUBER: Yes, that's
9 something you would want to look at and consider.

10 JUDGE WARDWELL: And the lowest blow
11 counts, in fact the only material that I saw that
12 had any degree of low blow counts were the loess
13 materials. Is that a fair assessment?

14 WITNESS BACHHUBER: Within the power
15 block area, the loess soils are the lowest density,
16 lowest strength materials that did exhibit the
17 lowest blow counts. The loess, however though it
18 does exhibit a substantial cohesion and you don't
19 really pick that up in the standard penetration test
20 blow counts. It typically stands vertically in cut
21 slopes which shows that it does have a substantial
22 cohesion that would help reduce any development of
23 vibration-induced strength loss.

24 JUDGE WARDWELL: How much would you
25 relate that cohesion to partially saturated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 conditions as opposed to a true cohesion? Does this
2 material have any degree of plasticity, and if so
3 how did it achieve that?

4 WITNESS BACHHUBER: Yes, Jeff Bachhuber
5 again. It does have some cohesion. The clay
6 content in the loess varies, typically between
7 perhaps 5 and 15 percent.

8 JUDGE WARDWELL: Based on grain size
9 only?

10 WITNESS BACHHUBER: That's based on
11 grain size tests that we performed.

12 JUDGE WARDWELL: So it's clay-sized
13 particles, not necessarily clay. Is that a fair
14 assessment?

15 WITNESS BACHHUBER: That's correct,
16 clay-sized particles. Many of the cuts or the
17 vertical exposures I mentioned in the loess occur
18 well above the groundwater table in deposits that
19 appear to be drained and dry. And so that supports
20 that we do have cementation not just related to
21 partial saturation or water tension-induced, but
22 truly from a cementation.

23 JUDGE WARDWELL: Before I move on to
24 explore that last statement, out of the corner of my
25 eye I thought I saw some motion over here. Would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 staff like to comment?

2 WITNESS CONSTANTINO: Yes, I think -
3 this is Carl Constantino again. I think the issue
4 of the development of excess pore pressure in the
5 loess as opposed to the development of uplift on any
6 base mat, if the base mat is located in the
7 alluvium, any excess pore pressure developed in the
8 loess would be very localized. So the chance of
9 inducing excess pore pressure from that excess pore
10 pressure development would be I think not a real
11 issue. So impacting uplift response of the power
12 block structure, I don't think that's a serious
13 issue.

14 JUDGE WARDWELL: In regards to that,
15 would - who would like to comment on the knowledge
16 base of the water levels in the loess and the
17 relationship to any type of aquifer or zone that
18 exists in there that would create an avenue to have
19 fully saturated and potentially excess pressures
20 under a blast-induced loading? I'll start with the
21 staff. Who wants to talk about the hydrology of the
22 loess?

23 WITNESS CONSTANTINO: I'll pass that on.

24 JUDGE WARDWELL: No, we'll start with
25 the staff. We have a volunteer I think that's eager

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to talk.

2 WITNESS BAGCHI: This is Goutam Bagchi.
3 I'll venture an opinion. The blast pressure will be
4 dissipated very quickly, so for it to get into a
5 location where even lenses of aquifers might be
6 located, are very farfetched, very unlikely. And
7 based on the borings that have been done, they have
8 not located any lenses of aquifers that would have
9 to be dealt with. When more detailed site
10 investigations are done under the COL application
11 required by currently existing regulatory guides.
12 1.032 and 1.038 were mentioned earlier on this
13 morning.

14 JUDGE WARDWELL: Thank you.

15 WITNESS BACHHUBER: Jeff Bachhuber. I'd
16 like to add one more point regarding uplift
17 resistance. The plant foundations will be embedded
18 to some extent into the older alluvial deposits
19 below the loess. And the frictional resistance
20 against the side walls of the plant will help reduce
21 any potential uplift. They should provide a high
22 factor of safety against potential uplift induced by
23 pore water pressure in the loess.

24 JUDGE WARDWELL: Did you do any rough
25 calculations to indicate what that magnitude of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 safety would exist for an uplift?

2 WITNESS BACHHUBER: No, we did not
3 perform calculations. Those we are waiting until a
4 plant design has been selected and the depth of the
5 foundation is known. Our comparisons are a
6 qualitative basis.

7 JUDGE WARDWELL: Unless there's anything
8 else anyone would like to add, that's the questions
9 I have on that. I don't feel there's a strong need
10 to continue to pursue this if you don't want to
11 bring your witness in tomorrow for the blast
12 aspects, unless there's some other panel member who
13 wants to talk about.

14 MR. RUND: That's fine. We'll tell him
15 he doesn't need to come for that. Thank you.

16 JUDGE WARDWELL: That covers potential
17 differential settlements including vertical
18 settlements. I don't know what those were, but the
19 way you shoehorned liquefaction in there also,
20 blast-induced. But the other issue in regards to
21 why someone could hypothesize that the site is
22 unsuitable is that there isn't - that the control of
23 groundwater as it relates to the need for active
24 foundation underdraining and the inability to assure
25 adequate capacity and contingencies with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 potential safety factor for underdraining, and then
2 the development of excessive movement in the
3 existing plant from any aquifer drawdown if in fact
4 there is active underdraining taking place, makes
5 this an unsuitable site for the ESP. Based on that,
6 would someone from the staff like to start off and
7 kind of summarize the existing hydrogeologic studies
8 and the knowledge base of what we know about any
9 potential water levels that exist in the ground at
10 the power plant, the power block area?

11 WITNESS BAGCHI: This is Goutam Bagchi
12 of the staff. I may need to have Mr. Vail add to my
13 observations, and if so then I will request him to
14 do that. Starting off, please note that in the
15 hydrology area, the site characteristic for high
16 groundwater elevation is 62.5 feet MSL and the plant
17 grade is 132.5. Uplift is not really an issue at
18 all in this case. And standard designs are designed
19 to groundwater elevations within one foot of the
20 grade.

21 JUDGE WARDWELL: What data do you have
22 to support that position that I understand you're
23 saying, if I can paraphrase what you're saying, is
24 that the loess is always only has perched water
25 zones in it and it will never become saturated with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 its own water level at the surface. What is your -
2 what data supports - if what I just said is a fair
3 interpretation of what you're saying, what is your
4 information base that allows you to say that the
5 loess will never become saturated at some point?

6 WITNESS BAGCHI: Lance, would you like
7 to address that now or can he have some time to look
8 at the information that we have.

9 JUDGE WARDWELL: Yes, sure.

10 WITNESS BAGCHI: We had characterized
11 that in our pre-filed testimony, a summary of all
12 the hydrologic characteristics, characterization, in
13 response to Question Number - this would be Staff
14 Exhibit - is it a staff exhibit? Pre-filed
15 testimony? This is Issue A, site characterization.
16 It's in response to Question Number 3 on Page 4.
17 There's a summary of subsurface characterization of
18 the ESP site.

19 MR. RUND: As a point of clarification,
20 all those tables and figures that are listed in that
21 testimony have now been made exhibits.

22 JUDGE WARDWELL: Well, I see a list of
23 things that you reference, and again we still - we
24 didn't get those as pre-filed testimony, nor is
25 there a narrative that really helps support what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
-WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 your position is in regards - not only support, but
2 define what your position is in regards to the water
3 levels in the various zones and what the database is
4 that allowed you to reach those conclusions in your
5 review of the applicant's submittals.

6 WITNESS BAGCHI: I referred to - this is
7 Goutam Bagchi and I referred to Page 4, Item Number
8 6 in which we discuss. But to summarize really it's
9 based on observation well data.

10 JUDGE WARDWELL: And you're referring to
11 two pesometers in alluvium five and terrace deposits
12 - and again, I assume those terrace deposits are
13 alluvium - and eight in the Catahoula? -

14 WITNESS BAGCHI: Yes, sir.

15 JUDGE WARDWELL: And where does that
16 lead you to indicate any information in regards to
17 the loess? And then also, if you did have data on
18 that, you know, how did that relate to your setting
19 of levels in those other zones also?

20 WITNESS BAGCHI: Our primary interest
21 was to set the level in the area of the power block
22 so that the site characteristic would be set and any
23 calculations at the COL stage and consideration of
24 the groundwater level would be set on the basis of
25 the site characteristic. Maybe we'll take a couple

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of minutes.

2 JUDGE WARDWELL: Well, it would be
3 helpful if I could help guide you. If you could
4 take each strata and say, okay, here's what the data
5 shows in regards to water levels in that strata,
6 here's what we know about the aquifer
7 characteristics in that strata and then this is how
8 it relates to our potential need for both
9 construction, but operational foundation
10 underdraining. And then this is how the applicant
11 evaluated that and any potential backup system
12 should that fail during operations, if in fact it is
13 needed to have operational de-watering. That was
14 difficult for me to dig out for myself, that type of
15 narrative that provided that clear picture that it's
16 been evaluated by the applicant sufficiently to say
17 that this hypothesis can be rejected.

18 WITNESS BAGCHI: We can again refer back
19 to Figure 2.5-76. This was discussed. Exhibit 41
20 of the staff. There is an indication of the
21 groundwater level. The particular layer is
22 saturated. The well has been dug through that layer
23 and you'd have to indicate the behavior of the
24 layer. Maybe I'm not quite getting the thrust.

25 JUDGE WARDWELL: Well, I guess I'll go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 lower then. Again, can someone provide a narrative
2 of the water levels that are in each zone and how it
3 affects the design and step us through that? Or
4 shall I just ask individual questions to try to
5 achieve the same thing? We can go either way, I
6 don't care. I just thought someone might be able to
7 just provide a narrative. We have a loess
8 formation. We anticipate water levels ranging from
9 this to this, if there are any, and this is the data
10 that supported that position. And therefore this is
11 the relationship to the design aspects of that. The
12 Upland Complex alluvium water levels are such and
13 such. Here the aquifer characteristics are such and
14 such in regards to transmissivity and saturated
15 thickness. And here's how it would relate to the
16 proposed foundation design. And then do the same
17 thing with the old alluvium. Very similar to the
18 geologic description that was done this morning for
19 the strata, similar narrative for the hydrogeologic
20 conditions that are there.

21 WITNESS BAGCHI: We don't have that type
22 of detailed well observation, well information
23 through every type of geologic stratum at the site.
24 The important point was the water, groundwater
25 elevation in the area where the power block is going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to be located, because that directly applies to
2 pressure of the side walls, uplift of the power
3 block and those kinds of structural calculations.
4 So we relied on the data that was available in the
5 power block area from the wells. The groundwater
6 elevation there was 62.5. That's where we set it.

7 JUDGE WARDWELL: Is that a confined
8 aquifer or an unconfined aquifer in the alluvium, do
9 you know?

10 WITNESS BAGCHI: This is an unconfined
11 aquifer.

12 JUDGE WARDWELL: Do you know if the
13 applicant has committed to or sees a need for or has
14 even evaluated the potential for operational
15 underdraining of the power block area?

16 WITNESS BAGCHI: I think operational
17 underdraining or de-watering has been proposed for
18 construction, probably would be necessary.

19 JUDGE WARDWELL: My question was in
20 regards to operations. I'm aware that construction
21 would have de-watering, yes, but what about
22 operations? Would there be a long-term
23 underdraining of that building foundation, the power
24 block foundation for operations?

25 WITNESS BAGCHI: Well, this is a COL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 activity. It's going to be reviewed at that time
2 and determined whether or not a permanent underdrain
3 system will be necessary.

4 JUDGE WARDWELL: So there's no
5 commitment one way or another as far as you remember
6 or understand?

7 WITNESS BAGCHI: No.

8 JUDGE WARDWELL: Would the applicant
9 like to comment on that?

10 WITNESS EVANS: Lori Evans for the
11 applicant. Without knowing the exact reactor type
12 and the exact footprint of the structures it would
13 be difficult at this point to say whether or not a
14 permanent drain system would be necessary. At the
15 ESP stage. At COL when the reactor design and the
16 exact location are known, then you can make those
17 determinations.

18 JUDGE WARDWELL: Wouldn't the bounding
19 range that you have provide you enough information
20 to take a rough cut at whether or not an underdrain
21 system is needed and to what degree and what flow
22 rate you might have to deal with? I mean, you could
23 hypothesize a site that would be so difficult to
24 maintain the drawdown that an underdrain system
25 would be impossible to maintain and certainly assure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that it would never fail and have a backup system to
2 counteract any failure if in fact you needed that
3 for design. That would preclude the site from being
4 a suitable one for a power plant to be built,
5 wouldn't it?

6 WITNESS BAGCHI: Your Honor, Goutam
7 Bagchi for the staff. Existing power plants have
8 permanent de-watering systems. I don't believe the
9 Unit 1 has any permanent de-watering system, does
10 it?

11 WITNESS EVANS: Lori Evans for the
12 applicant. They have an intermittent de-watering.

13 WITNESS BACHHUBER: Jeff Bachhuber for
14 the applicant. During construction they handled
15 groundwater inflows through the alluvial deposits,
16 or as they called the terrace deposits, by using
17 sumps. And so they did not have very high flow
18 rates. They were able to control it easily during
19 the construction period. With deep excavations that
20 extended to the Catahoula formation.

21 JUDGE WARDWELL: And now how did you
22 apply that to your ESP analysis in regards to the
23 potential need for underdraining?

24 WITNESS BACHHUBER: With respects to
25 drainage requirements during construction we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 evaluated what was done for the existing plant,
2 compared that to the material properties that we
3 encountered in the ESP borings, compared those
4 materials to similar deposits at the existing plant
5 site and made a determination that a similar
6 approach could be used. So integrating sumps,
7 perhaps drainage points that weren't used for the
8 existing plant, but that was an extra measure that,
9 you know, we would be able to apply for a plant at
10 the ESP site. But in any case the inflow rates
11 shown through precedent excavations for the existing
12 plant demonstrated that we would be able to handle
13 inflows using conventional-type techniques.

14 JUDGE WARDWELL: And that's for
15 construction, correct?

16 WITNESS BACHHUBER: Correct.

17 JUDGE WARDWELL: How would you
18 extrapolate that same information to the needs for
19 operations?

20 WITNESS EVANS: Again, we looked at
21 similarities or assumed similarities between the
22 existing plant and the new plant. And very limited
23 de-watering is required for Unit 1. In the proposed
24 power block area for the ESP plant groundwater
25 levels to a certain extent are controlled by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 surface elevation of the Catahoula formation which
2 in fact is lower under the ESP power block area. So
3 we would anticipate actually slightly lower
4 groundwater levels in the ESP power block area.

5 JUDGE MCDADE: Just so the record is
6 clear, that was Lori Evans who made that statement.

7 WITNESS EVANS: Lori Evans for the
8 applicant.

9 WITNESS CONSTANTINO: Can I - this is
10 Carl Constantino, can I?

11 JUDGE WARDWELL: Based on that
12 statement, what would you conclude as an expert in
13 this field in regards to the feasibility of
14 underdraining the existing power block area at this
15 site? Is it feasible, really feasible? Is it a
16 little shaky pizza, or boy it's going to be hard to
17 underdrain that if we need to?

18 WITNESS EVANS: Lori Evans for the
19 applicant. I believe it is feasible.

20 JUDGE WARDWELL: Thank you. Now, sorry.

21 WITNESS CONSTANTINO: Yes, I just wanted
22 to make a comment. Carl Constantino again. There
23 are two issues associated, and we're not talking
24 about the construction period, we're talking about
25 operational. There are really two issues associated

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with underdraining. The first really has to do with
2 the impact on the design of the facility. Based on
3 the suspension log data, the groundwater elevations
4 are indicated on Figure 2.5-76 and they were
5 inferred, really not measured. And they show the
6 groundwater elevation down - elevation of the order
7 of 60. The design of the plants are really, all
8 that I'm aware of are based on an assumed
9 groundwater elevation at plant grade. So there's a
10 huge safety factor from that design operation.
11 Underdrain systems are typically only required when
12 I have now a poorly constructed plant where lots of
13 material is flowing into the facility. I presume
14 that's not going to happen here. In New York we
15 have great experience with underdrain systems.
16 Water is permanently coming into every facility in
17 New York. So underdrain systems are easily
18 feasible. They're not things you like because
19 they're expensive to maintain. From a design
20 perspective they're, the groundwater location at
21 this site is most likely not an issue, just based on
22 the data that's available now.

23 JUDGE WARDWELL: And with that same
24 experience base, do you find it difficult to provide
25 backup systems or procedures or any need for if the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 primary underdrain system does not operate?

2 WITNESS CONSTANTINO: Yes, they're
3 difficult to install after the fact. So we try to
4 design systems which don't require underdrain
5 systems. And again, that's an operational kind of
6 consideration which you'll find later on, but for
7 structures that we typically encounter at nuclear
8 power plants, issues of groundwater inflow into the
9 structure are not a major issue.

10 JUDGE WARDWELL: You mentioned that the
11 water levels shown on Exhibit 41 were inferred and
12 not measured. Is that based on just the question
13 marks being along that line, or is that just a
14 standard copout that's used by the hydrogeologic
15 professor?

16 WITNESS CONSTANTINO: Well, standard
17 copout I guess, but from the suspension log you tend
18 to measure both MS. SUTTON: -wave and P-wave
19 velocities. And there's a big change in P-wave
20 velocity when you get down to that depth which is
21 essentially the velocity through the saturated. So,
22 and that, in my experience that's always been
23 relatively consistent with what we find from the
24 borings. These borings were, if I recall were
25 drilled in the wet so then you couldn't get any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 major good information from - on groundwater from
2 those borings, but the SPTs or the CPTs or the
3 suspension logging data shows relatively consistent
4 results. So anything above, any water encountered
5 above that would tend to be perched and not be a
6 major issue from any design perspective.

7 JUDGE WARDWELL: Any statements made by
8 the staff that the applicant would like to amplify
9 or modify in any aspect?

10 WITNESS LETTIS: This is William Lettis
11 for the applicant. Just to - we agree with the
12 staff's comments. Just to amplify or for another
13 exhibit, SERI Exhibit 14 is a - graphically depicts
14 the results of the velocity profiles that Carl
15 Constantino was just referring to for all three of
16 the borings that we drilled in the site area, and it
17 shows the sheer wave velocity and the P-wave
18 velocity profiles. Where the P-wave velocity
19 profile jumps up or kicks up is generally related to
20 saturated or groundwater conditions. And so this
21 shows - and you can also see we've put on the figure
22 the geologic contact between the loess and the
23 alluvium, the Upland Complex alluvium, and you can
24 see the groundwater table which is shown by the
25 black triangle for B-1, B-2 and B-3 over on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 right-hand side of the figure, the groundwater table
2 is generally below the loess and in the Upland
3 Complex alluvium, but it's pretty clearly demarcated
4 by the velocity data, the P-wave velocity data.
5 It's not precise. As Carl says, did you use the
6 word "inferred"?

7 WITNESS CONSTANTINO: Guess.

8 WITNESS LETTIS: But we have pretty good
9 constraint on the level of groundwater and the
10 absence of groundwater in the loess above in terms
11 of saturation.

12 JUDGE WARDWELL: What information -

13 JUDGE MCDADE: Can I just interrupt for
14 a second. "Inferred" sounds a lot more scientific
15 than "guess." How reliable is this guess in your
16 view?

17 WITNESS CONSTANTINO: Carl Constantino
18 again. The guess is good, it's the location of the
19 guess that's difficult. So if I want to say the
20 groundwater elevation is 62.3, and it may be 70,
21 within that range I would say it's acceptable.

22 JUDGE MCDADE: But as far as being able
23 to state that it's in the alluvium as opposed to the
24 loess.

25 WITNESS CONSTANTINO: Oh yes, no, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 think that's - you can make that jump. That's not
2 an issue.

3 JUDGE MCDADE: That's a strong
4 inference?

5 WITNESS CONSTANTINO: That's a strong
6 inference and not a guess. It's just trying to
7 label a particular elevation that's a little more
8 difficult. The drill string on a suspension logger
9 is 10 meters. So trying to interpolate between
10 those measurement points is where the smearing of
11 the data occurs.

12 JUDGE MCDADE: Okay, and the difference,
13 you know, the reasonable range within which it's
14 going to fall, am I correct that from your
15 standpoint, from an engineering standpoint would not
16 pose a major problem?

17 WITNESS CONSTANTINO: No. Not at all.
18 Because the design condition for each of the
19 advanced reactor systems that I've reviewed,
20 groundwater is assumed to be up at the ground
21 surface. So if it's down below, there's no impact
22 on the design.

23 JUDGE MCDADE: And whether it's down
24 below by 90 feet or 92 feet isn't going to make a
25 material.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: And so you're saying
2 that as far as any analysis that was performed at
3 the ESP stage, that the loess was assumed to be
4 saturated at groundwater table up through the loess.

5 WITNESS CONSTANTINO: That's right.

6 JUDGE WARDWELL: Is that correct from
7 the applicant's standpoint also?

8 WITNESS EVANS: Lori Evans for the
9 applicant. Yes, that is correct.

10 JUDGE WARDWELL: Thank you. Just out of
11 curiosity, because now that last question made this
12 question moot, but I thought I'll ask it anyhow.
13 What - do you have any data or information in
14 regards to whether or not there is a potential that
15 the loess does in fact get saturated during the
16 right climatic and river level conditions? And no
17 is an acceptable answer, I was just wondering
18 whether you had any information.

19 WITNESS EVANS: Lori Evans for the
20 applicant. We don't have any definitive information
21 at this point. We have some preliminary
22 investigation from the COL investigations, but
23 nothing definitive yet.

24 JUDGE WARDWELL: I'm sorry, from the
25 what investigations?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS EVANS: The COL investigations.

2 JUDGE WARDWELL: Okay, thank you.

3 WITNESS BACHHUBER: Jeff Bachhuber,
4 SERI. I'd like to add that we did look for evidence
5 of seepages on the slopes around the site. And we
6 did not find any seeps or evidence of substantial
7 past seeps down to the elevation of the existing
8 plant grade or the proposed plant grade of about 133
9 feet. And there is a 25-foot high cut slope in
10 loess on the site, and so we can evaluate the upper
11 25 feet of loess, and again did not find evidence of
12 seeps in that material.

13 JUDGE WARDWELL: And you were looking
14 for the seeps in regards to the drainage - in
15 drainage basins A and B and in the front face that's
16 directed towards the river, the west face bluff?

17 WITNESS BACHHUBER: Yes, that would be
18 from observations of the cut slope, the trends in
19 the north-south direction across the site and also
20 in the basin A or the tributary slope and the river
21 bluff slope to the west of the site.

22 JUDGE WARDWELL: Thank you. I guess - I
23 don't know whether this is the best place to ask,
24 but I think I will because we're talking about
25 groundwater, but certainly for the EIS and the SER

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 it was recognized that there isn't a lot of
2 information in regards to aquifer properties which
3 were part of the reasons I was trying to - my line
4 of questioning was going on. And to the point that
5 the water quantity and quality under the EIS was
6 deemed to be unresolved, an unresolved issue for the
7 EIS. Given that same situation for hydrologic
8 alterations to the groundwater, wouldn't they also
9 be unresolved? I don't know if anyone here can
10 comment on that. We may have to wait for another
11 panel, but.

12 WITNESS VAIL: This is Lance Vail and I
13 was responsible for the environmental review related
14 to hydrology. In the aspects of hydrologic
15 alteration that we were looking at, there would be a
16 change potentially in the water table and in the
17 flow pass, in the subsurface that I think you're
18 alluding to. And that uncertainty would, you know,
19 result in some uncertainty about the impact. But
20 the staff didn't determine that there was anything
21 that would result in an impact of the hydrologic
22 alteration that wasn't already covered in the
23 unresolved aspect of it in the water use and water
24 quality issue. So we made an effort not to
25 essentially double count impacts that there would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 some uncertainty, but we did not see a hydrologic
2 alteration impact that would reach the level of
3 moderate or large.

4 JUDGE WARDWELL: And that's because you
5 don't expect much alterations in the hydrologic
6 conditions with the building and the operations of
7 the power block area?

8 WITNESS VAIL: Well, we certainly expect
9 it locally, but hydrologic alterations that are
10 going to affect the environment in a general sense,
11 we didn't think that that was sufficient to reach a
12 level of moderate or large.

13 JUDGE WARDWELL: And what is - if you
14 don't know the aquifer characteristics, what is the
15 basis for your conclusion of that? That's what I'm
16 having a hard time grasping.

17 WITNESS VAIL: The impacts associated
18 with this are expected to be localized with the
19 exception of the potential impact of the drawdown,
20 particularly in the Catahoula which could go offsite
21 which we did say that that was unresolved under the
22 water use side.

23 JUDGE WARDWELL: Okay, thank you.
24 Anything applicant would like to add to that?

25 WITNESS EVANS: Lori Evans for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 applicant. I have nothing to add.

2 JUDGE WARDWELL: Everyone happy here?

3 Okay.

4 JUDGE MCDADE: The answer is yes.

5 Ecstatic.

6 JUDGE WARDWELL: That handles straw man
7 hypothesis - straw person hypothesis number one.
8 We're getting close to the end of A. We just have
9 two more hypotheses to deal with. The second one is
10 that one could argue that the sediments dredged up
11 for any construction in the river for any structure
12 that might be intake, outtake, whatever is being
13 built out on the river would end up being
14 categorized as hazardous waste and that the economic
15 difficulties in handling, storing and disposal of
16 those dredge wastes would make construction in the
17 river unfeasible and therefore there is no, as
18 presently proposed, mechanism for water management
19 at the site and would make it an unsuitable site. I
20 haven't even asked any questions yet, I drew out the
21 hypothesis. That's good. And again, keep in mind,
22 these are not my hypotheses, these are ones I think
23 we need to be sure we can refute.

24 Isn't this a safety issue if in fact the
25 sediments preclude construction of the structures

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 for makeup water, not as I think was referred to as
2 we were trying to describe this in our previous
3 orders, an environmental issue. It's an
4 environmental issue also. It's certainly an EIS
5 issue, but I'm coming at it from the safety side,
6 that because these would have to be handled, the
7 economics of doing it would preclude the use of
8 that. Therefore, you don't have that river as a
9 makeup water source. Would you like to comment on
10 that? It's obvious you would like to comment on
11 that, so please do.

12 WITNESS BAGCHI: No, no, first of all
13 though Your Honor I didn't quite understand what you
14 meant by sediment and dredging. Would you kindly
15 describe that one more time, your hypothesis?

16 JUDGE WARDWELL: Sure. I assume that in
17 order to build the intake and outfall structures in
18 the river -

19 WITNESS BAGCHI: Outfall structures.

20 JUDGE WARDWELL: Well, either one, I
21 don't know which. I don't know the details of it.
22 You will relay that to me if in fact I misconceived
23 it, but I assume that for both any intake structures
24 and outfall structures that sediments would have to
25 be dredged from the river. The soil in the bottom

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

— WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the river, I call them sediments. That dredging
2 I assume, and I don't know whether I assume it or
3 whether I read it, that the characterization of
4 those sediments has been deferred to the COL stage
5 as a design detail. This hypothesis says wait a
6 minute, shouldn't that have been looked at at the
7 ESP stage to assure that in fact there's not a fatal
8 flaw with doing that activity. And the fatal flaw
9 that someone could hypothesize would be you go in
10 there at the COL stage and all of a sudden you
11 realize that there are excess radionuclides from the
12 previous outfall, or there are just heavy metals or
13 whatever. We don't know what's in those sediments.
14 Now you find out that they are, and they
15 characterize as a hazardous waste by EPA standards.
16 Now you have to handle any dredging that takes place
17 as - the sediments from it as a hazardous waste, and
18 that's a whole another level of issues that someone
19 could hypothesize would make it economically
20 infeasible to use that option. Therefore, you can't
21 build whatever structure you wanted to build that
22 required the dredging and therefore this ain't a
23 good site. That's the hypothesis.

24 WITNESS BAGCHI: Okay. Maybe I will be
25 missing one or two of your questions. If I do,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 please remind me. This is Goutam Bagchi of the
2 staff. Let me address the safety aspect of it
3 first. Intake, if there is one, there will be one,
4 is not safety-related. It is for normal plant heat
5 sink. It can be withdrawn from the river based on
6 its depth of the channel and constant flow. It's
7 eminently feasible.

8 JUDGE WARDWELL: Without dredging?

9 WITNESS BAGCHI: Without any kind of
10 dredging. There is a large channel, a very deep
11 channel and constant flow of millions of cubic feet
12 of water per second flowing through. If we need to
13 develop intake from the river, I think it's entirely
14 feasible. We answered that in our pre-filed
15 testimony in response.

16 JUDGE WARDWELL: You will construct this
17 intake structure without any dredging of the river
18 bottom?

19 WITNESS BAGCHI: Well, that's not
20 safety-related, it's not a concern at this point for
21 the staff. It's just normal heat sink withdrawal
22 and however the applicant does it, that's their
23 responsibility. And we did not feel for a large
24 river like that it is infeasible. I certainly did
25 not think that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: If in fact you couldn't
2 use the river because of the - well, let me back up
3 a bit. You testified that that intake structure can
4 be built without any dredging. Not to get capacity,
5 just to physically get that into the river and
6 protect it from any future activities that takes
7 place in the river, you can do that without dredging
8 any sediments?

9 WITNESS BAGCHI: Whatever is necessary
10 to construct a pipeline to lay it out into the river
11 channel to ensure that it is permanently below the
12 level of water where there will be a constant flow
13 of water available or in other words below the low
14 water elevation of the river, substantially below
15 that, depending on the pumps used and so on. Laying
16 out a pipe and then withdrawing from that does not
17 in my mind require a dredging.

18 WITNESS VAIL: This is Lance Vail. And
19 again, I worked on the environmental review. And
20 there was going to be a dredging in the embayment
21 area. The construction of a surface diffuser and
22 stuff would not necessarily require dredging
23 activities, although potentially may move out,
24 depends I think on the time of year when they would
25 actually be able to do the construction on the level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 of the river and stuff. So there would be some
2 dredging potential and stuff that would go on in
3 there. But in the environmental review, we
4 specifically did not consider the cost-benefit of
5 these activities and our determination was that it
6 was technically feasible. Whether it's economically
7 feasible was not considered. And so we did not
8 address that issue. So the fact is that this
9 becomes hazardous waste and it results in
10 significant costs to the applicant to dispose of
11 that waste, that was not considered as part of our
12 analysis.

13 JUDGE WARDWELL: Under the environmental
14 order, I understand that.

15 WITNESS VAIL: Under the environmental.

16 WITNESS BAGCHI: And under safety - this
17 is Goutam Bagchi again. Under safety, it is not a
18 safety-related structure. We don't worry about
19 that.

20 JUDGE WARDWELL: If for whatever reason
21 you couldn't take water out of the river or put
22 water back into the river, how would you do that at
23 this site? Those activities? How would you provide
24 the water for the heat sink makeup?

25 WITNESS BAGCHI: Do we need water?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 There are proposed plants where the plant is dry
2 cooling.

3 JUDGE WARDWELL: And is that what would
4 have to take place at this site if in fact you
5 couldn't use the river?

6 WITNESS BAGCHI: We don't need to
7 speculate at this point. They have not explored
8 that issue. We don't need to speculate how they're
9 going to cool the normal population of the plant.

10 JUDGE WARDWELL: Well, we do under this
11 hypothesis have to explore that, and that's what I'm
12 trying to get a better feeling. While the makeup
13 water is not a direct safety-related, isn't it tied
14 to it such that you would be - that it would make it
15 as a decision being that it isn't an effective site
16 to be permitted?

17 WITNESS BAGCHI: I think they discussed
18 the potential for using an underground basin for the
19 ultimate heat sink source, and any makeup would
20 really be the makeup for the evaporation loss. Very
21 minor loss. So that can be made up from wells and
22 some other kinds of sources. There is nothing that
23 I considered intrinsically at fault with the site
24 that would not allow the location - siting a plant
25 there.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: But isn't it true that
2 we haven't characterized the aquifers enough to
3 determine the capacity associated with those?

4 WITNESS BAGCHI: That is true sir, but
5 at this point, at Early Site Permit stage we are not
6 even sure what kind of a reactor design they would
7 employ that would require water-cooled ultimate heat
8 sink. And we did not feel that this is the
9 appropriate point at which we try to characterize
10 all of the aquifers which then become disrupted by
11 construction activities and our conclusions at this
12 stage need to be revised later on. So I think it's
13 wise and best to leave it for the COL application
14 stage. We just need to determine whether or not a
15 reactor could be safely sited at this site.

16 JUDGE WARDWELL: Any amplification or -

17 MS. SUTTON: And Your Honor -

18 JUDGE WARDWELL: - that the applicant -

19 MS. SUTTON: As a matter of law before
20 they answer, I just would like to remark that this
21 is calling for vast amounts of speculation in terms
22 of the inability to withdraw or return water to the
23 river. So they can answer but it is purely
24 hypothetical and speculative.

25 JUDGE WARDWELL: It is a hypothesis that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the sediments have not been characterized
2 whatsoever. We have no knowledge of what those
3 sediments are like in the river, is that correct?
4 Let me ask that.

5 WITNESS EVANS: Lori Evans for the
6 applicant. It is correct that we did not
7 characterize the sediments during the ESP stage. I
8 also would like to address just generally the idea
9 of the feasibility of using water from the
10 Mississippi River. There are in fact a number of
11 users of water from the Mississippi River both for
12 industrial purposes and for public water supplies,
13 both upstream and downstream of the plant.

14 JUDGE WARDWELL: And what I'm trying to
15 get on the record is testimony that allows us to
16 move forward without that characterization of the
17 sediments. And not even, is this correct that not
18 only have the sediments not been characterized,
19 there is no information whatsoever on any of the
20 chemical characteristics of the sediments? There
21 hasn't been any sampling done of the sediments, is
22 that correct or not?

23 WITNESS EVANS: Lori Evans for the
24 applicant. Sediment sampling is done as part of
25 Unit 1's routine radiological monitoring program.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 And then there is additional limited data done by
2 other agencies of the Mississippi River that was
3 presented in the application.

4 JUDGE WARDWELL: And were those sediment
5 quality parameters reviewed to assure yourself that
6 it wouldn't be a problem in regards to handling
7 sediments if needed during the construction of
8 either the intake or the outfall structures?

9 WITNESS EVANS: We did not do that
10 analysis.

11 JUDGE TRIKOUROS: Let me ask a question
12 to maybe help this thing along a little bit. Is it
13 possible for a plant, an existing plant that meets
14 10 C.F.R. § 20 requirements, all the normal release
15 requirements, to result in sediment and in a river
16 that it discharges to to be characterized as
17 radwaste? Is that a physical possibility? The
18 releases are monitored, the site - the environment
19 external to the site is monitored. Is the
20 postulation possible, that you would have a
21 sedimentation in the river that would be
22 characterized as radwaste from a nuclear power plant
23 operating that meets all of its requirements for
24 normal release? I think if the answer to that
25 question is no, then I think it goes a long way

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 towards answering Judge Wardwell's concern.

2 JUDGE MCDADE: Perhaps this isn't the
3 panel that's going to be able to offer expert
4 testimony in response to that. But sir, can you?

5 WITNESS KLEMENTOWICZ: Yes, my name is
6 Steven Klementowicz. I'm a senior health physicist
7 within NRR. And part of my significant experience
8 is with the radiological environmental monitoring
9 programs. Each operating nuclear power plant is
10 required to have a REMP. As part of the REMP they
11 are required to sample their discharge canal, the
12 sediment. So during the environmental review that
13 will be discussed later I believe in Issue I, we
14 will present as part of our testimony that we did
15 look at several years worth of REMP data. I do not
16 have the information with me, but that is a part of
17 an operating power plant to sample and analyze the
18 sediment for plant-produced radionuclides. It does
19 not do chemical analysis, but we are looking for
20 licensed radioactive material being discharged.

21 JUDGE MCDADE: Okay. And just so, to
22 make sure I understand at least the import of the
23 testimony that you gave and going back to the
24 previous witnesses, that first of all it is your
25 testimony that you believe that you would be able to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 construct the necessary - any necessary intake and
2 outflow structure without any significant dredging;
3 that secondly, even if that were not possible and
4 you were not able to withdraw water from the
5 Mississippi that you did not believe that that would
6 be a limiting factor making this an unsuitable site,
7 that you would be able to get sufficient water from
8 the aquifer without adversely affecting the aquifer.
9 And using - designing the plant accordingly so that
10 that would occur within the plant parameter envelope
11 of this application. Is that a correct summary of
12 what you were testifying to, or did I misunderstand?

13 WITNESS BAGCHI: Goutam Bagchi. I'm not
14 implying that all of the water would have to come
15 from the aquifers. Distribution of different
16 cooling requirements can be designed. It's
17 technically entirely feasible. The site does not in
18 my opinion have any intrinsic fault that would allow
19 siting of a plant here infeasible. I'm sorry, my
20 English wasn't all that great. What I meant to say
21 is that the site does not have any intrinsic
22 impediment for siting a nuclear power plant.

23 JUDGE MCDADE: Okay, but Judge
24 Wardwell's hypothesis, again he described this as a
25 straw man hypothesis, was that you would not be able

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 to withdraw water from the Mississippi River for the
2 operation of the facility for whatever reason.
3 Would that render this an inappropriate site for the
4 plant, or within the plant parameter envelope of
5 this application would you be able to proceed anyway
6 to construct and operate the facility?

7 WITNESS BAGCHI: I think the permit-
8 holder could proceed irrespective of the hypothesis
9 made by Judge Wardwell.

10 JUDGE MCDADE: But nevertheless you
11 believe that the hypothesis raised is unlikely, that
12 based on your experience that you see no impediment
13 to being - no realistic impediment to being able to
14 use the water from the Mississippi?

15 WITNESS BAGCHI: I fully agree with
16 that, Your Honor.

17 JUDGE WARDWELL: Let me just add one
18 more, then we'll get to you. I'll complete the
19 thought on this. I think I asked it before, but let
20 me make sure I hear this. And you also testified
21 that you could install the intake and outfall
22 structures without any dredging if needed? In your
23 opinion?

24 WITNESS BAGCHI: That is my personal
25 opinion, yes sir.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: How about your
2 professional opinion?

3 WITNESS BAGCHI: Yes, professional
4 opinion.

5 JUDGE WARDWELL: Thank you.

6 JUDGE MCDADE: Sir?

7 WITNESS ZINKE: George Zinke with the
8 applicant. With regard to your hypothesis with
9 regard to safety and the need for water for safety,
10 our application proposed that if we pick a design,
11 and the only designs that we're trying to bound with
12 the application, if we pick a design that needs a
13 source of safety-related water, then we would design
14 a facility to have that water. Meaning that
15 similar, and we said similar to with the Unit 1.
16 What that means is that what we've done for Unit 1
17 is we designed and built a facility which holds the
18 water. It has basins and it has the water, so that
19 we do not - with our application we are not trying
20 to permit using the Mississippi as a source for any
21 safety-related water need.

22 JUDGE WARDWELL: Or any other water
23 besides what's stored in your tank.

24 WITNESS ZINKE: Or any other water -
25 yes. Or any other water other than what would be in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a designed storage tank facility structure. And so
2 therefore, at least that's how I understand the
3 hypothesis and how our application is presented.

4 JUDGE WARDWELL: I think that's another
5 nice nugget to have refuting this hypothesis. And
6 let me just make sure I understand this correctly
7 because this is the side that I don't gather. They
8 call me the olo-ologist. I'm not a radioactive
9 person. I know the ology side, not the other side.
10 What needs do you have, or what facilities do you
11 have, or what is required by the NRC to supplement
12 the water that is in that storage tank that you now
13 use as your ultimate heat sink that doesn't require
14 any river water or groundwater for that matter.

15 WITNESS ZINKE: Okay, for the - and each
16 design that we would look at and pick would have
17 different requirements, so let me give as an example
18 for our current Unit 1, the design requirements
19 include things like it has to have a 30-day supply
20 of water. And so then calculating the usage of the
21 water for its safety-related needs, you know,
22 following an accident, that 30 days would, you know,
23 the water is there. That allows then post-30 days,
24 depending upon the needs of that design, that we
25 have a variety of ways of bringing in water, whether

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it would be trucked in, but it would, you know, we
2 have a variety of ways of replenishing after the 30
3 days. So taking that as an example, what we would
4 do with our Early Site Permit, if we pick a design,
5 then we would design the structure with the
6 regulatory guidance associated with the design we
7 picked of how much water is needed, you know how
8 long it's good for, what happens after water, the
9 safety-related water needs, after that point in
10 time. What are the ways of replenishing so that all
11 of that then matches. And then all of that design
12 factoring how much water you need, for what period
13 of time, what happens after, that all gets put into
14 the COL application with the design that's
15 referenced, and then all that gets reviewed and
16 reviewed against the staff's acceptance criteria at
17 the COL.

18 JUDGE WARDWELL: Are the existing radial
19 wells safety items?

20 WITNESS ZINKE: No, they are not.

21 JUDGE WARDWELL: Thank you. I think
22 that helps clarify stuff. Anyone else like to add
23 any more comments on this?

24 WITNESS KLEMENTOWICZ: Excuse me?

25 JUDGE WARDWELL: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS KLEMENTOWICZ: This is Steve
2 Klementowicz again. I would like to add that there
3 are nuclear power plants that do not discharge
4 radioactive effluents into any body of water. And
5 they operate, you know, very successfully. So
6 that's just another piece, that they do not have to
7 discharge their liquid radioactive effluents into a
8 body of water. There are other methods to process
9 that water and to dispose of it.

10 JUDGE WARDWELL: Thank you. The last
11 one is one that I think was addressed fairly well,
12 but I want to make sure we get it on the record and
13 talk about it a bit. And that is that the desired
14 withdrawal rate that was proposed by the applicant,
15 something in the neighborhood I think of 3,700
16 gallons per minute from the Catahoula and the
17 drawdown effects from the deeper zones during this
18 process would have an adverse impact on the water
19 quality in the upper zones of the Catahoula. And
20 I'd just like to explore for a minute on why that
21 wouldn't necessarily preclude this from being a
22 viable site, the fact that it's unresolved in
23 regards to what is the capacity of that Catahoula
24 and then in turn what is the effects on the water
25 quality in the upper zones caused by the upper

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 gradients from the lower zones. And would someone
2 from the staff like to comment on that?

3 WITNESS VAIL: Yes, this is Lance Vail.

4 And just to make sure everyone understands, one of
5 the unique interests of this site was the fact that
6 this proposed site overlies a sole source aquifer
7 that has a special designation within EPA and has
8 specific requirements on activities that would
9 involve federal agencies. So it has a particular
10 interest in terms of any potential impacts to the
11 water quality. The question as to the unresolved
12 issue is in fact associated with the fact that the
13 limited characterization data that we have with the
14 Catahoula did not provide adequate basis for us to
15 come up with a conclusion of the potential drawdown
16 impacts on the Catahoula. However, in the ESP
17 application, they did provide some information on
18 the impacts of the existing wells that they have
19 that are - we understood at the time were actually
20 completed into the Catahoula. And now it's my
21 understanding there may be some change in the
22 definition of where those were actually completed.
23 But we didn't have an adequate basis we felt to
24 conclude that the drawdowns associated with that
25 incremental water use would be small enough that it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 might not induce water of lower quality to either
2 enter from above or below into the Catahoula.

3 JUDGE WARDWELL: Is there any
4 circumstance where that would end up to be a fatal
5 flaw if in fact even minimal pumping from the
6 Catahoula would impact the upper zones of the sole
7 source aquifer?

8 WITNESS VAIL: If - a fatal flaw.

9 JUDGE WARDWELL: Yes. And that - to
10 translate that fatal flaw meaning that the site
11 would be deemed unsuitable and that it shouldn't be
12 granted an ESP permit.

13 WITNESS VAIL: If the Environmental
14 Protection Agency in the consultation that's
15 required under the Safe Drinking Water Act which is
16 where the sole source provision is derived from,
17 were to identify that the Catahoula cannot be used,
18 then there would need to be an alternative source of
19 water identified to replace the water from the
20 Catahoula.

21 JUDGE TRIKOUROS: Is this going to be
22 discussed as part of the presentation that's being
23 made on alternatives, which includes - design
24 alternatives, which includes, as I understand it,
25 various ultimate heat sink options? Is this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 something that we're going to be talking about later
2 as well?

3 WITNESS VAIL: At this point it's not in
4 the presentation on alternatives.

5 JUDGE WARDWELL: We're speaking about
6 that operational, I forgot the right word for it,
7 incidental water of 3,700 gallons per minute that
8 they're proposing to use out of the Catahoula and
9 the potential impacts associated with using that.

10 WITNESS VAIL: Yes, and the staff's
11 conclusion is that with the Mississippi River being
12 adjacent, that if the Catahoula was to be determined
13 to be inadequate, that it was highly likely that
14 there would be an alternative source that could
15 replace the water demand that was expected to come
16 from the Catahoula. So that's a part of the
17 rationale that we used as to why this would not make
18 the site unsuitable.

19 JUDGE WARDWELL: Is there a reason -
20 what is the reason why they have decided not to - do
21 you know of the reason why they decided not to
22 continue use of the radial wells and instead build
23 an intake structure for any plant makeup water such
24 that using a similar type of well for this 3,700
25 gallons per minute wouldn't be - the same reason it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 would apply to any type of other well that they
2 might want to develop down there, to supply this
3 3,700 gallons per minute.

4 WITNESS VAIL: I wouldn't speculate, but
5 I suspect the applicant can answer that.

6 WITNESS EVANS: This is Lori Evans for
7 the applicant. There are actually various
8 possibilities for obtaining water supply. The
9 Catahoula formation is a possibility. There are
10 documented wells in the area in the Catahoula
11 formation with discharges ranging from I think
12 approximately 200 to 500 gallons per minute. The
13 radial wells do have a very large capacity and
14 theoretically could be used as a supply. The
15 Mississippi River could be used as a supply. So
16 there are multiple potential sources available.

17 And as far as the Catahoula formation is
18 concerned, I wanted to add that there are two
19 regulatory safeguards that would prevent us from
20 negatively impacting the Catahoula aquifer. First
21 is the sole source for designation which would
22 require review, and then the second would be the
23 state withdrawal permit. The state could deny a
24 withdrawal permit or could reduce the quantity that
25 could be withdrawn.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: Thank you for that, but
2 that to me amplifies the need to think a little
3 harder on alternative sources because without
4 definition of what that response to the Catahoula to
5 any pumping would be in regards to potential impacts
6 says that if there isn't alternative sources that
7 may be a detrimental site characteristic for placing
8 a plant at this facility. Do you know of the reason
9 why radial wells aren't being considered for the
10 intake structure that are now being used for the
11 existing plant?

12 WITNESS EVANS: Lori Evans for the
13 applicant. Yes, we did do a cursory review. There
14 have been numerous detailed studies done for radial
15 well production and it was determined that they
16 would not have an adequate production capacity for
17 plant service water for a new unit. However, it is
18 possible that a radial well could be used for this
19 other water which would be the 3,570 number that
20 you're -

21 JUDGE WARDWELL: As opposed to what
22 number that's needed for plant service water?

23 WITNESS EVANS: Correct.

24 JUDGE WARDWELL: No, what is that
25 number, do you know off the top approximately?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS EVANS: I don't know off the top
2 of my head.

3 JUDGE WARDWELL: Does anyone know what
4 that is? It'd be nice to just.

5 MS. SUTTON: Mr. Zinke will answer that
6 question.

7 JUDGE WARDWELL: Yes.

8 MS. SUTTON: Your Honor, we would like
9 to introduce another witness to answer that
10 question, Mr. Al Schneider. His professional
11 qualifications are included in SERI Exhibit 1 and
12 his pre-filed testimony has been entered into the
13 record.

14 JUDGE MCDADE: Okay. Do you swear that
15 the testimony that you give or state that the
16 testimony that you give under penalty of perjury is
17 true and correct, will be true and correct?

18 WHEREUPON,
19

20 ALCUIN SCHNEIDER
21 was duly sworn and assumed the witness stand.

22 JUDGE MCDADE: Okay, you are under oath.
23 Please proceed. And given the fact that I'm
24 mumbling that, it may be worthwhile for us after we
25 finish this particular thing to take a few minute

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 break. I think the temperature here under the
2 lights is getting up over 100. So I need to go out
3 and change my shirt I think. But sir? That's
4 probably more information than we really need. The
5 image of that at least.

6 MR. SCHNEIDER: I'm Al Schneider with
7 Enercon Services speaking for the applicant. The ER
8 has a figure, 2.3-29. I don't know that it's an
9 exhibit, but the makeup water for the plant is
10 78,000 gallons a minute. And there's an additional
11 - in the PPE or in this figure we had an additional
12 3,400 gallons a minute for ultimate heat sink makeup
13 if that were required. And then the miscellaneous
14 makeup of 3,570 gallons a minute all added up to
15 about 85,000.

16 CLERK: Can you speak closer into the
17 mic?

18 MR. SCHNEIDER: Okay. A total of about
19 85,000 makeup was required. And based on the
20 information that exists for the aquifers where the
21 radial wells are installed, they just don't have the
22 capacity.

23 JUDGE WARDWELL: Do you know about what
24 the capacity, what the yield is of any one of those
25 radial wells? Within an order of magnitude.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. SCHNEIDER: Eight thousand gallons a
2 minute.

3 JUDGE WARDWELL: Thank you. That
4 handles - unless there's something else anyone else
5 would like to add on this issue, I think that
6 satisfies my questions.

7 JUDGE MCDADE: Do you have anything
8 before we take a break?

9 JUDGE TRIKOUROS: No, not before we take
10 a break.

11 JUDGE MCDADE: Okay. It's now about
12 2:35. If we take a 15-minute break until 2:40, does
13 that work for staff?

14 MR. RUND: That's fine.

15 JUDGE MCDADE: The applicant?

16 MS. SUTTON: Yes, Your Honor.

17 JUDGE MCDADE: We're in recess.

18 (Whereupon, the foregoing matter went
19 off the record at 2:37 p.m. and went back on the
20 record at 2:56 p.m.)

21 JUDGE MCDADE: The hearing will come to
22 order. Before we proceed with the questioning, let
23 me just go through a couple of preliminary things
24 procedurally here. We anticipate we've got only a
25 very short additional questioning on Hearing Exhibit

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 A. We're then going to move ahead to Hearing
2 Exhibit B. I anticipate that our questioning on
3 Hearing Exhibit B should probably take about an
4 hour, give or take. We would then move on to
5 Hearing Exhibit D. We had indicated to you the
6 other day that we did not anticipate needing any
7 witnesses on Hearing Exhibit C given the fact that
8 there was - given our review of the pre-filed
9 testimony on Exhibit C. Upon further review it
10 appears that there's one brief question. I know the
11 staff has a Dr. Li as the individual. We told you
12 you didn't have to have him available here. If he
13 is readily available and you can bring him over
14 today that's fine. If he isn't, tomorrow, again it
15 should be a relatively short, you know, just a
16 matter of a few minutes.

17 JUDGE WARDWELL: Well, let me ask this.
18 Maybe someone on this panel or the applicant's panel
19 or someone else here might be able to address this.
20 The only question I have was what is the seismic
21 acceleration coefficient for the site if someone was
22 going to do a pseudostatic analysis. And someone
23 here - if someone can answer that just say that you
24 can and we'll ask that question appropriately and
25 then we don't have to worry about getting the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 seismologist here.

2 MR. CAMPBELL: Your Honor, this is Tison
3 Campbell for the staff. Yung Li is in the audience
4 so he can come forward when necessary.

5 JUDGE WARDWELL: Unless the applicant
6 could answer that question. The design seismic
7 acceleration coefficient.

8 MS. SUTTON: One moment, Your Honor.

9 WITNESS BAGCHI: Your Honor, could you
10 kindly say that again, please?

11 JUDGE WARDWELL: Yes. I'm interested in
12 what is the seismic acceleration coefficient that
13 would be used in a simplistic analysis like a
14 pseudostatic stability analysis or something like
15 that for the site. The 0.whatever or the 0.1-
16 something g that would be used as an acceleration
17 coefficient.

18 WITNESS BAGCHI: The minimum design
19 requirement in Appendix -

20 JUDGE WARDWELL: I don't want testimony
21 now, I just want to know whether anyone can testify
22 that's here so that we don't have to bring in the
23 seismologist. Because oftentimes a geotech engineer
24 or someone else will be able to testify to what that
25 value is for this site.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MS. SUTTON: Your Honor, our witnesses
2 cannot answer that question.

3 JUDGE MCDADE: So let's move along,
4 finish -

5 MR. RUND: I'm not sure if our witnesses
6 can, but our witness is here so when we get to that
7 question we can bring him up and swear him in.

8 JUDGE MCDADE: Judge Trikouros?

9 JUDGE TRIKOUROS: I'd like to just close
10 out the Hearing Issue A with a simple question, I
11 think. There's a statement made on Page 3 of the
12 pre-filed testimony that says that Permit Condition
13 2 precludes the release from the radwaste system,
14 eliminates the necessity for further
15 characterization. The first part of my question is,
16 is that referring to the ESP stage or forever?

17 WITNESS BAGCHI: This is Goutam Bagchi
18 with the staff. The Early Site Permit Condition,
19 Condition Number 2 is intended to be executed for
20 the plant design operation until plant shutdown.

21 JUDGE TRIKOUROS: Until what, I'm sorry?

22 WITNESS BAGCHI: Until plant shutdown.

23 JUDGE TRIKOUROS: For plant life, the
24 entire plant life?

25 WITNESS BAGCHI: Right, the entire plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 life.

2 JUDGE TRIKOUROS: So -

3 WITNESS BAGCHI: I have a presentation
4 with two slides. If you want to get into the
5 feasibility of this permit condition, the reasons
6 why we put it there, what are the requirements, I
7 have gone into a little bit of detail and I have a
8 presentation with just two slides. I could do that
9 now.

10 JUDGE TRIKOUROS: When were you planning
11 to do it, as part of B?

12 WITNESS BAGCHI: It's at your
13 convenience, Your Honor.

14 JUDGE TRIKOUROS: If you were not
15 planning it, then I'd like to hear it now. If you
16 have it planned for some point down the road, then
17 we'll wait. But there are other questions on Permit
18 Condition 2 as well.

19 JUDGE WARDWELL: I think it'd be
20 worthwhile because it also will also blend into
21 Hearing Condition B nicely. So I think this is as
22 good an opportunity if you're prepared to do that
23 now. I think we'd appreciate it.

24 WITNESS BAGCHI: There are two slides
25 related to issues on, let's see, accidental release

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 issues. There are only two slides there, but I will
2 make the presentation and describe my reasoning for
3 presenting the slide, the material in the slides.

4 JUDGE WARDWELL: Okay. And those have
5 been marked as an exhibit?

6 WITNESS BAGCHI: The presentation
7 material has not been, Your Honor.

8 MR. RUND: The slides have been marked
9 as an exhibit. If you just give us one moment we'll
10 figure out which slides those are in and we may even
11 be able to get that up on the display.

12 JUDGE MCDADE: That's fine.

13 MR. RUND: I believe the slide we're
14 talking about appears in Staff Exhibit Number 18
15 which is the presentation slides for Hearing Issue
16 H.

17 JUDGE TRIKOUROS: Did you say Staff
18 Exhibit 18?

19 MR. RUND: I apologize.

20 JUDGE MCDADE: Staff 18?

21 MR. RUND: I'm sorry, that's Staff 19
22 for Issue I.

23 MR. CAMPBELL: Your Honor, it's Slides
24 51 and 52 from that exhibit.

25 JUDGE TRIKOUROS: I'm sorry, did you say

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 51 and 52 or 61 and 62?

2 MR. CAMPBELL: Fifty-one and 52.

3 JUDGE TRIKOUROS: Fifty-one and 52.

4 MR. CAMPBELL: Yes, sir.

5 JUDGE MCDADE: Okay, this is Staff

6 Exhibit 19, Page 52 headed Accidental Release

7 Issues. Is that where you are?

8 WITNESS BAGCHI: Yes, Your Honor.

9 JUDGE MCDADE: Okay, let her rip.

10 WITNESS BAGCHI: My presentation is on
11 issues related to accidental release of liquid
12 radioactive effluents. I will talk about the
13 feasibility of Permit Condition 2, groundwater
14 monitoring requirements associated with accidental
15 release and the need for radwaste tank failure
16 analysis at the COL stage.

17 A robust design such as that of safety-
18 related structures, systems and components provides
19 a reasonable assurance that the radwaste facility,
20 including the liquid effluent-containing tanks, will
21 not fail under postulated accidents and extreme
22 natural hazards. Locating the radwaste facility on
23 the nuclear island or on the power block itself
24 enhances containment of accidental radioactive
25 effluent spillage. Radwaste facilities are to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 designed to prevent uncontrolled release of
2 radioactive materials caused by spillage in
3 buildings or from outdoor components. All tanks
4 inside and outside the plant, including contents of
5 storage tanks, should have provisions to monitor
6 liquid levels. Designated high liquid level
7 conditions should actuate alarms both locally and in
8 the control room. There are over several thousand
9 reactor years worth of operating experience to date,
10 but there has never been any accidental liquid
11 radioactive release event from radwaste facilities.

12 There is no groundwater monitoring
13 requirement for accidental releases. Accidental
14 release of liquid radioactive effluent is such a
15 rare event that it can be directly associated with
16 the plant where the event occurred. Due to
17 construction activities associated with new reactor
18 designs, it is not appropriate to use site
19 properties at the ESP stage to establish an
20 effective monitoring plan. And then let's go to
21 Slide 2, the next slide.

22 As I indicated earlier, there is no
23 groundwater monitoring requirement associated with
24 accidental liquid radioactive effluent releases. An
25 accidental release event is so rare that the plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is immediately identified. At the ESP stage it's
2 not appropriate to establish a monitoring plan. As
3 I described in my previous discussion, radwaste tank
4 design is robust and there is reasonable assurance
5 that the radwaste facility and the associated tanks
6 will withstand the effects of extreme natural
7 hazards and postulated accident conditions.
8 Currently existing guidance should ensure the
9 robustness of radwaste facility design during the
10 review at the COL stage. There are requirements for
11 alarmed monitoring of liquid effluent. This is kind
12 of repeating myself, so I'll dispense with that.

13 Retention by an intermediate sump or
14 drain tank that is designed for handling radioactive
15 materials and that has provisions for routing to
16 liquid radwaste system is also acceptable. Indoor
17 radwaste tanks should have curbs or elevated
18 thresholds with flow drains routed to liquid
19 radwaste treatment system. Outdoor tanks should
20 have dyke or retention point capable of preventing
21 runoff in the event of a tank overflow and should
22 have provisions for sampling collected liquids and
23 routing them to the liquid radwaste system. The
24 staff conclusions related to the hydrological safety
25 of the proposed ESP site are based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 comprehensive and independent review of the site
2 characteristics. Conformance to applicable
3 regulations and in cognizance of the regulations and
4 regulatory criteria that are applicable at the COL
5 stage. That was my prepared presentation.

6 JUDGE TRIKOUROS: So what you're saying
7 is that in answer to my original question with
8 respect to whether the lack of site characterization
9 requirement was for the ESP only, you're saying no,
10 it is for the ESP and COL, for operation of the
11 plant through the end of its design life.

12 WITNESS BAGCHI: That's correct, Your
13 Honor.

14 JUDGE TRIKOUROS: Okay. And you're
15 saying that that is true of both radwaste liquid
16 inventory inside a radwaste building in addition to
17 any radwaste that's stored in outside tanks?

18 WITNESS BAGCHI: Yes, Your Honor. This
19 is the philosophy of regulating radwaste facilities
20 as it exists today. Regulatory Guide 1.143 provides
21 all these requirements.

22 JUDGE TRIKOUROS: Are there any plants
23 in existence today that you know of that has this
24 requirement? Or is this a new requirement
25 associated with the next generation plant?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 WITNESS BAGCHI: It was revised fairly
2 recently. I don't have the data revision, but no,
3 not all existing plants have this.

4 JUDGE TRIKOUROS: Because as far as I
5 know, the liquid radwaste tank failure is a design
6 basis accident for - at least, wherever I've looked.
7 I can't say I've looked at every plant in the
8 country. But you're saying in essence, and
9 specifically in your slide, that the liquid radwaste
10 tank failure is no longer a design basis accident
11 for this plant, whatever plant - as a permit
12 condition requirement.

13 WITNESS BAGCHI: That's my
14 understanding. That's how it can be executed and
15 carried out. This regulatory guide was revised in
16 November 2001.

17 JUDGE TRIKOUROS: Now one of the things
18 that I have a little bit of concern with is the
19 statement that you made regarding the fact that any
20 leakage from the tank - specifically I'm concerned
21 with outdoor tanks, not so much indoor tanks. I
22 think indoor tanks you can show that with proper
23 sump flows to holdup tanks and you know, properly
24 designed containment walls and liners you could
25 effectively meet your Permit Condition 2 with a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 very, very high likelihood for any indoor system.
2 But with respect to the outdoor tanks, you indicated
3 that one of the reasons it's acceptable is that
4 there would be a liquid level monitoring which
5 really would mean that you would know that it
6 leaked, not that you would prevent it from leaking.

7 WITNESS BAGCHI: Your Honor, you prevent
8 it from spreading because you have to have curbs and
9 other requirements in this regulatory guide.

10 JUDGE WARDWELL: You'd have to have
11 what, I'm sorry?

12 WITNESS BAGCHI: Curbs around the tank.

13 JUDGE WARDWELL: Oh, curbs.

14 JUDGE TRIKOUROS: All right, so what
15 you're -

16 WITNESS BAGCHI: Inside and outside.

17 JUDGE TRIKOUROS: All right. So you're
18 saying basically that the staff would to some very
19 high probability assure that the design of these
20 systems would be leak-proof? As far as getting into
21 the groundwater, getting into the earth?

22 WITNESS BAGCHI: I didn't say leak-
23 proof, but I did say that it would not get into the
24 ground or surface water with high likelihood of
25 success.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE TRIKOUROS: All right, now what
2 about other leakage from other sources. For
3 example, spent fuel pool leakage, leakage in
4 possibly other tanks that may be onsite, piping,
5 possibly underground piping. Analogous to the
6 problems that have been identified in plants
7 throughout the country and as evaluated in the
8 lessons learned task force report. So radwaste not
9 being the only source of radioactive material that
10 might get onto the ground.

11 WITNESS BAGCHI: I am aware of some of
12 the conclusions drawn there, that that's routine
13 release. But before I give it to my colleague Mr.
14 Klementowicz, he's going to address the lessons
15 learned related issues. But am going to try to
16 address the other factors of design. By design you
17 could have guard pipes. By design you're required
18 to consider relative displacement between buildings
19 and between anchors of piping. So there are plenty
20 of ways to meet this criteria. It is eminently
21 feasible to do this.

22 JUDGE TRIKOUROS: And you're saying it
23 applies to not only radwaste, but to all sources of
24 radioactivity onsite that might get into the
25 groundwater?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS BAGCHI: Low level radioactivity
2 I'm not going to address. That's routine release
3 and Steve will address that. Please forgive me, I
4 didn't relate to that.

5 JUDGE WARDWELL: I heard phrases like
6 "very high likelihood." I heard phrases like
7 "reasonable assurances that it wouldn't get into the
8 groundwater." However, when I read the permit
9 condition, those aren't the words that are used in
10 the permit condition. The permit condition says
11 preclude any and all accidental releases. It's hard
12 for me to envision anyone designing something
13 precluding any and all, because the criteria as I
14 read it is not a very high likelihood or reasonable
15 assurances. How do you address that?

16 JUDGE TRIKOUROS: And also, the permit
17 condition says radwaste, if I remember correctly.

18 JUDGE WARDWELL: Yes, it's specific to
19 radwaste systems.

20 JUDGE TRIKOUROS: It doesn't cover other
21 radioactivity.

22 JUDGE WARDWELL: Right, correct.

23 WITNESS BAGCHI: Any and all is probably
24 a little too strong, but in reality it can be
25 achieved. That's my belief.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: I think you were
2 mentioning detention ponds. The radwaste systems do
3 include pipes conveying this radwaste liquid to
4 various locations of the outdoor tanks, indoor
5 tanks, et cetera, and those pipes are part of the
6 radwaste system or aren't they?

7 WITNESS BAGCHI: Next generation plants
8 don't have those.

9 JUDGE WARDWELL: They don't have any
10 piping connecting?

11 WITNESS BAGCHI: They - some designs
12 might, but most designs don't.

13 JUDGE WARDWELL: But if some designs do
14 as far as ESP stage, we have to still consider that.

15 WITNESS BAGCHI: Consider that a
16 possibility, yes.

17 JUDGE WARDWELL: Okay.

18 JUDGE TRIKOUROS: Now with - this is
19 strictly associated with liquid radwaste leakage
20 we're talking about.

21 WITNESS BAGCHI: Yes, sir.

22 JUDGE TRIKOUROS: Not gaseous. So
23 analysis of gaseous radwaste tank failures would
24 still be design basis accidents?

25 WITNESS BAGCHI: That would be addressed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 by someone else in the staff.

2 JUDGE TRIKOUROS: Okay.

3 WITNESS BAGCHI: I will not try to
4 address that.

5 JUDGE WARDWELL: I have another question
6 for you. If - even given the fact that there's
7 maybe comfort that designs could be developed to
8 preclude any and all accidental releases, is there
9 not still a necessity to do something to assure that
10 those designs are functioning?

11 WITNESS BAGCHI: If we have appropriate
12 alarms, appropriate indications that these things
13 are not working properly, plant operator would know.

14 JUDGE WARDWELL: Well, and those alarms
15 are, I would assume, part of the monitoring. That's
16 monitoring.

17 WITNESS BAGCHI: Yes, sir.

18 JUDGE WARDWELL: And that lets you know
19 that there's been some release, that in fact the
20 designs aren't working. Isn't it logical also then
21 to include some type of monitoring around those
22 systems to verify that when those alarms went off
23 there wasn't a release to the adjacent environment?

24 WITNESS BAGCHI: I believe there is
25 radiation monitoring instrumentation equipment in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the plant.

2 JUDGE WARDWELL: Let me rephrase the
3 question I guess. Isn't there a need to monitor the
4 adjacent groundwater around the radwaste systems if
5 in fact you are going to issue this as a permit
6 condition to verify that in fact you are precluding
7 any and all accidental releases of radionuclides
8 from the radwaste system into a liquid pathway which
9 would be the groundwater.

10 WITNESS BAGCHI: We probably don't need
11 to do that at the ESP stage. At the COL stage when
12 you do have a design, we know the proper locations
13 of everything, there will be an adequate review to
14 determine whether or not we need groundwater
15 monitoring system for radioactivity.

16 JUDGE WARDWELL: Isn't it reasonable to
17 assume that you would if in fact you're going to
18 have a permit condition like this as the only
19 mechanism to assure that you are precluding any and
20 all? I'm not saying defining what it is, I'm just
21 saying isn't it logical to assume that there will be
22 some sort of groundwater monitoring around the
23 radwaste systems, however defined it is at the COL
24 stage, to assure that this permit condition is being
25 achieved.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS BAGCHI: Your Honor,
2 conceptually you're looking forward and perhaps
3 there is nothing wrong with that, nothing wrong with
4 what you've suggested. But in order to have an
5 effective plan, we would have to speculate where
6 these things are going to be. Just to have a
7 generality that there shall be some kind of a
8 monitoring is not very effective or attractive to
9 me.

10 JUDGE WARDWELL: It may not be
11 attractive, but there will be a reason why we need
12 to address that as we'll see later on in our
13 questioning. So let me ask you this question. In
14 your professional opinion, do you think it is likely
15 in order to assure that this permit condition is
16 being achieved that there will be some groundwater
17 monitoring around the radwaste systems? Yes or no.

18 WITNESS BAGCHI: There are other ways to
19 achieve that. For example, having hydraulic
20 gradient towards, concentrated towards the radwaste
21 facility. There are so many ways to do that aside
22 from just -

23 JUDGE WARDWELL: I'll ask the question
24 one more time and then I'll quit asking it. In your
25 professional opinion do you believe it is likely

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that there will be some sort of groundwater
2 monitoring related to the radwaste system that will
3 be implemented to assure that the applicant is
4 achieving this permit condition which requires them
5 to design that system to preclude any and all
6 accidental releases of radionuclides into the
7 potential liquid pathway?

8 WITNESS BAGCHI: It would be a
9 reasonable measure to implement at that stage.

10 JUDGE WARDWELL: Thank you.

11 JUDGE MCDADE: Let me interject
12 something here. I just want to make sure that I
13 understand it, that in response to an earlier
14 question from Judge Wardwell, I thought you said
15 that "any and all" might be a bit of an
16 overstatement. Am I correct? Is that what you
17 said?

18 WITNESS BAGCHI: I did say that, Your
19 Honor.

20 JUDGE MCDADE: Now, the way the permit
21 condition is currently worded, if we were to approve
22 the application as currently worded that would be a
23 requirement and they would be in violation if the
24 system did not in fact preclude any and all. Are
25 you suggesting that that permit condition be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 modified?

2 WITNESS BAGCHI:- No, Your Honor. I
3 think the permit condition can be achieved through
4 design.

5 JUDGE MCDADE: But that permit condition
6 is preclude any and all.

7 WITNESS BAGCHI: Yes, Your Honor. With
8 a strong emphasis on the design itself it could be
9 achieved, so at this point I would say that the
10 permit condition is restrictive but not
11 unreasonable.

12 JUDGE MCDADE: Okay. So we start out
13 with the premise that any and all release of
14 radwaste is prohibited. But we now talk about
15 accidental, and obviously accidental by its
16 definition is accidental. As I understand it, you
17 say we don't need a ground - and on your slide Page
18 51 of Exhibit 19 you indicate that groundwater
19 monitoring is not required for accidental release,
20 and I believe the reason that you said is because of
21 other systems within the plant. If there were such
22 a release, you would be aware of it at the time and
23 would be able to take appropriate action and be able
24 to determine whether or not the engineering did in
25 fact prevent the release of any and all of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 radwaste, is that correct?

2 WITNESS BAGCHI: Yes, Your Honor.

3 JUDGE MCDADE: Okay. And am I correct
4 that you believe that that - the design plus those
5 additional engineering factors within inside the
6 plant are sufficient to ensure that the condition is
7 being met, that there is not in fact any radwaste
8 that is being released into the groundwater?

9 WITNESS BAGCHI: That's a correct
10 interpretation of what I wanted to say. Yes, sir.

11 JUDGE MCDADE: Okay. And in your
12 professional opinion no more is required. Because
13 under the permit no more is required.

14 WITNESS BAGCHI: That is - yes, and I
15 will preface that by saying the following. We do
16 the reactor design with all kinds of preventive
17 measures and defense-in-depth and all those other
18 kinds of safeguards. Nevertheless, accidents can
19 happen.

20 JUDGE MCDADE: Okay. But as I
21 understand on this, the condition is that even if an
22 accident happens, it will be designed so that there
23 will not be a release. And you believe that there
24 are sufficient monitoring devices within the
25 facility that no separate monitoring of groundwater

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is necessary in order for the NRC to ensure that
2 this permit condition is being met throughout the
3 operating life of the facility. Am I correctly
4 interpreting what I think you're saying?

5 WITNESS BAGCHI: Yes, sir.

6 JUDGE MCDADE: Okay.

7 JUDGE WARDWELL: And does that include
8 what you labeled as outside tanks? Or maybe it was
9 one of the judges on the panel.

10 WITNESS BAGCHI: It can be designed that
11 way, yes sir.

12 JUDGE MCDADE: Okay. Does the applicant
13 have anything to add to that?

14 WITNESS MORRIS: Marvin Morris for the
15 applicant. I guess I'd just like to clarify that
16 our understanding is that the permit condition only
17 applies to liquid radwaste.

18 JUDGE MCDADE: That's what we're talking
19 about.

20 WITNESS MORRIS: Okay. Secondly, I
21 think groundwater monitoring to prevent the release
22 to the environment is kind of after the fact.

23 JUDGE MCDADE: Well, it's to identify as
24 opposed to preclude.

25 WITNESS MORRIS: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE MCDADE: It identifies it.

2 WITNESS MORRIS: As far as meeting the
3 permit condition, what you would do is to monitor
4 the tank failure itself or the possibility of the
5 tank failure to make sure that there is no release
6 instead of monitoring the ground to find out that
7 you had one.

8 JUDGE WARDWELL: How does the tank get
9 filled if it's an outside tank?

10 WITNESS MORRIS: Well, if you have an
11 outside tank it's filled from the radwaste system
12 inside, the components inside.

13 JUDGE WARDWELL: But how does it get
14 from the outside to the inside?

15 WITNESS MORRIS: It's generally piped.

16 JUDGE WARDWELL: Is that pipe - are
17 there any pipes that are below - are there any pipes
18 that are not visible?

19 WITNESS MORRIS: I think if you had
20 buried pipes and you had to meet this permit
21 condition, you would have to put guard pipes to
22 ensure that if there were any leaks that they would
23 be contained.

24 JUDGE WARDWELL: And your definition of
25 a guard pipe is a pipe within a pipe?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS MORRIS: That's correct.

2 JUDGE WARDWELL: And what -

3 WITNESS MORRIS: I'm sorry?

4 - JUDGE MCDADE: A subterranean gutter?

5 JUDGE WARDWELL: A pipe within a pipe.

6 What assurances are you that the guard pipe will not
7 leak?

8 WITNESS MORRIS: Well -

9 JUDGE WARDWELL: Whatever caused the
10 original pipe to leak may cause this one.

11 WITNESS ZINKE: George Zinke with the
12 applicant. I think we are - we're going down a
13 strange path because the Early Site Permit focused
14 on site issues and the questions that Marvin is
15 trying to answer have to do with what are the
16 features of the design, which is something that gets
17 specified within the, like a design certification
18 licensing process. There is an interface, so when
19 the staff has presented this license condition, we
20 understand the permit condition places on us the
21 requirement to pick a design that meets - that the
22 staff has determined has met their design
23 requirement. So the requirements of that design and
24 how the staff reviews what are the specific
25 requirements in order to meet the staff's words get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reviewed when the staff reviews the design. It
2 doesn't get - it's not associated with the Early
3 Site Permit.

4 JUDGE WARDWELL: Right, and I certainly
5 understand that. And the reason I was asking these
6 questions leads us into Hearing Issue B because the
7 hypothesis, to just give you a preview attraction of
8 what's going to come next, is that the hypothesis
9 states that there is - to achieve this condition, to
10 assure that this condition is met, there will be
11 groundwater monitoring. Because that's the only way
12 to assure that this condition is met. Now that's a
13 hypothesis. Let's refute it. So don't look at me
14 cross-eyed and say you're nuts. The point that I'm
15 raising, this doesn't say it's my hypothesis. It's
16 our straw man one that we need something on the
17 record to say this is a lousy hypothesis. But the
18 lousy hypothesis I am presenting says there will be
19 groundwater monitoring because there is no way to
20 design absolutely to assure that as is stated in the
21 permit condition precluding any and all. That's an
22 absolute, that's not a gray area. Therefore, the
23 only way to assure that the applicant's meeting that
24 is there's going to be groundwater monitoring. Now,
25 this site, to continue on with our hypothesis, has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 such adverse existing conditions in the groundwater
2 that a person is unable to detect any type of
3 accidental release from the radwaste system. That's
4 where we're going to go with Issue B, and that's why
5 I was leading this question of it seems - I do not
6 know of any design that precludes this from ever
7 happening. And so I want to get some support for
8 where that comes back to at an Early Site Permit
9 unless you've characterized what the existing
10 contamination or lack of contamination is, i.e., the
11 baseline conditions for the ESP plant. You don't
12 know where you're at at this point whether or not.
13 You could have an adverse situation at that plant
14 right now that would preclude us from using
15 groundwater monitoring in regards to meeting this
16 permit condition.

17 MS. SUTTON: Given that prelude, Your
18 Honor, to Issue B it seems that the first part of
19 your hypothesis was just addressed through the line
20 of questioning between Judge McDade and Mr. Bagchi.

21 JUDGE WARDWELL: Right, it is. I'm
22 satisfied, I just wanted to address why I understood
23 what he was saying.

24 MS. SUTTON: I understand.

25 JUDGE WARDWELL: That doesn't refute why

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 we're at - why we went under A anyhow, and we
2 haven't even gotten into B yet. I just wanted to
3 give you a highlight of where I was going with this.
4 I am not after what is your design there at the COL
5 stage. I am just trying to give a flavor for what's
6 there, why there's some potential for it and why
7 someone could easily make that hypothesis at the ESP
8 stage to say you've got an unmonitorable site
9 because there are sites that are unmonitorable, not
10 necessarily power plants, but there's lots of other
11 environmental sites where people - there are other
12 sites where people wanted to build something that
13 are unmonitorable and it precluded that construction
14 because you can't tell whether or not the site is
15 performing as you wish it to. That's where I'm
16 going with it.

17
18 WITNESS ZINKE: Yes sir, and I
19 understand where you're headed. The part of the
20 hypothesis that doesn't fit with what we have to do
21 as the applicant with the license condition is that
22 I do not have the choice of saying that this design
23 plus ground monitoring meets that license condition.
24 I don't have that option in order to say that meets
25 the license condition. The license condition says

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the design has to prevent. Ground monitoring can't
2 prevent. So I cannot add any form of ground
3 monitoring and say well now I meet that license
4 condition.

5 JUDGE WARDWELL: Right, but the
6 regulatory staff, in order to comfort themselves
7 that you are meeting that, besides just your word,
8 oh I promise and here's my design, that concrete
9 will never leak. Well, we know concrete leaks.
10 Those liners in the detention pump will never leak.
11 Well, we know they leak. So let me just finish
12 this. Go ahead.

13 JUDGE MCDADE: I was just going to say,
14 for our purposes at the Early Site Permit stage, the
15 question is whether or not there has been an
16 adequate characterization of the existing conditions
17 so that if there is an accident subsequently, that
18 will be determined. And whether or not it is
19 appropriate for us to have a condition for
20 additional characterization of the existing
21 conditions as a condition of the Early Site Permit.
22 Am I correctly interpreting where we are on this?

23 JUDGE WARDWELL: Well, we aren't there
24 yet because we're not in Issue B yet. So that's
25 where we'll go, but not to the degree you think -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE TRIKOUROS: You've indicated that
2 the staff will review the design of the radwaste
3 system. It will review it at the COL stage,
4 possibly as part of the DCD, and determine for
5 themselves. I'm assuming it'll involve some sort of
6 an engineering plus probabilistic risk analysis,
7 possibly procedural evaluation, to assure themselves
8 that the design criterion is met. That's what I
9 think I heard. It will be evaluated at that level.

10 With respect to leakage, what I also
11 heard was that level indications on tanks, possibly
12 radwaste indication, rad monitoring indications
13 inside of buildings, et cetera. Some design method
14 will be utilized to give - for the staff to have
15 comfort that they're meeting that permit condition.
16 That's what I heard.

17 I also heard that as a result of that
18 there will be no onsite characterization either at
19 the ESP stage or at the COL stage. I asked the
20 question regarding the lessons learned task force
21 and I didn't get an answer to that question. I
22 understand that those recommendations are not yet
23 haven't been promulgated into formal requirements,
24 but I'm simply asking that it is likely, given the
25 circumstances, that they may be. Is there anything

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that can be done as part of this Early Site Permit
2 to capture that, and is there any reason to do that
3 as part of the Early Site Permit? Because we're
4 talking about systems, not radwaste.

5 WITNESS KLEMENTOWICZ: Yes, this is
6 Steve Klementowicz. I worked on the lessons learned
7 task force report. I wrote the health physics
8 regulatory requirement section. You threw out a lot
9 of items that we addressed in the lessons learned
10 task force. Let me just start by saying our
11 conclusion about the regulatory requirements. There
12 are no existing regulatory requirements that require
13 either an ESP or a currently operating facility to
14 have groundwater monitoring to detect inadvertent
15 releases. That was our conclusion. So bringing
16 that forward to an ESP, there are no regulatory
17 requirements that the staff could impose to require
18 onsite groundwater monitoring. And you're correct,
19 the recommendations in the task force report were
20 recently the subject of a Commission vote. And it
21 was decided that those recommendations would not be
22 subject to Commission follow-up, that it would
23 remain within the program office to appropriately
24 address those recommendations. So the staff does
25 not know or have a sense or feeling if those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 recommendations will become regulations or not.

2 JUDGE TRIKOUROS: So what you're saying
3 is the ESP should not address it at all?

4 WITNESS KLEMENTOWICZ: I'm saying that
5 the staff has no regulations to back up if it were
6 to say onsite groundwater monitoring is a permit
7 condition. I have nothing, no legal regulatory
8 basis to cite for that. Our existing - in my
9 testimony I did discuss that the radiological
10 environmental monitoring program, the REMP, is
11 primarily an offsite monitoring program. There is a
12 provision that if the licensee is using any onsite
13 water for drinking water purposes or for their
14 personnel, then that water must be included in the
15 REMP. Very few operating facilities actually
16 perform onsite water monitoring. Most have chosen
17 to import water from offsite. In discussion with
18 the applicant and review of their environmental
19 monitoring report, they do in fact have an onsite
20 well. But I could not even venture to guess that
21 that would be able to adequately pick up any
22 inadvertent releases from any of the radwaste
23 systems.

24 JUDGE TRIKOUROS: It sounds like you're
25 saying there is no basis for including any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 discussion of this subject in the ESP.

2 WITNESS KLEMENTOWICZ: That's correct,
3 that's what I'm saying.

4 JUDGE WARDWELL: And are you saying that
5 in regards to the need to characterize the aquifer
6 both in regards to existing impacts from the
7 existing plant, background let's just call it now
8 existing water quality and transport mechanisms?

9 WITNESS KLEMENTOWICZ: This is Steve
10 Klementowicz. What I'm saying is, well, I do not
11 have any knowledge or expertise in that area. What
12 my expertise is in effluent monitoring and
13 environmental monitoring. The issue you're
14 addressing is the quality of the aquifer and I only
15 deal with the radiological releases and the surveys
16 and monitoring required to make a dose assessment
17 from them. So I can't address that.

18 JUDGE TRIKOUROS: Let's assume that this
19 plant has a liquid radwaste tank failure that it's
20 an outdoor tank, that somehow it gets into the
21 groundwater by virtue of some operator error perhaps
22 or some unanticipated situation which would then be
23 an event that was outside the design basis of the
24 plant. Do I assume then that what would happen
25 there is that an analysis would be done of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 radiological effects of that release and a report
2 issued, et cetera, that that would be basically the
3 implications of that?

4 WITNESS KLEMENTOWICZ: Let me give you
5 the larger picture for outside tanks. There is a
6 technical specification, a condition which limits
7 the quantity of radioactive material that can be
8 contained in that outside tank. The basis for that
9 control is to limit the concentrations of
10 radionuclides that they will be less than the
11 effluent concentrations contained in Table 2 of
12 Appendix B to 10 C.F.R. Part 20. Should there be an
13 uncontrolled release of that tank so that the
14 concentrations would not exceed those Appendix B
15 values at the unrestricted area. So I have a little
16 bit of a differing opinion here. The NRC has a tech
17 spec condition that gives some credit that these
18 tanks may have an uncontrolled release and therefore
19 we have limited the potential health impact by
20 limiting the amount of radioactive material that can
21 be contained in those outside tanks to keep it
22 within the limits of 10 C.F.R. Part 20. So that's
23 the basis for those tanks.

24 As far as the inadvertent release, 10
25 C.F.R. Part 20, 20.1501 requires surveys and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 monitoring commensurate with the radiological hazard
2 of a discharge. And we have practical experience,
3 if you obviously have read the lessons learned task
4 force report, of numerous facilities that have
5 leaked from their spent fuel pool or have had a
6 radioactive waste line corrode and leak into the
7 ground. Once that becomes - once that information
8 appears, the licensee is required pursuant to
9 20.1501 to perform surveys and radiological
10 monitoring to assess, evaluate and to see if there
11 is any dose impact to workers and to members of the
12 public.

13 JUDGE WARDWELL: This is onsite
14 monitoring we're talking about.

15 WITNESS KLEMENTOWICZ: Yes.

16 JUDGE WARDWELL: And would that include
17 groundwater monitoring?

18 WITNESS KLEMENTOWICZ: Yes.

19 JUDGE WARDWELL: If in fact that it's
20 unknown what the existing was before this would
21 happen, how would you know whether it was coming
22 from the recent - and again, rather than a failure,
23 I like to just use, you know, small leakage out of
24 this over a long period of time and all of a sudden
25 you're concerned about. Isn't there a possibility

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that you'd be unable to discriminate between what
2 was there before and what has occurred from this
3 recent incident?

4 WITNESS KLEMENTOWICZ: Yes.

5 JUDGE WARDWELL: And how do we address
6 that - and isn't that a fundamental site
7 characteristic that in fact if the existing
8 groundwater was in such shape that it would preclude
9 what you just mentioned as what would take place if
10 there was indications of a potential problem, a
11 potential release from an outside radwaste system,
12 that it would preclude this site from being an
13 acceptable site.

14 JUDGE TRIKOUROS: Let me just interrupt.
15 Is groundwater monitored offsite?

16 WITNESS KLEMENTOWICZ: Yes. It's a
17 requirement as part of the REMP.

18 JUDGE TRIKOUROS: All right. So the
19 only indication you would have with respect to Judge
20 Wardwell's question would be offsite, changes in the
21 offsite monitoring data?

22 WITNESS KLEMENTOWICZ: And there would -
23 if the - well, let's talk about currently operating
24 plant. If they use the groundwater, onsite
25 groundwater for any purposes for their personnel,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 then that must be included in their monitoring
2 program. So if they did detect licensed radioactive
3 material, they would have some indication that
4 something is unusual.

5 Going back to the regulation 20.1501,
6 yes, that is an after the fact once you discover
7 that there has been a leak or that you have
8 radioactive material where you didn't expect it, and
9 that's where the regulation kicks in that you shall
10 do this monitoring and evaluation. The lessons
11 learned task force report did acknowledge that there
12 could be inadvertent discharges that could be
13 undetected until they reached the unrestricted area.
14 And that's why the recommendations were put in that
15 the NRC needs to consider additional onsite
16 groundwater monitoring. But as I say, as of today
17 there is no regulatory requirement for us to impose
18 that condition.

19 JUDGE TRIKOUROS: There's also no
20 regulatory requirement to have radwaste systems
21 designed to preclude any and all leakage.

22 WITNESS KLEMENTOWICZ: That's not an
23 area that I'm experienced in. I deal with it after
24 it leaks.

25 JUDGE WARDWELL: I was trying to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 formulate a question that says - that asks you
2 whether in your professional opinion, what would be
3 the difference if in fact the permit condition said
4 instead just what those limitations were in 20
5 whatever this is, 10 C.F.R. 20; whatever that -
6 where you say it's below the effluent limitations.
7 That to me seems more realistic than saying preclude
8 any and all, and I just, I don't know why the "any
9 and all" is there. It seems to make more sense that
10 you'd do it in regards to just what's required by
11 those regulations for those discharge. That's all
12 you can store out there, so that's what you're
13 allowed to discharge if there's an accidental
14 release.

15 WITNESS KLEMENTOWICZ: If I may add that
16 our systems and components individual who was on the
17 task force also made some conclusions that the
18 existing systems and components, the piping are
19 essentially commercial grade. And they have leaked,
20 and there's no NRC requirements that would basically
21 require safety grade material to prevent the
22 underground radwaste line from leaking. Again, so
23 those were some of the recommendations that
24 increased monitoring or leak detection systems, the
25 pipe within a pipe such as they have for spent fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 pools. They have the tell-tales. And that was a
2 situation at the Salem plant where the licensee, the
3 water got around and it was not visible through the
4 tell-tales and seeped out. So the recommendations
5 are that, you know, some of the systems have
6 increased monitoring to see if there is a leak. But
7 again, those are just recommendations. What will
8 happen to them, I do not know.

9 JUDGE WARDWELL: The task force didn't -
10 wasn't a motivator for the wording that's in this
11 particular permit condition or have anything
12 associated with that type of thing?

13 WITNESS BAGCHI: It was after the fact,
14 Your Honor. This is Goutam Bagchi. So the task
15 force lessons learned was not a factor in getting
16 these words. But something bothered me about what
17 you said. Isn't it better to have the requirements
18 of minimum radioactive inventory in the tanks and so
19 forth. There is a technical specification
20 requirement. This is technical specification.
21 Those requirements are there. So why would one add
22 something that is not necessary? It will come as a
23 result of any operating license granted as a result
24 of construction of a new plant.

25 The other thing that you said concerned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 me a little bit - or let me just elaborate why there
2 was any and all. "Any" is considering leakage from
3 the radwaste treatment facility itself and "all"
4 meaning the storage locations around the yard. So
5 "any and all" made sense at the time when we wrote
6 the condition.

7 JUDGE TRIKOUROS: Could you say that
8 again? That's interesting.

9 WITNESS BAGCHI: My thought was that
10 "any" would come from radwaste treatment system
11 itself, so we want to preclude that. Radwaste
12 treatment system would be robust and would be
13 designed to preclude any release. That is the basic
14 tenet and the philosophy of Reg Guide 1.143. As a
15 matter of fact, it goes on further to say that if
16 you design your facility to this regulatory
17 guidance, then you achieve as low ALARA, as low as
18 reasonably achievable. So given that philosophy, it
19 was - this permit condition was in sync with that
20 thinking.

21 And "any" came from the fact that, well,
22 if we have radiation treatment system we should not
23 allow any kind of release from the radwaste
24 treatment system. And "all" meaning if there were
25 distributor holding tanks out there in the yard and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 so forth, so "all" was a catch-all word to capture
2 things like that.

3 JUDGE TRIKOUROS: What reg guide did you
4 say, by the way?

5 WITNESS BAGCHI: 1.143.

6 JUDGE WARDWELL: Let me just - and I
7 think that's appropriate to have that as a goal and
8 as a guideline for focusing your design that you can
9 then compare the applicant's design to this goal.
10 But I think there's a monumental leap when it's now
11 transferred into a permit condition. And that's
12 what I'm having a hard time still - we're getting
13 there, but we needed to talk about this some more in
14 regards to how it relates to whether or not the site
15 is characterized sufficiently to allow this to be a
16 reasonable, practical type of permit condition.

17 WITNESS BAGCHI: Oh, I have no doubt in
18 my mind whether or not the site is suitable for
19 siting a new power plant. It is eminently suitable.
20 I have not found any impediment, as I said at least
21 a couple of times during my statements, that it has
22 no intrinsic impediment to siting a plant. You
23 know, irrespective of what your hypothesis said,
24 there is a nuclear power plant that's producing
25 power safely operating for over 20 years or so. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was involved in the plant when it was being built.
2 In a different capacity, not in hydrology, but
3 nevertheless I visited the plant, I did the plant
4 site tour and I have kept informed about how safely
5 the plant has run.

6 JUDGE WARDWELL: Well, and that's - it's
7 the presence of that plant that drives this line of
8 questioning that we'll address once we get to Issue
9 B.

10 JUDGE MCDADE: Perhaps also if I could
11 interject right now at this point in time, we're
12 sort of floating from A to B. I think we've gone
13 past the brink and we're well into B. We are then
14 going to move on to D. What I wanted to just
15 mention to both the staff and the applicant, if you
16 have witnesses who you feel that you can release at
17 this point in time and they wish to leave. We're
18 not trying to throw anybody out. If you want to
19 stay, please stay. All I'm saying is that if you're
20 not finding this as fascinating as we are and you're
21 not going to be offering further testimony today on
22 Hearing Issue B or Hearing Issue D and you want to
23 go and do something else, to just allow you the
24 opportunity right now to think about that. And if
25 you want to tell any of your witnesses they can go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with the understanding we're going to move forward
2 to B and then to D today and that should take us to
3 the end of the day. Do you want to take a moment to
4 discuss this?

5 MS. SUTTON: No, Your Honor, we're ready
6 to proceed with B.

7 JUDGE MCDADE: No, but my question is
8 did you want to discuss whether or not any of your
9 people you want to release, or would you prefer to
10 keep them here?

11 MS. SUTTON: On behalf of the applicant
12 we do not want to release them. They will stay
13 here.

14 (Laughter)

15 JUDGE MCDADE: And they knew that
16 beforehand, right?

17 MS. SUTTON: Yes, they did.

18 MR. RUND: I'll leave it up to the
19 witnesses. I mean, I think almost everybody up
20 there would be up there for B or D. If they are
21 only involved in D they could step down and come
22 back. It makes no difference to me.

23 JUDGE MCDADE: No, I just want to make
24 sure that the witnesses here don't say 'Why the heck
25 was I sitting there the last two hours, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 when I could have been out doing something more
2 productive' in their mind.

3 JUDGE WARDWELL: Are you through with A?

4 JUDGE TRIKOUROS: I am through with A
5 for now.

6 JUDGE WARDWELL: So we want to sit the
7 witnesses for B now.

8 JUDGE MCDADE: Well, I mean I think all
9 the witnesses for B have pretty much wandered in
10 during the course of the proceeding. It is a
11 question now not of seating new people, but
12 releasing - and I hate to use the word "old" because
13 he'll interrupt and say "old witnesses" just like
14 "old aquifers" are inappropriate. But the witnesses
15 who were testifying earlier. That's all. Let's
16 move ahead. Doesn't seem like anybody wants to
17 leave. If they do, they're free to.

18 Well actually, some of the people that I
19 see getting up are witnesses on Exhibit D and B. So
20 you know, before you let them go, make sure that
21 you've got your witnesses on B and D.

22 MR. RUND: I'm sorry, are we going to go
23 right from B to D so if somebody's on D you'd like
24 them to stay up there?

25 JUDGE MCDADE: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. RUND: Okay. I'm sorry then.

2 JUDGE MCDADE: I mean they don't have to
3 stay right there in the box.

4 MR. RUND: Oh yes, okay.

5 JUDGE MCDADE: They can wander around,
6 but -

7 JUDGE WARDWELL: They need to be here.
8 I think it would be better if they weren't sitting
9 there during B so it doesn't get confusing.

10 MR. RUND: Mr. Bagchi and Mr.
11 Klementowicz are our witnesses for B so if they
12 could please stay put and everybody else.

13 WITNESS BAGCHI: Lance can stay also?

14 MR. RUND: Yes, I think if he'd like to.

15 WITNESS BAGCHI: Well, I might need his
16 help.

17 MR. RUND: Absolutely then.

18 JUDGE MCDADE: Okay. That little
19 administrative matter took longer than I thought it
20 was going to, but I guess we're ready to go ahead.
21 And let me ask the witnesses who are here on B who
22 have been told they can't go, do you need a couple
23 of minutes before we get started or are you ready to
24 just soldier on?

25 WITNESS KLEMENTOWICZ: I'm ready.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 JUDGE MCDADE: Everybody over there on
2 the staff?

3 WITNESS BAGCHI: Yes, Your Honor.

4 JUDGE MCDADE: And the applicant's
5 witnesses?

6 MS. SUTTON: We're ready, Your Honor.

7 JUDGE MCDADE: Okay. And just as an
8 aside, and you know, well, let's just move ahead.
9 Okay. Roll them.

10 JUDGE WARDWELL: And I think the
11 hypothesis is beaten to death here, but just quickly
12 -

13 JUDGE MCDADE: The first hypothesis, but
14 we're talking about, you know, only a particular
15 kind of release and site characterization. If you
16 wish to kick further down the field?

17 JUDGE WARDWELL: I'll reiterate it and
18 maybe say it in a different fashion. It is a fact
19 that there's an existing plant there and raising the
20 issue of whether it's of interest to determine what
21 is the existing groundwater quality for use in
22 determining whether or not this is a suitable site
23 under the hypothesis that there could be such
24 adverse impacts from the existing plant, however
25 unlikely, that need to be refuted to assure that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 anything that's done in the future to verify that
2 Permit Condition 2 is being achieved is not
3 preempted from being achieved once we get to the COL
4 stage. So with that in mind I guess I'll just ask
5 the question, do any of the panel members know of
6 any water quality data at the site that would
7 indicate - let me just ask, is there any water
8 quality data from the power plant, the power block
9 area, to define or even indicate what types of
10 constituents might be in the groundwater that exists
11 to date.

12 WITNESS KLEMENTOWICZ: This is Steve
13 Klementowicz and I have, and I guess we'll have to
14 enter this into the file, the 2005 data from the
15 Annual Radiological Environmental Operating Report
16 for the Grand Gulf Nuclear Station. And as I
17 mentioned earlier, they do onsite groundwater
18 monitoring. So there is data in this report on the
19 radionuclide or lack of radionuclides in this
20 groundwater. So that data is known.

21 JUDGE WARDWELL: Do we have a plant view
22 of where those wells are located and can you comment
23 on what is the water quality based on that? You're
24 saying you have to submit this as an exhibit. It
25 hasn't been submitted yet?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS KLEMENTOWICZ: Yes, it will have
2 to be submitted, and there are figures that outline
3 the sample collection sites.

4 JUDGE MCDADE: How long would it take
5 you to lay your hands on this data in a hard copy
6 form?

7 WITNESS KLEMENTOWICZ: It was handed to
8 me. But however, the data is in the NRC's ADAMS.
9 It is a public document. And by just typing in the
10 name of the station and the report it would come
11 right up.

12 JUDGE MCDADE: One of the things about
13 judges is we don't type stuff in, we just ask people
14 to give it to us.

15 WITNESS KLEMENTOWICZ: Right, and I will
16 enter this into the record.

17 WITNESS EVANS: Excuse me. Lori Evans
18 for the applicant. We do not have data that is that
19 current, but we do provide similar data within the
20 ESP application. And those have already been
21 submitted as exhibits.

22 JUDGE MCDADE: Do you have the exhibit
23 number?

24 WITNESS EVANS: Yes. The map is SERI
25 Exhibit 3. The exact well location is not marked on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 here. We do have - we have a modified version of
2 this figure that will show the well locations.
3 Essentially you see the water tank labeled on this
4 map and the wells are located just to the west of
5 that, just outside of the setback line boundary.

6 JUDGE MCDADE: Okay. Before I lose
7 track of that, I would want to note when we next
8 break if you could give that data to - I need to get
9 closer to the microphone. I've been telling other
10 people to do it and I've been not doing it myself.
11 I apologize. But the next time we break if you can
12 give that data to Mr. Rund and please have that then
13 marked as Staff Exhibit 46, get the appropriate
14 copies made and hand it out. But at this point we
15 can proceed.

16
17 (Whereupon, the above-
18 referred to document was
19 marked as Staff Exhibit No.
20 46 for identification.)

21 JUDGE WARDWELL: Are these the same
22 wells that you have data for, or are they other
23 supplemental wells that you have data for also?

24 WITNESS KLEMENTOWICZ: They should be
25 the same wells unless the applicant licensee has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 changed the locations.

2 WITNESS EVANS: They are the same wells.
3 Sometimes the samples I believe are taken from the -
4 actually from the water distribution system. And we
5 do have a table that provides the sampling
6 locations. That is SERI Exhibit Number 16. And
7 then monitoring results are provided in SERI Exhibit
8 Number 18.

9 JUDGE WARDWELL: And how many different
10 locations in the power block area do we have water
11 quality data from?

12 WITNESS EVANS: Pardon me, can you
13 repeat your question please?

14 JUDGE WARDWELL: How many different
15 locations within that power block area do we have
16 samples and water quality data from?

17 WITNESS EVANS: None, Your Honor, just
18 from these wells that are immediately adjacent to
19 it.

20 JUDGE WARDWELL: Could you just point
21 out right behind you. Just point out right there
22 where those wells are that you're speaking of? And
23 that's the only location. So there's - when you
24 said wells, there must be several at the same spot?

25 WITNESS EVANS: That's correct, Your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Honor. There are two wells that are actively in use
2 currently.

3 JUDGE WARDWELL: Okay. And just so the
4 record is clear you pointed to the far left side of
5 the exhibit.

6 MS. SUTTON: Your Honor, we have an
7 additional exhibit that indicates the wells that Ms.
8 Evans is referring to and we would like to enter
9 them into the record as SERI Exhibit 31. We'll
10 provide you hard copies. Mr. O'Neill will provide
11 them stamped.

12 (Whereupon, the
13 above-referred to document
14 was marked as SERI Exhibit
15 No. 31 for identification.)

16 JUDGE MCDADE: You have no objection?

17 MR. RUND: We have no objection.

18 JUDGE MCDADE: Okay. It's received.

19
20 (Whereupon, the document
21 previously marked as SERI
22 Exhibit No. 31 for
23 identification was admitted
24 into evidence.)

25 JUDGE MCDADE: And I also should note we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 made reference to Exhibit 46. We'll handle it the
2 way we did the earlier exhibits. I'm going to admit
3 it at this point in time.

4
5 (Whereupon, the document
6 previously marked as Staff
7 Exhibit No. 46 for
8 identification was admitted
9 into evidence.)

10 JUDGE MCDADE: When we have a break,
11 give the counsel for SERI an opportunity to review
12 it. If they have any objection to it and are
13 considering it, just note that and it can be
14 withdrawn at a later point in time. But for now it
15 is admitted as Exhibit 46 and the witness can refer
16 to it subject to it being stricken later if there's
17 an objection.

18 MS. SUTTON: There's no objection.

19 JUDGE WARDWELL: Would you comment on
20 the actual water quality results?

21 WITNESS KLEMENTOWICZ: This is Steve
22 Klementowicz. From the 2000 report that I have
23 there were no detectable radionuclides observed at
24 this well.

25 WITNESS MORRIS: This is Marvin Morris

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 for the applicant. I reviewed the REMP reports for
2 the last eight years at SERI and for all of the
3 years for each annual report there was no detectable
4 radiation in the water wells either onsite or
5 offsite.

6 JUDGE WARDWELL: Have you looked at a
7 rough estimate of what the potential travel times
8 are from the existing plant to say that, yes, if
9 there was problems it should have reached this
10 particular location by now?

11 WITNESS MORRIS: I have not looked at
12 those.

13 JUDGE WARDWELL: Has anyone?

14 WITNESS MORRIS: We don't have that with
15 us.

16 JUDGE WARDWELL: And your testimony is
17 that there is - everything's below detection levels.

18 WITNESS MORRIS: That is correct.

19 JUDGE WARDWELL: Do those tables show
20 what the detection limits are? Because I know
21 sometimes they can vary widely.

22 WITNESS MORRIS: Yes, it's done on an
23 isotopic basis, the isotopes they're looking for,
24 and it gives the lower limit of detection and what
25 they measured. But what they measured was all LLD.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS KLEMENTOWICZ: This is Steve
2 Klementowicz, and yes, the report I have, it does
3 indicate the LLDs that were used for each
4 radionuclide.

5 JUDGE WARDWELL: Hang on just a second.
6 Take a quick nap while I'm floundering here. So
7 with this supplemental testimony, is it fair to say
8 that in response to Question - well, in the Answer 5
9 on Page 5 of Issue B where the staff says that they
10 did not receive any data in the SERI application on
11 radiological conditions at the site, we now can say
12 that at least we have a sample from one well, one
13 location through a couple of wells with radiological
14 data.

15 WITNESS KLEMENTOWICZ: Steve
16 Klementowicz. Yes, that's correct.

17 JUDGE MCDADE: Is there anything in that
18 data that gives you pause about the suitability of
19 the site?

20 WITNESS KLEMENTOWICZ: Steve
21 Klementowicz. No. There's no - the data is good.
22 And by "good" I mean there were no detectable
23 radionuclides of plant origin.

24 JUDGE WARDWELL: In regards to Answer 7
25 on Page 6, it stated that the NRC has experiences

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 with licensees who have performed monitoring and
2 using that as one of your bases for why it's not a
3 particular issue or whatever. But could you
4 elaborate more on - do you have any experience with
5 existing sites where they're proposing a new site in
6 addressing any situation like we have here?

7 WITNESS KLEMENTOWICZ: You're asking the
8 question - this is Steve Klementowicz - you're
9 asking the question if there are other ESP
10 applicants that I'm aware of that have had
11 inadvertent leaks or are proposing increased onsite
12 monitoring? Is that the question?

13 JUDGE WARDWELL: You say in your
14 testimony in A-7 that hypothetical inadvertent
15 radiological releases from the proposed new plant
16 could be separated from historic impacts through a
17 program of radiological surveys and specialized
18 monitoring.

19 WITNESS KLEMENTOWICZ: Yes, that's
20 correct, and the practical experience we have is for
21 multi-unit sites. Once they discovered an
22 accidental leak or spill, the licensee did extensive
23 surveys and monitoring, did excavations, installed
24 groundwater monitoring, and basically used that to
25 backtrack to the source of the leak. A particular

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 plant that had a - suspected that the leak came from
2 a spent fuel pool did very extensive groundwater
3 monitoring to trace it back to the source. So my
4 discussion here related that once they know that
5 there is a leak, whether it's a single-unit, multi-
6 units, licensees can through extensive and
7 specialized monitoring determine which particular
8 unit did the leak, or that the leak occurred. But
9 your previous discussions were relating, you know,
10 before the fact, and that's where I stated we have
11 no regulatory requirements before the fact. It's
12 after the fact, once they become aware of it.

13 JUDGE TRIKOUROS: You're saying that a
14 proper design which includes instrumentation to
15 determine that there has been a leak would be
16 sufficient to implement an onsite monitoring program
17 that would provide very valuable information
18 regarding the quantity of leakage and the location
19 of the leakage?

20 WITNESS KLEMENTOWICZ: Well, let me not
21 take all that credit. The lessons learned task
22 force report, the collective all of us on the task
23 force discussed all of the recommendations. And
24 when we looked at systems components, NRC
25 requirements, surveys, monitoring capabilities, it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 was our opinion and our recommendation that if the
2 NRC put out guidance and requirements to require
3 increased or required onsite monitoring, that then,
4 you know, an inadvertent leak would be detected well
5 before it went into the unrestricted area. So they
6 would know that they had a leak and could work to
7 fix it, but it would still be onsite and so it would
8 not get into the public domain.

9 JUDGE TRIKOUROS: But wouldn't it be
10 better to have a more direct indication? For
11 example, if you did have a guard pipe around
12 underground radwaste piping and radiation detection
13 capability within that guard pipe, that you would
14 immediately know if there's a leak occurring before
15 it even gets out of the guard pipe, that in essence
16 - knowing it at that point seems to me would be more
17 useful.

18 WITNESS KLEMENTOWICZ: This is Steve
19 Klementowicz. I'm looking through the conclusions
20 of the systems and components section and - from
21 what I read here it looks like, yes, they do
22 recommend improved maintenance trending and use of
23 leak detection and monitoring systems along with
24 increased quality grade of the piping. Obviously in
25 a health physics perspective you want to contain the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 radioactive material at the source. That's always
2 the preferred option.

3 JUDGE TRIKOUROS: Some of that might
4 actually get implemented in the process of
5 implementing Permit Condition 2.

6 WITNESS KLEMENTOWICZ: Yes, that would
7 be my opinion.

8 JUDGE WARDWELL: How many sites do you
9 know of where there is multiple power plants there
10 where they're able to discriminate the actual source
11 through these post investigations?

12 WITNESS KLEMENTOWICZ: Approximately
13 half a dozen.

14 JUDGE WARDWELL: Okay, so a significant
15 number, not just one or two.

16 WITNESS KLEMENTOWICZ: Correct, yes.

17 JUDGE WARDWELL: And is that what you
18 mean by your first sentence to Answer 7 in regards
19 to this program of radiological surveys and
20 specialized monitoring. Is that again all post
21 monitoring?

22 WITNESS KLEMENTOWICZ: Yes.

23 JUDGE WARDWELL: Okay. At the very last
24 sentence in that paragraph, or well let me read up a
25 bit above that. It says, in addition there is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 requirement in 10 C.F.R. 50.36(a) to submit an
2 annual report that specifies a quantity of each of
3 the principal radionuclides released to unrestricted
4 areas in liquid and gaseous effluents. However, the
5 regulation does not required the data to be reactor-
6 specific. As a matter of practice, licensees do a
7 best effort to apportion the radioactive effluents
8 to each reactor unit. Do you have any idea what's
9 involved with that apportioning effort?

10 WITNESS KLEMENTOWICZ: Yes, on multi-
11 unit sites, some facilities - there's a green light
12 on. Okay.

13 JUDGE WARDWELL: I was sitting too
14 close. Everyone heard my heavy breathing and
15 thought - well, I don't know what you thought -

16 WITNESS KLEMENTOWICZ: Okay, there we
17 go. So multi-unit sites sometimes share a common
18 discharge point. However, when you go follow that
19 trail of radwaste systems back to the individual
20 reactor, there are separate radwaste gas storage
21 tanks, separate liquid radioactive storage tanks
22 specific to each unit. As part of the discharge
23 process, the licensee knows what is in each tank.
24 So they keep an inventory of the radioactive
25 material in each tank and when they go to make a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 discharge to the environment they have to sample,
2 analyze and run calculations on the projected dose
3 from each unit, from each tank. So they do have
4 very unit-specific information. And so when they
5 submit this annual effluent release report, all
6 along each unit has been tracking the amount of
7 radioactive material released and the resultant -
8 the dose from those discharges. Which follows with
9 the tech spec requirement to keep effluents ALARA in
10 accordance with Appendix I to Part 50 which is unit-
11 specific. So in order to demonstrate compliance
12 with that requirement, they do have to be able to
13 separate, you know, be able to measure and quantify
14 the radiological effluent discharges per unit to
15 comply with Appendix I.

16 JUDGE TRIKOUROS: These are not
17 inadvertent. We're talking normal -

18 WITNESS KLEMENTOWICZ: These are the
19 routine, normal effluent discharges.

20 JUDGE WARDWELL: All those last
21 sentences deal with just the license discharge.

22 WITNESS KLEMENTOWICZ: That's correct.

23 JUDGE WARDWELL: I think I just have -
24 no, I've got two more questions. I just want to
25 verify that under Issue A, Answer A-9 on Page 13,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 the first full paragraph on Page 13 says a
2 groundwater sample is taken at two wells, and again,
3 isotropic and tritium analysis are performed. Those
4 are the wells that we're speaking of?

5 WITNESS KLEMENTOWICZ: Yes. This is
6 Steve Klementowicz. Those are the REMP, the
7 Radiological Environmental Monitoring Program
8 routine wells.

9 JUDGE WARDWELL: And do you concur, as
10 the applicant?

11 WITNESS EVANS: This is Lori Evans for
12 the applicant. One sample is taken onsite, one well
13 location, and one well location is offsite.

14 JUDGE WARDWELL: But those were the ones
15 that, sentence refers to what we were talking about
16 about a half hour ago -

17 WITNESS EVANS: Correct, Your Honor.

18 JUDGE WARDWELL: - we were pointing out
19 the wells. I just wanted to confirm that.

20 WITNESS KLEMENTOWICZ: That's correct.

21 JUDGE WARDWELL: Then I think I'll ask
22 one more question and that is in your professional
23 opinion, do you believe there is reasonable
24 expectations that a post investigation would be able
25 to discriminate between power plants, duplicate -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 multiple power plants at a given site if there was
2 an inadvertent release.

3 WITNESS KLEMENTOWICZ: This is Steve
4 Klementowicz. Yes, I do believe that, and
5 experience and the data we have shows that to be
6 true.

7 JUDGE WARDWELL: Thank you. Thank all
8 of you. Does the applicant have anything they want
9 to add into this mix in regards to what we've been
10 talking about?

11 MS. SUTTON: We have nothing further,
12 Your Honor.

13 JUDGE MCDADE: Okay, I think -

14 MS. SUTTON: One administrative matter.
15 We do now have marked the copy of SERI Exhibit 31.

16 JUDGE MCDADE: Okay. And if you could
17 just pass that up.

18 JUDGE WARDWELL: And we will be getting
19 the staff's marked version also, correct?

20 JUDGE MCDADE: Yes. It has already been
21 accepted as Exhibit 46. We are now going to move on
22 to Hearing Issue D. It might be appropriate for us
23 to take a very brief break. It is now 20 minutes
24 after. Can we take a break until 4:30 and then come
25 back promptly at 4:30? Is that enough time for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 applicant?

2 MS. SUTTON: Yes, Your Honor.

3 JUDGE MCDADE: For the staff?

4 MR. RUND: That's fine for the staff.

5 JUDGE MCDADE: We are in recess.

6 (Whereupon, the foregoing matter went
7 off the record at 4:23 p.m. and went back on the
8 record at 4:36 p.m.)

9 JUDGE MCDADE: The hearing is now called
10 to order. A question arise - we have finished with
11 Hearing Issue B. Is the staff's witness with regard
12 to Hearing Issue C currently present?

13 MR. RUND: Yes, he's seated in the
14 witness box.

15 JUDGE MCDADE: Okay. And is the
16 applicant ready to proceed with?

17 MS. SUTTON: Hearing Issue C by Mr.
18 Bachhuber, yes.

19 JUDGE MCDADE: Okay. Would you please
20 identify the witness, I believe you said Dr. Li?

21 MR. RUND: Yes. Dr. Li, please identify
22 yourself for the Board?

23 WITNESS LI: Yes. Yung Li, seismologist
24 working with the Division of Engineering at the NRC.

25 JUDGE MCDADE: Okay, thank you. You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 don't need to stand and in fact it would be better
2 if you don't because then you can be closer to the
3 microphone and our court reporter won't yell at me
4 anymore.

5 WITNESS LI: I understand.

6 JUDGE MCDADE: Okay. Or as much. The
7 witness for the applicant, would you please - no,
8 but just for the record to identify yourself.

9 WITNESS BACHHUBER: Yes. Jeff Bachhuber
10 from William Lettis & Associates representing SERI.

11 JUDGE MCDADE: Okay. And you have
12 already been sworn, but Dr. Li you have not. I
13 would ask that you state that subject to the
14 penalties of perjury that everything that you will
15 say in testimony will be true and accurate.

16 WHEREUPON,

17

18 YUNG LI

19 was duly sworn and assumed the witness stand.

20 JUDGE MCDADE: Okay. You are under
21 oath. We are ready to proceed. Judge Wardwell?

22 JUDGE WARDWELL: Yes, I just have one
23 question. You probably have already heard it and
24 that is what is the acceleration coefficient for the
25 site that would be used in any type of simplistic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 pseudostatic analyses as an extra driving force or
2 caused from the site earthquake.

3 WITNESS LI: If I understand it
4 correctly you are referring a conventional
5 methodology used to estimate a seismic load input in
6 the building codes, building design or conventional
7 building design or regular building design.

8 JUDGE WARDWELL: And it's also used, and
9 we use it - it's been used in slope stability
10 analyses also.

11 WITNESS LI: Yes. But in the critical
12 structure such as nuclear facility we use site-
13 specific response spectrum, which is expressed by
14 the SSE, or called a safe shutdown earthquake ground
15 motion.

16 JUDGE WARDWELL: I'm aware of that, but
17 somewhere later on and I can't remember where it's
18 come up, and I will know it once we get to it later
19 on in the hearing, in regards to someone brought up
20 this acceleration coefficient. And so I thought at
21 least if you did know it, I'd like to get it on the
22 record for what someone would use in case we do want
23 to use it later on. I understand - let me back up a
24 bit. I have read your seismic analysis. I found it
25 very thorough and knowing where the site is and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 low seismic activity that takes place there I see no
2 need to address anything in the work you've done. I
3 thought it was very well done and very well
4 presented.---I just - that's why originally yesterday
5 I said we have no questions for you. In something I
6 read within the last 24 hours this came up and I
7 said we ought to get it on the record in case we
8 need it later on. And I was afraid you might even
9 laugh at me for asking this because it is,
10 certainly in your field you must just cringe when
11 anyone wants to use this coefficient. But if you
12 happen to know what is the map coefficient that
13 Algermisen used to - originally did, and other
14 people have amplified maps showing this acceleration
15 coefficient for a site. I would appreciate anyone
16 who would know what that is to present that at this
17 time.

18 WITNESS LI: Okay. Yes, as I just
19 mentioned, in the critical structure like nuclear
20 facility we do a site-specific analysis. The final
21 result from that site-specific analysis including
22 the controlling earthquake input and the soil
23 response issue is the safe shutdown earthquake
24 ground motion. It's not a single point acceleration
25 record. It's a continuous response spectrum,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 relatively smooth. So at that, if you want to know
2 a specific point there I can let you know there's a
3 P ground acceleration which is 0.19g for this
4 particular site.

5 JUDGE WARDWELL: Do any of the - anyone
6 else want to comment on that particular value from
7 the staff? From the applicant, do you have any
8 comments on that?

9 WITNESS BACHHUBER: Yes, Jeff Bachhuber
10 from the applicant. Mr. Li was correct in that for
11 a critical facility you do calculate a site-specific
12 ground motion for that analysis. We did calculate
13 the SSE not for the purpose of performing slope
14 stability analysis, but it does provide bounds. And
15 the value of 0.19g that was mentioned from that
16 design spectra would be appropriate for an initial
17 assessment of slope stability. During the COL
18 phase, quantitative analysis will be performed.
19 That work is deferred to the COL stage because it
20 depends on the exact location, embedment, design of
21 the plant so that critical location or cross-
22 sections for analysis could be determined. And at
23 that point the level of earthquake input would be
24 conferred or developed specifically for that
25 analysis. But it would more than likely be around

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 0.19g.

2 JUDGE WARDWELL: Are you familiar with
3 the Algermisen maps that were initially created I
4 think in '54 or so and have been updated since, that
5 present given return periods and acceleration
6 factors?

7 WITNESS LETTIS: This is William Lettis
8 for the applicant. The Algermisen maps were the
9 national probabilistic hazard maps for the U.S.
10 They've been updated a number of times by Art
11 Frankel now and they provide return periods of 10
12 percent in 50 years and 2 percent in 50 years. So
13 did you have a question in regards to those?

14 JUDGE WARDWELL: And you are familiar
15 with those maps.

16 WITNESS LETTIS: Yes.

17 JUDGE WARDWELL: Do you have any idea
18 what that map would show in regards to the
19 acceleration factor?

20 WITNESS LETTIS: Yes, it's - I don't
21 know that off the top of my head.

22 JUDGE WARDWELL: Does anyone? I
23 understand someone from staff may know what that is.

24 WITNESS LI: May I comment on this
25 issue? That map is for a general design purpose.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 It's not applicable to the critical facility because
2 you don't have site-specific input.

3 JUDGE WARDWELL: I'm aware of that.

4 WITNESS LI: Okay.

5 JUDGE WARDWELL: Just I think later on
6 it may come up and I can't remember why and I just
7 want to get it on the record so in case we need it
8 we have that available. Hopefully we won't even
9 need it because I can't remember where it came up,
10 but I thought while I had you available I would get
11 what this is. And I wasn't - in fact, I'm a little
12 surprised it's as high as 0.19 but it's probably
13 because of the conservative nature of your analysis
14 and being a very critical facility it's a very high
15 value compared to what I'm used to, but that's fine.
16 I just wanted to get it on the record. Yes.

17 WITNESS BAGCHI: This is Goutam Bagchi.
18 I just wanted to point out that the frequency
19 associated with the national hazard map was
20 described by Dr. Lettis and those frequencies are
21 considerably lower - I mean higher than the
22 frequency for earthquakes considered for this
23 particular design. It's 10 to the -5 median. It is
24 highly conservative. And I would venture to guess
25 without - I don't know what that hazard map will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 call for at Grand Gulf site, but it would be
2 considerably less than 0.19gpga.

3 JUDGE WARDWELL: That would be my guess
4 too. Yes. Okay, thank you, that's all. And I
5 understand, I know the sensitivity. We accept your
6 testimony and what you've provided in the pre-filed
7 testimony as what is needed for this facility.
8 Absolutely, there's no question. We are not
9 proposing to use this whatsoever unless it happens
10 to come up. And maybe I dreamt it last night for
11 that matter, I don't know.

12 WITNESS LI: If you come across it in
13 the next few days, I mean whenever -

14 JUDGE WARDWELL: You will know about it.

15 WITNESS LI: We are ready to answer your
16 question.

17 JUDGE WARDWELL: Sure, thanks.

18 WITNESS LI: Thanks.

19 JUDGE MCDADE: And when everybody has
20 been using the word "guess" here in this context,
21 they mean based on their training, experience and
22 their professional judgment they infer that it would
23 be. That's the definition of "guess"?

24 WITNESS BAGCHI: Yes, Your Honor.

25 JUDGE MCDADE: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 (Laughter)

2 JUDGE WARDWELL: I was trying to
3 expedite the hearing here though.

4 JUDGE MCDADE: So are we ready to
5 proceed to Hearing Issue D?

6 MR. RUND: We're prepared and I guess we
7 could dismiss Dr. Li for now.

8 JUDGE MCDADE: Yes. Thank you.

9 WITNESS LI: Thank you.

10 JUDGE WARDWELL: Ready to roll? Many of
11 my questions have already been addressed under slope
12 stability, but let's continue to pursue it. In
13 Hearing Issue D on Answer A-3, Page 2 there was a
14 discussion of what had taken place. And the
15 question I have is what data did the staff use
16 that's available to ascertain the sheer strength of
17 the geologic materials, and what are the values that
18 were used in the preliminary estimates that are
19 mentioned under this Answer A-3 on Page 2. The last
20 sentence of the second paragraph talked about
21 preliminary estimates of simplified soil stability
22 evaluations, indicated standoff distances on the
23 order of 100 feet, potential failure to surface
24 through the bluff material would not intersect the
25 plant cross-section. And my question is what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 available sheer strength values are there for the
2 various strata and then what values were used in
3 this preliminary assessment.

4 WITNESS CONSTANTINO: This is Carl
5 Constantino. With respect to the loess material,
6 Engineering Report 02 indicates that strength tests
7 from the UFSAR, friction angles of the order of 33 -
8 34 degrees were typical. And based on that, doing a
9 simple linear back to the envelope, a simplified
10 analysis on slope stability, you could back out the
11 potential range that any slope would - how far back
12 it would break out using that simplified model. The
13 materials below -

14 JUDGE WARDWELL: By linear -

15 WITNESS CONSTANTINO: Linear failure.

16 JUDGE WARDWELL: So your infinite slope
17 analysis, if you will.

18 WITNESS CONSTANTINO: No, no, a
19 triangular slope. Infinite slope.

20 JUDGE WARDWELL: Okay.

21 WITNESS CONSTANTINO: So it's a
22 triangular slope stability simplified and that sort
23 of bounds the range to make a judgment on what an
24 appropriate setback distance would be if you wanted
25 to get away from that slope failure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 JUDGE WARDWELL: And that that you
2 pictorially represent on one of your exhibits, the
3 failure plane that ends up -

4 WITNESS CONSTANTINO: Yes -

5 JUDGE WARDWELL: - level, that's at a
6 factor of safety of one. That said it would fail at
7 that point. Right.

8 WITNESS CONSTANTINO: Approximately it
9 would fail. So otherwise you'd have to go into a
10 detailed numerical analysis which wasn't done. And
11 I think in fact that conservative estimate, instead
12 of using 33 degrees we used 30 degrees or something
13 simple.

14 For the lower materials slope stability
15 wasn't really an issue but the strengths based on
16 the SPT blow counts were very much higher. So that
17 evaluation indicated that if there was a slope
18 failure it would be restricted to the loess
19 material. We weren't too concerned about slope
20 failures in the stiffer materials below.

21 JUDGE WARDWELL: I think it's mostly in
22 the loess -

23 WITNESS CONSTANTINO: Yes, right.

24 JUDGE WARDWELL: - that that's of
25 interest. Do you have any indication of any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 information that would talk about creep
2 displacements of the loess as an over-consolidated
3 material such that they would continue to
4 retrogressively work their way back to the plant,
5 given enough time?

6 WITNESS CONSTANTINO: Long-term behavior
7 of the loess material, that's an issue. I think the
8 data available would indicate, or not the data
9 available. The data available is really relatively
10 simplified. You couldn't make judgments of that
11 from the data that's available. These kind of fine
12 grain materials are susceptible to long-term creep
13 effects. I think where our recommendation was what
14 is the potential - let's assume such creep effects
15 will occur. What long-term impact would that bring
16 to the design of the plant. I don't think there's
17 any information that we saw which would preclude the
18 consideration of a creep effect. Especially if one
19 talks about in addition to creep, erosion due to
20 ground - Mississippi - erosion of the base or just
21 normal rainfall runoff. So I think our perspective
22 was creep may occur, probably will occur in the
23 long-term and how can we design the plant to ensure
24 that that's not an issue from the plant. And that
25 led to the estimate of the standoff distance and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 also placing - making sure that the foundation of
2 the base mat is located suitably below any potential
3 breakout point of a failure plane. So the strengths
4 available from a lateral stability point of view
5 would not be a problem.

6 JUDGE MCDADE: Doctor, in this context
7 when you use the term "long-term" can you give us an
8 idea temporally of what that means? Are we talking
9 about years, decades, centuries?

10 WITNESS CONSTANTINO: Well, I know I'm
11 old, but in my lifetime I've seen many slopes
12 disappear, creep. So when I talk about long-term, I
13 think of the order of 5, 10, 15 years is relatively
14 long-term for these materials. Loess materials are
15 particularly unusual also because they have these
16 peculiar characteristics. When they're dry they
17 look very fine and if they happen to be wet for some
18 reason they could lose their strength
19 characteristics. They're a different kind of
20 material than the silts you would normally see. So
21 my perspective always was let's assume this is going
22 to happen and how we can ensure that that's not a
23 major player in the evaluation of the plant
24 facility.

25 JUDGE WARDWELL: In your professional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 opinion is there anything in the information you've
2 gathered in your review on the behavior of that
3 loess that would preclude this from being a suitable
4 site from the plant location.

5 WITNESS CONSTANTINO: No, provided we
6 take care of those issues of moving the plant
7 foundation down deep enough and doing an evaluation
8 of lateral stability, sliding, overturning and SSI
9 evaluation of this profile, this topographic profile
10 which has this also. So both of those I think. If
11 you do that, I have no issue with your being able to
12 design the facility. But I think you have to do
13 that.

14 JUDGE MCDADE: So for your purposes this
15 is a situation where there is a reasonable
16 possibility that this will occur within the
17 timeframe that the plant will be open and operating,
18 and that therefore in order to have the site
19 suitable, you have to assume that it will occur and
20 plan accordingly, but that that does not pose any
21 insurmountable engineering barriers.

22 WITNESS CONSTANTINO: Oh no, I think
23 that's true. I think from a safety perspective you
24 wouldn't always consider that situation, but I think
25 the process to design the facility to incorporate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that is very straightforward. So I don't think
2 there's any indication that it would preclude you
3 from using the site.

4 JUDGE WARDWELL: Any comment from the
5 applicant?

6 WITNESS BACHHUBER: Yes. Jeff Bachhuber
7 representing the applicant. And just to reinforce a
8 couple of points and also add some additional
9 information to what Carl had discussed. The
10 strength values in the loess actually were
11 determined during the ESP from samples collected
12 from borings for the ESP program. We performed a
13 number of tri-axial shear tests and a value of 33 -
14 34 degrees for the loess was determined on the basis
15 of those tri-axial tests. We also performed four
16 CPT soundings that were extended all the way through
17 the loess and based on that we were determining
18 undrained shear strengths of around 2,000 to 8,000
19 pounds per square foot. So relatively high values
20 for that material. And so we do have specific
21 measurements from the ESP program.

22 WITNESS CONSTANTINO: Jeff, before you
23 leave that point, could I respond?

24 WITNESS BACHHUBER: I would like to keep
25 going.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 WITNESS CONSTANTINO: Oh, you can keep
2 going, I just want to respond to the comment you
3 made about -

4 WITNESS BACHHUBER: Sure.

5 WITNESS CONSTANTINO: - using the CPT
6 data. Just to clarify that issue. All the CPTs
7 were taken in the center of the site, basically.
8 There was really no major effort to look at strength
9 values for the loess along the slope. And if I was
10 evaluating the slope I would worry about that. So I
11 just wanted to clarify that point. There is a
12 difference of opinion.

13 WITNESS BACHHUBER: Okay. And the loess
14 deposits are a continuous layer. Where we did
15 perform the CPT soundings they were in the same
16 layer of loess that's exposed in the slopes.

17 WITNESS CONSTANTINO: But it's pretty
18 clear -

19 WITNESS BACHHUBER: Based on comparisons
20 of the various CPT and borehole data the loess is
21 pretty consistent in properties. And so what we see
22 in the slope face, we visually examined the loess.
23 It was similar to the loess that we encountered in
24 the borings and within the zone of the CPT testing.
25 And so based on that we were able to correlate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 it's a reasonable approximation of the loess in the
2 slope face. Now, we will perform in the COL phase
3 additional investigations very close to the slope
4 where we are going to perform the slope stability
5 analysis, just to confirm that that is indeed a
6 fact.

7 All the slopes do expose loess. As Dr.
8 Constantino mentioned, the loess is lower strength
9 than the underlying alluvium and this would tend to
10 force any failures to be constrained to the loess
11 deposits. In fact, the loess extends below the base
12 of the slopes, both the Mississippi River bluff, the
13 tributary slope near Basin A and the cut slope that
14 runs across the site all expose loess. And so that
15 is a fundamental strength property to use for the
16 slope stability analysis.

17 With regards to long-term performance of
18 the loess, the Mississippi River bluff slope has
19 existed for thousands of years and so it actually is
20 a long-term analog regarding the behavior of loess.
21 We could push it way back. And this record of time
22 would include high stages of Mississippi River,
23 periods of intense rainfall. So we think it's a
24 good model of the long-term performance of the
25 loess, an actual model onsite. And in that slope we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 do not see any evidence of large-scale
2 retrogressive-type failures that extend for
3 significant distances back from the top of the bluff
4 slope. And so based on that comparison we were able
5 to rule out that that is a likely scenario, that we
6 would have large-scale retrogressive failure working
7 back from the river bluff.

8 A couple of the exhibits we have help
9 illustrate some of the relationships between the
10 slopes and the ESP plant area. And that would be
11 Exhibit SERI 5 and SERI 11. And also SERI 3 is an
12 exhibit that's useful. I'll start out with SERI 3
13 if you could pull that up. This is a plan map
14 showing the exploration locations, both explorations
15 for the ESP project and also for the UFSAR. And on
16 this map, within the circular ESP envelope you can
17 see four dark triangles and those represent the
18 locations of our CPT soundings and you can see that
19 there is one of these triangles labeled CPT 3 that
20 occurs near the top of the river bluff. And so one
21 is this shows that our CPTs are distributed
22 throughout the ESP envelope and they also are
23 located very close to the river bluff.

24 On Figure SERI 11, pull that up. This
25 is a cross-section through the river bluff and it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

-- www.nealrgross.com

1 shows the same CPT that was shown on that plan map,
2 WLA CPT 3, and you can see it as a vertical line
3 near the top of the river bluff. And so that shows
4 the spatial position of that data point with
5 relation to the bluff slope. This also shows that
6 the Layer 2, which is the loess, it extends - it
7 makes up the face of the Mississippi River bluff and
8 extends back below the site. And so the
9 characterization of that layer, it's a continuous
10 layer. And so our other CPTs also provide
11 reasonable information to help bound the properties
12 of the loess.

13 And then on Figure SERI 5 this is a
14 cross-section. The previous cross-section in SERI
15 11 has a vertical exaggeration. This cross-section
16 in Exhibit 5 is at a 1-to-1 scale. So it shows the
17 true slopes and geometric relationships between the
18 river bluff and the ESP envelope. And on this
19 figure you can see the proposed reactor building
20 envelope defined, the Mississippi River bluff and
21 also the setback zone that's established around the
22 ESP site envelope. And here I'm showing a
23 projection, a hypothetical failure plane that would
24 extend from the base of the bluff slope to the edge
25 of the setback line. And in order to have a failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 plane extend back to the setback it would have a low
2 angle on the order of 15 degrees. If we have a
3 projected a hypothetical plane all the way to the
4 reactor or building envelope it would be lower,
5 perhaps on the order of 8 degrees. And comparing
6 that angle, inclination angle, to the sheer strength
7 of 34 - 33 degrees, it shows that we have a
8 significant factor of safety with relation to
9 development of a failure plane back to the envelope
10 area.

11 JUDGE WARDWELL: In your professional
12 opinion is there anything in the behavior of the
13 loess that would lead you to believe that the site
14 would be precluded from being adequate for the
15 siting of a new power plant?

16 WITNESS BACHHUBER: No.

17 JUDGE WARDWELL: Thank you.

18 WITNESS BACHHUBER: We believe the
19 setback zone we have established provides a very
20 conservative safe distance back from the river
21 bluff.

22 JUDGE WARDWELL: Are you prepared to
23 discuss further or submit any extra testimony in
24 regards to recent observations that you've taken
25 place at the site, or is that too preliminary? You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 mentioned it earlier in the hearing in regards to
2 the -

3 WITNESS BACHHUBER: No, I -

4 JUDGE WARDWELL: - slough areas.

5 WITNESS BACHHUBER: Let me check.

6 JUDGE WARDWELL: You've already
7 mentioned that it's now, as I'll paraphrase what I
8 remember you saying, and I'll look at the
9 transcript, but that some of these areas that were
10 mapped as sloughed areas may in fact not be. I'm
11 sure you want to - that's the inference I got from
12 your statement. I'd have to read it again, but it
13 wasn't a definitive statement that they definitely
14 are, it's just you were kind of just updating us, so
15 there wasn't really much meat in that testimony. I
16 was wondering whether you'd want to say any more
17 about that, a more definitive position on what those
18 are or aren't.

19 WITNESS BACHHUBER: First I'd like to
20 make a statement that all the analyses and
21 information I just described were based on the ESP
22 only. So all of that data is within the SSAR. It
23 does not include the additional -

24 JUDGE WARDWELL: Right, I assume that
25 was, so that's good. And your concluding remark in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 your professional opinion that based on the ESP data
2 and analysis that you performed, there's nothing in
3 your professional opinion that precludes this site
4 from being suitable for the plant from a slope
5 stability aspect?

6 WITNESS BACHHUBER: That is correct.

7 JUDGE WARDWELL: Okay.

8 WITNESS LETTIS: This is Bill Lettis for
9 the applicant. Regarding the additional work
10 performed since the ESP, the staff has not had the
11 opportunity to review any of that information and so
12 it would be most likely inappropriate for us to
13 present those findings or any conclusions based on
14 that without having provided the opportunity to the
15 staff to look at that.

16 JUDGE WARDWELL: That's good, I just
17 wanted to make sure that I didn't preclude that. I
18 think that's the appropriate approach. Okay.

19 JUDGE MCDADE: At this point do you have
20 anything further, any further comment on that?

21 WITNESS CONSTANTINO: This is Carl
22 Constantino again. Yes. There are a number of
23 points where Jeff and I disagree. One of them is to
24 use the tri-axial data, available tri-axial data
25 unless there is new data you're talking about, from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 samples taken near the center of the loess to those
2 taken at the boundary because of the confinement
3 issues. You would run those tests at different
4 confining pressures. So that's one issue.

5 One of the overriding issues is the
6 potential impact of the construction on the slope
7 away from - slope between the edge of the
8 construction to the Mississippi River. That's an
9 issues that has to be looked at. Its potential
10 impact is to weaken that loess material. And my
11 concern always would focus on the loss of capacity
12 of that loess and how that would potentially impact
13 the plant. That none of those issues have ever been
14 evaluated yet, none of the advanced reactor systems
15 look at that issue, and I would presume that it
16 would be something you would worry about.

17 JUDGE MCDADE: Starting at this point
18 and going back to sort of my preface to this earlier
19 today, we aren't here doing a sort of de novo review
20 of the application and the data, we're doing a
21 review of the staff's review, and we have been
22 instructed when the staff's position is reasonable
23 and it has a reasonable basis in fact and logic to
24 give whenever possible deference to that opinion.
25 So it seems, given the guidance that we have, this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 is a real issue and we start to decide that this is
2 something that needs to be planned for. Although
3 there may be a difference of professional opinion as
4 to the probability or possibility of this occurring,
5 it seems from our standpoint the bottom line is
6 assuming that it might, what then. And I take it
7 from the standpoint of the applicant, the applicant
8 takes the position that although they consider the
9 drift of this particular area to be unlikely based
10 on all of the data available, that nevertheless as
11 part of the application you concede that as part of
12 your engineering you will be required to assume that
13 it is a possibility and the engineering will take
14 that into consideration. And the engineering will
15 be built accordingly so that it would not pose a
16 problem if in fact the staff's evaluation as to
17 probability is the, you know, correct. Am I correct
18 in that?

19 WITNESS BACHHUBER: That is absolutely
20 correct and that is our plan, that we will perform
21 additional stability analysis considering all
22 potential failure modes once the plant design is
23 selected and we can determine the most appropriate
24 location for the analysis.

25 JUDGE MCDADE: Okay. And the question I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 guess to the staff and it may be to the witnesses
2 and it may be to the staff counsel, is there
3 anything currently in the proposed permit which
4 would mandate that either the applicant submits
5 additional data to the staff on which the staff
6 changes its professional opinion as to the
7 likelihood or in the alternative will require that
8 the engineering design is such that it will account
9 for, take into consideration the possibility and
10 ensure the safety of the facility even if this was
11 to occur. What is there currently in the proposed
12 permit that handles that? Are you prepared to
13 respond to that?

14 WITNESS CONSTANTINO: Yes. If I look at
15 - I'm trying to find it - where in the table. If I
16 look at Action Items 210 and 11, both of those
17 really address those issues.

18 JUDGE MCDADE: And you're satisfied that
19 that meets the concerns that you have just raised
20 here?

21 WITNESS CONSTANTINO: Yes. If they are
22 addressed, I think that satisfies my interest.

23 JUDGE WARDWELL: And these are COL
24 action items, and what are the numbers again?

25 WITNESS CONSTANTINO: 2.5-10 and 2.5-11.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Page A-8.

2 JUDGE WARDWELL: And as far as the
3 applicant is concerned that would be the approach
4 that you would take in the future action? Or you
5 have no comments in regards to that -

6 WITNESS BACHHUBER: That is correct and
7 that's a typical standard of practice for design of
8 a nuclear facility.

9 JUDGE WARDWELL: And the only other
10 additional thing is look forward to future
11 discussions with staff's reviewer in regards to
12 professional opinions on how this is approached.
13 And that's always healthy. I wish I was invited to
14 join you.

15 (Laughter)

16 JUDGE WARDWELL: But I can't. That's
17 all the questions I have. I appreciate the input
18 from both, unless there's some other final
19 statements people would like to have on that issue.
20 It was very helpful.

21 JUDGE MCDADE: Okay. Is there anything
22 further from the staff?

23 MR. RUND: Staff has nothing further on
24 Issue D.

25 JUDGE MCDADE: Okay, from the applicant?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

... www.nealrgross.com

1 MS. SUTTON: Nothing further.

2 JUDGE MCDADE: Okay. It is now after
3 5:00 and what I'm proposing we do is recess for this
4 evening, pick up again tomorrow at 9 o'clock in the
5 morning with Hearing Issue E. Is there any other
6 preliminary matter that needs to be taken care of
7 before we recess for the evening?

8 MR. RUND: Staff has nothing.

9 JUDGE MCDADE: The applicant?

10 MS. SUTTON: Nothing further.

11 JUDGE MCDADE: Okay. For the witnesses
12 that remain here, I do want to thank you very much
13 for being here and for the testimony that you've
14 given. It has been extremely helpful and we
15 appreciate the work that's gone into being prepared
16 as wonderfully prepared as you were. We greatly
17 appreciate it and we would ask the staff to convey
18 to those of your witnesses who have left those
19 comments as well.

20 JUDGE WARDWELL: That's what I was going
21 to say when I raised my finger, I just wanted to
22 thank everyone for their candor and their
23 straightforwardness with which the questions were
24 answered. That makes the hearing go much more -
25 it's much more informative and makes it go in a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 more expeditious manner. I look forward to more
2 tomorrow.

3 JUDGE MCDADE: Judge Trikouros, anything
4 further?

5 JUDGE TRIKOUROS: I have nothing
6 further, thank you.

7 JUDGE MCDADE: We're in recess. We'll
8 see you all in the morning. Thank you.

9 (Whereupon, the foregoing matter went
10 off the record at 5:14 p.m.)
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

CERTIFICATE

This is to certify that the attached proceedings
before the United States Nuclear Regulatory Commission
in the matter of:

Name of Proceeding: Grand Gulf Early Site

Permit Hearing

Docket Number: 52-009-ESP

Location: Rockville, Maryland

were held as herein appears, and that this is the
original transcript thereof for the file of the United
States Nuclear Regulatory Commission taken by me and,
thereafter reduced to typewriting by me or under the
direction of the court reporting company, and that the
transcript is a true and accurate record of the
foregoing proceedings.



Charles Morrison
Official Reporter
Neal R. Gross & Co., Inc.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com