

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
538th Meeting

Docket Number: (not applicable)

PROCESS USING ADAMS
TEMPLATE: ACRS/ACNW-005

SUNSI REVIEW COMPLETE

Location: Rockville, Maryland

Date: Thursday, December 7, 2006

Work Order No.: NRC-1348

Pages 1-430

ORIGINAL

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

**ACRS OFFICE COPY
RETAIN FOR THE LIFE OF THE COMMITTEE**

TROY

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

December 7, 2006

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on December 7, 2006, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS (ACRS)

538th MEETING

+ + + + +

THURSDAY,

DECEMBER 7, 2006

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The meeting was convened in Room T-2B3 of Two White Flint North, 11545 Rockville Pike, Rockville, Maryland, at 8:30 a.m., Graham B. Wallis, Chairman, presiding.

MEMBERS PRESENT:

- GRAHAM B. WALLIS Chairman
- WILLIAM J. SHACK Vice Chairman
- SAID ABDEL-KHALIK Member
- GEORGE E. APOSTOLAKIS Member
- J. SAM ARMIJO Member
- MARIO V. BONACA Member
- MICHAEL CORRADINI Member
- THOMAS S. KRESS Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBERS PRESENT: (cont'd)

2 OTTO L. MAYNARD Member
3 DANA A. POWERS Member
4 JOHN D. SIEBER Member-At-Large

5

6 ACRS STAFF PRESENT:

7 ERIC OESTERLE
8 JERRY WILSON
9 DONNIE HARRISON
10 MARK RUBIN
11 JOE COLACCINO
12 DAVID FISCHER
13 NICK SALTOS
14 JENNIFER ULE
15 HIPOLYTO GONZALEZ
16 TIM COLLINS
17 JOHN FERRER
18 KAMAL MANOLY
19 MIKE MAYFIELD
20 BILL CULLEN
21 DAN BARASS
22 BRUCE MUSICO
23 JIMI YEROKUN
24 JOHN MONNINGER
25 JOCELYN MITCHELL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ALSO PRESENT:

ROBERT GURDAL

BRYAN ERLER

ALAN NELSON

MARTIN HUG

ROBERT PRATO

CHARLES TINKLER

CHRIS HUNTER

RANDY SULLIVAN

BIFF BRADLEY

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

I-N-D-E-X

<u>AGENDA ITEM</u>	<u>PAGE</u>
Opening Remarks by the ACRS Chairman	5
Draft Final Regulatory Guide DG-1145, "Combined License Applications for Nuclear Power Plants"	9
Draft Final Regulatory Guide DG-1144, "Guidelines for Evaluating Fatigue Analyses Incorporating the Life Reduction of Metal Components Due to the Effects of the Lightwater Reactor Environment for New Reactors"	112
Proposed Revisions to Standard Review Plan Section 13.3, "Emergency Planning"	192
State-of-the-Art Reactor Consequence Analysis Project	293
Adjourn	

P-R-O-C-E-E-D-I-N-G-S

(8:32 a.m.)

CHAIRMAN WALLIS: Good morning. The meeting will now come to order.

This is the first day of the 538th meeting of the Advisory Committee on Reactor Safeguards. We say all this so that the members know where they are and what they're doing.

During today's meeting the Committee will consider the following: Draft Final Regulatory Guide DG-1145, "Combined License Applications for Nuclear Power Plants"; Draft Final Regulatory Guide DG-1144, "Guidelines for Evaluating Fatigue Analyses Incorporating the Life Reduction of Metal Components Due to the Effects of the Lightwater Reactor Environment for New Reactors"; Proposed Revisions to Standard Review Plan Section 13.3, "Emergency Planning"; State-of-the-Art Reactor Consequence Analysis Project; and the Preparation of ACRS Reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Dr. John T. Larkins is the Designated Federal Official for the initial portion of the meeting.

We have received no written comments or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 requests for time to make oral statements from members
2 of the public regarding today's sessions. A
3 transcript of portions of the meeting is being kept,
4 and it is requested that the speakers use one of the
5 microphones, identify themselves, and speak with
6 sufficient clarity and volume so that they can be
7 readily heard.

8 I will begin with some items of current
9 interest. Dr. John Larkins, our Executive Director,
10 is retiring on January 4, 2007. As the Director --
11 Executive Director for the past 13 years, he has been
12 very devoted to the Committee, and has provided
13 outstanding management support to the members.

14 He has continually ensured a high level of
15 technical and administrative support to the Committee
16 in performing its statutory obligations effectively
17 and efficiently. His many contributions include the
18 selection of new members and consultants to the
19 Committee, reappointment of members, formulation and
20 execution of the Committee's operating budget,
21 resolution of conflict of interest issues, and quality
22 assurance of ACRS office activities.

23 Increasing the number of ACRS members to
24 the statutory maximum of 15 is one of his recent
25 achievements. Additionally, Dr. Larkins was

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 instrumental in improving communications and
2 cooperation between the ACRS, the NRC staff, and the
3 Commission. His devotion, enthusiasm, and unrelenting
4 effort to support the Committee are second to none and
5 are very much appreciated by all of us and
6 particularly by me personally.

7 On behalf of the Committee, I would like
8 to thank Dr. Larkins for his dedication to the
9 Committee, wish him happy retirement, and good luck in
10 his future endeavors. Where is John? He's hiding
11 behind --

12 (Applause.)

13 Now I turn to Frank Gillespie. You all
14 know he started his career with the NRC in 1975 as an
15 Inspector in Region I. From 1978 to 1980, he served
16 as a Section Chief in Region II. Mr. Gillespie was in
17 the Office of Nuclear Regulatory Research from 1980 to
18 1986, first as the Safeguards Branch Chief and
19 subsequently as the Director of the Division of
20 Accident Evaluation and the Division of Risk Analysis
21 and Operations.

22 In 1986, he worked at Batelle Memorial
23 Institute, returning to the Office of Nuclear Reactor
24 Regulation in 1987. From 1987 until the present, he
25 has held various Division Director and Deputy Division

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Director positions, the most recent being Director of
2 the Division of License Renewal.

3 I'm happy to report that effective
4 November 27, 2006, Mr. Gillespie started his
5 transition into the new position of Executive
6 Director, ACRS and ACNW, and will assume the full range
7 of responsibilities effective January 4, 2007. So
8 please congratulate Frank on his appointment.

9 (Applause.)

10 Also, Mike Snodderly, who has been with
11 the ACRS since October 2002, is leaving to join the
12 Office of New Reactors as the Branch Chief for the
13 Containment Systems Branch for the ESBWR and ABWR in
14 January 2007.

15 As a Senior Staff Engineer for two years,
16 Mr. Snodderly provided outstanding technical support
17 to the Committee in reviewing several complex
18 technical issues, including risk-informed and
19 performance-based regulatory approaches, use of PRA in
20 the regulatory decision-making process, implementation
21 of the Commission's phased approach for PRA quality,
22 and risk-informed revisions to 10 CFR 50.44.

23 As a Branch Chief for both ACRS and ACNW
24 staff, he provided leadership to the technical staff
25 and ensured high-quality technical support to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Committee in reviewing various regulatory issues,
2 including license renewal, core power uprate
3 applications, and PWR sump performance issues.

4 He was an outstanding Senior Staff
5 Engineer and an exceptional Branch Chief. And on
6 behalf of the Committee, I would like to thank him for
7 his numerous contributions and wish him good luck in
8 his new job.

9 Thank you very much, Mike.

10 (Applause.)

11 There are some other items of interest
12 that have been handed out, this pink-covered
13 collection here. You'll note there are some
14 presentations by Commissioners. And for those of you
15 who missed The Washington Post yesterday, the article
16 on Commissioner McGaffigan has been reprinted on
17 page 50.

18 I'd now like to move to our business. The
19 first item on the agenda is the Draft Final Reg. Guide
20 DG-1145. I turn to my colleague Tom Kress to lead us
21 through this one.

22 MEMBER KRESS: Thank you, Mr. Chairman.

23 We had a spirited subcommittee meeting.
24 And, as you know, DG-1145 is a substantial document,
25 and it was difficult to decide which parts of a full

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 day meeting which was also too short we could cover in
2 just a couple of hours here.

3 So you have the agenda in front of you,
4 and those are the items we thought might be of both
5 interest and might be of some controversy to the
6 Committee. So without any further introduction, I'll
7 turn it over to the staff and let them give you the
8 right introduction.

9 MR. OESTERLE: Thank you, and good
10 morning, everyone. My name is Eric Oesterle. I'm the
11 Lead Project Manager on Draft Regulatory Guide
12 DG-1145. I'm in the Guidance Infrastructure and
13 Financial Review Branch with the Division of New
14 Reactor Licensing in the Office of New Reactors.

15 I want to thank the full Committee for
16 allowing the staff this opportunity to provide this
17 informational briefing on DG-1145.

18 This morning I would like to provide the
19 full Committee with an overview of DG-1145. As Dr.
20 Kress indicated, we had a subcommittee meeting last
21 week on Thursday, November 30th, and the staff came
22 before the subcommittee on future plant designs and
23 provided presentations on some specific areas of
24 interest on DG-1145.

25 Based on the requests of that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 subcommittee, we are here today to provide selected
2 presentations to the full Committee. Following this
3 overview, you will hear a presentation on
4 probabilistic risk analysis, public workshop issues
5 and public comments, and then, finally, a discussion
6 on conformance, completeness, and consistency of
7 DG-1145.

8 With the increasing interest and attention
9 focused on new reactor -- potential new reactor
10 licenses, development of DG-1145 became a tremendous
11 undertaking and a very important one. In recognizing
12 that importance, and the importance of this guidance
13 document for potential COL applicants, the ACRS
14 requested that the staff provide it with an
15 informational briefing and the status on its
16 development, and that is our purpose here today.

17 This guidance document was developed in
18 response to external stakeholder requests for timely
19 guidance based on intended submittals of COL
20 applications in 2007. This effort was very intensive,
21 it was expedited, and it was a committed effort on the
22 part of the staff, with a high level of external
23 stakeholder participation during its development.

24 This guidance document has had a high
25 level of NRO and NRR management attention, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certainly has the interest of the Commission.

2 This guidance document follows the Part 52
3 rulemaking that was issued in March of this year. It
4 does not impose any new requirements. And as someone
5 eloquently put it in the subcommittee meeting last
6 week, that the rule rules, so the guidance document
7 cannot impose any new requirements. It must defer to
8 the Part 52 rulemaking.

9 This guidance document is consistent and
10 has been developed consistent with the SRP format and
11 content, such that the sections correspond with each
12 of the SRP sections. In addition, this guidance
13 document provides a roadmap to other technical guides,
14 technical regulatory guides, and industry standards.

15 One last thing before we get started into
16 this presentation. This draft guide, which the ACRS
17 members reviewed, was based on the proposed Part 50
18 rule that was issued in March of this year. As you
19 may know, the Part 52 rule has been revised and
20 submitted to the Commission last month.

21 There were changes made to that rule, and
22 as a result of those changes that were sent to the
23 Commission, some of the presentations today will
24 reflect or acknowledge changes that must be made to
25 the guidance to conform with the rule that was sent to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the Commission. And we recognize that additional
2 changes may be necessary to this guidance document to
3 conform with any changes that the Commission decides
4 are necessary when they disposition that rule.

5 The purpose for DG-1145 was to provide
6 guidance to potential applicants on the format and
7 content for a combined license application pursuant to
8 10 CFR Part 52. This guidance document recognized
9 that several scenarios were possible for a COL
10 applicant, so this guidance document provides guidance
11 for a COL applicant referencing neither a certified
12 design nor an early site permit, and you may hear this
13 referred to as a custom design.

14 It also provides guidance for a COL
15 applicant referencing a certified design, but not an
16 early site permit, and it also provides guidance for
17 a COL applicant referencing both a certified design
18 and an early site permit.

19 For several years prior to the development
20 of these --

21 MEMBER APOSTOLAKIS: Just --

22 MR. OESTERLE: Yes, sir.

23 MEMBER APOSTOLAKIS: -- for my own benefit
24 here, so when is this application submitted? Before
25 they do anything on the site, right? Do they say, "We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 intend to build a reactor, and here is our
2 application," is that correct?

3 MR. OESTERLE: There are several
4 scenarios, and I'll defer to Jerry Wilson to help me
5 out with this question.

6 MR. WILSON: Jerry Wilson, Office of New
7 Reactors. I call Dr. Apostolakis' attention to 10 CFR
8 50.10. Applicants are allowed to do certain
9 activities on the site without getting approval from
10 the NRC, so there are site investigations.

11 We are currently doing a rulemaking on
12 that provision in which the Commission is considering
13 whether we should increase the amount of -- let me
14 call them pre-construction activities on the site
15 without any approval from the NRC, and even before
16 submittal of an application.

17 So I can't give you an exact answer to
18 that question at the moment, because it's before the
19 Commission.

20 MEMBER APOSTOLAKIS: I guess, you know, I
21 was reading selected chapters, and the thing is that
22 this application -- wow --

23 (Laughter.)

24 There are certain things such as, you
25 know, goals for core damage frequency and large

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 release frequency, and the reason why I'm asking is
2 because depending on when the application is submitted
3 a PRA may or may not be complete.

4 So when you say that, you know, here is a
5 goal, and I haven't done anything yet, and all I have
6 a certified design and maybe the early site permit,
7 how do I demonstrate that I am complying with the
8 goals? Or is this a continuing process, and you are
9 updating the PRA as, you know, the testing strategies
10 are defined and all that?

11 I mean, there are certain not quite
12 requirements, but I don't know what to call them --
13 goals. When is the final time when you say, "Now, if
14 you don't demonstrate to me that you are meeting these
15 goals, I'm sorry, but I have to refuse doing A, B, C"?

16 MR. OESTERLE: The changes to the Part 50
17 rule that went to the Commission did make some changes
18 with respect to the requirements for submitting a PRA.
19 And I'm going to defer to Donnie Harrison, who is --

20 MEMBER APOSTOLAKIS: Okay.

21 MR. OESTERLE: -- providing the next
22 presentation this morning specifically on PRA to try
23 to address your question.

24 MEMBER APOSTOLAKIS: Yes. The question is
25 not really specifically on PRA. It's the timing of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 things. I mean, when you ask for something --

2 MR. HARRISON: Yes, and I -- this is
3 Donnie Harrison from the Division of Risk Assessment
4 of NRR. To answer the question is is if you have a
5 design certification, that means you addressed, at
6 least at the design stage, the PRA -- a design-
7 specific PRA that carries assumptions. Many of those
8 end up with, if you will, ITAAC requirements or
9 commitments to do walkdowns.

10 Obviously, even at a plant licensing
11 stage, you haven't built a plant yet, so you still
12 can't perform a walkdown. So what will happen is you
13 will do a plant-specific update of that design-
14 specific PRA, make it plant-specific, fill in the
15 details that you've got. That will be what's used in
16 the COL review, but you will still have assumptions
17 result -- for confirming, if you will, what was
18 actually built to make sure it represents.

19 That would occur prior to operation.
20 You'll have the seismic walkdown, the fire walkdowns.
21 All those things will occur there to, if you will,
22 confirm or to meet the commitments that are made as
23 part of the COL phase.

24 MEMBER APOSTOLAKIS: And is that kind of
25 common knowledge? Because I didn't get that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 impression from the document. Everybody knows that?
2 I mean, maybe that's the case.

3 MR. RUBIN: Well, this is Mark Rubin, also
4 from the staff. A couple of the specific items you
5 mentioned, such as large release frequency, kind of
6 the Level 2 interface items, the NSSS vendor will do
7 some envelope calculations to characterize a typical
8 site and show that those can -- those metrics can
9 typically be met by that design at a "typical" site.

10 When a COL vendor -- excuse me, when a COL
11 applicant comes in, they will show that their site
12 characteristics -- population density, meteorology,
13 all those factors -- is well scoped or bounded by what
14 was used, or they will do site-specific calculations
15 to show that the metrics are met. So either way the
16 specific requirements will be demonstrated for that
17 site, either through bounding analysis or site-
18 specific calculations at the COL stage.

19 MR. COLACCINO: This is Joe Colaccino,
20 also from the Office of New Reactors. And Dr.
21 Apostolakis has hit on one of the issues that was
22 predominant during the workshop meetings between the
23 NRC and the industry -- is the timing of when this
24 information needed to come in.

25 Now, remember, under Part 52 we're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 resolving all safety issues before the issuance of the
2 license. And the staff needs information sufficient
3 to resolve all its safety issues before that. Now,
4 some of the industry has told us in certain areas that
5 this information may not necessarily be available, but
6 there's still -- I mean, in some areas I think they're
7 looking at this from a Part 50 type strategy.

8 And I will just tier off of what Mr. Rubin
9 said, just that when you discuss bounding analyses or
10 bounding things, the staff is going to need, in those
11 areas where that information is not available, like
12 for instance that particular piece of equipment has
13 not been procured yet, the licensee -- the applicant
14 is going to have to make -- providing bounding
15 information such that the staff will be able -- at the
16 time of the license be able to resolve all safety
17 issues.

18 So, and that has been a fundamental
19 discussion that we've been having.

20 MEMBER APOSTOLAKIS: So the time of the
21 license is when? I suspect when it is, but when is
22 it?

23 MR. COLACCINO: Well, the timing of the
24 license will be before -- you know, we think -- the
25 way that we hear -- the industry discusses it will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 before the vast majority of the construction has been
2 started. I mean, Part 52 does tell them that they can
3 proceed at their risk, and the information that the
4 industry has been telling us is that they are very
5 cognizant of this risk.

6 MEMBER APOSTOLAKIS: So at that point, you
7 should have either specific information or some sort
8 of bounding information that after they build it what
9 they promise will, in fact, be met.

10 MR. COLACCINO: And that's what's embodied
11 -- what should be embodied at the staff -- you know,
12 if we've done it correctly, it should be embodied in
13 the ITAAC, the verification process.

14 MEMBER APOSTOLAKIS: It's just that I
15 didn't get that feeling of the time sequence of events
16 by anything in the document.

17 MR. COLACCINO: And -- you know, and when
18 the document was developed, you know, quite frankly we
19 looked at this from a very generic basis. And I'll
20 just take one of the timing -- I think it's the
21 classical one -- is the meteorology example is that we
22 have given a document that they needed two years of
23 met data, but the COL applicants have told us they
24 won't have that in time, but they want it at a later
25 point.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, I mean, this is -- I just wanted to
2 say that this is one of the predominant discussions we
3 had in the workshops.

4 Thank you.

5 MEMBER APOSTOLAKIS: Thank you very much.

6 MEMBER CORRADINI: Since George raised it
7 now, but I expect -- if you're going to get to this,
8 I'll defer -- is that said actually at the
9 subcommittee last time said it best, which is in some
10 sense DG-1145 is a checklist of all the things that
11 the licensee has to remember to have ready either by
12 substantive information, bounding information, or an
13 ITAAC to show the process to resolve it, and then pass
14 all this information on to you all, and then you will
15 then look at that information and say, "Okay. We have
16 enough to proceed, or we don't have enough to
17 proceed."

18 So the timing in some sense is they think
19 they know the right time. They send it over the fence
20 to you. You look at what's given, compare it to 1145
21 saying you've got to have this, you've got to have
22 that, you've got to have this, you've got to have
23 that. And then you say, well, we're missing something
24 here. What about this?

25 So in a sense it's a checklist to minimize

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the communication back and forth. Do I have it
2 approximately right?

3 MR. OESTERLE: I would say very, very
4 approximately. It's much, much more --

5 (Laughter.)

6 -- much, much more than a checklist. It
7 provides applicants with the -- with guidance on the
8 entire set of information --

9 MEMBER CORRADINI: Right. But it's --

10 MR. OESTERLE: -- that's needed, and it
11 also contains a checklist.

12 MEMBER CORRADINI: But it's a guide that
13 tells -- as we went through it last time, it's a guide
14 that tells them for this particular thing, take
15 Chapter 6, go look at this rule, this guidance. For
16 PRA, go look at this rule, this guidance. Am I --

17 MR. OESTERLE: It includes that. It's
18 more of a roadmap than a checklist. If you want to
19 give --

20 MEMBER CORRADINI: Excuse me. That's a
21 much better characterization. I apologize.

22 MR. OESTERLE: If you want to give some
23 specific technical guidance, this DG-1145 document
24 does point you to specific technical regulatory guides
25 and industry standards for that technical guidance.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This is the roadmap for how to put together your
2 application and what information it needs to contain.

3 MEMBER CORRADINI: But then, as a roadmap,
4 the timing of when this roadmap -- the timing at which
5 you then submit down the road is not given. So in
6 some sense it -- following the roadmap gives you
7 enough information to say this is an appropriate time
8 that we can actually understand where you're going and
9 the timing is right, or generates questions.

10 MR. OESTERLE: I would say that the
11 guidance document assumes that the large majority of
12 information is required at the time of submittal.

13 MEMBER CORRADINI: Right.

14 MR. OESTERLE: There are specific areas
15 where information is not available at that time, and
16 the guidance document will reflect, I would say,
17 options that the applicant has, which we'll discuss
18 also a little bit later this morning, on either
19 providing that information, updating that information,
20 or verifying that the as-built or as-procured
21 information conforms with the design as licensed.

22 MEMBER APOSTOLAKIS: How long is the
23 process expected to take?

24 MR. OESTERLE: I'm not in a good position
25 to answer that question. This is guidance for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicant to provide us with the information. If
2 you're asking me, how long does it take the staff to
3 review that application and issue the license, I'm not
4 knowledgeable enough to answer that question.

5 MEMBER APOSTOLAKIS: Do you --

6 MR. OESTERLE: Perhaps another member of
7 the staff could.

8 MR. WILSON: Jerry Wilson, Office of New
9 Reactors. We have planning assumptions. The specific
10 answer, of course, is very case-dependent. Just
11 recalling off the top of my head, why don't you assume
12 three years. You know, it depends on what they're
13 referencing or not referencing, and a variety of other
14 factors.

15 MEMBER APOSTOLAKIS: But from the time of
16 submission.

17 MR. WILSON: Yes.

18 MEMBER APOSTOLAKIS: Okay. To the
19 license. Okay. Thank you very much.

20 MR. OESTERLE: Okay. Moving on, for
21 several years prior to the development of DG-1145, the
22 staff was engaged with the industry, in particular
23 Nuclear Energy Institute, otherwise known as NEI, in
24 their effort to develop guidance for COL applicants.
25 And that document was NEI 04-01.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The guidance developed in NEI 04-01 was
2 considerable. However, it considered what we call the
3 base case. That is, the base case is a COL
4 application that referenced a certified design and an
5 early site permit. In addition, although this
6 guidance document had a very substantial amount of
7 usable information and guidance, it was focused
8 predominantly on one standard design, the AP1000,
9 which had yet to be certified.

10 During staff reviews of NEI 04-01,
11 consistent questions came up about a roadmap -- how do
12 we use this document to get us to where we need to be
13 in terms of issuing a license? And the guidance in
14 DG-1145 attempted to provide that roadmap.

15 During the last quarter of 2005, following
16 approval of the Energy Policy Act, the NRC engaged in
17 interactions with a growing number of external
18 stakeholders who expressed serious interest in
19 applying for a COL.

20 The increase in the number of potential
21 COL applicants resulted in the possibility for several
22 different COL application scenarios. That is, the
23 staff heard about potential plans for COL applications
24 referencing a certified design, COL applications
25 referencing design certifications in progress, COL

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applications referencing an early site permit and a
2 design certification in progress, etcetera.

3 So it became clear to the staff as a
4 result of these interactions that a more comprehensive
5 guidance document for COL applicants was needed. And
6 at that time, the staff did not hear from any
7 particular applicant that would meet the base case.
8 That is, no COL applicant was talking about
9 referencing a certified design and an early site
10 permit. In response to those discussions with
11 external stakeholders, the staff began development of
12 DG-1145.

13 To develop DG-1145, the staff went back to
14 Reg. Guide 1.70, which was the standard format and
15 content of safety analysis reports for nuclear
16 powerplants, lightwater reactors. And with that being
17 said, DG-1145, using Reg. Guide 1.70 as its basis,
18 also provides guidance to that limited set of
19 reactors, lightwater reactors. It does not provide
20 guidance to high-temperature, gas-cooled reactors or
21 other non-LWR reactors.

22 Project managers were assigned the heavy
23 lifting, if you will, during the drafting of the
24 initial sections of DG-1145 using Reg. Guide 1.70 as
25 the basis and updating it to include information from

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 updated SRPs including the draft '96 updates of the
2 standard review plan, guidance contained in the draft
3 NEI 04-01 document, and experience from NRC
4 certification of standard designs, experience from NRC
5 reviews of ESP applications, and numerous SECY papers
6 and their associated SRMs that were related to new
7 reactor licensing.

8 These draft sections of DG-1145 were
9 provided to staff technical reviewers to update,
10 refine, and include any additional applicable
11 guidance.

12 The format and content requirements for
13 DG-1145 was also based on the proposed Part 50 rule
14 that was issued in March of this year. Planning for
15 the development of DG-1145 took place during the
16 latter part of 2005, and in January of this year is
17 when we started developing DG-1145 in earnest.

18 Upon completion of the draft work in
19 progress sections of DG-1145, they were placed on the
20 NRC's public website. Monthly public workshops were
21 held beginning in March 2006 to discuss these draft
22 work in progress sections that had been completed, and
23 public comments and feedback were solicited on these
24 sections.

25 The public workshops continued through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 September of 2006, even though all draft work-in-
2 progress sections were posted on the NRC's public
3 website by June 30, 2006.

4 This was an extraordinarily intense and
5 focused effort over six months, and took place in the
6 public domain. External stakeholder participation and
7 involvement was consistently high and very
8 constructive.

9 The public workshops resulted in over 500
10 comments, which the staff reviewed, resolved, and
11 discussed with external stakeholders, and included in
12 an appendix to DG-1145 when it was issued as a draft
13 for public comment. Incorporation of these public
14 workshop comments took place during July and August --
15 a challenging time for any major work activity.

16 The draft was issued for a 45-day public
17 comment period on September 7, 2006. But prior to
18 that, on September 1st, the draft DG-1145 document was
19 made available to external stakeholders on the NRC's
20 public website.

21 The format and structure of DG-1145 is
22 consistent with the structure of other NRC regulatory
23 guides. Part C, which provides the regulatory basis
24 and the real heart of this regulatory guide, is
25 divided up into four different sections. Part C.1

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provides guidance for a COL applicant that references
2 neither a certified design nor an early site permit,
3 and it is often referred to as a custom design.

4 It reflects the requirements and it's
5 consistent with the information content requirements
6 of 10 CFR Part 52.79, again, as it was proposed in
7 March of 2006.

8 In Section C.1, although it was not
9 intended to be guidance for a design certification
10 applicant, much guidance can be gleaned from this
11 section by such an applicant, and we have been told of
12 that effect by General Electric as they were
13 developing their ESBWR certification.

14 It was also anticipated that Section C.1
15 could provide some benefit for guidance to a COL
16 applicant referencing a certified design in progress.

17 Section C.2 provides guidance on the
18 requirements for additional technical information and
19 is consistent with the proposed requirements of
20 Part 52.80.

21 Section C.3 developed guidance for COL
22 applicants referencing certified designs and early
23 site permits and provides guidance associated with
24 topics unique to these scenarios.

25 Part C.4 provided guidance on

1 miscellaneous topics associated with the COL
2 applications and new reactor licensing.

3 Now, to help clarify the differentiation
4 between these sections, I've provided a little
5 viewgraph that hopefully puts things in better
6 context.

7 This large gray stack you may want to
8 consider as the entire stack of information that a COL
9 applicant needs to submit, whether they reference a
10 certified design and early site permit or not.

11 Sections C.1 and C.2 of DG-1145 provide
12 information for the entire stack needed by a COL
13 applicant.

14 In Section C.3, C.3.1 provides guidance
15 for a COL applicant that references a certified
16 design. So you can see, although this stack is not to
17 scale, you can see that there is a large portion of
18 information that has already been resolved by the
19 certified design, and that -- the portion on early
20 site permit information and remaining information is
21 what that type of applicant would need to submit,
22 remaining information being information on site-
23 specific design features, like cooling towers or
24 intake cooling structures or that sort of thing.

25 CHAIRMAN WALLIS: Now, is the size of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 these boxes supposed to represent the amount of effort
2 or content or something? Because it looks as if
3 there's a real advantage to having an ESP, and the
4 remaining information looks pretty small. Is that
5 realistic, what you have up there?

6 MR. OESTERLE: In general, yes. Although
7 it's not to scale, the way this has been represented
8 is designed to show that there are some advantages to
9 resolving safety issues early on in the process by
10 referencing a certified design and an early site
11 permit, and that was fundamentally the intent of the
12 Part 52 process -- early resolution of safety issues.

13 CHAIRMAN WALLIS: And there are people who
14 have an ESP without a certified design, where one is
15 underneath the other.

16 MR. OESTERLE: Right.

17 CHAIRMAN WALLIS: Is that permutation
18 covered by this picture or --

19 MR. OESTERLE: No, it's not.

20 MEMBER CORRADINI: Does that exist -- does
21 what Graham just said really occur? I wasn't aware of
22 that.

23 MR. COLACCINO: This is Joe Colaccino from
24 the staff. All the COL applicants are referencing
25 designs that are either certified or under review. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ultimately everyone will reference a design that is
2 certified.

3 MEMBER POWERS: I guess it a little bit
4 depends on what you mean by "under review." I mean --

5 MR. COLACCINO: I'm sorry. Actually,
6 thank you very much. Either -- there is a third
7 permutation for that, because with the EPR we actually
8 do not have that design certification application.
9 Thank you for pointing that out.

10 MR. OESTERLE: So Sections C.3.1 and C.3.2
11 were intended to provide guidance for COL applicants
12 referencing a certified design and an early site
13 permit. C.3.2 really identifies guidance for what we
14 previously referred to as the base case, a COL
15 applicant referencing both a certified design and an
16 early site permit.

17 CHAIRMAN WALLIS: So in terms of the ACRS
18 work on this, the bottom box is by far the biggest.
19 What do we have to do with the remaining information,
20 if anything? How much work is involved for us with
21 what you call "remaining information"?

22 MR. WILSON: This is Jerry Wilson, Office
23 of New Reactors. I'd first like to emphasize the
24 point Mr. Oesterle made that that diagram is not to
25 scale. So let's not try and draw too many conclusions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from it.

2 Now, focusing on the remaining
3 information, a key facet there are the operational
4 programs that the licensee is going to use to operate
5 their plant. Those clearly have safety significance,
6 and I would envision that the Committee would want to
7 review those programs.

8 MEMBER MAYNARD: There would also, I would
9 assume, be some site-specific issues with cooling,
10 whether it's cooling towers, your essential surface
11 water system. They are some site-specific things that
12 also are going to get into some of the safety systems,
13 too.

14 MR. WILSON: That's correct.

15 MEMBER APOSTOLAKIS: But we will have to
16 write a letter on the license itself, right? So
17 whatever it takes to help us write that letter we will
18 do.

19 MR. OESTERLE: The remaining set of
20 information also depends on the specific reactor
21 technology that is referenced in the certified design.
22 For example, we have reactor designs that incorporate
23 passive safety systems that have already been
24 certified or are under certification review, and we
25 have reactor designs that are in pre-application

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 process that incorporate the traditional active safety
2 systems.

3 So for the COL applicant it really depends
4 on which one of those reactor technologies they
5 choose.

6 CHAIRMAN WALLIS: I'm just trying to look
7 at sort of our workload. I know that certifying the
8 design takes many subcommittee meetings and a lot of
9 technical work. Early site permits we have some
10 experience with. We have some idea how big that
11 workload is. And it may be that the remaining
12 information is about the same effort as the early site
13 permit or could in some cases be more, couldn't it?

14 MR. COLACCINO: It could -- this is Joe
15 Colaccino. It could certainly be more. And I'll just
16 point out that of the 19 COLs -- I don't know what the
17 number is today. I haven't checked. I haven't
18 checked this morning. But only three of them
19 reference an early site permit, so 16 of them do not.
20 And that's very important. So that there will be a
21 number -- you know, the COL referencing an ESP and a
22 design certification is really more the exception than
23 the rule.

24 MEMBER MAYNARD: Well, even those with an
25 early site permit, not all the early site permits are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a complete, everything included type permit. There
2 are still out issues or questions to still be
3 submitted and resolved as part of the COL application,
4 too.

5 MR. OESTERLE: Right.

6 MEMBER POWERS: How many of the COL
7 applications that you've looked at up 'til this
8 morning have greenfield sites?

9 MR. COLACCINO: Well, we haven't gotten --
10 this is Joe Colaccino again. We haven't -- obviously,
11 we haven't gotten any COL applications. But of the 19
12 that are in, I don't know if there are any. I don't
13 think there are any that are in the first wave, or at
14 least in the -- like I said, I haven't checked. But
15 I'm not going to say that 100 percent sure, because I
16 don't have the list in front of me.

17 MEMBER POWERS: Sure.

18 MR. COLACCINO: One comes to mind, but I
19 don't know if that -- I think the vast majority -- I
20 think I'd be safe to say that the vast majority are at
21 a -- have operating reactors adjoining the site.

22 MR. OESTERLE: All right. Moving on, I
23 just want to show the makeup of Section C.1. It
24 includes all of the traditional FSAR chapters with
25 some additions. Chapter 19 is a new chapter, and that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will include the results of the PRA. Chapter 1 has an
2 asterisk by it as well. The reason being is that that
3 chapter is expanded, based on the information that is
4 provided in the certified designs.

5 MEMBER APOSTOLAKIS: You said Chapter 19
6 will be the results of the PRA, but not the PRA
7 itself.

8 MR. OESTERLE: That's correct.

9 MEMBER APOSTOLAKIS: And why is that?

10 MR. OESTERLE: The reason for that is the
11 Part 52 rule, as I mentioned this morning --

12 MEMBER APOSTOLAKIS: Yes.

13 MR. OESTERLE: -- DG-1145 provides
14 guidance, and the rule rules. The current Part 52
15 rule does not require submittal of a PRA. However, it
16 does require that the results of the PRA are included
17 in the FSAR portion of the application.

18 MEMBER APOSTOLAKIS: But you cannot take
19 them at face value. I mean, the moment you look at
20 some results you will ask questions, how did you get
21 this, how did you get that. So, I mean, how do you
22 convince yourselves that the PRA results are valid?

23 MR. OESTERLE: On that point, I'm going to
24 defer to Donnie Harrison.

25 MR. HARRISON: This is Donnie Harrison

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 again with the Division of Risk Assessment. If we can
2 maybe defer for another 15 minutes, we'll get to some
3 slides that talk explicitly about that.

4 MEMBER APOSTOLAKIS: Fine.

5 MR. HARRISON: So, but you're right.

6 MEMBER APOSTOLAKIS: I am right. So we
7 did defer it, then. Why did you want to defer it?
8 You said I'm right.

9 (Laughter.)

10 CHAIRMAN WALLIS: George, this is a
11 question raised by the subcommittee. We had quite a
12 discussion about it, and I would very much appreciate
13 your discussion of it as well, you know, when we get
14 to it. We spent some time on this in the
15 subcommittee.

16 MEMBER SIEBER: On the other hand, the
17 Commissioners told him to do it this way.

18 MR. HARRISON: That's correct.

19 MEMBER APOSTOLAKIS: But from the
20 practical point of view, I'm trying to understand what
21 will happen.

22 MEMBER SIEBER: Well, you can ask all the
23 questions you want.

24 MEMBER KRESS: Well, the short answer is
25 that the PRA will be available for audit by the staff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 That's the short answer.

2 MEMBER APOSTOLAKIS: How about -- I mean,
3 are there going to be 365 RAIs flying all over the
4 place? I mean, you get the PRA eventually piecemeal,
5 is that really -- well, I'll -- we'll wait until
6 Donnie --

7 MR. HARRISON: Yes, we'll get there.

8 MEMBER APOSTOLAKIS: -- gets to the hot
9 seat.

10 MR. HARRISON: Okay. Thank you.

11 MR. OESTERLE: Moving on to Part C.2, the
12 format of Part C.2 also was based on the proposed
13 Part 52 rule issued in March of this year. And that
14 included requirements -- or this included guidance on
15 the PRA, ITAAC, and the environmental report. The
16 latest Part 52 rule that was sent to the Commission
17 will require a change in these topics.

18 For example, just like I mentioned, the
19 Part -- the current Part 52 rule with the Commission
20 now does not require submittal of the PRA, so much of
21 the guidance from C.2.1 will be relocated to
22 Chapter 19.

23 Part C.3 includes guidance for COL
24 applicants referencing certified design and an ESP.
25 Those -- that guidance is provided in Section C.3.1

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and C.3.2. The additional sections under C.3 provide
2 guidance for topics associated with COL applicants
3 that reference a certified design and an ESP, like the
4 finality of an environmental impact statement
5 associated with an early site permit, COL action items
6 that are included in certified designs and early site
7 permits, design acceptance criteria that are included
8 in certified designs, COL application timing, which
9 addresses the scenario where a COL applicant
10 references a design certification in progress, for
11 example, and then ITAAC for COL applications
12 referencing a certified design and/or an early site
13 permit. Part C.4 also includes guidance on
14 miscellaneous topics related to COL application.

15 And to wrap this up, I'll go over the
16 status of DG-1145. The comment period for DG-1145
17 closed on October 23, 2006.

18 CHAIRMAN WALLIS: I'm curious about this
19 certified design in progress. Does that mean that the
20 design itself is in progress, or that the
21 certification is the only thing which is in progress?

22 MR. OESTERLE: The certification is --

23 CHAIRMAN WALLIS: The design would have to
24 be complete?

25 MR. OESTERLE: As complete as required by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the design certification guidance.

2 CHAIRMAN WALLIS: Thank you.

3 MEMBER APOSTOLAKIS: Now, when you say 700
4 total comments received, I mean, we have a long list
5 of NEI comments.

6 MR. OESTERLE: Yes.

7 MEMBER APOSTOLAKIS: These are counted
8 here. I mean, they don't count as one.

9 MR. OESTERLE: Yes. All those -- that
10 entire list of NEI comments, plus a few additional
11 comments, comprise that 700 number. Right. They
12 include typos and editorials and some larger issues.

13 Staff is currently working on resolving
14 these public comments and revising DG-1145 as
15 appropriate, and also revising DG-1145 to conform with
16 the final proposed Part 52 rule that went to the
17 Commission.

18 CHAIRMAN WALLIS: Now, are these going to
19 result in any substantial changes? Say, because, you
20 know, we have seen the version, and we think -- do you
21 anticipate any significant change as a result of the
22 public comments?

23 MR. OESTERLE: In some areas, the comments
24 are consistent with the changes in the Part 52 rule.
25 So with respect to those changes, yes, there will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some significant changes, although minimal.

2 CHAIRMAN WALLIS: Significant, although
3 minimal. That's --

4 MR. OESTERLE: The number of --

5 (Laughter.)

6 The number of significant changes will be
7 small.

8 (Laughter.)

9 MEMBER APOSTOLAKIS: One would expect
10 that. I mean --

11 MR. OESTERLE: We have a process in place
12 to ensure consistency between DG-1145 and the updates
13 to the standard review plan and the updates to
14 regulatory guides. We have project managers assigned
15 to DG-1145 sections for coordination and resolution of
16 public comments with tech staff, and they are also
17 assigned the same sections for the SRP updates for --
18 to ensure the coordination and consistency.

19 The plan is to publish DG-1145 final as
20 Reg. Guide 1.206 after incorporation of these public
21 comments and final issuance of the Part 52 rule.

22 The staff is considering additional public
23 forums to update external stakeholders on Reg.
24 Guide 1.206 prior to publication. And we are looking
25 at such things as putting the completed sections of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Reg. Guide 1.206 up on the NRC's external website, and
2 we're also looking at holding a public workshop, board
3 workshops.

4 MEMBER MAYNARD: I don't know if you're
5 going to cover this later or not, but on the standard
6 review plan, consistent with the reg. guide standard
7 review plan, one of the comments that I had on 1145 is
8 that it referenced a whole lot of generic letters,
9 branch technical positions, and the staff is going
10 through reg. guides and updating them to new rules.

11 I didn't understand the need for
12 referencing a lot of old correspondence. I'm not sure
13 why the SRPs and reg. guides can't be brought up to
14 date.

15 MR. OESTERLE: In fact, one of the changes
16 that we need to make to the guidance document to
17 conform with the final proposed Part 52 rule is to
18 update the requirement associated with looking at
19 incorporation of operational experience contained in
20 those old generic letters and bulletins.

21 There is a new requirement that doesn't go
22 all the way back to, say, 1980. It just makes you
23 look at more recent examples.

24 MEMBER MAYNARD: It just seems like it's
25 -- it would be a lot cleaner for everyone if we could

1 clean all that up maybe.

2 MEMBER SIEBER: Well, this whole effort is
3 schedule-driven, I think.

4 MR. OESTERLE: Yes.

5 MEMBER SIEBER: And that's why some of the
6 intermediate documents are not being consolidated and
7 updated. They're just referenced to carry them along
8 as a package, and it's more complicated this way.
9 Otherwise, we would be two years getting all this
10 done, I think, if you had to go back and do that work
11 for each one of the sub-level reg. guides that are
12 involved, and standards.

13 MR. OESTERLE: And that's a good segue
14 into the next slide.

15 MEMBER APOSTOLAKIS: This Committee will
16 have a chance to review the final version of the
17 regulatory guide.

18 MR. OESTERLE: The final version of Reg.
19 Guide 1.206?

20 MEMBER APOSTOLAKIS: Yes. Sorry? This is
21 it?

22 MR. OESTERLE: I understand this is --

23 MEMBER APOSTOLAKIS: But you are going to
24 change things.

25 MR. OESTERLE: We were requested to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provide an informational briefing, and that's what
2 we're doing today.

3 MEMBER APOSTOLAKIS: No. I understand
4 what you are doing today. But even if we issue a
5 letter this time around, when do we issue --

6 MEMBER SIEBER: If they issue it again, we
7 have an opportunity to review it again.

8 CHAIRMAN WALLIS: If the changes turn out
9 to be significant and not minimal --

10 MEMBER APOSTOLAKIS: Who will judge that?

11 CHAIRMAN WALLIS: -- then I think you
12 might want to let us know. And we have, then, a
13 choice of saying whether or not we want to comment on
14 those changes.

15 MEMBER APOSTOLAKIS: David?

16 MR. FISCHER: I was going to say the same
17 thing. If we want, in our letter we could ask them to
18 report on significant changes that are made to DG-
19 1145.

20 MEMBER APOSTOLAKIS: It seems to me this
21 is important enough for the Committee to plan on
22 writing a letter when 1.06 is in its final draft form.
23 The letter may be, "It's very good. Thank you." But
24 I think we should plan on writing a letter, not rely
25 on somebody's judgment that these changes are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 significant. We should make that judgment.

2 MR. OESTERLE: To put this all into
3 schedule context, we are schedule-driven, and this
4 shows the reason for the schedule. If you look all
5 the way over on the right, we anticipate the first new
6 COL applications coming in around September of '07.
7 And with the -- at least one requirement of Part 52
8 for applicants to evaluate the standard review plan in
9 effect six months prior to docketing.

10 So if we go back six months, that brings
11 us to March. So that is one of the drivers for the
12 schedule on Reg. Guide 1.206.

13 And with that, that concludes my prepared
14 remarks on DG-1145 overview. Next is a presentation
15 on probabilistic risk assessment.

16 MEMBER APOSTOLAKIS: Did you make -- did
17 members make detailed comments on the PRA at the
18 subcommittee meeting?

19 MEMBER KRESS: We had a significant
20 discussion on it, yes.

21 VICE CHAIRMAN SHACK: I think we addressed
22 all the comments that you made in your e-mails to us.

23 MEMBER CORRADINI: Yes, I think they
24 overlap to some extent, too.

25 MEMBER APOSTOLAKIS: Okay. So I shouldn't

1 raise them again, then?

2 VICE CHAIRMAN SHACK: You can raise them
3 again, so you get your answers, but we did discuss
4 them.

5 MEMBER APOSTOLAKIS: Okay. Do we get the
6 same answer today?

7 (Laughter.)

8 MEMBER KRESS: One reason we put this on
9 the agenda is because we knew you'd be here --

10 MEMBER APOSTOLAKIS: Okay.

11 MEMBER KRESS: -- and could take advantage
12 of this opportunity.

13 MR. HARRISON: My name is Donnie Harrison.
14 I'm with the Division of Risk Assessment. And for the
15 members that were here at the subcommittee meeting,
16 this is going to look very familiar. We're basically
17 going to present the same information and --

18 CHAIRMAN WALLIS: So we didn't change your
19 mind in any way at all.

20 (Laughter.)

21 MR. HARRISON: We had lots of discussion,
22 but we didn't have any resolutions I guess.

23 What we're going to talk about is -- the
24 first thing will be the recent change that was made to
25 Part 52, and its impact on the staff's review, and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guidance document. We'll then briefly talk about the
2 bases for the regulatory guidance, where the PRA bases
3 come from, the grouping of the objectives of the PRA
4 and severe accident evaluations, and then just an
5 outline of what the Chapter 19 of the FSAR regulatory
6 guidance is.

7 As hopefully as you're aware of by now is
8 -- in the proposed rulemaking there was a requirement
9 under 52.80(a) that the PRA be submitted as additional
10 technical information. So it was addition to the
11 Chapter 19 of the FSAR by the applicant.

12 We got public comments on that. After
13 completion of the draft guide, our original approach
14 was to reject the public comment and to maintain the
15 requirement for the submission of the PRA. After we
16 drafted the DG-1145, that NRC position was changed,
17 and we accepted the public comment, that the PRA did
18 not need to be submitted but needed to be maintained
19 available for staff audit at the vendor or plant site
20 location.

21 MEMBER CORRADINI: Just -- you probably
22 did this, and I just don't -- I didn't write it down,
23 so it's my memory. What was the rationale for the
24 public comment that didn't -- that suggested that it
25 not be submitted? Can you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: It's basically this basis.
2 It's that it wasn't necessary to submit it because it
3 would be available for review to the staff at an
4 offsite location. So the submission was --

5 MEMBER CORRADINI: And, logistically, that
6 -- from the comment that was better, you know, and no
7 worse, not a burden? The logistics of it are kind of
8 still throwing me.

9 MR. HARRISON: Well --

10 MEMBER CORRADINI: But is that -- what
11 that discussed at all?

12 CHAIRMAN WALLIS: That seems to -- we said
13 this at the subcommittee. This seems extraordinary.
14 I mean, with modern electronics, it's no different to
15 send it than to have it available at your site.

16 MEMBER APOSTOLAKIS: It's just a CD.

17 MEMBER SIEBER: It's not uncommon to have
18 documents like this available only at the plant site,
19 you know, not only PRAs but other kinds of documents.
20 This is not unusual.

21 MEMBER CORRADINI: You gave some examples.
22 What were a couple of those that you mentioned that
23 were --

24 MEMBER APOSTOLAKIS: You have to speak
25 into the microphone.

1 MEMBER CORRADINI: Sorry.

2 MEMBER SIEBER: There aren't submitted --
3 a lot of tech spec bases aren't submitted. They are
4 submitted in summary form, but the real basis or the
5 technical basis is at the plant. Perhaps the staff
6 can come up with a couple of others like that.

7 MR. HARRISON: The details of the
8 Chapter 15 analyses, the thermal hydraulic codes,
9 those are not -- those aren't submitted.

10 MEMBER SIEBER: The reload safety analysis
11 is --

12 MR. HARRISON: The detailed analysis --

13 MEMBER SIEBER: -- just a letter? But it
14 does not have the analysis connected to it and is not
15 submitted?

16 MEMBER APOSTOLAKIS: But maybe that was
17 appropriate at the time when everything was on paper.
18 I mean, this is a matter of submitting a CD.

19 MEMBER SIEBER: Well, it's appropriate
20 now. That's the way it is now, today.

21 MEMBER APOSTOLAKIS: Yes. But, I mean,
22 because of the tradition. But now, you know, a CD is
23 -- you know, a PRA can be there.

24 CHAIRMAN WALLIS: There has to be another
25 rationale. I think in the subcommittee we talked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about the business of it -- there being some reason,
2 legal reason or something that this should not be
3 officially part of the application.

4 MEMBER MAYNARD: Well, there are --

5 CHAIRMAN WALLIS: But it still should be
6 available.

7 MEMBER MAYNARD: -- number of reasons
8 other than just, I mean, you can submit anything quite
9 easily on a CD. But whenever you start submitting
10 things on the docket, there are -- you do incur --
11 there's more legal issues, there's more complications
12 as to what has to be done, the reviews of that. You
13 have other regulations that start coming into play
14 that makes it far more complicated than if you can
15 just have the document available for review at the
16 site. So there are a lot of good reasons for that.

17 MEMBER BONACA: And one example is, by the
18 way, you know, now you have this information in great
19 detail in the hands of another analyst who may raise
20 questions on a daily basis about things which are in
21 the PRA. And that's some of the reasons for them --
22 for concern about submitting a PRA.

23 The other one is the PRA will change all
24 the time. There will be modifications, and so on and
25 so forth. So there is -- I think the applicant will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 submit a PRA.

2 I'm just telling you what I've seen in the
3 past. The applicant submits a PRA. He will have to
4 commit practically to submitting every modification he
5 makes to the PRA, because he has a document submitted
6 on the docket that now has changed. So there has to
7 be some change process that is -- goes together with
8 that. So there are a number of issues which I'm not
9 -- which have to be dealt with when you submit that
10 kind of information.

11 MEMBER CORRADINI: If I might just -- if
12 this is appropriate, I just wanted to ask, though,
13 Mario -- the second part of that -- I thought last
14 week, now I may have misheard again, that there is no
15 requirement that the PRA be updated. So this is --
16 even if it was a static document, having it reside at
17 the locale versus somehow here is in some sense a
18 filter for -- now I'm going to say this, and maybe
19 this is an inappropriate -- a filter for unwanted,
20 just I want to call it useless interchange, whereas if
21 it were here you could get a lot of people asking
22 questions that would just not be -- it would be
23 appropriate for the licensee and the staff to deal
24 with.

25 MEMBER BONACA: I think the issue --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mentioned the changes, because the PRA will change all
2 the time.

3 MEMBER CORRADINI: But it's not required,
4 though.

5 MEMBER BONACA: It's a critical issue.
6 That's a central issue. If, in fact, you perform a
7 PRA and put it on a shelf, I would say that any
8 licensee wouldn't care. I mean, that's fine. Put it
9 on the shelf, put it on --

10 MEMBER CORRADINI: And I would say --

11 MEMBER BONACA: -- it stays there, and
12 that's it. It becomes an obsolete document very
13 quickly.

14 MEMBER SIEBER: If you submit it to the
15 agency, it becomes a public document.

16 MR. HARRISON: Well, no, not in this
17 situation. It would have been under -- Part 52.80(a)
18 would have been additional information. It would not
19 be part of the FSAR. So it would have been -- it
20 would be docketed but not available, if you will.

21 MEMBER MAYNARD: Well, it's still
22 available. I think anything admitted is available,
23 unless you are able to get it withdrawn.

24 MR. COLACCINO: Yes. This is Joe
25 Colaccino. Just a clarification on a point Donnie

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 just made. If it was submitted on the docket, then it
2 would be available to the public.

3 MEMBER MAYNARD: That's right.

4 MR. COLACCINO: So in this scenario, the
5 way it's now proposed in Part 52, it would be
6 available at the site for staff audit.

7 MEMBER MAYNARD: Right.

8 MEMBER APOSTOLAKIS: But it could be
9 submitted according to Donnie and not be available to
10 the public.

11 MR. COLACCINO: And this came up -- Joe
12 Colaccino again. That came up last week, is that
13 we're -- certainly, there isn't anything in Part 52
14 right now that would preclude an applicant from
15 submitting their PRA.

16 MR. RUBIN: And also, there are procedures
17 in place to submit information and withhold it from
18 public disclosure, such as proprietary withholdings,
19 which many PRAs have come in with, or safeguards
20 material.

21 MEMBER SIEBER: On the other hand, that's
22 just not a rubber stamp. You actually have -- there
23 actually has to be proprietary stuff in there.

24 MR. HARRISON: page by page verification.

25 MEMBER SIEBER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: So just to drive the
2 point home, if -- let's take the path that Eric had
3 mentioned, which is -- or somebody had mentioned,
4 there is 19 out there and they all had design
5 certifications, either on the docket or being
6 reviewed. All of those design certifications have a
7 PRA attached to them, correct?

8 MR. HARRISON: Correct.

9 MEMBER CORRADINI: And those are part of
10 the record already, public record?

11 MR. HARRISON: Correct. Yes.

12 MEMBER CORRADINI: So the --

13 VICE CHAIRMAN SHACK: But the EPR one
14 won't be submitted, as I understand it.

15 MEMBER CORRADINI: Well, I thought I heard
16 the opposite last week.

17 MR. WILSON: This is Jerry Wilson. Let me
18 give a little bit of background from a rulemaking
19 perspective.

20 MEMBER CORRADINI: Let me finish my
21 question, and you can see why I'm asking it, because
22 then what I'm kind of thinking from my head is if
23 Mario's point about certain things are reasonable
24 because they'd be there, then it would be things
25 related to the site -- to site-specific issues. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the base, full scope, whatever the right terminology
2 is of the PRA via design certification, is already
3 publicly available.

4 So I know a good deal of where one is
5 going with the plant already, I thought, if I
6 understand this, except now for the one thing that
7 Bill has mentioned, that the EPR may not be in this
8 mode.

9 MR. WILSON: Jerry Wilson. I want to
10 remind the Committee that I and my colleagues on the
11 Part 52 rulemaking working group were here before the
12 Committee with the proposed Part 52 rule, and this was
13 part of what we were discussing at that time. And
14 this Committee wrote a letter on that subject, and
15 I'll call your attention to the fact in the letter,
16 you know, they said that you don't have to submit the
17 PRA.

18 Now, with that in mind, and a couple of
19 other factors that we considered while we were
20 deciding how to put the rule together that we
21 submitted to the Commission, one is that my colleagues
22 in the PRA Branch are working with industry to develop
23 guidance on performing PRAs.

24 It's the expectation of NRO management in
25 the future applicants and licensees will have PRAs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 performed in accordance with that guidance, and in
2 their view would reduce the need for the staff to be
3 reviewing these PRAs to the level of review that we
4 have done in the past.

5 And that factored into this decision as
6 well, and so -- and also, you know, it's a forward-
7 looking rule. We're looking to the future on this.
8 But the other factor is the point that Mr. Harrison
9 mentioned. We have the vision that it's like analyses
10 done for Chapter 15.

11 The applicant summarizes their Chapter 15
12 analysis in their FSAR. But if the details in the
13 analysis aren't submitted, and if the staff feels the
14 need to look at that, they can do it. And so looking
15 forward in the future, NRO management felt that the
16 PRAs could be handled in a similar manner. And that's
17 why the rule is as it is today, that you have to have
18 a PRA. If you reference a certified design, you have
19 to update that PRA to take into account those
20 additional site-specific design features.

21 But you have to submit, as Mr. Harrison is
22 going to point out, the results and summary of the
23 PRA. But the detailed PRA you don't have to submit.
24 That's the staff's view at this point in time.

25 MEMBER APOSTOLAKIS: If the staff has a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question about a particular number or result, they
2 would have to go to the site to find out why this is
3 so, or they can request information that will be
4 submitted?

5 MR. WILSON: Both options are available.
6 As in anything else, it's like thermal hydraulic
7 analyses that this Committee looks at. They don't
8 necessarily submit the details of that, but the staff
9 either goes out and does an audit at the vendor's
10 place or asks questions and has additional information
11 provided.

12 MR. HARRISON: And, George, just -- the
13 jump forward, on the next slide we talk about the
14 impact of that change, and one of the impacts is for
15 us to be able to understand and confirm the PRA
16 results and insights. It's expected that we'll need
17 to do audits, and fairly long-term audits, at the site
18 location, so that we can fully understand the PRA and
19 its bases and developing the RAIs even. So we're
20 going to --

21 MEMBER MAYNARD: Yes. But I would contend
22 that you would probably save time in the long run by
23 doing it that way, because otherwise you're going to
24 be going back and forth with requests for information.
25 It's going to be handled, and it's going to take a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 long time and a lot of time on both the licensee and
2 the NRC staff in just reviewing and submitting
3 questions.

4 And you're a lot better off being right
5 there where the information is available. You'll get
6 a lot more resolved in a shorter period of time.

7 MR. HARRISON: Right. And that's the staff
8 -- in response, that's how the staff sees going
9 forward is that that will need to be done.

10 MEMBER BONACA: I would expect that also
11 the staff would develop a SPAR model at some point to
12 these plants, and, you know, to develop that you go to
13 the plant, you sit down with the analysts, and you
14 review the PRA.

15 PRA without the analysts that work on it
16 really it's not very understandable, because there are
17 so many assumptions you have to communicate back and
18 forth what is represented there.

19 MEMBER APOSTOLAKIS: So when this
20 Committee, then, writes a final letter, say approving
21 the license of a particular reactor, we will have to
22 go to the site to review the PRA, to look at the PRA
23 if we want to look at it?

24 MEMBER SIEBER: Yes.

25 MEMBER APOSTOLAKIS: We will have to do

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that?

2 MEMBER SIEBER: Sure.

3 MEMBER APOSTOLAKIS: Why can't we get it
4 on a CD? It's not part of the docket if they give it
5 to us.

6 MEMBER SIEBER: If it's sent to us, it is.

7 CHAIRMAN WALLIS: No, I don't think that's
8 exactly true. I think the subcommittee went through
9 this.

10 MEMBER APOSTOLAKIS: Oh, come on.

11 CHAIRMAN WALLIS: And I thought you said
12 there was nothing that prevented the licensee from
13 sending supplementary information, which could be a CD
14 of the PRA.

15 MEMBER SIEBER: But once it gets into the
16 agency's paper system, it's a public document.

17 CHAIRMAN WALLIS: It's labeled
18 proprietary. It doesn't have to --

19 MEMBER SIEBER: Because it's proprietary
20 or one of these other --

21 MEMBER APOSTOLAKIS: No. But the PRA we
22 have now for the ESBWR, we are not allowed to give it
23 to the public. It says don't do that.

24 (Laughter.)

25 It's a control document, whatever they

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 call it, a control document.

2 MEMBER APOSTOLAKIS: It is proprietary
3 information.

4 MR. RUBIN: Right. This is Mark Rubin.
5 An ESBWR PRA was submitted to the staff, but not as
6 part of the safety analysis report.

7 MEMBER APOSTOLAKIS: So it can be done.

8 MR. RUBIN: It was, but Part 52 says it
9 doesn't need to be submitted.

10 MR. HARRISON: And you need to --
11 actually, take me back to the slide before the last
12 bullet. Under Part 52, under design certification,
13 which an ESBWR was submitted under that guidance, I
14 think that's 5247, they had a requirement that the PRA
15 be submitted.

16 Okay. When the change was made to Part 52
17 to eliminate the requirement in 52.80(a), they made
18 conforming changes. So they also deleted the
19 requirement going forward for plants that make
20 submissions under design certification will also not
21 have to submit a design-specific PRA. Those would be
22 maintained at the design vendor's site for review and
23 audit.

24 MEMBER BONACA: I don't see --

25 MEMBER APOSTOLAKIS: The question is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 really simple.

2 MEMBER BONACA: Yes.

3 MEMBER APOSTOLAKIS: Is this Committee
4 going to have access to it? Or we will be told no,
5 you travel to Texas to see it?

6 MEMBER SIEBER: Well, it's the rule that
7 governs what gets submitted and what doesn't. And the
8 rule says the licensee doesn't have to submit it.

9 MEMBER BONACA: But the question is --

10 MEMBER APOSTOLAKIS: The statutes also say
11 that this Committee has to write a letter.

12 CHAIRMAN WALLIS: What George is saying
13 is, how does this Committee make a decision?

14 MEMBER APOSTOLAKIS: Yes.

15 CHAIRMAN WALLIS: This Committee may say,
16 without the PRA, we would refuse to make a decision.

17 MEMBER MAYNARD: Well, I believe we would
18 be able to get the information that we needed. And I
19 personally don't see a problem if some of this
20 required or would call for us going to the site. I
21 don't think there's -- I think it would be even a good
22 idea for the ACRS to --

23 CHAIRMAN WALLIS: No, that's a
24 tremendous -- the 19 applications this Committee has
25 to travel to sites. That's ridiculous.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Let's face it, none of
2 these applications are risk-informed.

3 MEMBER BONACA: The Thermal Hydraulic
4 Committee makes decisions regarding the adequacy of a
5 LOCA analysis.

6 MEMBER SIEBER: But why do you need to
7 look at it?

8 MEMBER BONACA: Without having the
9 analysis in front, right? I mean, you get the vendor
10 coming in describing to you the analysis, the
11 assumptions. You ask specific questions. You don't
12 have the analysis in front of you. You don't have a
13 computer code with the actual results of everything.
14 You can ask for that, but --

15 CHAIRMAN WALLIS: Sometimes we do get the
16 analysis.

17 MEMBER BONACA: Get information.

18 CHAIRMAN WALLIS: In the case of AP600, I
19 got several boxloads of --

20 MEMBER BONACA: And, in fact, I believe it
21 was for the PRA we are getting the PRA to do the
22 design phase. I think there is a distinction to be
23 made for the reluctance of the licensee at the moment
24 in which you have an operating plant, and you have a
25 docket there. And you now have a commitment -- a moot

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 commitment to so many things in the PRA, including
2 training, operating crews, the assumptions you made in
3 human factors inside the -- they're all inside the
4 PRA.

5 I mean, PRA reaches so far, and as far as
6 I know from the years I was in the industry that was
7 one of the reasons for the reluctance to give the
8 information, because you have a changing model all the
9 time. You are making decisions there regarding --

10 CHAIRMAN WALLIS: I don't think you're
11 right about thermal hydraulics. I have a whole stack
12 of stuff in my -- at home which is to track the GE
13 code that's used for thermal hydraulic analysis.
14 Everything is there, supposedly, all the assumptions
15 and equations and coefficients and everything are
16 there. I can see it.

17 MEMBER CORRADINI: So can I ask an analogy
18 question? Since you had a very good analogy, one of
19 you three back here, which was it's just like a
20 Chapter 15 analysis. You don't want to send all that
21 junk over the wall. It's going to be at the plant.
22 So how is that handled if this Committee was reviewing
23 an old-fashioned reactor with a Chapter 15 analysis in
24 great detail? How is that information properly
25 transferred, so that one could make a decision?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: In the FSAR.

2 MEMBER CORRADINI: And it seems to me --
3 no, no, the results were in the FSAR, the way I
4 understood Jack's point, and all the rest of the stuff
5 was sitting back at the utility or the --

6 MEMBER SIEBER: The vendor.

7 MEMBER CORRADINI: -- at the vendor,
8 excuse me, or whatever.

9 MEMBER SIEBER: They reviewed AP1000, and
10 that's where we went. We went to the vendor's shop in
11 Pittsburgh.

12 MEMBER CORRADINI: Okay.

13 MEMBER SIEBER: That's the way you do it.

14 MEMBER CORRADINI: Okay.

15 MEMBER APOSTOLAKIS: No, but we had the
16 PRA.

17 CHAIRMAN WALLIS: But it's not true that
18 they didn't submit -- as I say, with AP600, which is
19 very much like AP1000, I had several boxloads of stuff
20 sent by Westinghouse, which contained all of the
21 assumptions in their --

22 MEMBER SIEBER: Well, they like to give it
23 to you. On the other hand, under the rule they don't
24 have to give it to you.

25 CHAIRMAN WALLIS: They don't have to, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I just don't think --

2 MEMBER SIEBER: And if you ask them for
3 it, they can say, "Go away."

4 MEMBER CORRADINI: But just from an
5 analogy standpoint, it seems to me, to answer George's
6 question, we would have to follow a similar thing as
7 a Chapter 15 analysis, which is when there's detail
8 there is some protocol that we have to go through.

9 MEMBER SIEBER: And we don't need the PRA
10 to make our decision, because this is not a risk-
11 informed application.

12 MR. SALTOS: Excuse me. This is Nick
13 Saltos. If I can add a clarification between the
14 analogy between Chapter 15 and Chapter 19. Chapter 15
15 requires that they submit their input to the codes to
16 the staff. The analogy in the PRA, the input is the
17 fault trees, event trees, DARTA, all that stuff are
18 input, are not codes. We never ask for codes in a
19 PRA. We never ask for thermal hydraulic codes. We
20 never asked for CAFTA or codes used for quantification
21 for uncertainty analysis. But we always asked for
22 input like fault trees, the logic model.

23 MEMBER BONACA: Well, that's because you
24 already approved the code --

25 MEMBER APOSTOLAKIS: We have that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BONACA: -- the topical, right? We
2 had a topical for --

3 MR. SALTOS: We have that in the
4 certifications that we've had so far. But the
5 proposed rule, I don't know what -- how it is going to
6 be implemented. It talks about a summary description
7 of the PRA. Whatever does that mean? It means that
8 we are not going to have the event trees and the fault
9 trees and the fire analysis. I don't know.

10 CHAIRMAN WALLIS: I might disagree with
11 you, but you never asked the codes. We went through
12 this many times. You did ask for codes, and the ACRS
13 recommended that you were able to run the vendor's
14 thermal hydraulic codes. And some vendors actually
15 gave you their codes.

16 MR. SALTOS: Are you talking about PRA?

17 CHAIRMAN WALLIS: One particular one that
18 refused to give you --

19 MR. SALTOS: I'm talking about the PRA.

20 CHAIRMAN WALLIS: Yes. I'm talking about
21 thermal hydraulic.

22 MR. SALTOS: Yes.

23 CHAIRMAN WALLIS: You put that in the same
24 box with PRA.

25 MR. SALTOS: Well, we do not ask -- it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 my understanding, never asked in the past anybody who
2 applied to certify the design to submit any thermal
3 hydraulic code to us.

4 MEMBER BONACA: Well, because they are
5 already submitted and reviewed as part of the topical
6 report. I mean, the NRC makes a separate
7 determination for the computer code. Licensing the
8 code -- I mean, approve it, and then --

9 MEMBER APOSTOLAKIS: But not for the PRA
10 codes, that's his point, which is true.

11 MR. HARRISON: Yes. Nick's point is that
12 for the Chapter 15 analyses all the methodologies and
13 codes, they use approved NRC-endorsed codes.

14 MEMBER APOSTOLAKIS: Right.

15 MR. HARRISON: For the PRA, that is not
16 the case. It has not -- we have not done reviews and
17 approved the code for --

18 MEMBER APOSTOLAKIS: Again, I'm trying to
19 envision the process here. Let's say there is a
20 particular COL that's submitted next September or
21 October. This Committee will start reviewing it,
22 right? Because eventually we'll have to write a
23 letter. Is there going to be a PRA subcommittee
24 meeting?

25 MR. HARRISON: I would be surprised if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there wasn't at least a discussion on PRA during a
2 subcommittee meeting. I don't know which --

3 MEMBER APOSTOLAKIS: Okay.

4 MR. HARRISON: -- subcommittee would --

5 MEMBER APOSTOLAKIS: So that subcommittee
6 -- now, the members preparing for the subcommittee, I
7 hope they will not have to go to the site to read the
8 PRA.

9 MR. HARRISON: From the submission, what
10 you will have is the --

11 MEMBER APOSTOLAKIS: The results.

12 MR. HARRISON: -- the description of the
13 PRA and its results and the severe accident evaluation
14 description.

15 MEMBER APOSTOLAKIS: But we will not know
16 what kind of data they used? I mean, Nick said that
17 they will be -- these are inputs.

18 MR. RUBIN: Let me supplement a little
19 bit. This is Mark Rubin again from DRA. Under the
20 current guidance in 1145 and the expectations from our
21 industry stakeholders, the information in SRP 19 --
22 with respect to the PRA would be relatively brief,
23 high-level, qualitative information.

24 Now, with the change in Part 52, we're
25 thinking of revisiting that to see if we can get more

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 detailed results information. But it will be a
2 function of whether we can get agreement from OGC that
3 it's not part of the plant's design basis, because as
4 many of the members have indicated PRA conceptually
5 changes and it's to reflect plant changes. And you
6 don't want to really hold a plant to PRA changes.
7 It's the opposite you want to do -- reflect changes in
8 the plant.

9 So senior NRO management has indicated its
10 desire that severe accident and PRA information not be
11 part of the plant's licensing basis. Industry
12 stakeholders have also indicated that. From the
13 working level of the staff, it seems reasonable that
14 that be the case, because we use it as a licensing
15 evaluation tool in severe accident space.

16 What we need to do is get a consensus view
17 from OGC along those lines, and then we could perhaps
18 beef up the SRP 19 submittal to include more detailed
19 quantitative PRA information. But currently it's
20 restricted to qualitative very brief summary
21 information.

22 MEMBER APOSTOLAKIS: But some --

23 MEMBER SIEBER: But you haven't crossed
24 that bridge yet?

25 MR. RUBIN: Excuse me, sir.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: You have not crossed that
2 bridge yet. OGC hasn't agreed to that, right?

3 MR. RUBIN: We're working with senior
4 members of OGC, and we're laying the planks for the
5 bridge.

6 MEMBER APOSTOLAKIS: Is information
7 submitted to the ACRS for evaluation -- does it become
8 part of the licensing basis?

9 MR. RUBIN: No.

10 MEMBER APOSTOLAKIS: So I can see, you
11 know, the legal problem resolved. No, it's not part
12 of the licensing basis for the reasons you have --

13 MEMBER SIEBER: If it's in the application
14 it is.

15 MEMBER APOSTOLAKIS: But every single
16 piece of information we get becomes part of the
17 licensing basis. I don't believe that. I mean,
18 that's incredible. So --

19 MEMBER SIEBER: Okay. I stand corrected.

20 MEMBER CORRADINI: He said public
21 information, not licensing --

22 MEMBER APOSTOLAKIS: Well, it can be
23 controlled. It can be controlled.

24 MR. RUBIN: Dr. Apostolakis, I believe you
25 are absolutely correct. It certainly does not become

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 part of the licensing basis, but my limited
2 understanding is that it becomes public if it's part
3 of an ACRS meeting and deliberations. But your staff
4 can advise you, certainly, much better than I.

5 MEMBER APOSTOLAKIS: It becomes -- the
6 public part is what is discussed here.

7 CHAIRMAN WALLIS: Right.

8 MEMBER APOSTOLAKIS: But not all details
9 are --

10 CHAIRMAN WALLIS: But what we get as
11 members, I often get stuff which is stamped
12 proprietary information.

13 MEMBER APOSTOLAKIS: Yes, sure. Even the
14 documents we have now for --

15 CHAIRMAN WALLIS: And I don't give it to
16 the public.

17 MEMBER KRESS: We quite often have closed
18 meetings.

19 CHAIRMAN WALLIS: Right.

20 MEMBER APOSTOLAKIS: Another thing that
21 the members should remember --

22 MEMBER SIEBER: The e-mails among us are
23 public documents.

24 MEMBER APOSTOLAKIS: It's one thing to say
25 it's available on the site for audit. That's not a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 day's work. I mean, the staff can afford to go there
2 for maybe two weeks to review it, but the members
3 cannot. So to say that we will go there and spend a
4 day, day and a half, that's not really a review.
5 That's not really very informative, because, really,
6 you have to have it at home and sit down and study it.

7 So I think there's going to be a problem
8 there, and the language has to be such that there will
9 be a lot of flexibility, because I do appreciate all
10 the issues about making it part of the licensing
11 basis. And that's not my problem. I don't want to --
12 I mean, if that's a problem, don't do it.

13 But to say that, if you want to see what
14 happened, you have to travel there, it just seems
15 unreasonable to me, because I have to write a letter
16 at the end that says, yes, go ahead and operate.

17 MR. WILSON: This is Jerry Wilson. If I
18 could remind the Committee that the regulations we're
19 discussing are regulations applying to the applicants
20 who are submitting applications to NRC staff. The
21 ACRS is an independent statutory committee, and you're
22 not constrained by the staff's rules. And you can ask
23 for whatever you want to ask for.

24 MEMBER APOSTOLAKIS: We are constrained by
25 the Commission's rules, though, aren't we?

1 VICE CHAIRMAN SHACK: Well, you can ask,
2 George. They don't have to supply.

3 MEMBER KRESS: And we don't have to agree.

4 MEMBER BONACA: No, I don't think that
5 there will be a reluctance, I think, from the plant to
6 supply until they start the plant. I think that the
7 problem becomes when you start a plant and you have --

8 MEMBER APOSTOLAKIS: Yes, that's when you
9 start changing things.

10 MEMBER BONACA: And that's really where
11 you would want to have --

12 MEMBER APOSTOLAKIS: Yes. I don't really
13 care about that.

14 MEMBER BONACA: But up to that point, I
15 don't see that there should be any reluctance. I
16 mean, this is, you know, information to do with a
17 decision and --

18 CHAIRMAN WALLIS: I think, George, what we
19 need to do is just put a couple of sentences in our
20 letter.

21 MEMBER APOSTOLAKIS: We should, yes.

22 CHAIRMAN WALLIS: Which we can then appeal
23 to later on, and then that will help us to --

24 MEMBER ABDEL-KHALIK: Can I ask a
25 question?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Of course.

2 MEMBER ABDEL-KHALIK: Would the staff
3 expect to approve any COL without doing an onsite
4 audit?

5 MEMBER APOSTOLAKIS: That's a good
6 question.

7 MEMBER ABDEL-KHALIK: Do you foresee a
8 situation where you would approve a COL application
9 without an onsite audit?

10 MR. RUBIN: This is Mark Rubin again.
11 Boy, it's hard to answer absolute. Let me
12 characterize --

13 MEMBER ABDEL-KHALIK: Can you make a
14 judgment?

15 MR. RUBIN: Sure. I'll be glad to give
16 you a judgment. Under the conditions that the
17 majority of the PRA analysis is done during the final
18 design approval and the design certification, because
19 that's where we look at the NSSS, and the majority of
20 the plant PRA parameters, and all that a COL has to do
21 is changes in that design which very likely will be
22 nothing, plus site-specific parameters that were
23 probably scoped by bounding calculations.

24 I could conceive it's possible that a COL
25 could submit sufficient information through RAIs to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 alleviate the need for a site-specific audit. But I
2 would characterize it as doubtful. I would
3 characterize the need for a site-specific audit for
4 the FDA part of a PRA review as essential, and I could
5 see no way that we would get through a PRA review for
6 that state of the PRA assessment without a site-
7 specific audit to look at the actual PRA.

8 MEMBER ABDEL-KHALIK: So in the majority
9 of cases, you would expect that, you know, you receive
10 this information as specified in 1145, but inherent in
11 this process the staff will have to do an onsite audit
12 to check the details of the PRA.

13 MR. RUBIN: Yes. We do onsite audits of
14 PRAs for much less significant PRA scope issues than
15 this. We do it for risk-informed applications now
16 where we think there may be some questionable modeling
17 or scope issues. This is much more broad, and I'll
18 defer to Nick Saltos here who does a number of these
19 evaluations.

20 Nick, could you conceive of us not doing
21 an audit?

22 MR. SALTOS: Well, we are talking about
23 here a COL with a -- that references a certified
24 design or an application for a certification of a
25 design. Those things are different. If you have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 certified design, you have a PRA, you have reviewed
2 the PRA, you have applied the PRA to identify design
3 and operational requirements like what systems are
4 going to be safety-related versus non-safety-related,
5 regulatory treatment of non-safety systems, tech
6 specs, ITAACs.

7 The PRA provides input to the licensing
8 basis. I heard here people saying that the PRA is not
9 part of the licensing basis. That's true. But the
10 PRA is used -- is applied, is an application of the
11 PRA to provide input to the licensing basis. The PRA
12 has identified that these are not ITAACs, that they
13 are not identified by the deterministic reviewers, has
14 modified ITAACs, has contributed to a change -- non-
15 safety-related systems to safety-related systems, has
16 identified tech specs --

17 CHAIRMAN WALLIS: Well, I --

18 MR. SALTOS: -- requirements of non-safety
19 systems, we know all that stuff.

20 CHAIRMAN WALLIS: I'm going to ask Tom
21 Kress if it isn't time to move on. We could spend a
22 lot of time on this.

23 MEMBER KRESS: It is time to move on. I'd
24 like to make one more statement about the PRA. I
25 think our problem stems from the fact that we dance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 around the issue of whether the PRA is part of the
2 licensing basis. I personally think it ought to be,
3 and that would solve our problems. We could deal with
4 -- we could deal with how the -- get to it and look at
5 it, and everything.

6 You know, we just heard that it's part of
7 determining RTSS, it's part of determining safety
8 systems, it's used for the site EIS. I think it ought
9 to be part of the licensing basis, and then we'd quit
10 dancing around this issue. But that's a personal
11 opinion.

12 MEMBER SIEBER: Well, that's also a
13 subject -- policy subject --

14 MEMBER KRESS: Oh, sure. It's a policy --

15 MEMBER SIEBER: -- for the Commissioners
16 to --

17 MEMBER KRESS: -- issue.

18 MEMBER APOSTOLAKIS: But also, I think
19 it's important to come back to something that Mr.
20 Wilson said, that in our letter of May 22, 2006, we
21 agreed that the PRA should not be submitted. It's not
22 really clear that that's what we're saying. We are
23 saying updates to the PRA need not be submitted to the
24 NRC. There is a slight difference there. Big
25 difference.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: There's a way to handle
2 that with the thermal hydraulic codes that have been
3 blessed that changes the rules.

4 MEMBER APOSTOLAKIS: Well, I'm glad it
5 was --

6 CHAIRMAN WALLIS: We were quoted out of
7 context. We were -- we're missing a key word
8 "updates," right?

9 MEMBER APOSTOLAKIS: Well, if you read it,
10 it's not very clear what it means, but I think the
11 intent was that the updates should not --

12 CHAIRMAN WALLIS: Our letter is not clear,
13 George?

14 MEMBER APOSTOLAKIS: -- be submitted. But
15 some original PRA should be. Anyway, I mean, it will
16 be a major problem for me if we have to write a letter
17 -- well, we will have to write a letter at the end
18 saying, yes, go ahead, operate, or not, and, you know,
19 to have had meetings where I don't have the
20 information.

21 MEMBER KRESS: Let's move on, please.

22 MR. HARRISON: Okay.

23 CHAIRMAN WALLIS: I think eventually you
24 would get that information, George.

25 MEMBER APOSTOLAKIS: I believe I -- we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will, too. Yes.

2 CHAIRMAN WALLIS: So let's move on.

3 MR. HARRISON: Okay. And I'll try to move
4 quickly to catch us up a little bit here.

5 MEMBER APOSTOLAKIS: Well, Donnie, let me
6 ask you a question, because we are running out of time
7 here.

8 (Laughter.)

9 You don't have to -- I'm sorry. I notice
10 that a lot of this presentation is we did this, we did
11 that, we were told this, and we were told that. And
12 there isn't really any technical content, and there is
13 only half an hour left. So I'm proposing to the
14 Committee that we discuss some of the technical issues
15 and forget about who said what, unless there is
16 something very important, you know, okay, we got 700
17 comments, yes, all right, what do you think?

18 MR. HARRISON: No, that's fine. If you've
19 got --

20 MEMBER APOSTOLAKIS: Does the Committee
21 agree?

22 CHAIRMAN WALLIS: Well, we had the same
23 problem with the subcommittee. I thought we were
24 meeting to receive comments from the subcommittee that
25 would help the staff, and we spent a lot of time on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 other things. I'm not quite sure, Tom, how are you
2 going to fit that in today? Are you going to fit in
3 some technical matters or not?

4 MEMBER APOSTOLAKIS: I mean, this issue of
5 large release frequency, Donnie, maybe I'm missing
6 something, but have we defined it anywhere? And where
7 is this 10^{-6} per year coming from?

8 MR. HARRISON: Okay. And that one I can
9 actually give you an answer.

10 MEMBER APOSTOLAKIS: Well, I'm sure you
11 can, but --

12 (Laughter.)

13 But this is the kind of question I want to
14 ask, not we have experience with design certification.
15 I know you are very experienced, very experienced.

16 MR. HARRISON: This fits into this slide.

17 MEMBER APOSTOLAKIS: Tom, what --

18 MEMBER KRESS: I think it's a good idea.
19 We shouldn't be a slave to --

20 MEMBER APOSTOLAKIS: Okay. So if we look
21 at the PRA section -- as a side remark first, it seems
22 to me the statements like "applicants should not
23 artificially increase PRA results" don't belong here.
24 I mean, you are -- you should delete that kind of
25 thing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: Okay. That was a comment,
2 because in addressing the multiple different goals you
3 don't want to be in a situation where an applicant is
4 slightly not meeting a goal. And to meet it they --

5 MEMBER APOSTOLAKIS: But that's
6 understood.

7 MR. HARRISON: -- finagle their results.

8 MEMBER APOSTOLAKIS: The issue of bright
9 lines has been discussed, and I don't think it -- but
10 there are two questions on this particular point.
11 First of all, when did the agency decide to use the
12 large release frequency as opposed to the large early
13 release frequency as a metric? And the 10^{-6} , and then
14 a probabilistic goal for the condition or containment
15 failure probability of .1, is that consistent or
16 inconsistent with a 10^{-6} ?

17 MR. RUBIN: It was -- Mark Rubin. It was
18 in 1990, and Donnie will give you the specific
19 references. All these came from direct Commission
20 guidance when we started the evolutionary and advanced
21 reviews, starting from the EPRI requirements document.
22 And I'll remind those Committee members who weren't
23 here then that these were the first times that the
24 PRAs were actually used an integral part of the
25 staff's safety review process.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And Donnie will give you the actual policy
2 guidance, because the staff sent up --

3 MEMBER APOSTOLAKIS: Okay.

4 MR. RUBIN: -- some position and technical
5 resolution and criteria papers, and the staff --
6 excuse me, and the Commission modified them
7 significantly for our review process.

8 MEMBER APOSTOLAKIS: When was this?

9 MR. RUBIN: It started in 1990, and we
10 continued to get guidance for about three or four
11 years as we continued with ABWR and AP600.

12 MEMBER APOSTOLAKIS: So the concept of
13 large release frequency has been in the book since
14 1990?

15 MR. RUBIN: Yes, sir.

16 MR. HARRISON: For advanced reactors. For
17 evolution in --

18 MEMBER APOSTOLAKIS: And then, in 1990 --
19 oh, for advanced --

20 MR. HARRISON: Yes. It was -- this is
21 related to SECYS and SR --

22 MEMBER APOSTOLAKIS: And the 10^{-6} , too?

23 MR. HARRISON: The 10^{-6} was actually
24 brought up in I think the '90 timeframe. It was
25 actually explicitly reconfirmed in a later SECY SRM

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to --

2 MR. RUBIN: This is the only place that
3 the staff applies the decision that -- the severe
4 accident decision metric of 10^{-6} for large release
5 frequency, and it's only applied for new reactor
6 licensing. And that's Commission-specific direction.

7 MEMBER APOSTOLAKIS: So if those guys,
8 then, later want to invoke Regulatory Guide 1.174 to
9 make a risk-informed change, then they will have to
10 live with this new goal.

11 MR. RUBIN: That gets to the heart of the
12 issue of whether severe accident and PRA evaluations
13 that are part of the initial Part 52 licensing is part
14 of the plant's licensing basis or not. If we go under
15 the assumption that it is not, then we do the
16 assessment one time for the design certification
17 evaluation, and then they will be covered by the same
18 Reg. Guide 1.174 delta assessment that everyone else
19 is.

20 If we assume that it's a living
21 requirement, then your postulate is correct. And
22 that's why we're seeking OGC guidance.

23 MEMBER CORRADINI: He understood that.
24 Can you do that one more time?

25 (Laughter.)

1 Slower.

2 MR. RUBIN: I would say it would be my
3 pleasure, but I'm confusing myself. But, sure, I'd be
4 glad to. Here's the issue. This is the only place
5 that we have a large release versus a large early
6 release frequency, and it's a baseline rather than a
7 delta change criteria. And when the staff sent up a
8 policy Commission paper proposing a CDF and a large
9 early release criteria, the Commission responded with
10 essentially, "No, we believe there are other metrics
11 and other values that are more appropriate to the
12 advanced reactors."

13 They proposed a different baseline CDF
14 value than the staff had proposed, and they proposed
15 large release frequency in combination with a
16 conditional containment --

17 CHAIRMAN WALLIS: You said there were
18 other metrics. That really mystified me. You meant
19 there were other values of the conventional metrics.

20 MR. RUBIN: No. There were other metrics.

21 CHAIRMAN WALLIS: What are those
22 mysterious metrics which are superior?

23 MR. RUBIN: Conditional containment
24 failure probability.

25 CHAIRMAN WALLIS: Okay. So it --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. RUBIN: And there are values to those
2 other metrics, but they were different. And the large
3 release frequency they proposed as one in a million
4 chance of having a large release.

5 And if we look at it as a one-time review
6 checkoff, then we will look at the Level 2 PRA
7 analysis, and we have Mr. Paola here to explain in
8 detail how that's done, and so we won't look at just
9 the early releases, which have the potential for early
10 fatalities and consider timing and evacuation. We'll
11 look at all of the releases that could be considered
12 roughly large and independent of timing.

13 And then, we'll see if it meets the one in
14 a million probability that the Commission mandated,
15 but we would only do it through -- for the final
16 design approval and design certification review. If
17 the severe accident and PRA acceptance guidelines that
18 the Commission policy SECYs -- and there were about
19 three or four of them -- is considered part of the
20 plant's licensing basis, then those guidelines would
21 have to be considered through the life of the plant,
22 and continuously reevaluated as the plant changes,
23 data changes, model changes, and your state of
24 knowledge changes.

25 And that seems perhaps overly burdensome

1 and perhaps unnecessary, because we already have in
2 place risk change control metrics that both the staff,
3 the Commission, and at the time the Advisory Committee
4 thought were adequate to control changes in plant
5 risk.

6 So we're working on it with OGC and senior
7 management, but right now we think doing it just
8 during licensing -- and it's the only place that
9 metric exists right now from Commission guidance -- is
10 probably enough and --

11 CHAIRMAN WALLIS: I'm really puzzled,
12 Mark. You seem to be using OGC to interpret what the
13 Commission meant. Why don't you just ask the
14 Commission?

15 MEMBER SIEBER: That's why they're using
16 OGC.

17 MR. RUBIN: The Commission sent guidance
18 down for the review of the advanced reactors.

19 MEMBER APOSTOLAKIS: It was a different
20 Commission.

21 CHAIRMAN WALLIS: Yes.

22 MEMBER CORRADINI: So since I started this
23 by asking you to do it again, so let me just try to
24 translate back so I get it in less words. And I'll
25 probably get it wrong, but just let me try to say it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: And less time maybe?

2 MEMBER CORRADINI: Well, that's all right.
3 Probably not. So, but the other piece -- so what you
4 said was there is going to be, I'll call it, measure 1
5 at the time of licensing, and there will be measure 2
6 which, if I use measure 1, would be -- have been
7 included in it, because the LERF is essentially a
8 subset of the LRF.

9 But let's just say I've got measure 1
10 during licensing, and I've got a different measure as
11 life proceeds down a path. The other thing that you
12 -- that somewhere in there you've said, and then you
13 pointed to the young man behind you, was that I've got
14 a third measure which is the containment failure
15 probability, which would only be applied at licensing,
16 and then, from then on, not at all.

17 MR. RUBIN: It would --

18 MEMBER CORRADINI: Have I got it right?

19 MR. RUBIN: Not quite. Sorry I didn't go
20 into those areas. The quantitative containment
21 performance conditional failure probability was
22 imposed by the Commission for licensing. The staff --

23 MEMBER CORRADINI: But only for licensing.

24 MR. RUBIN: Only for licensing. However,
25 the staff doesn't have a quantitative containment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 performance goal in Reg. Guide 174. It uses a
2 qualitative defense-in-depth concept to roughly
3 achieve the same thing. High confidence that you have
4 containment integrity long term if at all possible.
5 And so we look for -- we look for challenges to the
6 containment that will give containment failure, and we
7 try to find ways to prevent that from occurring. But
8 we don't have an actual numerical metric like the
9 Commission gave us for licensing.

10 MEMBER CORRADINI: But what I said,
11 though, to begin with is that's the containment
12 failure probability of 0.1.

13 MR. RUBIN: Only used once.

14 MEMBER CORRADINI: It was only used once,
15 just as the LRF is only used once.

16 MR. RUBIN: Yes, sir.

17 MEMBER CORRADINI: Okay. Thank you.

18 MR. HARRISON: Yes, and just -- that's
19 assuming that OGC provides the guidance that
20 Chapter 19 input is not part of the licensing bases.

21 MEMBER CORRADINI: Okay. Thank you.

22 MEMBER KRESS: I think specifying both in
23 LRF and a conditional containment failure probability
24 is an overspecification. One can be derived from the
25 other.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: In fact, I'm not sure
2 they are consistent here.

3 MEMBER KRESS: They have to be made
4 consistent in my mind. And not only that, you are
5 very correct in saying that LERF, L-E-R-F, is a subset
6 of LRF. Not only is it a subset, it's more than
7 likely about 95 percent of it. So specifying one or
8 the other doesn't make much difference in PRA space.

9 MR. RUBIN: Dr. Kress, the one thing I
10 would just amplify your point on -- and you're
11 absolutely correct -- is that other than the baseline
12 initial licensing, the Commission has given us no
13 goals for baseline plant risk. All the other guidance
14 we have from the Commission is risk changes after
15 licensing. There are no baseline plant risk goals.
16 Only for initial licensing on new reactors.

17 MEMBER KRESS: That ought to be part of
18 the site approval, the risk criteria. But we don't
19 really have them. We have site characteristics and
20 site population densities and other things, but we
21 don't have any risk goals -- risk rules. We have
22 goals, we have the QHOs, but so far they are not
23 individual plant risk metrics that have to be met.
24 But, you know, if I had my way, I'd change all of
25 that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: Tom?

2 MEMBER KRESS: Yes.

3 CHAIRMAN WALLIS: I want to ask you
4 something. We have this agenda here. We're way
5 behind. Is there any time we're ever going to get
6 comments on anything other than PRA?

7 MEMBER KRESS: Well, I'll tell you how I
8 suggest we proceed. Let's dispense with the agenda
9 and say, does anybody have any questions in these
10 areas --

11 MEMBER APOSTOLAKIS: Well, some people
12 have left now, so --

13 MEMBER KRESS: Yes.

14 MEMBER SIEBER: I think there's one thing
15 that we can say is there is no new ground being formed
16 in the preparation of DG-1145. All this does is
17 endorse a lot of existing regulatory guides, codes and
18 standards, rules and other documents, and then it
19 specifies what has to be in the application. And so
20 from that standpoint, there is nothing new here.

21 And in our review, we all reviewed and
22 found a few little things that we wondered about. For
23 example, in my own case, I've wondered where some
24 things I expected to find were, but the document is
25 very big, and I didn't read the entire document. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it turned out they're in there.

2 And so from the standpoint of looking at
3 the details of what these regulatory guides, rules,
4 Appendix A criteria, and all these other documents
5 say, nothing is new.

6 MR. HARRISON: That's correct. If you
7 look at it from like the design cert experience, the
8 SECYs and SRMs, the draft guide, at least in the PRA
9 area, is trying to bring that all into one place and
10 provide a concise --

11 MR. COLACCINO: This is Joe Colaccino from
12 the staff. I just want to change one word. Instead
13 of "endorse" I would say "roadmap," because the
14 endorsements would be contained without the regulatory
15 guides themselves. But what the document does is
16 provide a roadmap to that information.

17 MEMBER SIEBER: And an analogy that turned
18 up in the subcommittee meeting is that with DG-1145 in
19 the current rules that are there, we could submit an
20 application and build a perfect 1980s-type plant.

21 (Laughter.)

22 MR. HARRISON: Yes, I think that was your
23 comment the last --

24 MEMBER APOSTOLAKIS: Is the .1 CCFP
25 consistent with a 10^{-6} for LRF?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HARRISON: Yes, that I would clarify.
2 I think they are different, because no matter how low
3 you get the CDF -- you could have a plant come in with
4 a design that says their core damage frequency is less
5 than 10^{-8} , therefore, their large release frequency is
6 going to be less than 10^{-8} . So they automatically
7 meet the large release frequency.

8 However, they still have to meet the goal
9 of .1 for the containment, so you have that -- so that
10 would mean that they would --

11 MEMBER KRESS: But that .1 --

12 MR. HARRISON: -- it acts as a defense-in-
13 depth --

14 MEMBER KRESS: -- that .1 is weighted by
15 the CDF, and that sort of takes care of that problem.
16 The .1 is not just multiplied by the CDF. It's
17 weighted by the -- each sequence has a CDF and a
18 conditional containment failure --

19 MEMBER APOSTOLAKIS: Okay.

20 MEMBER KRESS: -- but the one we're
21 talking about has that sequence's contribution to that
22 weighted by the CDF. It's divided into it. So it's
23 a percent.

24 MR. RUBIN: Yes, sir. It's weighted,
25 but --

1 MEMBER KRESS: That takes care of that
2 problem.

3 MR. RUBIN: It's weighted, but it doesn't
4 eliminate the fact that as you reduce CDF lower and
5 lower and lower, the remaining very severe sequences
6 have very high conditional containment failure
7 probability. So as you make the plants safer and
8 safer, you drive up the conditional failure
9 probability higher and higher. And so that gives a --
10 it seems to give an incentive to a designer to run the
11 CDF higher, so they can come closer to achieving the
12 .1 value. And that's not our objective.

13 MEMBER KRESS: Yes.

14 MR. RUBIN: And we wanted to make that
15 clear as Dr. Apostolakis pointed out. That's foolish.

16 MR. HARRISON: And, again, if you think of
17 it, if you're dominated by -- because you get the risk
18 low enough at your plant, you get the CDF low enough,
19 you may be dominated by very high CCFPs for the
20 sequences that are left. I mean, it's proportional.
21 So you could end up with a plant with a very high
22 containment failure probability for its CDF, because
23 you've gotten rid of everything that's successful
24 containment, so --

25 MEMBER APOSTOLAKIS: Okay. Changing the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 subject, in the RTN assessed discussion chapter, it
2 says that this process started with a comprehensive
3 Level 3 baseline PRA.

4 MR. HARRISON: And that's incorrect.

5 MEMBER APOSTOLAKIS: Okay.

6 MR. HARRISON: We need to revise that
7 section.

8 MEMBER APOSTOLAKIS: Okay.

9 MR. HARRISON: The metrics are LRF, CDF,
10 CTFP. Those are all taking you up to -- they take you
11 up to a Level 2 PRA, if you will, but they don't take
12 you to Level 3. So that's a -- that was something
13 that --

14 MEMBER APOSTOLAKIS: So that will be
15 fixed.

16 MR. HARRISON: Yes.

17 MEMBER APOSTOLAKIS: And the final
18 conclusion, LRF will be used one time for the approval
19 or --

20 MR. HARRISON: That's an open question.
21 That's the question with OGC.

22 MEMBER APOSTOLAKIS: But that's --

23 MR. HARRISON: That's the current
24 understanding.

25 MEMBER APOSTOLAKIS: And then, from then

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on, risk-informed changes will go back to 1.174.

2 MR. RUBIN: That is --

3 MEMBER APOSTOLAKIS: Could be.

4 MR. RUBIN: Right. That's one path
5 forward. Yes. The other path --

6 MEMBER APOSTOLAKIS: I don't know. The
7 issue of making sense has to be --

8 MR. HARRISON: Well, the issue becomes if
9 OGC rejects that path, then you would have to maintain
10 the metrics that are in the LRF, the CDF, the CCFP.
11 Even under a Reg. Guide 1.174 submittal later, you
12 would have to -- you would have to maintain those
13 bases. So --

14 MEMBER APOSTOLAKIS: Of course, this is a
15 technical question more than a legal question. But --

16 MR. HARRISON: Because it would become
17 part of the licensing basis, yes.

18 MEMBER APOSTOLAKIS: Oh.

19 MR. HARRISON: So that's the ultimate
20 question to the lawyers.

21 MR. RUBIN: None of these plants would --
22 this is Mark Rubin again. None of these plants will
23 have problems meeting the CDF goal. They're much
24 safer than that.

25 MR. HARRISON: It's just that the LRF is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 more restrictive than the LERF. And so you may not
2 have as much flexibility for mods down the road.

3 CHAIRMAN WALLIS: Well, I hear a silence.
4 Maybe we can move on?

5 MEMBER KRESS: I think so. Or let --

6 MEMBER APOSTOLAKIS: The uncertainty
7 analysis should identify major contributors to the
8 uncertainty. We don't do that now, do we?

9 MR. HARRISON: As part of your design
10 certs, I believe -- Nick, correct me if I'm wrong here
11 -- but they have done fairly extensive both
12 uncertainty sensitivity analyses to get an idea of the
13 magnitude of the uncertainty in the calculations
14 and --

15 MEMBER POWERS: Well, the common practice
16 -- I mean, the practice that the staff is using in
17 some of its phenomenological models is to come back
18 and have a ranking of the uncertainties, and bounds to
19 a linear correlation coefficient between the
20 uncertainty and the calculated output with a
21 probability and, in fact, an uncertainty range on that
22 ranking.

23 MEMBER APOSTOLAKIS: I think they are
24 identifying the major contributors to risk, but not
25 the contributors to uncertainty.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: These are specifically
2 contributors to uncertainty.

3 MR. SALTOS: If I can answer what we did
4 so far in the design certifications. We identify the
5 areas of uncertainty. For example, squib valves, we
6 don't have a lot of information about squib valves,
7 especially the size that are used in advanced
8 reactors.

9 Software common cause failures, we don't
10 have a lot of experience about these. So we identify
11 these kind of areas of uncertainty, and then we
12 perform sensitivity studies to see how it will impact
13 the results, and then go from there, take that into
14 account in the decisionmaking -- you know, identify
15 requirements for the design changes or operational
16 requirements.

17 MR. HARRISON: And I think one of the
18 insights on like the AP600 or AP1000 was the
19 uncertainty in the thermal hydraulics for the passive
20 features, right? That was another area where --

21 MR. RUBIN: Low delta P for injection.

22 MR. HARRISON: -- low delta P.

23 I'll go through this very quickly, then.
24 And if there's nay technical questions, ask. But the
25 basis for the reg. guide for the PRA section comes out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the SECYs that -- much as Dr. Sieber mentioned, the
2 policy statements, experience with design
3 certification reviews, and then just the requirements
4 that are in 10 CFR 52.79 specifically requiring a
5 description of the PRA and its results, the severe
6 accident evaluations that have to be performed.

7 The objectives that are derived from those
8 policy statements and SECYs with -- endorsing SRMs can
9 be grouped -- I think we had nine objectives
10 identified of the PRA and severe accidents. You can
11 lump them into two groups.

12 The first group, which includes the goals,
13 the quantitative goals, are to assess the balance of
14 preventive and mitigated features, and to show that
15 there's a risk reduction from the current plants. And
16 that dates to the severe accident policy statement in
17 1985. So you're comparing it to plants of that
18 vintage.

19 The other group is how the PRA is being
20 used and applied. It's being used to support RITNESS.
21 It's being used to support the RATH program. You'll
22 develop ITAACs, other commitments and interface
23 requirements. So those are the uses and applications
24 of the PRA, so you can lump them into those two
25 groups.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This is just an outline of what the
2 Chapter 19 regulatory guidance is. This would be the
3 topics that you would cover in the FSAR. So there
4 would be an introduction. The applicant would -- you
5 would expect him to describe the objectives, the nine
6 objectives, any others that they're applying for the
7 PRA.

8 19.2 would be the PRA results and
9 insights. This would include how they're using the
10 PRA. And if they're making an application in parallel
11 with a COL, or even a design certification, but if
12 they're making, for example, a risk-informed ISI
13 application to go along with their COL application,
14 they would need to describe that and how the PRA is
15 being used in that application.

16 You have the severe accident evaluations,
17 which is the more traditional deterministic severe
18 accident topics that are split into preventive and
19 mitigative categories. There is a section on PRA
20 maintenance. And, again, this is PRA maintenance for
21 the applications. So how you're using the PRA, what's
22 the PRA quality, level of detail, scope that you need
23 for those applications, and how do you maintain that
24 going forward.

25 Section 19.5 is -- it becomes a commitment

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 section or the ITAAC, the COL action items. What
2 things are you going to have to confirm or verify
3 after you get your license and establish those at this
4 stage, so that you know I've done a PRA-based seismic
5 analysis, or I've done a fire analysis. When I build
6 a plant, if I move cables or I change something, I
7 need to come back and make sure my results haven't
8 changed, my overall results and insights haven't
9 changed.

10 And then, the last section is a conclusion
11 section where we're asking that the applicant
12 explicitly address the nine objectives and state at
13 that point how they believe they've met those
14 objectives.

15 CHAIRMAN WALLIS: Have you finished?

16 MR. HARRISON: Yes.

17 CHAIRMAN WALLIS: Thank you very much.

18 Tom, we do have another item I'd like to
19 finish this morning, if we can get to it. And then we
20 have -- not your business, but we have another item on
21 the agenda after the break. I would hope we could
22 finish up before lunch.

23 MEMBER KRESS: We have until 10:45.

24 CHAIRMAN WALLIS: We have until 10:30.

25 You've got five minutes now.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: My agenda says --

2 CHAIRMAN WALLIS: Well, it's okay. But
3 I'm just wondering what you're -- how you're going to
4 get us through --

5 MEMBER APOSTOLAKIS: No, that's a break,
6 Tom.

7 MEMBER KRESS: Well, I suggest -- yes, I
8 see. I suggest that, since there's only one slide
9 basically on the conformance, completeness, and
10 consistency -- and we can read that -- why don't we
11 get a -- spend five to ten minutes on the industry
12 concerns and public comments, and maybe skip to slides
13 -- in that area I have slides 4, 5, and 6. Maybe
14 present those three slides, and we can --

15 MEMBER APOSTOLAKIS: What is the industry
16 concern?

17 MEMBER KRESS: And take no more than 10
18 minutes.

19 MR. OESTERLE: This is Eric Oesterle again
20 from Division of New Reactor Licensing. We held a
21 number of public workshops on development of DG-1145.
22 We had a lot of participation from industry. Some of
23 those workshops identified comments that did carry
24 over through into the public comment period, and I
25 summarize some of these issues and comments in these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 next three slides.

2 They are certainly not in order of
3 priority, but they are issues that still need to be
4 worked through by the staff and industry. The first
5 bullet is on COL information availability. That was
6 a consistent item throughout the workshops and
7 comments.

8 Due to the use of Reg. Guide 1.70 as the
9 basis for DG-1145, and the staff's predominant
10 experience in licensing plants using the Part 50
11 process, workshop discussions focused on areas of the
12 guidance document in which information was requested
13 that would not be available at the time of the COL
14 application submittal, or even after the COL issuance.

15 This is one of the most challenging areas
16 for the staff in terms of being able to negotiate the
17 paradigm shift from the Part 50 licensing process to
18 the Part 52 licensing process. Comments on COL
19 information availability were made in several areas
20 where the guidance document requested information that
21 would not be available at the time the COL application
22 was submitted.

23 I'll give you an example. Section
24 C.I.8.3.2 for onsite DC power systems requested
25 battery characteristic curves. These battery

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 characteristic curves will not be available until
2 batteries have been procured, which will be after the
3 submittal of the COL application and could likely be
4 even after the issuance of the COL license.

5 As another example, the guidance in
6 Section C.I.3.6.2 for determination of pipe rupture
7 locations and dynamic effects associated with
8 postulated rupture of piping requested that applicants
9 provide information in addition to their design
10 criteria on detailed information on containment
11 penetrations and protective assemblies or guard pipes
12 to be used for piping penetrations of containment
13 areas. This detailed information is not expected to
14 be available at the time the COL application is
15 submitted.

16 The staff is currently reviewing the
17 available methods by which verification can be
18 performed to ensure that the information, once
19 provided by the COL applicant or licensee, conforms
20 with the licensing design, and those verification
21 methods include ITAAC, they include engineering design
22 verification, and also include construction
23 inspections by the staff.

24 Another area that incurred some discussion
25 during the workshops were the verification activities

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 themselves. Do we do inspections, or do we impose
2 ITAAC? In areas where the guidance document requested
3 that information, that would not be available at the
4 time the application was submitted. There were
5 certain places where the guidance requested the
6 applicant to identify the ITAAC that had been proposed
7 to verify that information.

8 Commenters suggested that instead of ITAAC
9 that construction inspections rather than ITAAC were
10 more -- the more appropriate verification method. We
11 are still looking at that.

12 There were some discussions on first-of-a-
13 kind engineering inspections. Those areas are very
14 limited to the first time that the vendors actually
15 translate the high-level design information contained
16 in the certified design documents to documents that
17 you can take and go build a plant with -- construction
18 drawings, procurement specs, and things like that.

19 Right now, you could not take the design
20 certification document and hand it to an AE and say,
21 "Hey, here, go build this." There needs to be some
22 translation of these high-level design documents.

23 So the FOAKE inspections were designed to
24 ensure that this translation was adequate, and those
25 would be limited. There was also discussions on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 engineering design verifications, and that's more or
2 less once -- once the procurement specs had been
3 developed, it was kind of like a QA/QC check to ensure
4 that the applicant's or the licensee's process now
5 ensures that the equipment that they asked for is what
6 they got.

7 CHAIRMAN WALLIS: Are there any of these
8 public comments that are substantial or make
9 substantial changes in the -- well, I asked you that
10 before, and you said they were minimal. Which ones of
11 these are significant?

12 MR. OESTERLE: The one on COL information
13 availability is --

14 CHAIRMAN WALLIS: That's important.

15 MR. OESTERLE: Right. It won't make a
16 significant or substantial change to the document, but
17 it will be a -- we're intending more of a generic
18 change, and we're considering having applicants
19 identify those areas where information will be
20 provided later or will be updated, and to propose
21 methods for doing so, including identifying what
22 section of the application those items are included
23 in.

24 One area that -- another area that's going
25 to change in a more generic nature is providing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guidance for plants that incorporate passive safety
2 system designs. Originally, we intended this document
3 to be a very generic document, and not focus
4 specification on particular reactor vendor designs.
5 But in some areas, we acknowledge that providing
6 another level of generic guidance for areas for
7 passive plants, if you will, would be beneficial.

8 And examples include guidance in Chapter 8
9 for applicants to identify or provide guidance for
10 applicants that do not rely upon safety-related
11 Class 1E emergency diesel generators, because they
12 have 72-hour capacity batteries.

13 Likewise, we looked at providing guidance
14 for those applicants in Chapter 9 in the areas that
15 included guidance on diesel generator support systems.
16 There's intake air, combustion air, lubrication
17 systems, starting air systems, cooling water systems.
18 If you don't have Class 1E safety-related diesel
19 generators, the pedigree of those supporting systems
20 also changes.

21 I think we talked quite a bit about plant-
22 specific PRA, and I'll just move on.

23 One area that we had some good success on
24 was on the maintenance rule discussions. In fact, we
25 have a separate breakout session on that from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 workshops. And the initial guidance that was provided
2 in DG-1145 was -- provided comprehensive guidance on
3 the maintenance rule and practically gave everything
4 that the agency knew about in terms of maintenance
5 rule and how plants are to maintain their program,
6 even after they've begun operating.

7 We have scaled that back somewhat based on
8 workshop comments and discussions to -- for
9 applicants, just to provide the information necessary
10 to get their license.

11 Digital I&C continues to be an area where
12 there are discussions between staff and industry. I
13 will point out that most, if not all, of the digital
14 I&C areas are covered by DAC, the design acceptance
15 criteria. And those contain elements of design
16 completion and design implementation, so the staff and
17 industry are continuing discussions on those in order
18 to reach resolutions on design issues. In fact, there
19 have been some -- one of the brings to the Commission
20 on new reactor licensing included digital I&C as one
21 of the specific topics.

22 MEMBER SIEBER: And some of the
23 fundamental issues in I&C are not yet codified.

24 MR. OESTERLE: I think that's correct.

25 MEMBER SIEBER: Yes. There's got to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 more work.

2 MR. OESTERLE: There were some --

3 MEMBER SIEBER: We'll be revising this
4 document once that work is complete.

5 MR. OESTERLE: There were some discussions
6 on ITAAC, the guidance that was provided on ITAAC, and
7 certain areas seemed to be much more detailed than
8 necessary, and it was not consistent with the idea
9 that ITAAC was intended to verify top-level
10 performance requirements or design requirements for
11 the plant.

12 Other areas of workshop discussion and
13 comments included the format and content for an
14 environmental report. Also, the finality of an
15 environmental impact statement associated with an
16 early site permit. The Part 52 rule that went up to
17 the Commission largely clarified the issues with
18 respect to finality of an environmental impact
19 statement associated with an ESP that a COL applicant
20 references. And we will revise DG-1145 to conform
21 with that rule.

22 There were also some discussions on human
23 factors engineering which are also covered by design
24 acceptance criteria, rad waste treatment systems with
25 a focus there on temporary or mobile skid-mounted rad

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 waste treatment systems, and then what I call varied
2 guidance.

3 When we resolved comments that came up
4 during the workshops, we included the responses to
5 those comments in an appendix to DG-1145. And in some
6 areas where we acknowledged or accepted the comments,
7 we failed to move the basis for acceptance into the
8 guidance document, and we want to make sure that --
9 and we are making sure that the basis for accepting
10 that guidance does not stay in the appendix and gets
11 moved forward into the guidance document.

12 Does that get us back on track?

13 MEMBER KRESS: I think that does it. Why
14 don't we turn the meeting back to you now.

15 CHAIRMAN WALLIS: Well, how about the
16 other members who haven't spoken yet. Do they have
17 comments on this guide?

18 MEMBER KRESS: Well, we could ask for
19 those, yes.

20 CHAIRMAN WALLIS: Nothing wishing to
21 speak?

22 MEMBER MAYNARD: I've got just a couple.
23 I don't know if they got discussed in the subcommittee
24 meeting or not. I'll keep it real brief.

25 In Chapter 9, the auxiliary systems, to me

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there appear to be some discrepancies as to what's
2 being asked for some of the things. Up towards the
3 front of it, it's pretty methodical. You wanted this,
4 this, this, and this, and then toward the end of
5 Chapter 9 sometimes the safety analysis or safety
6 evaluation wasn't asked for, sometimes an inspection
7 wasn't, and it wasn't clear that there was logic or
8 rationale for that. So just kind of consistency
9 through that.

10 Another comment -- I think it's
11 Chapter 13, Operations, a lot of things that need to
12 be submitted, including like organization charts and
13 things and resumes. I think you need to take a look
14 at how much of that do you really need to have and
15 continue to get updated? What gets done with that
16 when it's here? And how timely is that anyway when
17 that's known ahead of time?

18 Take a look at that and see -- I believe
19 some of those things become a burden not only on the
20 licensee but also on the staff, and doesn't
21 necessarily add any safety benefit whatsoever. So
22 those are kind of -- I've already covered my other
23 generic comments on reg. guides and references to
24 generic letters and just a hodge-podge of a lot of
25 things here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. OESTERLE: We received similar or
2 identical comments to those which you just mentioned
3 from NEI, and we are looking at those to resolve.

4 CHAIRMAN WALLIS: Anything else?

5 SB*: I just have a couple of comments on
6 Chapter 15. You -- in particular for new designs, and
7 that -- I know that it doesn't apply to certified
8 designs, right? These are custom plants that you're
9 talking about. But quite often the word "limiting,"
10 and things like this are used. And it's not very
11 clear what you mean by these things exactly.

12 And also, with regard to new designs, how
13 these scenarios can be found, because I think there is
14 mention there that analysis doesn't have to be done,
15 but somehow you're going to pull these cases out of
16 the air or wherever. So I think the guidance is
17 rather unclear with regard to what should be done, in
18 particular for cases where there isn't a lot of
19 experience.

20 And in that chapter also there doesn't
21 seem to be that much guidance for what happens with
22 designs which are, for example, passively cooled, you
23 know, so there needs to be a little bit more clarity.
24 In any case, I've given my detailed comments, which
25 hopefully will be passed on to you regarding that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. OESTERLE: Yes, we have those
2 comments, and we'll be considering them.

3 SB*: Let's clear it up a little bit.

4 CHAIRMAN WALLIS: Thank you very much.

5 Are we now through with other member
6 comments?

7 MEMBER KRESS: I was wondering if this is
8 the right time, or maybe later, to ask members if they
9 have specific comments about what should go in the
10 letter, or should we wait until --

11 CHAIRMAN WALLIS: Well, we have time when
12 we're writing the letter to do that probably --

13 MEMBER KRESS: Okay. Well, we'll --

14 CHAIRMAN WALLIS: -- rather than now.

15 MEMBER KRESS: Why don't we wait and do it
16 then.

17 CHAIRMAN WALLIS: Yes. When we actually
18 pull things together for the letter, we'll do that.

19 NEI is on the program. I told -- they're
20 not going to have anything to say.

21 MEMBER KRESS: No, they're not --

22 CHAIRMAN WALLIS: So let's move on to the
23 break, and we will take a break for 15 minutes until
24 five minutes before 11:00. Then, we will take up the
25 next item at that time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Whereupon, the proceedings in the
2 foregoing matter went off the record at
3 10:41 a.m. and went back on the record at
4 10:57 a.m.)

5 CHAIRMAN WALLIS: Please come back into
6 session and we'll move on to the next item on the
7 agenda which is the Draft Final Regulatory Guide DG-
8 1144, "Guidelines for Evaluating Fatigue Analyses"
9 etcetera.

10 Before I hand over to my colleague, Dr.
11 Armijo, I'd like to note that the presentation that
12 I've been given here contains too many slides and I
13 hope that we can somehow get through them
14 expeditiously.

15 MEMBER APOSTOLAKIS: It's not PRA, Mr.
16 Chairman. It will be very quick.

17 (Laughter.)

18 CHAIRMAN WALLIS: I was tempted to say
19 that myself. Thank you. Okay, so let's get started.

20 MEMBER ARMIJO: Mr. Chairman, we reviewed
21 this topic at the Metallurgy Material from Reactor
22 Fuel Subcommittee yesterday. We had very detailed
23 discussions and presentations from the staff from
24 Argonne National Laboratory, as well as presentations
25 from ARIVA and the ASME Code people.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There was a lot of discussion. I think it
2 was a very valuable discussion and the really
3 addressed is focused on the appropriate way to design
4 for the effects of coolant environment on structural
5 materials.

6 We have a lot of data and fortunately we
7 now have a lot of data and so the issue is how to use
8 that data instead of arbitrary margins to do your
9 design.

10 This morning the presentations will be
11 made by the staff, by Mr. Gonzalez. He will be
12 introduced by Jennifer Ule of the Office of Research.
13 In addition, we've had requests for five-minute
14 presentations each by Mr. Gurdal of ARIVA and Mr.
15 Erler of the ASME.

16 So with that, I'd like to turn it over to
17 Jennifer Ule.

18 MS. ULE: Hi, thank you. Good morning.
19 I'd just like to represent the Office of Research
20 Management. My name is Jennifer Ule. I'm a Deputy
21 Division Director for Materials Engineering in the
22 Division of Fuels, Engineering and Radiological
23 Research.

24 Yesterday, you heard a very detailed
25 technical presentation from the staff regarding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 incorporating the effects of the environment on
2 fatigue life and we're hoping today we'll have a brief
3 summary of that and continue to defend the position
4 that the staff is looking for your support for going
5 out with a reg. guide to deal with the situation about
6 the environmental effects of fatigue life. The
7 purpose for that is support new designs which we feel
8 is something that is of vital importance to do so.

9 Thanks for that and Hipolito Gonzalez will
10 start the presentation.

11 MEMBER POWERS: I don't want you to get
12 away that easily, Jennifer.

13 (Laughter.)

14 MS. ULE: Okay, this isn't thermal
15 hydraulics.

16 (Laughter.)

17 MEMBER POWERS: This is an important issue
18 as opposed to thermal hydraulics.

19 (Laughter.)

20 MEMBER POWERS: Looking back through the
21 document and I'm sure the presentation of the
22 subcommittee last, although I didn't attend, you know,
23 this is an exposition in empiricism that's quite
24 impressive. But I see little in this exposition that
25 would reflect what I would call fundamental

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 understanding of the fatigue phenomenon. And
2 recognizing that that's a fairly challenging area to
3 undertake, I pose this question to the Office of
4 Research. Is there anything going on within research
5 or should there be anything going on to develop what
6 I would call a fundamental, mechanistic understanding
7 of fatigue?

8 MS. ULE: I could say and certainly the
9 technical staff can support me on this, our goal here
10 was to get a reg. guide that supports new designs
11 because we have concerns with the situation that the
12 current fatigue rules would not have an environmental
13 effect. And with that we had a certain amount of time
14 to get something in place and we did so.

15 We always with any modeling you have to
16 understand a certain amount of the mechanisms, but
17 with regard to -- and rightly said, it is an empirical
18 argument.

19 We have a certain amount of activities
20 associated with moving forward into a more proactive
21 arena for materials management and we have budget set
22 aside to do exactly what you're saying, not only to
23 look into more of the mechanistic understanding of
24 some of the degradation mechanisms associated with the
25 materials arena.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So with that we are heading in that
2 direction, but at the same time when we have a safety
3 issue at hand, we do have to get something in place
4 that we're comfortable, is acceptably accurate and
5 conservative.

6 MEMBER POWERS: Could you provide the
7 Committee, actually, I don't care if you provide the
8 Committee or not, but provide me with a list of those
9 programs that you think fall within this development
10 of fundamental understanding of the materials
11 degradation?

12 MS. ULE: Sure, we can get that very
13 quickly back to you.

14 MEMBER POWERS: Thank you.

15 MS. ULE: Does the tech staff want to have
16 any other comment about any other modeling area of the
17 mechanistic or fatigue? So we agree there is a need
18 to have that. It's a matter of balancing priorities
19 with regard to a finite --

20 MEMBER POWERS: Well, I understand that I
21 did not take the position that there's a need. I
22 asked if you thought there was a need and you said
23 that there is.

24 MS. ULE: I didn't say it quite that
25 strongly.

1 MEMBER POWERS: I understand.

2 MS. ULE: Don't get me wrong.

3 MEMBER POWERS: I've got your exact words.

4 (Laughter.)

5 MS. ULE: In a perfect world, we would
6 understand mechanistically everything. And certainly
7 the more you understand something mechanistically, the
8 more confident you are, but at the same time, there
9 are finite resources and in providing we can
10 demonstrate through empiricism and appropriate test
11 conditions that are considered prototypic, then we can
12 establish the safety.

13 MEMBER POWERS: The challenge I see, of
14 course, is that you reveal in your empiricism a
15 substantial environmental effect and, of course, you
16 characterize that environment as best you can at the
17 time. You're very likely to find something new and
18 exciting, especially as we move to designs where you
19 haven't an experiential data base as rich as we have
20 for the existing reactors.

21 MS. ULE: Right. And note that we do have
22 in-service inspection programs to try to monitor
23 things as they --

24 MEMBER POWERS: Which I would be prepared
25 to take the position that they've largely been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 unsuccessful.

2 MS. ULE: ISI programs. That's a whole
3 different argument.

4 MEMBER POWERS: That's a whole different
5 argument, but I would be prepared to defend that point
6 of view.

7 MS. ULE: ISI has been proven effective in
8 a variety of situations. We do recognize that in
9 certain particular areas, certain geometries, certain
10 specific materials that some ISI techniques are not as
11 effective as we'd like.

12 MEMBER POWERS: Or you're telling me that
13 the technique is successful except where it isn't.
14 And that's --

15 MS. ULE: Yes.

16 (Laughter.)

17 MS. ULE: Certain specific situations. We
18 do have inspections going on in the Office of Research
19 to demonstrate and determine the effectiveness of ISI
20 programs and we can come back to the Committee on it
21 if you --

22 MEMBER POWERS: I think about every three
23 years, we augment those lists of special situations
24 where it's not effective.

25 MEMBER ARMIJO: I think that's the issue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of mechanistic understanding is very important because
2 when changes occur, you don't know whether those
3 changes are going to increase the degradation effect
4 of the environment or decrease it and we've seen the
5 effects of, funny effects of the oxygen content,
6 different for ferritic materials versus austenitic
7 materials. So I think that's work that's valuable.
8 It's a little off the subject at this point and I
9 think we have limited time, so I would like to just
10 proceed with the presentations and keep it as brief as
11 you can.

12 MR. GONZALEZ: Thank you, Jennifer. First
13 of all, I would like to acknowledge William Collins
14 from the Office of Research and John Ferrer for NRR
15 for their help and comments on this project.

16 So basic agenda is first we're going to
17 talk about the motivation to perform this work, to
18 have an overview of the Regulatory Guide 1.207, have
19 an overview of the technical basis report and present
20 a summary of the regulatory positions and show their
21 resolution of the public comments for both draft NUREG
22 and draft reg. guide.

23 NRR requested RES to develop guidance for
24 determining acceptable fatigue life of ASME pressure
25 boundary components with a consideration of light-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 water reactor environment. This guidance is going to
2 be used for supporting reviews, application that the
3 Agency expects to receive for new reactors.

4 The industry was notified of the
5 initiation of this work. And in addition, this is one
6 of the high priority reg. guides, has to be completed
7 by March 2007.

8 Here is an overview of how the reg. guide
9 relates to the regulatory requirements. General
10 Design Criterion 1 and General Design Criterion 13
11 states that safety-related structural system and
12 component must be designed, fabricated, tested and
13 erected to a quality standard commensurate with the
14 report of the safety function performed and to the
15 highest quality, practical quality standards.

16 10 CFR 50.55(a) endorses the ASME boiler
17 and pressure vessel code for the design of safety-
18 related system and components. That's Class 1
19 components and the ASME Code Section includes the
20 design fatigue curves.

21 This ASME fatigue curves, design curves do
22 not address the impact of the reactor and coolant
23 system environment.

24 So the objective of the reg. guide is for
25 providing guidance for determining an acceptable

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fatigue life of the pressure boundary component with
2 consideration of the light-water reactor environment
3 and for the major structural materials. That would be
4 carbon steel, low-alloy steels and austenitic
5 stainless steels and nickel-based alloys, for example,
6 Alloy 600 and 690.

7 And so doing I will describe the approach
8 that the NRC staff considers acceptable to support
9 reviews of application for new reactors.

10 Limitations, it's only going to apply to
11 new plants and this means there's no backfit intended.

12 So now I'm going to -- Omesh is the
13 contractor that came from Argonne National Lab that
14 developed the technical basis report.

15 CHAIRMAN WALLIS: Just looking at this,
16 "compliance regulatory guides is not required." But
17 it is required that they analyze fatigue and they must
18 use some kind of a curve or something. Is there
19 anything else available?

20 I don't see what else they could do but --
21 they use either the ASME Code or they use your guide,
22 that's it.

23 MEMBER POWERS: Or they can submit another
24 --

25 CHAIRMAN WALLIS: Are there other things

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 out there?

2 MEMBER APOSTOLAKIS: These are the
3 legalities of the issue.

4 CHAIRMAN WALLIS: No, but --

5 MEMBER APOSTOLAKIS: You have a regulatory
6 guide.

7 CHAIRMAN WALLIS: Essentially, these are
8 the choices, aren't they? They don't have a choice of
9 doing something else, do they? Just from the point of
10 view of what's there technically that's available? Is
11 there some other guidance that they could use?

12 MEMBER APOSTOLAKIS: There's --

13 MR. FERRER: This is John Ferrer from NRR.
14 I think as we discussed yesterday there are several
15 proposals within the ASME code that were made either
16 by the --

17 CHAIRMAN WALLIS: Yes, they're within the
18 ASME code, yes.

19 MR. FERRER: But they could be used as a
20 basis for submitting an alternative proposal.

21 CHAIRMAN WALLIS: Well, that's where the
22 alternative might lie then.

23 MR. FERRER: Yes.

24 CHAIRMAN WALLIS: Okay. Thank you.

25 MR. GONZALEZ: I will, I'll make sure --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we probably will do the technical basis report
2 presentation.

3 MEMBER POWERS: I hope you have reduced
4 the number of sentences.

5 MEMBER ARMIJO: Yes. Give me just about
6 15 or 20 minutes.

7 MEMBER POWERS: Okay.

8 MR. COLLINS: What we're discussing is
9 the effect of light-water reactor cooling environments
10 on the fatigue life of structural steel. And there's
11 a large amount of data developed during the last 20 to
12 30 years which shows that there's a significant effect
13 of coolant environment on the fatigue live of these
14 steels. And this data is very consistent irrespective
15 of where it was generated, which lab. It shows
16 similar traits without any exception. And it's also
17 consistent with the larger data base which we have on
18 crack growth rates.

19 Environmental effect on crack growth rates
20 are quite well established. The mechanism is quite
21 well established, at least in several of these alloys,
22 and the mechanism of environmental effects on crack
23 initiation also appear to be similar. And this data
24 has been evaluated to identify the key parameters
25 which influence fatigue life. And these parameters

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are very similar to what effects we see on crack
2 growth rate. And the analysis has also defined the
3 range of these parameters over which environmental
4 effects are significant. So we know exactly the
5 conditions under which there will be environmental
6 effects.

7 The question is if these conditions exist
8 in the field, then we will see similar effects and
9 they have to be addressed. As we know, subsection NB-
10 3121 recognizes that the current fatigue design curves
11 do not include the effect of aggressive environment
12 which may accelerate fatigue failure.

13 So the burden in a way is on the designer
14 to better define the design transience so that we
15 understand what possible effects of environment --

16 CHAIRMAN WALLIS: So this figure, this
17 number of 20 was just introduced out of the air? It
18 wasn't used to cover other environments at all?

19 MR. COLLINS: No.

20 MEMBER ARMIJO: It happened to do that.

21 CHAIRMAN WALLIS: It happened to do that,
22 but it wasn't because they had tested in other
23 environments?

24 MEMBER ARMIJO: Correct.

25 CHAIRMAN WALLIS: And that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 appropriate, okay.

2 MEMBER ARMIJO: That was good judgment by
3 people a long time ago.

4 MR. COLLINS: A little background
5 information. We are talking about fatigue life. What
6 do we mean by fatigue life?

7 The data which was used to generate
8 current core design codes, the specimens were tested
9 to failure. So quite often these curves are termed as
10 cycles to failure, but the attempt was to define
11 conditions to avoid crack initiation.

12 All the data which we have obtained in the
13 last 20 to 30 years in this fatigue life is defined as
14 the decrease of the peak load by 25 percent. For the
15 size of specimens, this would correspond to about 3
16 millimeter crack.

17 CHAIRMAN WALLIS: Is it dependent on how
18 thick the steel is?

19 MR. COLLINS: All this happens about
20 quarter to three-eighth inch --

21 CHAIRMAN WALLIS: In the samples.

22 MR. COLLINS: In the samples. So what the
23 data is showing is initiation of 3 millimeter cracks.
24 The number of cycles needed.

25 MEMBER APOSTOLAKIS: What does 25 percent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 load drop mean?

2 MR. COLLINS: After crack advances, the
3 total load on the sample will decrease because the
4 cross section is depleted.

5 MEMBER APOSTOLAKIS: I see.

6 MR. COLLINS: So you can relate how deep
7 the crack is.

8 And we know on the cyclic loading --

9 CHAIRMAN WALLIS: So this is the same
10 thing when you have a pipe which has a thick wall?

11 MR. COLLINS: It will start as a small
12 crack and it will propagate.

13 CHAIRMAN WALLIS: But the life is the
14 same, independent of how thick it is?

15 MR. COLLINS: No. For complete failure,
16 it would be different, but to initiate a crack depends
17 on the loading initiatives are there and so on.

18 CHAIRMAN WALLIS: How do you define life
19 for a big pipe compared with life for your little
20 sample?

21 MR. COLLINS: Life would be only to
22 initiate a crack and beyond that we use crack growth
23 rate correlations or expressions to see how it will --

24 CHAIRMAN WALLIS: There's still a lot of
25 life left in this thing after it's had its fatigue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 life?

2 MR. COLLINS: Fatigue life is initiation,
3 number of cycles to initiate a crack, which we can
4 defect.

5 CHAIRMAN WALLIS: So it doesn't fail. It
6 still has got a lot of life left in it after that.

7 MEMBER POWERS: After the cracks form,
8 then they use this probabilistic fracture mechanics
9 and come up with 10^{45} years.

10 CHAIRMAN WALLIS: Are you not talking
11 about complete failure, once they reach this life.

12 MR. COLLINS: So fatigue life can be said
13 to be associated with more of these cracks from some
14 10 micron size to 3 millimeter size and fatigue life
15 is divided into two stages, initiation stage and a
16 propagation stage.

17 Initiation is growth of about 300 micron
18 and beyond that --

19 CHAIRMAN WALLIS: Could you tell me, I'm
20 sorry, I have to pursue my question a bit more. When
21 we look at your curves and you've got a syllabus, a
22 cycle life and all that, that's related to the life of
23 the plant, 40 years, 60 years and so on. But because
24 you're only going to 3 millimeters doesn't that mean
25 that there's still something like a 100 years of life

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 left in this pipe?

2 MR. COLLINS: That's where flow evaluation
3 analysis --

4 CHAIRMAN WALLIS: Is that true or am I
5 wrong? Is that true that you've still got decades of
6 life left in the pipe?

7 MR. FERRER: It's totally dependent on the
8 type of loading. We do have an evaluation of that
9 issue and when we resolved GSI-190 we had a risk
10 assessment performed where they took the Argonne
11 correlations to determine how long it took for crack
12 initiation. Then they went through crack growth
13 evaluation to determine how long it took to go through
14 a wall.

15 In some cases, under some loading
16 conditions, it goes through very quickly and under
17 other loading conditions --

18 CHAIRMAN WALLIS: Tomorrow?

19 MR. FERRER: Not tomorrow, but very
20 quickly in terms of multiples of the time it takes to
21 initiate the crack.

22 CHAIRMAN WALLIS: But it takes maybe 30
23 years to initiate the crack to get to 3 millimeters.
24 Is it another 30 years before anything happens?

25 MR. FERRER: Well, the intent is to go to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the design life before you initiate the crack and then
2 there should take -- again, it's a variable, depending
3 on the loading conditions how long it would take for
4 the crack to grow through a wall and cause a leak.

5 CHAIRMAN WALLIS: So are you answering my
6 question? I'm trying to put this in perspective.
7 Does it really matter that we get this precisely if
8 there's a whole lot of life anyway?

9 MR. FERRER: I think if we go on to the
10 basis that we discussed yesterday for the fatigue
11 initiation was a 95/5 basis, so you have a 95 percent
12 confidence, fewer than 5 percent fatigue initiation.
13 The only reason that that's acceptable is because you
14 have some remaining life after you initiate the crack.

15 MEMBER SIEBER: I suspect the uncertainty
16 of crack growth rate is substantially more than the
17 initiation rate and so it's much more difficult to say
18 how much longer will it last once a crack initiates
19 than it is to predict when the crack --

20 CHAIRMAN WALLIS: It's reasonably
21 conservative to assume that the fatigue life is the
22 life of the pipe?

23 MEMBER SIEBER: I wouldn't want to run it
24 up to the last minute.

25 MR. FERRER: I wouldn't.

1 CHAIRMAN WALLIS: Okay, I'm just trying to
2 put it in perspective. Three millimeters seems very
3 small in a very thick wall.

4 MR. FERRER: Let me add one thing to this.
5 The piping system has to be able to sustain the design
6 loads, so if you were to get a situation where you
7 would say it's acceptable to run the crack through the
8 wall, you might not have enough section thickness to
9 take something --

10 CHAIRMAN WALLIS: We have examples of
11 pipes which have had long, big cracks. We have them
12 now.

13 MR. FERRER: Yes, you have examples, but
14 they may not have been loaded up to their design
15 loading.

16 CHAIRMAN WALLIS: You still haven't
17 answered my question, really. Maybe you won't. I
18 still don't have an idea. Is this important in the
19 life of the pipe?

20 MR. FERRER: Yes.

21 CHAIRMAN WALLIS: How important is it?

22 MEMBER POWERS: Depends on the pipe.

23 CHAIRMAN WALLIS: Depends on the pipe.
24 Okay, so there is no answer to my question.

25 These are big pipes. It must make a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 difference.

2 MEMBER POWERS: What he's telling you is -
3 - I think what you're telling him is it depends on
4 what service the pipe is receiving.

5 CHAIRMAN WALLIS: You know the service the
6 pipe is receiving, so you should be able to answer
7 that question.

8 MEMBER APOSTOLAKIS: But is it a matter of
9 years? That was your original question?

10 CHAIRMAN WALLIS: How many years is it?
11 If it's 30 years to get a 3 millimeter crack, does
12 that mean I've got another something like 30 years
13 left in the pipe? That's the question I'm trying to
14 ask.

15 MR. MANOLY: May I respond to that? My
16 name is Kamal Manoly and I'm the Branch Chief of the
17 General Mechanics Branch, NRR.

18 In response to your question, the pipe
19 during operation does not see the design load. The
20 design load is much higher than what you see during
21 operation. So if you have a crack and then you see a
22 design load like seismic event, with a cracked pipe,
23 it's not the cross section that you need. It's a lot
24 less than you need.

25 CHAIRMAN WALLIS: Can the ASME answer my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 question?

2 Are you from ASME?

3 MR. MAYFIELD: No, they disowned me years
4 ago. This is Mike Mayfield. I'm the Director of the
5 Division of Engineering in the Office of New Reactors.

6 Professor Wallis, you're talking about
7 great, thick pipes which is true for the primary
8 coolant loop. They'll run 2.5 to 3 inches or more.
9 That's not necessarily the biggest concern.

10 As you start getting to smaller diameter
11 pipes, the thickness comes down. Surge lines will run
12 a bit over an inch --

13 CHAIRMAN WALLIS: All those are true
14 statements.

15 MR. MAYFIELD: Sir?

16 CHAIRMAN WALLIS: All those are true
17 statements. What's the answer to my question?

18 MR. MAYFIELD: Let me go back to the
19 relative importance of three millimeters. Three
20 millimeters is a nice size that we typically see in
21 well-controlled laboratory samples. If you impose the
22 same number of cycles on a pipe specimen and you get
23 to that initiated size, three millimeters may not be
24 the appropriate size. It's the nice size we can
25 detect at the 25 percent load drop in a well-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 controlled, polished laboratory sample.

2 So I think there are two things I would
3 challenge in the proposition you put forward. First
4 of all, all the pipes aren't great thick things. And
5 secondly, three millimeters isn't necessarily the
6 initiation size you would see in a pipe.

7 CHAIRMAN WALLIS: You see the question is
8 what does a test in these little samples with a three
9 millimeter crack have to do with what happens in a
10 pipe in a plant. That's a very simple question. I'd
11 like to have an answer.

12 MR. MAYFIELD: And the answer is just as
13 one of the Members suggested, it depends. And it
14 depends --

15 CHAIRMAN WALLIS: That's no use at all.

16 MR. MAYFIELD: I disagree. I think it's
17 very useful and it depends on is the pipe, has the
18 pipe been counterbored? How thick is it actually?
19 What are the cyclic loads imposed? And it varies
20 where you are --

21 CHAIRMAN WALLIS: You're acting like a
22 professor. I just want a simple, straightforward
23 answer.

24 The designer must know.

25 MR. MAYFIELD: The answer is yes and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reason is depending, as John pointed out, when we
2 looked at GSI-190, what we found is that you can drive
3 a crack, an initiated crack through wall in much less
4 than the design life of the pipe of the plant in some
5 cases.

6 In other cases, it's multiples of the
7 design life of the plant. There isn't a simple yes or
8 no answer to your question.

9 VICE CHAIRMAN SHACK: This is Bill Shack.
10 Let me try another shot at it just to -- the design
11 basis for the pipe says there are no cracks in it.
12 Now that you've got a crack, you have to address the
13 fact that you've got a cracked pipe. You go through
14 a crack disposition analysis.

15 What you find from that crack disposition
16 analysis will vary from case to case, depending on the
17 loads that you have, but you now have to address the
18 situation that you've initiated a crack.

19 CHAIRMAN WALLIS: But what I'd like to get
20 is an answer. Let's same the main circuit pipes won't
21 fail for another 100 years, but there are certain
22 pipes which we've analyzed when they get cracks like
23 this which would fail in 10 years. Some answer, which
24 is --

25 VICE CHAIRMAN SHACK: Failure is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 relative thing. Do you mean growth through the wall?
2 Do you mean --

3 CHAIRMAN WALLIS: You don't know. You
4 don't know.

5 VICE CHAIRMAN SHACK: It varies in
6 situation. As John has said, you do the analysis, you
7 get relatively --

8 CHAIRMAN WALLIS: People must have done
9 the analysis. Okay, I won't ask any more. I'm very
10 disappointed.

11 MEMBER ARMIJO: Graham, I mean we have
12 detected fatigue cracks in components, reactor
13 components. They're not through wall. They probably
14 would not grow for a long time, but yet we've repaired
15 or replaced them because we just don't want to operate
16 with those kinds of defects for reasons. Good
17 reasons.

18 And so I think the issue here is try to
19 design a plant so that you don't create a lot of small
20 cracks. And these are relatively small, but if it's
21 a thin-walled pipe, it could be significant. It might
22 not last very long.

23 MEMBER MAYNARD: The purpose of all this
24 seems to be two-fold. One is to identify the types of
25 conditions and situations that cause fatigue so that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you can help in the design phase to design as much of
2 that out as possible. The other is identifying those
3 characteristics, those things that will cause, shorten
4 the fatigue life or have a crack initiation earlier so
5 you know what places to monitor and where to help with
6 the inspection process.

7 Is that --

8 MEMBER ARMIJO: Yes. It's just a --

9 MEMBER MAYNARD: It's a tool to be used to
10 identify vulnerabilities.

11 MEMBER ARMIJO: And to eliminate them, if
12 we can.

13 MEMBER POWERS: Because the Committee has
14 so much interest in cracks, I'll help to continue the
15 discussion.

16 In the exposition in the document, there
17 is really a quite nice discussion of these, I believe
18 you call them microstructural cracks and then you have
19 mechanical engineering cracks.

20 What was -- and they had different
21 characteristics. One will propagate and the other
22 does not at given stress levels. But you get high
23 enough from stress level and they all propagate.

24 What I wondered and came away from the
25 document wondering is that there is some understanding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of what is qualitatively different about these cracks,
2 other than the fact that they are shorter and longer?
3 Or do we not know? Probably what I'm asking is, is
4 there something very different about the cracked tips
5 on these two classes of cracks that you identify?

6 MR. COLLINS: Very small cracks, less than
7 200 microns. The growth is sheer crack growth. It is
8 typically 45 degree to the stress action, along strip
9 lines. And that extends about a couple of grains.
10 Typically grain sizes would be 25 to 50 microns. So
11 it extends beyond that. It switches to a densely
12 cracked growth, which is perpendicular to the stress
13 cracks.

14 What we typically see in a fracture
15 surface for fatigue is that densely cracked growth,
16 which is very well marked with striations. You can
17 see inside them.

18 MEMBER POWERS: Yes, looks like fatigue
19 striations.

20 MR. COLLINS: The effect of alignment on
21 densely cracked growth is very well known. The reason
22 we added that part in our document was to see does
23 environment affect even the small cracked growth? And
24 that's what we have done to mark these samples,
25 fatigue samples, to see how much of an effect

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 environment does. And we see that in fact the effect
2 of environment may be even larger than what we see in
3 crack growth rates.

4 CHAIRMAN WALLIS: N is the number of
5 cycles to get a 3 millimeter crack in your sample?
6 What does the same number of cycles do to a major pipe
7 in a reactor loop? Would it create a 3 millimeter
8 crack or does it create a 30 millimeter crack? What
9 does it do? What does the same N do in a real
10 situation?

11 MR. COLLINS: There are three parameters
12 which we have defined now in this fatigue life. At
13 certain stress levels, how much number of cycles would
14 be needed to create a 3 millimeter crack. Now if the
15 same conditions are known in a pipe, if the same
16 stress condition is there, the same number of cycles,
17 would create -- this will give you a probability -- if
18 you follow the design curve, it defines certain
19 problems.

20 CHAIRMAN WALLIS: Does it give you a three
21 millimeter crack or does it give you a 25 percent load
22 drop? What does it give you? What does it give you
23 in the real --

24 MR. COLLINS: The way we define in the
25 lab, because all we want to know is measure a crack

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 size.

2 CHAIRMAN WALLIS: What does it give you in
3 a real pipe?

4 MR. COLLINS: It would give me a crack
5 which I can detect, a crack of a size that I can
6 detect.

7 CHAIRMAN WALLIS: Three millimeter?

8 MR. COLLINS: About three millimeter.
9 That's an approximate number. It depends on the shape
10 of the crack --

11 CHAIRMAN WALLIS: That's all right. Thank
12 you. That's all.

13 VICE CHAIRMAN SHACK: This is Bill Shack.
14 It gives you a crack that now grows by fracture
15 mechanics. You know, one of the difference between
16 the microstructural crack is that you have a very
17 localized plastic zone. It's a grain by grain thing,
18 because it's not a continuum. When the crack gets to
19 be three millimeters or so, this material no longer
20 looks like individual grains. It's a continual --

21 MEMBER POWERS: You're only clear about
22 one question because whenever they try to answer it,
23 you say well, that's not answering my question.

24 CHAIRMAN WALLIS: We never get to the end
25 of the answer. That's okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Because you interrupt them
2 every time they try to answer.

3 MR. COLLINS: Just to briefly mention, the
4 Code design curves. The data that we have is obtained
5 on the small specimens, which are very smooth and
6 tested at room temperature under constant loading. In
7 the real situation, to apply this data to a real
8 reactor component, which is much larger in size,
9 surface roughness is there, there may be residual mean
10 stresses and all, to account for all these other
11 effects of variables which do it in fatigue life but
12 were not included in this data.

13 To account for that, what the code
14 procedure -- what the procedure Code uses now, is to
15 take the best fit of the data and then adjust this
16 mean curve for mean stress corrections and to account
17 for this using this factor of 2 and 20. These are
18 factors to account for variables which were not
19 included in the data, not investigated in the data.
20 And that's how we get the design curves.

21 Now the current design curve for
22 austenitic stainless steels is not consistent with the
23 current data. I plotted the ASME code mean curve for
24 austenitic stainless steels. This was the curve which
25 was used to draw up the current design curve. And the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 data which we have for type 316, 304, all of the data,
2 most of the data at low strain levels is to the left
3 of the curve. So the code curve is predicting longer
4 lives. So in this reg guide, a new design curve which
5 is consistent with the data is being proposed.

6 Now the affect of environments. For
7 carbon and low alloy steels, there are several
8 parameters which influence fatigue life. It doesn't
9 matter which steel type, a grade of steel, greatest
10 carbon steels or low alloy steels, effect is similar.
11 But there is strain threshold, below which effect of
12 environment is insignificant, or it does not occur.
13 And that is closer to the fatigue limit of the steel.

14 Other three parameters are very important,
15 strain rate, lower the strain rate, higher the effect.
16 And there is a threshold below which effects are
17 significant. Above that, more great effects. Maximum
18 factor of two. Temperature effect, again of
19 threshold, higher temperatures, larger effect. Same
20 dissolved oxygen, there is a threshold of low .04 ppm.
21 Higher oxygen, larger effect. And these are --
22 although you can say these are empirical, but they are
23 really consistent with the mechanisms that we know on
24 cracked growth rate. How dissolved oxygen would
25 affect and environmental effects.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Same thing in carbon, low-alloy steel.
2 Sulphur content of the steel is very important. And
3 the higher the sulfur content, the higher effect.
4 Surface roughness we know rough samples have lower
5 life in air, because they provide sites for crack
6 initiation, any scratch. And water, high dissolved
7 oxygen water, for carbon and low alloy steels, the
8 surface effect was not observed in some tests done in
9 the lab. Both smooth and rough samples gave similar
10 life.

11 Flow rate, all the tests which have done
12 in the lab, very slow flow rates, very low flow rates.
13 Whereas in the real systems they are higher flow
14 rates. Tests done to study the effect of flow rates
15 suggests that higher flow rates effect is less. And
16 this is again consistent with the understanding of the
17 mechanisms. It seems to flush the sulfide content
18 away --

19 CHAIRMAN WALLIS: Does the effect go away
20 in a main pipe in a reactor because the flow rate is
21 so big?

22 MR. COLLINS: If the flows are higher, it
23 would show a lower effect.

24 CHAIRMAN WALLIS: So why isn't that
25 accounted for in your predictions here? It seems to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be part of the reactor?

2 MR. COLLINS: Cracking may occur in a
3 stagnant region, so you know you have to consider the
4 locations and so on. If it can be demonstrated that
5 certain location flow is higher, on a case by case
6 basis this could be evaluated.

7 Similar effects on austenitic stainless
8 steels, there are certain parameters which affect --
9 steel type is not important. Radius grades have
10 similar effect. Gas stainless steels also have
11 similar effect. Same strain threshold, effects of
12 strain rate temperature are similar. There is a
13 threshold. Lower strain rate, higher effect. Higher
14 temperatures, greater effect.

15 Dissolved oxygen surface, roughness and
16 flow rate seem to have different effects on austenitic
17 stainless steels compared to carbon steel.

18 In this case, low oxygen has large effect
19 irrespective of the type of steel or what heat
20 treatment, whether it is sensitized steel or solution,
21 all have the same effects. High oxygen, some of the
22 nonsensitized steels have longer lives. Low carbon
23 grades, 316 ND and so on have longer lives.

24 Surface roughness in this case both rough
25 and smooth, we did see the effect of roughness in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 water and in air. Typically, life can be a factor of
2 up to three shorter for rough samples.

3 Flow rate, there was no effect of flow
4 rate on fatigue life of austenitic stainless steel.

5 MEMBER POWERS: In your document, you
6 report taking specimens, I presume on a lathe and
7 taking some emery paper to rough them up. And you
8 report here what your observations were on those.

9 I came away and said gee, you know, when
10 I think about large components being installed, yes,
11 they're certainly not mirror polished like typical
12 specimens, but they also seem to accumulate dents and
13 dings and scratches of macroscopic character and I
14 said is surface roughness correlation applicable to
15 those or is there something else that should be
16 applied to what I call macroscopic flaw.

17 MR. COLLINS: I think the next slide may
18 give you -- two slides down.

19 MEMBER POWERS: Sure, I'm patient.

20 MR. COLLINS: Based on these data which we
21 have, we can have correlations which would predict
22 fatigue life in air and in environment. Environmental
23 effects are lumped here, depending on the strain rate,
24 dissolved oxygen temperatures, sulphur content.
25 Expressed by these, we can determine the effect of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fatigue life in these environments, air or light water
2 reactor environments.

3 Now these expressions represent average
4 fatigue of the material for the median material. Same
5 correlations are for austenitic stainless steels and
6 can be used to predict life.

7 These correlations were determined from
8 distribution of heat to heat distribution, so that's
9 why these correlations represent the median material.

10 Now quite often it's suggested that lab
11 data may not apply to a real reactor condition. There
12 is one component test recently, this was sponsored by
13 EPRI. A stainless steel, U-bend tubes were tested in
14 PWR water at 240, and I plotted as the given strain
15 amplitude for the test what is the life they observed
16 for a leak through the pipe.

17 CHAIRMAN WALLIS: A leak, that's --

18 MR. COLLINS: Because you have relatively
19 thin walls --

20 CHAIRMAN WALLIS: Thin walls.

21 MR. COLLINS: So we define by leak. The
22 diamonds are very low strain rate. Circles are the
23 highest strain rate. And we know their lives. If I
24 know the number for base number in air, I can
25 determine what is the reduction. There are two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 methods I've used to determine life in air. An
2 average of about 10,000. So I get a reduction factor
3 of 5.8 at the low strain rate, 2.8 at the high strain
4 rate. And those correlations that I showed predict
5 reductions of 5.5 and 3.6.

6 CHAIRMAN WALLIS: What's the velocity of
7 the water?

8 MR. COLLINS: They use flow, regular flow.
9 It's in the paper. I can give you that number.

10 MR. GURDAL: They used different flow
11 rates.

12 MR. COLLINS: And actually, they did not
13 see the effect of flow rates, so they confirmed what
14 we see in the lab. That's another thing.

15 CHAIRMAN WALLIS: No effect of flow rates?

16 MR. COLLINS: Right.

17 MR. GURDAL: No. Wait a minute. This is
18 for stainless steel. For carbon steel, there is --

19 MR. COLLINS: Right. I'm just talking
20 about --

21 MEMBER MAYNARD: You've got to get to a
22 microphone.

23 MR. GURDAL: Sorry about that. My name is
24 Robert Gurdal from ARIVA. The goal, and I say it was
25 the only purpose to start with of these tests was to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 find if, for stainless steel you have the same flow
2 rate effect as you have for carbon steel and LAS.
3 What LAS means is low alloy steel. And they found
4 exactly like Omesh said that for stainless steel the
5 effect of flow rate is maybe something like 10 percent
6 maximum. In other words, negligible or you would say
7 none.

8 But for carbon steel, it's very important
9 for carbon steel and LAS, there is an effect of high
10 flow rate which is not in the methodology.

11 MEMBER POWERS: Excuse me, I'm confused.
12 We have two strain rates here. I see no measure of
13 flow rate on these plots.

14 MR. COLLINS: Irrespective of flow rate,
15 they got similar numbers, so these tests that you see
16 here, one is at a low strain rate, flow rate and
17 another at a higher flow rate and they gave similar
18 answers.

19 So the flow rate, I have not given that
20 information.

21 MR. GURDAL: The red ones, do you see the
22 red ones in the middle of the picture there, the
23 picture on the left?

24 MEMBER POWERS: I don't see any red ones.

25 MR. GURDAL: Sorry, that's four points and

1 these four have two high flow rate tests and two low
2 flow rate tests and they are together.

3 MEMBER POWERS: I'm just really confused.
4 The plot seems to have nothing to do with flow rate.

5 MEMBER ARMIJO: Right, it has nothing to
6 do with flow rate because there is no flow rate --

7 MEMBER POWERS: I am wondering why they're
8 bringing this point up.

9 MEMBER ARMIJO: I don't know. I agree
10 with you. I don't know why that's a discussion. The
11 issue here is would a small sample test predict
12 behavior of a real component, albeit a small U-bend
13 tube. That's all --

14 CHAIRMAN WALLIS: The reason flow rate
15 comes up is we were told that the higher flow rates there
16 is less effect of this fatigue on some circumstances.
17 That's why the question is --

18 MEMBER ARMIJO: In carbon steel, it is.

19 MEMBER POWERS: Again, flow rate has
20 nothing to do with this. It's a stainless steel and
21 it seems not to have a flow rate effect.

22 CHAIRMAN WALLIS: That's very useful
23 information.

24 MEMBER POWERS: I'm still trying to
25 understand a little bit about your comparison there,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is when you compared, did that come from the normal
2 installation flaws and dings and things like that?

3 MR. COLLINS: It was normal fabricated
4 tube, what you would use in a real system. So the
5 idea is to show that what we observed, the only
6 purpose of this slide would be to show what we predict
7 in the lab on a small specimen.

8 Actually, it shows good agreement with
9 what they observed in real material which was a normal
10 tube, not polished. In fact, they used different
11 surface finishes and so on.

12 Now getting back to how do we determine
13 the design curves. We get data on smooth specimens
14 and I mention just this specimen data to apply to a
15 real component, there are these adjustment factors of
16 2 and 20. Let's look at this 20. The current code,
17 this 20 is made up of three sub-factors, material
18 variability, tube size 2.5 surface finish, loading is
19 fitted in, taking into account. Total 20.

20 From our analysis of the current data we
21 get a number of materialability anywhere between 2.1
22 to 2.8. Size, minimum. This is from the literature
23 survey. We have looked at the studies which have been
24 conducted, the effects of these things and we get
25 minimum and maximum numbers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Surface finish, we get a number of 2 to
2 3.5. To answer your question, there is a good
3 correlation which has been developed based on the
4 experimental data correlating the surface finish, RMS
5 value of the surface finish on reduction in fatigue
6 life.

7 So when we used our samples to grind, we
8 measured the surface finish and used that correlation
9 to see what it would predict and that's what we saw.
10 And these numbers, 2 to 3.5 are based on typical
11 milling, machining, grinding, what surface roughness
12 we get from various fabrication and machining
13 processes, what range we would get and that's how we
14 established this.

15 So based on these, we see a minimum adjust
16 of 6, maximum of 27. If we use 20, then we are
17 suggesting that I have a very poor material. I have
18 rough surfaces and the worse loading history. That
19 would be somewhat conservative. So we used these four
20 sub-factors, used Monte Carlo simulations, as you
21 allow normal distribution for this, to come up with
22 the best adjustment needed to define the constant A
23 for the component.

24 And here, we see this is a distribution of
25 A, the constant A for a specimen and solid is for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 component. The median value has shifted by about 5.3
2 and 95th percentile number is an adjustment of about
3 12. So at least this analysis with what we have done
4 suggests that the 20 adjustment which is currently
5 used may be somewhat conservative.

6 CHAIRMAN WALLIS: Now would you say that
7 again? This business of the component, what do you
8 mean by the curve to the component?

9 MR. COLLINS: Our specimens were very
10 small and smooth. We make sure that there are no
11 scratches left. In a real component, surface finishes
12 are there and we know that surface finish would create
13 sites where cracks can form.

14 CHAIRMAN WALLIS: This isn't based on
15 tests of components?

16 MR. COLLINS: No. This is based on --
17 yes, correlating a surface finish.

18 CHAIRMAN WALLIS: Yes.

19 MR. COLLINS: So there is a conservatism
20 in the adjustment of 20.

21 To include environmental effects in
22 fatigue evaluations, two approaches have been
23 proposed. Either we come up with new design curves
24 which are applicable to light-water reactor
25 environments or we use some adjustment, correction

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 factor, F_{en} .

2 Because life in environment depends on
3 several parameters, we would need several design
4 curves to cover the range of conditions which occur in
5 actual reactor operation. If we come up with a
6 bounding curve, it would be very conservative, whereas
7 this correction factor, F_{en} approach is simple. It's
8 flexible. It can -- it allows you to calculate the
9 correction factor for any specific condition. The
10 only burden is we need to know what those conditions
11 are in the plant.

12 And these are the expressions, the
13 correction type is nothing but a ratio of life and
14 air, was there life in water.

15 CHAIRMAN WALLIS: Can I ask you about the
16 roughness of these pipes? Is this roughness
17 independent of age?

18 MR. COLLINS: Yes. Right. If you have a
19 rough spot, it will provide a potential site for
20 initiating a crack.

21 CHAIRMAN WALLIS: Is it independent of age
22 of the pipe. Does the pipe get rougher as it gets
23 older or smoother?

24 MR. COLLINS: No. Certain processes may
25 create sites, corrosion, pitting and all may create

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sites.

2 CHAIRMAN WALLIS: Austenitic steels and
3 oxygen environment don't suffer any kind of change in
4 the surface?

5 MR. COLLINS: Most austenitic stainless
6 steels form a protective oxide film which is quite
7 thin.

8 CHAIRMAN WALLIS: And the non-stainless
9 steels don't?

10 MR. COLLINS: It depends on the oxygen
11 level that you form a very stable oxide film in these
12 materials.

13 Water chemistry says that you would not
14 allow massive corrosion to occur.

15 CHAIRMAN WALLIS: That's massive. So I
16 don't need to worry about the effect of age on this
17 roughness?

18 MEMBER ARMIJO: It doesn't change very
19 much unless there was a lot of corrosion going on.
20 Then it would tend to literally smooth out unless you
21 got into a pitting phenomenon and then you'd have
22 another initiator --.

23 CHAIRMAN WALLIS: But there are, there is
24 a removal of material. We know that there are sudden
25 thoughts of these pipes where material is actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 removed. The wall gets thinner. So there must be
2 some effect on the surface if there's erosion.

3 MEMBER ARMIJO: It would tend to be more
4 of a smoothing --

5 CHAIRMAN WALLIS: Smooth? Does it produce
6 channels and things?

7 MEMBER POWERS: The worst reactive piece
8 in a surface --

9 CHAIRMAN WALLIS: You'd think so, you'd
10 think so. So it smoothes, these bends that get
11 eroded, the wall thinning occurs. They're smoother
12 where they're eroded than they were when they started?

13 MEMBER MAYNARD: Not necessarily. It
14 depends on what mechanism is causing that, especially
15 if there's any cavitation involved of water -- I've
16 seen some pipes that are like a lot of itty bitty pits
17 where it's been from an erosion from a cavitation.

18 CHAIRMAN WALLIS: Doesn't that affect this
19 roughness he's talking about?

20 MEMBER ARMIJO: I think those could lead
21 to other initiators of fatigue, but I think the
22 roughness here that you were asking about was the
23 initial as fabricated roughness and he's --

24 CHAIRMAN WALLIS: But he is moving this
25 curve by a factor of 12 or something because of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 roughness --

2 MEMBER ARMIJO: Right, known variability
3 in roughness in the --

4 CHAIRMAN WALLIS: As built.

5 MEMBER ARMIJO: As built.

6 CHAIRMAN WALLIS: As built. There are
7 places where the steel actually erodes and if it
8 erodes for the pitting mechanism, the roughness
9 changes.

10 MEMBER ARMIJO: That's correct.

11 CHAIRMAN WALLIS: Okay, and that's not
12 considered in this analysis?

13 MEMBER POWERS: I would not look at that
14 pitting in the same way I looked at roughness.
15 Pitting -- it's different and --

16 CHAIRMAN WALLIS: Finish is different than
17 roughness.

18 MEMBER POWERS: It's large scale.

19 MEMBER SIEBER: This isn't the dominant
20 failure mode of piping anyway. If you get a lot of
21 corrosion in pitting, that becomes the dominant
22 failure mode.

23 CHAIRMAN WALLIS: Well, maybe there's a
24 synthesis between the two.

25 MEMBER SIEBER: It might occur a day

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 earlier.

2 MEMBER POWERS: Or 10⁴⁵ years.

3 MEMBER SIEBER: Depending on where you're
4 standing.

5 (Laughter.)

6 MR. COLLINS: We have the correlations to
7 determine this correction factor, the actual
8 conditions, to incorporate environmental effects we
9 take the usage factors in air, U-1, U-2, and multiply
10 it by the corresponding correction factor and we get
11 the cumulative usage in the environment.

12 So the way we calculate the usage in air
13 is to use a design curve which is consistent with the
14 existing data or conservative with respect to the
15 data. The current Code curves for carbon steels and
16 low-alloy steels can be used, but since they use this
17 adjustment of 20 on life, you could reduce the
18 conservatism by using the design curves proposed in
19 this reg. guide. For austenitic stainless steels the
20 existing Code curve is not conservative, is
21 nonconservative with respect to the data and the new
22 curve, which has been proposed, should be used.

23 I'll get Hipo give some of the details
24 about the position.

25 MR. GONZALEZ: Thank you, Omesh. Now I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going to go through a summary of the regulatory
2 position that is in the reg. guide.

3 Regulatory Position 1 has -- is related to
4 carbon and low-alloy steels. It basically gives you
5 the guidance on how to perform the evaluations,
6 incorporate environmental effect in the fatigue
7 analysis. First, you have to calculate the fatigue
8 uses in air with the current ASME Code analysis
9 procedure, plus use the -- you're allowed to use the
10 ASME Code air curves or the UNAL air curves for carbon
11 and low-alloy steels.

12 MEMBER ARMIJO: And the reason for that is
13 because one is more conservative. If you want to use
14 it, go ahead.

15 MR. GONZALEZ: If you use the ASME current
16 code, it will be more conservative. So that's an
17 option that we -- the designers want it to be more
18 conservative, then they can use it.

19 Then we'll calculate the F_{en} , the
20 environmental factor to the equations and then
21 calculate the environmental fatigue uses factor with
22 the data equation, uses factor equation.

23 Regulatory Position 2 is for --

24 CHAIRMAN WALLIS: Can you apply this usage
25 factor to the ANL model, not to the ASME model?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Right? You have to apply the F to the ANL model.

2 MR. GONZALEZ: At the end to --

3 CHAIRMAN WALLIS: That's what it's based
4 on.

5 MR. GONZALEZ: You will apply the F_{en} to
6 the use factor.

7 MR. FERRER: This is John Ferrer. For the
8 carbon steel, we've given them two options. ANL has
9 developed a model based on their procedure for
10 environmental, for the air curves. And if you use
11 that ANL curve, you will use the ANL model with the
12 ANL F_{en} factor with the ANL calculated for fatigue
13 uses.

14 The other option that we've left in the
15 reg. guide is so we could stick with the existing ASME
16 fatigue curve which is more conservative. That would
17 be up to the designers' option. And if they would do
18 that, they would use the F_{en} factor with the ASME
19 calculated fatigue usage.

20 CHAIRMAN WALLIS: Which has no real basis
21 in the experiment. It's just a compromise of some
22 sort.

23 MR. FERRER: It's conservative compared to
24 a position we're recommending here for the carbon
25 steel.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: Only for carbon steel
2 where ASME is conservative?

3 MR. FERRER: Right.

4 CHAIRMAN WALLIS: Okay, thank you.

5 MR. FERRER: Somebody corrected me, and
6 low-allow steel.

7 MR. GONZALEZ: Regulatory position 2 will
8 apply to austenitic stainless steels. In this case,
9 we'll have to use the new ANL model stainless steel
10 curve when performing the ASME Code analysis
11 procedure. And then use the F_{en} equation and
12 calculate the environmental fatigue issues factor.

13 Regulatory Position 3 applies to the
14 nickel-chromium-ferric alloys will be Alloy 600, 690
15 and you can use the new ANL model air stainless steel
16 curve for the nickel-based alloys and then use it with
17 the ASME Code analysis procedures. Plus use the F_{en}
18 equation that is in there, in the technical basis.
19 Again, calculate the environmental fatigue uses
20 factor.

21 In summary, this reg. guide will endorse
22 the new air code for stainless steels and will also
23 endorse the F_{en} methodology. It will give guidance on
24 incorporating environmental correction fatigue, excuse
25 me, for incorporating and the environment correction

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 fatigue, the fatigue design analysis and this is shown
2 in Appendix A of the NUREG report. And also, the
3 report describes in detail the technical basis.

4 Now I'm going to move to the resolution of
5 the public comments. The draft guide and the draft
6 NUREG 6909 report were published on July 24th this
7 year and it was public comment for 60 days comment
8 period. This comment period ended September 25, 2006.

9 We received a lot of comments. Eight
10 correspondents submitted a total of 56 comments on the
11 draft guide and the draft NUREG reports and all
12 comments were addressed individually.

13 The resolution of the comments are
14 reflected in the final reg. guide and the final NUREG
15 report. And there were about six main issues that we
16 identified in the comments.

17 This next slide is just showing the
18 example of the table that I provided to the ACRS with
19 all the comments and the responses, staff response.
20 You can highlight that there were comments provided by
21 ARIVA, NEI, GE and even Japan, some commenters from
22 Japan.

23 MEMBER ARMIJO: Also ASME.

24 MR. GONZALEZ: Yes, ASME, of course,
25 sorry. The six issues that, main issues that were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 discussed. This is a list of the six. I'm going to
2 go quickly to some of them and probably give more
3 detail in the main ones.

4 The first one has to do with the operating
5 experience and applicability of the specimen data.
6 The comments were that there's no operating experience
7 that supports the need for this conservative design
8 rules. There were numerous examples of fatigue
9 cracking and nuclear power plant components reported
10 in an EPRI report that we reference here, 106696.

11 And the second comment was on questioning
12 the applicability of the specimen data being
13 representative of the actual components in service and
14 applicability of the lab data to conform the behavior
15 has been demonstrated by mock-up and component tests.
16 And in fact, it's the basis for the current ASME Code
17 T-curves.

18 MEMBER POWERS: I wonder, do you
19 understand why someone would say gee, there's no
20 operating experience that supports the need for
21 looking at these things?

22 MR. GONZALEZ: Probably they also were
23 referring to the -- any component failure experience.
24 There's no component failure actually to fatigue. But
25 there has been indications and flaws that --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Yes, it seems to me there
2 have been a half a dozen things, especially thermal
3 striping and things like that that suggest that
4 nuclear components are. I'm just wondering what would
5 motivate somebody to say there's no operating
6 experience.

7 MR. FERRER: I think that the motivation
8 behind that comment is that they have not been able to
9 translate the experience into showing, demonstrating
10 there was an environmentally-enhanced fatigue
11 initiation --

12 MEMBER POWERS: I see what you're saying.

13 MEMBER ARMIJO: But they couldn't show
14 that there wasn't either.

15 MR. FERRER: Yes. One of the reasons is
16 it's very difficult to have enough detailed data to do
17 that evaluation.

18 MEMBER SIEBER: This kind of evaluation
19 focuses on heat ups and cool downs of the entire
20 plant, as opposed to striping or oscillations of
21 valves or things like that.

22 I don't think there has been any of these
23 steep cycle failures.

24 MEMBER ARMIJO: Sort of the classic
25 fatigue failure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Thank heavens.

2 MR. GONZALEZ: The second issue is under
3 details on the approach, the methodology. There were
4 references made. The comment was there were
5 references made in other guidance in the report and
6 the papers listed in the report are for reference use
7 only. The regulatory position on the draft guide
8 contains the methodology that is endorsed by the reg.
9 guide and by the staff.

10 The second one, I'm going to read this.
11 Since the Draft Guide 1144 utilizes similar F_{en}
12 methodology that has been evaluated in MRP-47, the
13 issues in MRP-47 are considered to be equally
14 applicable to Draft Guide 1144 methodology. Some, but
15 not all of the issues raised in MRP-47 have been
16 specifically addressed in the Draft Guide 1144, so
17 based on this, the MRP would like to see more
18 clarification on remaining issues including Draft
19 Guide 1144 and the supporting documents.

20 I responded that the -- our staff
21 responded is that the level of analytical details
22 discussed on these comments are additional items under
23 MRP are beyond the scope of this regulatory guide. We
24 only address the F_{en} methodology has to be used.

25 The third issue is on adding the nickel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 base on fatigue curves and we already incorporated in
2 the final guide, in the final NUREG, the nickel-based
3 alloy curves and F_{en} methodology.

4 The fourth comment is that an increase in
5 the component usage factor will lead to more analyzed
6 piping break locations to more installed pipe whip
7 restraints and to the science that will be more
8 detrimental for normal operating conditions. And we
9 had a discussion yesterday on this and the staff
10 responds the staff will consider just defining the
11 modification with the appropriate technical basis of
12 the fatigue criteria for the postulation of pipe
13 breaks if implementation of the criteria results in a
14 significant increase in the number of required pipe
15 whip restraints.

16 And in addition, the necessity for
17 additional pipe restraints will disappear with a
18 susceptible leak before break analysis.

19 The fifth issue -- the commenter believes
20 that the attentive methods for fatigue analysis
21 provided in the report and the draft guide are too
22 conservative and should not be used for the design of
23 new reactors. So we responded that the staff position
24 is based on a 95 percent confidence that there is less
25 than 5 percent probability of fatigue crack

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 initiation. And the implementation of this criteria
2 resulted in a carbon steel and low alloy steel air
3 curves which are less conservative than the
4 ASME code curve.

5 The six issue has to do with the ASME code
6 case that ASME will develop a code case including the
7 ASME methodology that we presented, that is presented
8 in the reg. guide. The NRC staff will consider
9 endorsing the code case through its normal process for
10 revising regulatory guide 1.84.

11 I want to show in this slide that the main
12 revisions that were made from the draft guide to the
13 final regulatory guide 1.207. And the two main
14 points, we incorporated the ASME methodology for
15 nickel-base alloy material in the reg. guide in the
16 Regulatory Position 3 and the NUREG report in Section
17 6. And also, there was a revision of the high cycle
18 fatigue regime. The regime was 10^6 or more cycles.
19 And there were some editorial changes that were
20 clarifications of the technical basis report.

21 The conclusion to this presentation, we
22 feel that Reg. Guide 1.207 is ready for issuance and
23 the final Reg. Guide and the final NUREG 6909 report
24 reflects the resolution of the comments. Both
25 documents plan to be published in March 2007 and we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are seeking ACRS concurrence to publish the final
2 effective guide.

3 Thank you.

4 MEMBER ARMIJO: Any questions for Mr.
5 Gonzalez?

6 MEMBER MAYNARD: What does the staff
7 believe, what's the biggest impact this change will be
8 to the licensees or the designers? And what's the
9 biggest benefit from a safety standpoint? Just
10 summarize that.

11 MR. FERRER: I think the biggest impact,
12 I think ASME presented it and it may require them to
13 do some more detailed stress analysis to show
14 compliance with the new criteria.

15 Another impact that they brought up was a
16 potential for increased number of pipe rupture
17 locations and we've, in response to that comment said
18 we will consider adjusting the criteria so that we
19 don't get a big increase in the number of pipe rupture
20 locations.

21 The biggest benefit to safety is based on
22 the study that we did on the resolution of GSI-190
23 that this is not a major safety concern, however,
24 there is -- we would predict an increase in the amount
25 of leakage to occur if you had significant fatigue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 damage that wasn't accounted for in the criteria.

2 MR. CULLEN: This is Bill Cullen from the
3 Office of Research.

4 I'd like to also add a couple of points
5 here that occasionally seem to be lost in the
6 conversation. Remember that this procedure that is
7 described in the Reg. Guide, both gives and gets, we
8 are giving back to the industry because we have
9 reduced the code lines, created the code lines based
10 on factors of 2 and 12, rather than 2 and 20.

11 That's a give. On the other hand we have
12 developed very carefully, very statistically
13 accurately this concept of an F_{en} to account for the
14 environment, though we are getting back something in
15 that sense. They do now, the licensees bringing in
16 these applications will have to account for the
17 effects of the environment.

18 But on that score, I'd like to also add
19 another point. As you look at these equations for
20 F_{en} , you'll notice that they contain factors for
21 dissolved oxygen level, contain factors in the cases
22 of the carbon and the non-alloy steel, contain factors
23 for the sulphur content of those steels. We fully
24 expect that the materials that are going to go into
25 these new reactors will be far better than the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 materials that are in the existing fleet. If these
2 guys choose good materials for their carbon and low-
3 alloy steels, if they choose materials with low
4 sulphur contents, that F_{en} factor pretty much
5 disappears.

6 And if they keep the dissolved oxygen
7 under control, if the boilers keep their hydrogen
8 water chemistry carefully controlled, the dissolved
9 oxygen contents are going to be very low. The F_{en}
10 virtually disappears. Not quite. Not quite, but
11 virtually disappears.

12 So I want to make those points very well
13 that I think we should have new paradigms in the new
14 reactor fleet, the GEN 3 Plus Plus fleet that will
15 strongly affect the way this code gets applied and
16 I'll speak solely for myself, I'm not at all convinced
17 that this is going to be a hardship on the designers
18 of the new reactor fleet.

19 MEMBER SIEBER: You could actually say
20 that it would require a higher degree of control over
21 the chemistry.

22 MEMBER ARMIJO: It might.

23 MEMBER SIEBER: To avoid an impact.

24 MEMBER ARMIJO: It might.

25 MR. CULLEN: There would be that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consequence, that is true.

2 MEMBER SIEBER: That's a good thing, I
3 think.

4 MR. CULLEN: Right.

5 MEMBER ARMIJO: Any other comments or
6 questions from the Committee?

7 MEMBER POWERS: Just a phenomenological
8 question. Dissolved oxygen is important in some
9 circumstances and we have people trying to control
10 dissolved oxygen. Every once in a while they fail.

11 Has anyone ever looked at episodic events
12 of high oxygen in a background of low oxygen and how
13 it affects things?

14 MR. COLLINS: Yes, there have been studies
15 where they change oxygen and now the question is this
16 loading, somebody mentioned these are start ups and
17 shut downs or turbine trips. Depends where they
18 occurs. If it's a long period, then it may have, but
19 normally those are very short.

20 MEMBER POWERS: And short is a small
21 effect is what you're saying?

22 MR. COLLINS: I think once the water
23 chemistry is back --

24 MEMBER POWERS: It readjusts itself?

25 MR. COLLINS: Right, right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: All right, if there's no
2 more questions for the NRC staff, I'd like -- I guess
3 I'll have the ASME representative and then Mr. Gurdal.
4 So it's Mr. Erler first. Sure, wherever you're
5 comfortable.

6 MR. ERLER: I am Bryan Erler, the Vice
7 Chairman of the Board of Nuclear Codes and Standards
8 for ASME. And we had a good discussion yesterday at
9 the subcommittee meeting and I appreciate the
10 opportunity for that.

11 ASME has been a leader in developing the
12 fatigue criteria for over 40 years. I think we've
13 been taking a look at the data. We look across at all
14 of the monitoring of what happens and try to make sure
15 that we design rules and what I mean design rules, how
16 to design a plant adequate to be safe for the life of
17 the plants.

18 We're committed to working with regulatory
19 body to make sure that we consider all the facts and
20 one of the things that I'd like to make sure it's
21 clear is that clearly in the original criteria
22 document, we've talked about environment. Environment
23 was included in a discussion of 2 and 20. It wasn't
24 explicitly identified as to which, how much comes from
25 each of the elements of the variables, but we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 recognize it was a significant contributor.

2 I think the difference that we have here
3 in the discussion has been primarily in the fact that
4 where we're starting from. In an introduction by Dr.
5 Jennifer Ule, she stated that it was addressed to get
6 a guide. We wanted to get a guide out to address
7 environmental -- so they started with the objective of
8 developing a guide for including fatigue into the
9 curves.

10 What the NRC -- I don't think they made a
11 case to say that it needs to be done. The design
12 basis curves have been serving the industry quite
13 well. ASME Committee, made up of the experts that we
14 have around the world and certainly experts in
15 metallurgy and fatigue have been reviewing the same
16 data for 25 years and keep evaluating not the question
17 of how do we -- is do we need to and it's both
18 questions are being addressed as we, as a committee.
19 And the debate has been significant by many, many
20 experts across the board and many committees. We have
21 a Fatigue Committee. We have a Design Committee. We
22 have several task groups and it's a challenge to make
23 sure that we're doing the right thing.

24 At the same time, ASME has been very
25 effective at making sure we're addressing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 environmental impact of fatigue. We have passed
2 several appendices in Section 11 in order to deal with
3 Appendix L. We've addressed code cases to make sure
4 that we're addressing the in-service inspection side
5 of it.

6 So in case, from the very beginning in the
7 1960s, we have been aware of it and have been
8 following all of the data. It's where does it fit
9 into the design curve that we're talking about now.
10 Where does it really fit in our design basis and where
11 do we have to go?

12 If we go and look back at the experience
13 now we've had in Section 11, in collecting the data in
14 ISI and we see a license renewal, then we're really in
15 very good shape with regard to these plants. We have
16 allowed an additional 20 years. You look at the
17 transients. You look at the performance and fatigue
18 has not been a driver in terms of limiting the life of
19 the plant.

20 There's a lot of items with fatigue in
21 terms of vibration, temperature striation, other --
22 corrosion comes into the picture, but fatigue in
23 itself as an entity particularly environmental fatigue
24 or contributing part of fatigue has not been a key
25 driver. I think that's the part that the Committee

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Members really wrestle with quite a bit.

2 CHAIRMAN WALLIS: But there have been
3 fatigue failures.

4 MR. ERLER: There have been --

5 CHAIRMAN WALLIS: Fatigue has led --

6 MR. ERLER: Not due to the fact that the
7 design basis of the code was inadequate. If you look
8 at the Japanese and the French, they've proceeded with
9 their design rules dealing with this as not changing
10 the RCCM and not changing the Japanese code in dealing
11 with environmental fatigue and they are based on the
12 ASME Code.

13 So I don't think we're -- we're kind of --
14 we follow and work with the experts around the world
15 and work with the NRC and will work with them.
16 Obviously, if we want -- one of the challenges if we
17 say okay, we're going to put environmental fatigue
18 into the code, what we would do is we would probably
19 change significantly design basis and look at all of
20 the new variables and say what should we use as far as
21 our total design basis, rather than just say let's put
22 an impact of environment.

23 And that's where some of the discussion
24 comes, is our overall curve of 20 adequate and has it
25 served us well? So that's a debate that we can --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 well, will go on for a long time. But we do know we
2 need to keep our codes consistent with the regulatory
3 rules.

4 CHAIRMAN WALLIS: I ask you this question.
5 How big does F have to be before you decide you do
6 need to make a change to incorporate the environmental
7 effects? Apparently, you don't think it's necessary,
8 but clearly, if this effect got big enough, you'd have
9 to do something.

10 MR. ERLER: That's correct. I mean if you
11 look at --

12 CHAIRMAN WALLIS: Is it a question of it
13 not being big enough? Is that the issue and how big
14 would it have to be?

15 MR. ERLER: I really can't address that
16 because it's -- if you look at the various code cases
17 and various changes we've had, we've had F_{en} code
18 cases drafted up and get voted down. We've had
19 revised curves drafted up and voted down. And
20 everybody has their different set of rules, you now,
21 different set of reasons for it.

22 And the negatives are very clearly
23 documented in our balance that we have. And some of
24 it has to do with the issue of not a significant
25 contributor or why should we just address fatigue, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 environment when we really have other issues and we
2 should go back to the complete drawing board of our
3 design approach and then the issue comes up, but what
4 we had served us well, so it's kind of a -- the
5 consensus process amongst experts makes it a a
6 challenge to say I can't speak for ASME and give one
7 answer.

8 I can tell you what -- the stories of
9 what's been going on for 20 years and why our focus
10 has been on the operating cycle.

11 CHAIRMAN WALLIS: It's more of a technical
12 rationale. It's sort of a voting down as the
13 decision, a collective decision.

14 MR. ERLER: It's a technical --

15 MEMBER POWERS: It seems to me that the
16 staff agrees with you, don't they? Doesn't the staff
17 say yes, you can go ahead and use the ASME curves?

18 MR. FERRER: The ASME air curve for carbon
19 steel and then you apply the F_{en} factor. The question
20 is we should apply the F_{en} factor.

21 MR. ERLER: I think the issue of working
22 with the staff on an appropriate solution, given the
23 directive that says we should include it, I think is
24 a different objective for the Committee and maybe,
25 when you issue the reg. guide, that kind of puts us on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 notice that the U.S. is saying you want explicitly
2 covered environmental action, not just part of the 20
3 and 2. It's -- we want something that's in there.

4 And given that direction, the Board will
5 go back to the committees and go back and we'll
6 provide that, the direction, if that's the decision of
7 the staff and of the regulator. I guess the point
8 that we're making is that that's not necessarily the
9 uniform position around the world or of the experts.
10 The experts, you know, are quite happy debating this
11 issue. So the issue therefore is showing the cause or
12 the need is the challenge that we have.

13 The other part that I really wanted to
14 address a little bit because we didn't see it until
15 yesterday is the response, the six responses.

16 The first response is the need response
17 and I think referring to the EPRI document really
18 wasn't a good answer in terms of showing -- it
19 includes all other kinds of failures that you have and
20 are not just fatigue and not just environmental impact
21 of fatigue. I think it's worth the staff showing
22 specifically the need based on specific experience for
23 operating plants.

24 The other issue, if you look at item 2,
25 they agreed with the fact that it's difficult to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 implement the F_{en} and the issues that are identified
2 in MRP-47 are still an issue, but what they say is
3 that becomes our problem. They're making it sound
4 like the industry can go ahead and implement the F_{en}
5 procedure. There's issues in here that basically say
6 it's beyond the scope of this guide. They leave it up
7 to us to try to figure out how to implement it.
8 That's kind of -- it didn't really answer the issue.

9 The other one that I think that they
10 agreed with us on, two, is the fact that it has the
11 potential of adding more pipe-break restraints and
12 more pipe-break locations which could lead to more
13 pipe-break restraints and so okay, we're going to take
14 that away now. We'll change that. Which is a good
15 thing. I'm glad to get rid of breaks any place, as
16 long as it has a legitimate basis that we have.

17 But the fact of the matter is is the usage
18 higher in those locations, really? And you really
19 don't know because it just says that by the F_{en}
20 method, it will show higher usage factors in certain
21 locations.

22 So they've agreed basically as to how to
23 resolve it. It's sort of an IOU. We won't make you
24 put in restraints later on.

25 So I mean there's a lack of really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 addressing some of the specific comments that we have
2 sent and working with the staff, I think it could be
3 a benefit of the rest of the industry. I mean that's
4 the benefit of the committees that we have is the
5 experts and the experience.

6 These are not just vendors. These are
7 people who do research in the labs, who are present on
8 the committee, people who are at universities. We've
9 got some of the vendors, we've got engineering firms.
10 So it's a range and people from around the world and
11 that's a little different group to develop a solution
12 than just hiring Argonne to find a solution.

13 Using the benefit of what the expertise is
14 we would certainly like to work with the staff more
15 diligently to --

16 CHAIRMAN WALLIS: This is an aside. F_{en} ,
17 to me, is as fine an elements method used to get the
18 stresses in the first place and that's part of the
19 whole problem. F_{en} meaning two different things in
20 this context, which is not a very good idea.

21 MR. ERLER: This is a factor for
22 environmental.

23 CHAIRMAN WALLIS: But it's too bad that
24 you -- but it sounds very similar. So it's very good
25 to change -- yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Thank you very much.
2 Thank you. I think our last speaker and we're -- if
3 you hold the time, Mr. Gurdal, we'll be on time. five
4 minutes. You've got a full five minutes.

5 CHAIRMAN WALLIS: Then you're going to
6 stop it, right?

7 MEMBER ARMIJO: No, then I'm going to have
8 five minutes.

9 CHAIRMAN WALLIS: Okay.

10 MR. GURDAL: My name is Robert Gurdal,
11 that's G-U-R-D-A-L. I'm from Lynchburg, Virginia with
12 ARIVA. Thank you for giving me the opportunity.

13 First, is to come back to what Mr. Erler
14 just said, most of the fatigue failures the plants
15 have seen is again to the best of my knowledge, from
16 transients which were not known, but not from the fact
17 that fatigue analysis was done without the
18 environmental effects and then suddenly, because of
19 the environmental effects, you have a failure;
20 especially for thermostratification in a surge line.
21 That's the best example. All those thermostripping and
22 then you have all those SCC phenomenon. I think at
23 the low 600 welds of the surge line and different --
24 but not in the surge line itself. The surge line
25 itself which is ossiated steel, very important, 30

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 years, at least for the ARIVA plant and I think it
2 could even be 35 years, I've not seen a fatigue
3 failure which would be catastrophic, of course, but
4 not even a crack detection. Now that's what I would
5 say and that's to the best of my knowledge.

6 And that was to Mr. Erler. To the
7 gentlemen of the NRC there is something there they
8 said to look at the DO. The austenitic steel and the
9 fatigue curve, the new fatigue curve, of course, are
10 completely independent of DO. So it does not matter.
11 You don't need to do anything with a DO for the
12 stainless steel, and there is no s-factor for
13 stainless steel. So, for stainless steel and Omesh
14 can say and say if it's correct, it would be only
15 temperature and strain rate.

16 Strain rate is extremely difficult to
17 calculate in the FEA, finite environmental analysis,
18 so that at the end it's only temperature and maybe you
19 have to take the most severe strain rate, that's
20 extremely severe, factor 10, probably, maybe 8, I
21 don't know. Plus the fact that the new inert curve is
22 more severe. And, again, the surge line has not seen
23 fatigue failure due to the environmental effects of 35
24 years or something like that. So that was even before
25 my comments. I'm sorry about that. I'm probably

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 already through.

2 The other thing may be a surprise today
3 during the break is that ARIVA does not get the
4 answers to our technical comments before the reg.
5 guide is issued, 1.207. So if it's issued on March
6 15, whether it's in the morning or in the afternoon,
7 it does not matter. At the same time we get our
8 comments. So, that means we lost our time. That
9 means, that what it means, correct?

10 I mean, why did we work, we had those
11 conversations with the French, we lost our time,
12 correct? I mean --

13 MEMBER ARMIJO: You say, you mean wasted
14 your time?

15 MR. GURDAL: Yes.

16 MEMBER ARMIJO: Okay.

17 MR. GURDAL: Oh, did I say lost? Yes.
18 Wasted our time.

19 MEMBER ARMIJO: Okay.

20 MR. GURDAL: We worked for nothing. All
21 right. Oh, okay. A big thing is that it's important
22 to know for the industry that because of those new
23 rules, which will come out in March, we need to
24 redefine all our transients and make them a lot more
25 accurate, detailed, including strain rate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 calculations. In other words, the stain rate is a
2 function of the transients, so a big manager was
3 telling me the other day we have to turn around
4 completely the conservatism which used to be in the
5 transients and which is very important is going to be
6 now completely in the fatigue analysis.

7 In the transients they will have to be
8 exact, but exact I mean within maybe 10 percent and
9 which leaves a very big problem at the operation, how
10 do you call that? The room? You know, where they
11 have to follow the transients to be sure -- that's
12 going to be of course a nightmare, to say the truth.
13 But they need to live with it. That's for the new
14 plans. So that's just a comment.

15 So, in addition, that's in addition to
16 having the big location. So it's going to be more
17 severe because if there is a small deviation for a
18 transient, you cannot go back to your design,
19 functional spec., which is called the transients, and
20 go and okay, it's all right, it's all right. No, you
21 have to go back to the F_{en} analysis. Okay, so that's
22 going to be something.

23 Now, all right, that was the last,
24 hopefully that's my last topic. And it's that there
25 is a paper, a technical paper from PVP 2006 which has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 gained so much importance and that's on those tests
2 from Ireland that Omesh has mentioned, and there are
3 two things about that that I wanted to say. I wrote
4 it, but I'm going to try to say it quicker than that,
5 is the first one is I think when we perform
6 comparisons between the test results and anything that
7 we develop we should really compare with the design
8 curves and not to the best-fit curves, because that
9 gives you how much margin you have compared to the
10 design. Because what you do is design for the
11 component and not best-fit from the specimen. That
12 was the first comment. Is that clear?

13 And we haven't done that. I mean, we have
14 done it within our company but it was not shown today.
15 Or yesterday.

16 Second comment on that is the famous
17 comment, probably on the surface, and it's the fact
18 that there are four tests which are exactly the same
19 except for the flow rate. Too high flow rate and too
20 low flow rate. Otherwise, those flow tests are
21 exactly the same. It comes out that three of those
22 tests are what they call not polished and one is
23 electro-polished. That was so lucky that they had
24 that. Because the electro-polished gave a number of
25 cycles to failure to 3,800 if I cut the last two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 digits, and the other one is three numbers, 3,600 two
2 times and 3,400.

3 If you make the ratio and you stay with a
4 high flow rate, the factor is 1.06. If you take the
5 minimum of the other three, so the most severe, the
6 factor is 1.12. In the method of what we saw today,
7 this is the end for me, he gives the low number of 2
8 for that factor and 3 and one-half high. So, it's
9 the difference between 2.62.7 on one side and 1.1 on
10 the other. That's it.

11 MEMBER ARMIJO: Okay. Thank you. Thank
12 you. Well, any --

13 MR. GURDAL: We have a lot more.

14 MEMBER ARMIJO: Oh, we could, we'd be here
15 all day. But thank you for being brief.

16 MR. MAYFIELD: Mr. Chairman, if I could,
17 this is Mike Mayfield from Division of Engineering and
18 the Reactors. A couple of things that were said that
19 just in the last few minutes that I wanted to address.

20 I certainly agree with Mr. Erler that this
21 has been an active debate going back 25 years that I
22 know of personally. I would also say that it's not a
23 unanimous view among the international technical
24 community. There are at least one more views than
25 there are experts in the room at any given time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So this thing has been pretty much all
2 over the map. The staff has moved forward because we
3 believe that there is sufficient evidence that this
4 environmental effect on fatigue life needs to be
5 addressed.

6 The second issue that has come up a number
7 of times is, well, the service experience does not
8 indicate that there are a huge number of
9 environmentally-induced fatigue failures. If, in
10 fact, the service data indicated a large number of
11 fatigue failures where the environmental effect was a
12 driving consideration, we would be having an entirely
13 different conversation with this committee and with
14 the industry. We're looking to back-fit this
15 requirement and do additional analysis.

16 We agree that the ASME methodology
17 fundamentally is not flawed. There is a lot of
18 conservatism in it. However, as we move forward and
19 as the ASME has made changes, quite appropriately, to
20 the design methodology, there is the potential for
21 higher cyclic stresses in piping components over the
22 lifetime of a plant. And we believe that there is
23 sufficient evidence to show an environmental effect,
24 particularly that's going to show up in the later
25 life, if in fact you have these higher cyclic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stresses.

2 We believe that you put those things
3 together, there is a preponderance of evidence that
4 says this regulatory guide is timely and needs to move
5 forward as we look a designing and licensing new power
6 plants.

7 We, from the new reactor side, we
8 certainly hope the committee will endorse the
9 publication of the reg guide.

10 Thank you.

11 MEMBER ARMIJO: Okay. We've got two
12 minutes. I just ask the committee members for any
13 other comment.

14 MEMBER ABDEL-KHALIK: Can I make a
15 comment?

16 MEMBER ARMIJO: Yes. Of course.

17 MEMBER ABDEL-KHALIK: Thank you. You
18 know, we are all familiar with water chemistry
19 guidelines and frequently they change. And the
20 question is is there something that would
21 automatically trigger the licensee to re-analyze the
22 fatigue strength of various components if they're
23 contemplating a change in water chemistry guidelines?

24 MEMBER ARMIJO: Yes.

25 MEMBER POWERS: If they knew, if they knew

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it was significant, it could have a significant
2 impact, I think they would do it, sure. I don't know
3 if that would be a regulatory requirement, but if I
4 was an operator I'd sure want it --

5 MR. MAYFIELD: I'm sorry.

6 MEMBER SIEBER: There has been a couple of
7 instances where a licensee, particularly in license
8 renewal space, has had enough transients, you know,
9 heat-ups and cool-downs on the plant, where they're
10 approaching their maximum analyzed number and
11 therefore a re-analysis would be appropriate.

12 MR. MAYFIELD: This is Mike Mayfield. The
13 issue comes in if they're going to do something in
14 plant operation that would violate their licensing
15 basis or their design basis, they're going to have to
16 re-analyze to address it to show that they stay within
17 accepted limits.

18 MEMBER SIEBER: Before they do it.

19 MR. MAYFIELD: Before they do it.

20 MEMBER ARMIJO: Okay. Okay. Well I think
21 that will wrap up the presentation. I think we'll
22 have plenty of time to discuss the committee position
23 this afternoon or --

24 MEMBER POWERS: There is with all of these
25 standards this issue. We have on the one hand an NRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff whose interest is solely focused on protection
2 of public health and safety. Whereas the balance of
3 the community of experts has various kinds of
4 pressures on them and motivations. I wondered if Mr.
5 Mayfield would care to comment on that?

6 MR. MAYFIELD: I suppose it would be
7 inappropriate to simply say no?

8 (Laughter.)

9 From my own involvement with the codes and
10 standards, and I think it's actually a positive as a
11 part of the consensus standards process where you do
12 in fact bring diverse views to the table in
13 establishing codes and standards through that
14 consensus process. And I think that you generally get
15 a very robust product that addresses common interests
16 of not only plant operation and efficiency,
17 effectiveness, but also generally addresses public
18 health and safety. Just because they also have a
19 vested interest in it from a consensus standards
20 process.

21 I think this one of the, this
22 environmental effects issue is one of those areas
23 where the staff, with its driving consideration of
24 public health and safety, has a different view that we
25 believe outweighs the various views from the consensus

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 standards process.

2 That's one of the things that we have
3 historically discussed with ASME, that at the end of
4 the day, through our endorsement of the ASME code and
5 the various code cases, at the end of the day we have
6 to make the health and safety finding and, once in a
7 while, it doesn't happen very often, but once in a
8 while, the staff has to do something that is
9 inconsistent with where the code is. We then, we
10 don't do those things lightly. We don't do them very
11 often. But we, and we, I think, rarely have done them
12 when we haven't known that we were in conflict with
13 the code.

14 And when we are in a situation where we
15 have to make that kind of finding and take that step,
16 we try to work, as we go forward with the code, to
17 reconcile the dispute, but at the end of the day we
18 have to make a finding that we believe is consistent
19 with public health and safety and the regulations.

20 Does that help?

21 MEMBER POWERS: That was a superb answer.

22 MR. MAYFIELD: Thank you. I'd like to
23 know myself.

24 (Laughter.)

25 MEMBER MAYNARD: I think we'll have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 chance to discuss this later in more detail. I just
2 don't want the lack of comment at this point to
3 necessarily give the impression that I'm in full
4 compliance or in full agreement. Because I don't
5 think its -- I think there's a better time probably to
6 discuss some of that.

7 CHAIRMAN WALLIS: Okay, thank you. We'll
8 take a break until 1:30. Lunch break is 1:30,
9 something easy to remember, not fractional. we'll
10 take a break to 1:30.

11 (Whereupon, at 12:35 p.m., the meeting was
12 recessed, to reconvene at 1:30 p.m.)

13

14

15

16

17

18

19

20

21

22

23

24

25

A F T E R N O O N S E S S I O N

1:34 P.M.

1
2
3 CHAIRMAN WALLIS: Before we get started
4 with our business -- oh, okay. Before we get started
5 with our business, I would like to recognize one of
6 our outstanding staff members, Ethel Barnhard, who has
7 after approximately 40 years working with the
8 Committee will retire on January 3, 2007. Ethel has
9 handled several different jobs for the ACRS over her
10 tenure on the staff. This includes managing the
11 Committee's reference library and ensuring compliance
12 with FACA requirements, for document retention
13 retrieval, possibly the only person left in the Agency
14 who knows how to read microfiche film.

15 (Laughter.)

16 Manages the classification of Committee
17 documents and assures that we appropriately handle
18 classified material. She prepares the NUREG documents
19 that include compilation of ACRS ACNW reports and
20 letters. She's also responsible for handling Freedom
21 of Information Act requests relevant to ACRS ACNW
22 activities.

23 There are a long lists of tasks she's
24 handled for the Committee which I will not go into,
25 but I'm beginning to wonder as I read these who is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 going to do it when she is gone.

2 (Laughter.)

3 And the thing I really note, the thing I
4 really note which is my contact with her and I think
5 many of our contacts with Ethel is how the exceptional
6 job she has done in handling computer hardware and
7 software matters for the Members and for the ACRS ACNW
8 office staff. Without her, I probably wouldn't be
9 able to run my computer at all.

10 She has been rock solid in her devotion
11 and support of the ACRS or what amounts to most of her
12 professional career. Her professionalism and
13 willingness to assist the Members and the staff have
14 been very much appreciated, so thank you, Ethel, very
15 much indeed.

16 (Applause.)

17 As we are on the record, I think we should
18 move on with the next item of business.

19 The next item of business concerns
20 emergency planning. Our cognizant Member who has
21 really come up to speed on the business of this
22 Committee is Michael Corradini. I'll pass it on to
23 you to lead us through the next couple of hours.

24 Mike, please.

25 MEMBER CORRADINI: Thank you, Mr.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Chairman. So I'm Mike Corradini. I share the
2 responsibility of reviewing the design certification
3 applications for the current chairman of the Future
4 Plant Design Subcommittee, Dr. Kress.

5 The purpose of this part of the meeting is
6 to review the staff proposed revisions to the NUREG-
7 0800 Standard Review Plan, section 15.3 entitled
8 Emergency Planning. The proposed revision to SRP 13.3
9 was published in the Federal Register for public
10 comments, and the comment period has expired.

11 We will hear presentations from the
12 representatives of the Offices of Nuclear Security and
13 Incident Response, NSIR, and New Reactors NRO,
14 regarding the proposed changes, technical bases for
15 those changes, and the resolution of the public
16 comments. We will also hear from the NEI regarding
17 their comments on the proposed SRP. So we'll proceed
18 and I'll call upon Dan Barss or the NSIR to begin.

19 MR. BARSS: Thank you. Dan Barss, I'm a
20 Senior Emergency Preparedness Specialist. I use that
21 word senior carefully, that means I've been here the
22 longest and also they titled me as that. Also,
23 emergency planning is an interesting field. You know,
24 everybody is an expert in emergency planning.
25 Fortunately for me, I'm the one that gets paid for it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So hopefully if I do my job right, I'll continue to
2 get paid for it today.

3 As was said, we're going to talk about the
4 Standard Review Plan, NUREG-0800, particularly section
5 13.3, a small section of that very large document.
6 We're also going to talk about the DG-1145, the COL
7 application guide section 13.30, though it may not be
8 titled exactly that in the document. It is basically
9 covering the same section, the same type of material.
10 And those documents were written by the same person to
11 make sure we had some continuity between them
12 hopefully.

13 Before I get into them, I want to take a
14 little tour through the regulatory process and talk
15 about emergency planning a little bit, because I think
16 it's good to have that fresh in our minds as we begin
17 a discussion of emergency planning. As I've said,
18 everyone is an expert and we made a few changes in the
19 last few years or ten years or so, that may affect how
20 we do business.

21 This diagram has been used many times in
22 public. It shows starting in the center here, the
23 nice round circle, the combined license review and
24 hearing. That's where the rubber meets the road and
25 somebody gets a permit eventually to build a reactor.

1 Coming into that combined license they could choose
2 one of two paths, or I guess multiple paths, as you
3 heard this morning coming there. They could come with
4 an early site permit. They could come with a standard
5 design, they could come with both, or they could come
6 with neither.

7 And I want to talk a little bit about how
8 emergency planning fits in each of those different
9 parts of the process as we go along.

10 MEMBER APOSTOLAKIS: Which part of this
11 column on the upper left hand corner is the ACRS?

12 MR. BARSS: You guys fit in all three, the
13 standard design, the early site --

14 MEMBER APOSTOLAKIS: I know --

15 MEMBER POWERS: We're the blue background.

16 MR. BARSS: Emergency Planning has been
17 and continues to be part of the licensing process. I
18 list there on the slides some of the pertinent
19 regulatory sections. We'll talk a little more about
20 some of them as we go forward. And most important to
21 remember, there was a presidential decision in
22 December 7, 1979. In that decision, the President
23 re-emphasized the importance of the NRC and the
24 continued statutory responsibility we had for the
25 radiological health and safety to the public. That

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 same presidential decision though is the one that
2 really established FEMA, which is now part of DHS.
3 And a role which they play in the emergency planning
4 process concerning reactors, and it's important to
5 remember that as we look forward.

6 CHAIRMAN WALLIS: The President got
7 involved because of TMI? Is that why?

8 MR. BARSS: Yes, that was following the
9 Three Mile Island event and the events that came
10 after.

11 MEMBER APOSTOLAKIS: I'm a little
12 curious. You moved again. You're quick. Why when we
13 cite other regulations, it's always so many? I mean,
14 emergency planning in 50.33 and 50.47, what's the
15 difference?

16 MR. BARSS: Well, in 50.33 and 50.34,
17 that's the part, if I remember correctly, and my staff
18 will correct me if I'm wrong, talks about the PSAR and
19 the FSAR and it identifies different portions of
20 different parts of emergency planning that you have to
21 address at different levels going into that. 50.47 is
22 the primary, and we'll talk more about that as we move
23 forward. However, emergency planning regulations
24 along with Appendix E, 50.54 is conditions of license
25 and we'll talk about that as we move forward too.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They all play into it.

2 MEMBER APOSTOLAKIS: So in most of these
3 is just mentioned, it's 50.47 where --

4 MR. BARSS: 50.47 is the 16 planning
5 standards. But they all play a part in the
6 requirements of when things are submitted and what's
7 required. EP is sprinkled throughout the document.

8 You need to remember how EP came about.
9 EP or some type of emergency planning was there from
10 the beginning, but part of 1979 it was not heavily
11 emphasized. In fact, I have a copy of the sites'
12 emergency plan prior to 1979, and it's about 15-20
13 pages. That same document now is probably 15 books
14 because of the changes that have happened and the
15 amount of planning involved.

16 And it was after the Three Mile Island
17 accident that actually 50.47 came about, and those 16
18 planning standards which built on some of the work
19 that had gone on before that. So EP was, I don't want
20 to say a backfit, but EP was kind of embellished
21 greatly back then, and as time went on some of the
22 licenses that were already in place, and those that
23 were in the process of building they had to answer a
24 lot of additional requirements then.

25 And for the new applicants, hopefully

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we're not adding new requirements to them but holding
2 them to the same standards which has gone before. And
3 that's kind of the whole point I want to make as we go
4 through this, is your already existing set of
5 standards.

6 Focusing now on emergency preparedness,
7 there is what's called the reasonable assurance
8 finding for emergency preparedness that has be reached
9 before we issue a license.

10 CHAIRMAN WALLIS: Reasonable assurance of
11 what?

12 MR. BARSS: Reasonable assurance that the
13 applicant, or that the plans that are in place, both
14 the applicants and the state and local governments can
15 adequately protect the health and safety of the public
16 in the event of a radiological emergency. That's the
17 reasonable assurance finding, that we believe that
18 they have in place the mechanisms that they could
19 protect the health and safety of the
20 public if there was an emergency. That's what the
21 reasonable assurance findings based on and focuses to.

22 MEMBER CORRADINI: So this isn't really
23 not directly relevant, but just two examples pop in my
24 head and maybe if they're not applicable, one is
25 Shoreham and one is Seabrook.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BARSS: Well, Shoreham and Seabrook
2 are two late examples of what happened. And without
3 spending a lot of time on them, in the Shoreham case
4 you had the state and local authorities decided that
5 they didn't want to participate in the process. And
6 therefore -- I'll talk about this in a bit too further
7 on -- therefore, there was a need for us to figure out
8 a licensing process where what do we do with that
9 situation? And that's where 5047C, and I'll talk
10 about that as we move forward, was created. And
11 eventually that plant was licensed, but there was a
12 business decision made by the license holder to not
13 operate that plant and it was since decommissioned and
14 disassembled.

15 In the Seabrook case --

16 MEMBER CORRADINI: It wasn't the local,
17 state and local, but across the state lines, state and
18 local, if I remember correctly?

19 MR. BARSS: Well, I'm not sure who.

20 MEMBER CORRADINI: It was Massachusetts,
21 it wasn't New Hampshire.

22 MR. BARSS: Well, in the Seabrook case it
23 was the Massachusetts part of the emergency planning
24 zone that wasn't participating. That's correct.

25 MEMBER APOSTOLAKIS: I'm sure they had a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 good reason.

2 MEMBER POWERS: Actually, they focused on
3 one of the toughest aspects of emergency planning, and
4 that's how you treat transients and tourists.

5 I'd like to ask, you've highlighted here
6 reasonable assurance. There's another aspect of
7 emergency planning and that is adversity of plans, and
8 I hope you'll be able to talk about that diversity as
9 well as we go through here.

10 MR. BARSS: Yes, I address that later.
11 I'm aware of that question coming. Thank you for the
12 forewarning. Now I didn't finish quite there.

13 That 5047A, part of our regulations, I
14 think is somewhat unique at least for emergency
15 planning in that it specifically requires in there
16 that we, the NRC, make the final decision as to
17 whether or not we have this reasonable assurance and
18 whether or not the license can be issued. But it
19 clearly states in there that we rely on FEMA, now
20 known as DHS, for part of that finding.

21 They look at the off-site part of the
22 planning and give us their findings and
23 determinations. We look at the on-site part of the
24 planning, and then the results of their review come to
25 our ultimate conclusion and we remain the licensing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 authority. But we share the responsibility for that
2 review work with DHS and with FEMA. It says FEMA in
3 our regulations, FEMA is now DHS because of changes.

4 MEMBER APOSTOLAKIS: So what is the
5 relationship between FEMA and the NRC? I mean, they
6 set regulations and then we have to meet them or have
7 our own or what?

8 MR. BARSS: The regulatory authority rests
9 with the NRC. In our regulations that stipulate what
10 is required for the emergency planning are the NRC
11 regulations, 10 CFR. You will find in 44 CFR 350 a
12 companion set of regulations that FEMA has, and it
13 repeats the 16 planning standards that you find in
14 5047.

15 The common document that we use for our
16 evaluation we'll talk a little more about this as we
17 go forward, is NUREG 0654, which is also known as FEMA
18 rep 1. It's a joint document that was developed by us
19 and published jointly by us.

20 There is also a Memorandum of
21 Understanding, you see there, the last thing on the
22 slide. It's published in 44 CFR 3503A, appendix A.
23 That's an MOU between our two agencies which basically
24 talks about how we do that licensing and how we share
25 those responsibilities, who does what and establishes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a steering committee to basically govern the day-to-
2 day operations of that:

3 MEMBER APOSTOLAKIS: But in the actual
4 implementation of the emergency plans, FEMA plays a
5 role too?

6 MR. BARSS: When you get into response,
7 yes. FEMA and many federal agencies play response.

8 MEMBER MAYNARD: For exercises, in passing
9 we have been evaluators. They evaluate the off-site.

10 MR. BARSS: That is correct. There is an
11 exercise prior to licensing the plant, prior to where
12 any site is allowed to have a reactor, there's what we
13 can call a qualifying exercise. And biannually after
14 that, there's a requirement that there be an exercise
15 that involves state and locals as well as the utility
16 participate. And those are generally evaluated, I
17 would say generally but they are all evaluated to my
18 knowledge, the biannual exercise, by the NRC looking
19 at the on-site, by FEMA or DHS, looking at the off-
20 site part of that. If there are deficiencies
21 identified, they need to be corrected whether they are
22 on-site or off-site. And we'll talk a little bit
23 about that too as we move forward.

24 MEMBER MAYNARD: While we're on the
25 division responsibilities, I may have misread it but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it seems to me that in either the reg. guide or the
2 draft guide, it talked about the licensee needing to
3 submit off-site procedures, and I don't believe that
4 has been in the past and it looks like it could really
5 cause -- guess I would like to have some comments on
6 that. It doesn't seem appropriate to me.

7 MR. BARSS: We'll talk about that a little
8 bit later.

9 MEMBER MAYNARD: Okay, that's fine.

10 MR. BARSS: That's in here.

11 CHAIRMAN WALLIS: I am going back to my
12 reasonable assurance of public health and safety. I
13 don't quite know what that means. I mean, if you have
14 10,000 people on the beach and something happens at
15 Seabrook, do you expect no injuries of any sort to
16 those all 10,000 people? What does reasonable
17 assurance mean?

18 MR. BARSS: That's a good question. It
19 means in our concern that you have a plan that you can
20 implement, that could provide for the evacuation. The
21 basis of emergency planning --

22 CHAIRMAN WALLIS: But it could be a very
23 poorly implemented plan, and there could be quite a
24 few injuries.

25 MR. BARSS: Remember, the purpose of

1 emergency planning is not dose avoidance, but dose
2 reduction. And that's the intent here is to save
3 dose, if you can, if there is going to be an event.

4 CHAIRMAN WALLIS: You have to have some
5 idea of how, when your plan is good enough. I'm not
6 quite sure. Maybe you're going to explain that to us?
7 There are good ways of telling when your plan is good
8 enough.

9 MR. BARSS: And that's what our review
10 process and our exercise process is, is the review
11 establishes whether or not you have a workable
12 mechanism that meets the requirements that we've
13 established. And then through exercise, you
14 demonstrate the capability of implementing that plan
15 and being able to --

16 CHAIRMAN WALLIS: Your objective is to
17 have nobody suffer in any way?

18 MR. BARSS: No, I did not say that. I
19 said the purpose of emergency planning is dose
20 savings. To have a plan in place that if there is
21 going to be an event, you have a way of mitigating
22 that somehow. And if you can't mitigate it but
23 there's going to be an off-site release, that you have
24 a way of reducing or minimizing the dose that the
25 public could be receiving.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: There is somewhere in the
2 various things that the Agency has published on
3 emergency planning, a very nice hierarchy, where it
4 says the first thing to do is avoid a lethal dose.
5 Then once you've been able to do that it moves down
6 into the point that you have nobody being dosed at
7 all. But it takes it stepwise into thinking about
8 things. It's a nice hierarchy.

9 MR. BARSS: You need to remember, the
10 emergency plans are developed and we talk about the
11 ten mile and 50 mile EPZ. There was a whole range of
12 considerations that went into, or how big of a plan --
13 amount of planning area do you need, which accident do
14 you have to worry about, and the conclusions that were
15 made long ago is you don't worry about any particular
16 accident. You look at a range of them and you have to
17 have the capability to implement what would be
18 necessary for the worse case accident, but you don't
19 want to have to plan for the worst-case accident
20 because that would be rather constraining or limiting.

21 What you need is something that you can
22 expand, should that happen. And you kind of pick
23 something that is reasonable and I don't want to say
24 in the middle, but that is reasonably implementable
25 and plannable.

1 As we've already talked about, there are
2 16 planning standards in NUREG 0654. They are found
3 in
4 -- I'm sorry, in 10 CFR 50.47(b). That's where the 16
5 planning standards, you find them in the regulation.
6 Also in appendix E to 10 CFR 50 is additional
7 requirements for emergency planning. Originally,
8 appendix E was what was there, the 50.47(b) stuff what
9 was added later after Three Mile Island. In reg.
10 guide 1.01, that's where we the NRC tell the world
11 that we will use the Reg 0654 FEMA-REP-1, Rev.1 as the
12 acceptance criteria for our review of emergency plans
13 in accordance with the regulations. In also reg.
14 guide 1.01, I believe it's revision 4 of that, we
15 identify NEI 99-01 as an alternate set of emergency
16 actions or EALs that can be used.

17 There are others, schemes, other emergency
18 actions or schemes that can be used but the N 99-01
19 document is the latest and probably the most viable
20 and what we expect most people to go to and I believe
21 Alan Nelson will talk about that a little more later
22 today.

23 There are some other things in emergency
24 preparedness in the regulations I want you to be aware
25 of. As I said, 10 CFR 50.54(q) is a license condition

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that applies after the license is issued. That
2 requires an applicant to maintain in effect an
3 emergency plan that meets the previously stated
4 requirements. Once they've got the license they have
5 to continue to do that.

6 There is also in 50.54(s) again,
7 conditions of license, what I call the deficiency 120-
8 day clock. If, in running an exercise or our
9 inspections or whatever, we identify a deficiency or
10 FEMA identifies a deficiency in the off-site plans, we
11 can initiate what's known as a 120-day clock, which
12 gives the applicant or the licensee at that point the
13 opportunity to correct whatever that deficiency is.
14 And they get that time frame because emergency
15 preparedness is kind of a backup measure to the
16 multiple barriers and things which we have. It's
17 important but it's not critical to the safety at that
18 point. It's only a planning deficiency usually that
19 needs corrections, so we want to see it done timely
20 but it's not an immediate action.

21 At the conclusion of that 120-day clock or
22 process, and it's a whole process that it goes
23 through, if the applicant hasn't, or the licensee
24 hasn't successfully remedied or at least shown us a
25 plan of how they're going to remedy that, the agency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 does have the opportunity or the ability to shut the
2 plant down until such time as that is corrected. So
3 that capability exists in our regulations today.

4 MEMBER BANERJEE: Are these plans mainly
5 evacuations and --

6 MR. BARSS: No.

7 MEMBER BANERJEE: -- shelter or what --

8 MR. BARSS: Yes.

9 MEMBER BANERJEE: -- what are the crux of
10 this?

11 MR. BARSS: Well the plans are, one, the
12 first part is identifying that you have an emergency.
13 The second part of that is knowing who to contact.
14 And the third part is once you contact them, providing
15 them a recommendation as to what's going on and what
16 they, you think they need to do as a licensee. Then
17 it's the responsibility of the off-site agency,
18 whichever level that information goes to and the
19 decision-makers are, is to decide what type of
20 protective action they would need to take and then
21 implement that protective action based upon the
22 conditions, the recommendations, the local conditions,
23 the weather conditions, many factors. And that could
24 be --

25 MEMBER BANERJEE: But what are the options

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they have?

2 MR. BARSS: The options are shelter, tell
3 people stay where they are. Evacuate, a combination
4 of those. It depends on the event and the conditions.
5 There is --

6 MEMBER BANERJEE: Iron tablets?

7 MR. BARSS: Potassium iodide, KI, is one
8 of the options involved that they can --

9 MEMBER BANERJEE: There aren't that many
10 things you can do, right?

11 MR. BARSS: Pardon?

12 MEMBER BANERJEE: Are there a lot of
13 things that you can do, or --

14 MR. BARSS: Well, those are the three
15 primary ones. It's shelter, evacuate or take KI.
16 That's --

17 MEMBER POWERS: There are within each one
18 of those many subcategories. You could have preferred
19 sheltering. You could have radial evacuation. You
20 could have non-radial evacuation.

21 MEMBER MAYNARD: Another big part of the
22 plan is the staff necessary to try to mitigate
23 whatever release, so a big part that's going on is to
24 try to prevent any release too. That's all part of
25 the emergency plan too.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BARSS: And the important thing here
2 is, the plan is probably the most important thing in
3 that, you have established and you do this through
4 your exercises, the communication links, where people
5 know who to talk to. They know how it functions.
6 Because we don't know what the accident is going to
7 be. And what the conditions are going to be when the
8 accident happens.

9 So you have to kind of, I don't what to
10 say wing it, but emergency planning, a lot of
11 emergency planning, emergency response is done on a
12 wing-it basis. You take what plans you have. You
13 take the conditions you have, and you figure out
14 what's the best course of action using that
15 information and move forward. Having a structured
16 plan that you practice regularly gives you a structure
17 and a knowledge base to wing it effectively.

18 (Laughter.)

19 CHAIRMAN WALLIS: You've got to move a
20 large number of people who are all doing different
21 things. I may be out there, or not me or someone may
22 be near Vermont Yankee out there on a winter's day
23 cross-country skiing somewhere, you know. And there's
24 an accident. How is this person to know something has
25 happened?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BARSS: If he's out cross-country
2 skiing, then he deserves what comes to him -- we have
3 standards.

4 (Laughter.)

5 MR. BARSS: That's an important
6 consideration. And there are hunting areas, all
7 kinds of fishing areas ---

8 MEMBER BONACA: You do have sirens --

9 MEMBER MAYNARD: You have a siren system.

10 MEMBER BONACA: And ultimately, the state
11 is the one responsible for implementing whatever they
12 want to do.

13 MEMBER CORRADINI: Just to, just to get
14 back to Professor Wallis' question though, just to
15 push the point. I mean, at least in Wisconsin, the
16 same FEMA or the emergency planning at least there
17 whenever I hear a siren, the first thing one thinks of
18 is tornado. And there is a series of radio stations
19 or connection points that you then have to go to if
20 you want to know more. Either it would be radio or
21 television to find out what that siren means. But
22 that, as I remember it, since --

23 CHAIRMAN WALLIS: When I hear a siren, I
24 think my local fire department is out putting out a
25 fire.

1 MEMBER CORRADINI: Oh, it's a different
2 siren for the FEMA --

3 MR. BARSS: Generally, the siren is a 3-
4 minute blast so you will know that there's something
5 going on. But, more importantly, each of the plans
6 has to have specific to its area, and this is one of
7 the things that DHS looks at, figure out how to handle
8 transients like that. If you have large recreational
9 areas, we expect them to have specific plans as to how
10 they will get that information to them.

11 A lot of the time it is done with posters,
12 information, things in the phone book, posters at the
13 facility. There's hopefully training for people that
14 work at the facility and they would know to tell
15 people, here's what you do in this event.

16 So there is a lot of that that goes on
17 ahead of time and that's part of the exercise, I
18 guess, to make sure that those plans can be
19 implemented, that those people know how to do that and
20 can accomplish it.

21 CHAIRMAN WALLIS: I don't want to belabor
22 this, when we went to Vermont Yankee for a power
23 uprate, we had a lot of people from the public there
24 who talked to us and made statements. And one of the
25 things that came up many times was this lack of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 confidence in emergency planning. They said they had
2 sort of rehearsals and things and the buses didn't
3 show up at the school and things didn't happen.

4 Is that being sorted out effectively or is
5 this something that's in their perception which is not
6 true or what?

7 MR. BARSS: Without discrediting those
8 folks, I would say it's in there perception and not
9 true, because we have an evaluation done on those
10 exercises and if there are findings, we make sure that
11 they're correct, that DHS does that.

12 CHAIRMAN WALLIS: So it could be rumors
13 and things?

14 MR. BARSS: It could be rumors. And we do
15 get what we refer to as allegations, frequently, from
16 individuals, where they say hey, you know, this is
17 supposed to happen and it's not happening and here's
18 my reasoning and then we go out and we investigate
19 these things and we resolve those allegations and get
20 back to the people.

21 We take each and every one of those
22 instances very seriously. We even have these things
23 come up when we have public meetings for the new sites
24 where people will come up and say hey, this is an
25 existing site, well I have a problem with what's going

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on there now. That becomes if not an allegation,
2 something that we do look at and consider and make
3 sure that the question is answered.

4 MEMBER MAYNARD: Not all exercises are
5 full-blown exercises where you actually evacuate
6 people and everything like that.

7 MR. BARSS: I would say we never evacuate
8 people. Our regulations specifically state that we're
9 not supposed to make people move because that would be
10 unnecessarily --

11 MEMBER MAYNARD: But there are times when
12 you have an exercise you'll have maybe one school bus
13 and you'll have one group. It's all voluntary. It's
14 not a mandated thing, but typically, you're not going
15 to get all the buses. You make sure that you can find
16 the people that you need and everything like that, but
17 it could be the public could easily perceive that
18 things aren't happening if they don't see those
19 things, but they really are being taken care of.

20 CHAIRMAN WALLIS: I guess it must be very
21 difficult because suppose there's a major snowstorm in
22 a place and you have this happening. One thing, the
23 range of the sirens is decreased and also people can't
24 move.

25 MR. BARSS: That's where you rely on the

1 local authorities to make the right decision based
2 upon the existing conditions.

3 CHAIRMAN WALLIS: Ad hoc.

4 MEMBER MAYNARD: That's one of the major
5 considerations. Some times you come into sheltering
6 as opposed to evacuation and stuff.

7 MR. BARSS: As I've said, you've got the
8 plans, but the important thing is you have knowledge
9 of people to make the right decision.

10 MEMBER MAYNARD: But the other thing, if
11 you have some severe weather, licensees have
12 requirements also to report if they have a situation
13 that has degraded their ability to execute their plan
14 and what compensatory measures that they've put in
15 place for that too.

16 MR. BARSS: And in fact, when we have
17 hurricanes or other major events such as that, we do
18 monitor around the plants. We make contact with DHS
19 to find out whether or not there are concerns that we
20 need to be aware of and if there are, we make sure
21 that the appropriate things are taken care of. The
22 most notable example of that is Hurricane Andrew. It
23 went through Florida and the site there, Turkey Point
24 site, and in fact, the plant remained shut down for a
25 considerable amount of time until the roads were

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cleared because there were palm trees laying all over
2 the road. The plant was in good shape and could run,
3 but the evacuation wasn't cleared, so they remained
4 shut down until such time as those things were
5 remedied and there was better off-site conditions.

6 Just two last points. I don't know if I
7 talked about the reality presumption; 50.47(c) came
8 about pretty much because of the Shoreham and the
9 Seabrook type events. What that section of the Code
10 of Federal Regulations is basically it says if there
11 is a situation where the off-site agencies have
12 refused to participate or no longer want to
13 participate, the licensee or the applicant can provide
14 an emergency plan to cover that situation. And we can
15 evaluate that plan and what is known as a reality
16 presumption, as I've called it here is, when there is
17 a real emergency, the state and locals are going to
18 use whatever plan is available and they will act to
19 protect their public and based upon that, we have the
20 authority through the regulations and the ability to
21 approve those plans and have confidence that they can
22 be implemented when the time comes to do that. So
23 that provision exists in our plan or in our
24 regulations already.

25 Again, a point, remember, there are two

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sets of plans. Actually, I would say there are
2 multiple sets of plans. There is the on-site, the
3 utility plan; and the off-site, which could be the
4 state and local. When you start talking about locals,
5 you've got counties, you've got townships, you've got
6 towns, you've got hamlets and there can be up to 20,
7 25 different individual plans involved in one -- for
8 one utility. So there are multiple plans that need to
9 be reviewed and looked at.

10 MEMBER MAYNARD: Multiple states too.

11 MR. BARSS: Multiple states, multiple
12 jurisdictions and sometimes countries, depends on
13 where they build them.

14 Going back a little bit, in Part 50, it's
15 a two-step process where we issued a construction
16 permit and then later we issued an operating license.
17 That process, as we know, from the Shoreham and
18 Seabrook and other plants, was a difficult process so
19 in 1989 we were directed. We came back with an
20 alternative licensing process which you're familiar
21 with. It's called Part 52. And I won't spend a lot
22 of time on that, but it was to improve the regulatory
23 efficiency at greater predictability. It's
24 essentially the same information as Part 50, the
25 process is a little different. It combines that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 construction and operating license into one license,
2 one permit, and it adds these what we call ITAACs,
3 inspection, test, analysis and acceptance criteria.
4 And that criteria, that acceptance criteria, that's
5 what provides us the reasonable assurance that the
6 facility is going to be constructed and will operate
7 in conformity with the license and the applicable
8 regulations. That's what's built into the process
9 now.

10 Understand that as we go through the Part
11 52 process before they can load fuel, they have to
12 clear those ITAACs. They can clear the ITAACs
13 individually as they go along through construction.
14 We will publish that in the Federal Register at least
15 180 days before this scheduled initial fuel loading.
16 There is a publication made in the Federal Register of
17 that intent for operation and that provides then an
18 opportunity for one last chance at hearings for any
19 intervenors or petitioners, if they can show at that
20 point that the acceptance criteria has not been met.

21 Important to remember in the licensing
22 process now in Part 52 and it's currently in 52.79(d)
23 in the proposed or changes to the regulation will be
24 52.79(22). It's important that they, in their
25 application provide to us, the NRC, certifications

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 from off-site agencies that have emergency
2 preparedness responsibilities that those agencies
3 agree that the plans are practicable, that those
4 agencies are committed to further development of those
5 plans including field demonstrations which can be
6 interpreted to be exercises and whatever else they
7 need to do, and that those off-site agencies are
8 committed to executing the responsibilities, so before
9 we're going to begin reviewing that COL, we have to
10 see those certifications and those certifications have
11 to accompany that application.

12 MEMBER MAYNARD: This is compatible with
13 the 50.47(c) as far as if you end up with the
14 situation where there's, they're not playing, so to
15 speak?

16 MR. BARSS: If there is agreement that the
17 plans are practicable and they're committed to further
18 developing and that they agree to execute those, I
19 think that they're participating or if they agree to
20 them. So you get -- this allows you to get out of
21 that adversarial relationship where they say we're not
22 going to participate, not involved.

23 MEMBER MAYNARD: What if they don't
24 provide --

25 MR. BARSS: If they don't, then if they're

1 not agreeing that the plans are practical, then I
2 think we're at an impasse and I would leave it to our
3 lawyers to decide what we do there.

4 MEMBER CORRADINI: Actually, Otto is
5 bringing up something that we were kind of thinking
6 about here which is so if A, B and C are not met, then
7 they can't go forward with the COL.

8 MR. BARSS: That is my read of this is you
9 wouldn't go forward with the COL.

10 MEMBER CORRADINI: But just to say it from
11 the standpoint of in deference to 50.47(c), in that
12 case, there was a construction permit. I'm just doing
13 the old version of this. There was a construction
14 permit. They built the plant, it's been inspected.
15 They're now trying to obtain a fuel load and there's
16 no participation by the state and local or some
17 portion of the state and local agencies. And then
18 50.47(c) is triggered. There's no equivalent in 52.
19 That's what I'm kind of -- that's what I'm kind of
20 asking here.

21 MR. BARSS: The equivalent in 52 is that
22 the licensee can submit a plan that they developed on
23 their own in Part 52, just as they can in Part 50.
24 But there still needs to be this certification that
25 the plans are practical, that they're committed to,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that the off-sites are committed to participating in
2 that and that they'll execute their responsibilities.

3 If you can't get that certification, then
4 I'm not sure what they do.

5 CHAIRMAN WALLIS: How do you certify the
6 plants are practical?

7 MR. BARSS: I'm not sure yet.

8 MEMBER CORRADINI: Let me ask this
9 question differently, would you expect the -- so let's
10 break it down into pieces. If it was on an existing
11 site, a practical plan from all, you have empirical
12 evidence what were past practical plans, so that would
13 be it.

14 If it was a green-field site, in some terrain,
15 geography, whatever that was similar to existing
16 sites, but wasn't an existing site, still you have
17 some empirical evidence of practical. So it would
18 have to be a not making those two areas where I'd have
19 some potentially unusual set of

20 Am I off-base? I'm just trying to think -
21 -

22 MR. BARSS: As far as what is practical,
23 I guess that's in the eye of the beholder there and
24 coming to decision. If someone has developed a plan
25 --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: Certification can't be
2 so flexible that it is just in the eye of the
3 beholder.

4 MR. BARSS: You need to remember that
5 emergency planning is expected to be an integrated
6 plan. This isn't just the utility saying okay, I'm
7 going to build a plant and here it is. There needs to
8 be an agreement that these -- this is how we're going
9 to do business and is this going to work? And that's
10 where the practical part comes in, that there's
11 agreement to that.

12 We certainly have -- we've got 65 sites
13 out there built in many different regions of the
14 country with different government and organizations
15 and different people, so it's quite practical to
16 develop an emergency plan for just about anywhere.
17 It's just getting the parties to agreeing and working
18 at it to make that happen.

19 CHAIRMAN WALLIS: The big challenge from
20 the public about this practicability, presumably
21 there's some way in which you can respond which is
22 convincing?

23 MEMBER CORRADINI: There's somebody who
24 seems to be waving.

25 MR. MUSICO: Excuse me, if I can help?

1 This is Bruce Musico. I'm a Senior Emergency
2 Preparedness Specialist. I worked with Dan on this
3 document in Emergency Planning.

4 Just to clarify an issue, the question was
5 if we failed to obtain or the applicant failed to
6 obtain the appropriate certifications from the off-
7 site, could they still get the COL. The answer is
8 yes, they could. If you look at 52.79(22)(c)(ii), it
9 says "if certifications cannot be obtained after
10 sustained good-faith efforts by the applicant, then
11 the application must contain information including a
12 utility plan, sufficient to show that the proposed
13 plans provide reasonable assurance that adequate
14 protective measures can and will be taken in the event
15 of a radiological emergency at the site."

16 In essence, if you obtain the appropriate
17 certifications that address these criteria, there's no
18 need for utility plan. The off-site state and locals
19 are playing. If you cannot obtain these for whatever
20 reasons, then they couldn't get the COL and the
21 utility plan would have to be developed to account for
22 off-site emergency planning. So I hope that clears it
23 up for you.

24 MEMBER MAYNARD: That is helpful.

25 MEMBER ARMIJO: How could a utility plan

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 work without the cooperation of the local and state--

2 MEMBER POWERS: The Commission's decision
3 was, in fact, that the local authorities would, in the
4 event of an emergency, participate. It's impossible
5 to believe that they would not.

6 MR. BARSS: That's where 50.47 comes in
7 and the reality presumption is that when the problem
8 is there, they're going to act to protect and save the
9 public. They're not going to ignore that fact.
10 They're going to have to.

11 MR. MUSICO: Let me add to that. This is
12 Bruce Musico again. 50.47(c) is sometimes referred to
13 as the realism rule. There's a presumption or
14 assumption that where you have state and local
15 agencies that have stated in some way that they are
16 not going to play, if there is an emergency at the
17 plant, they're not just going to run away. There's a
18 presumption that in reality, they're going to utilize
19 any existing plan that can help them protect the
20 public around that area. That's called the realism
21 rule, 50.47(c).

22 Now that was what occurred about Seabrook
23 and Shoreham and some staff view that as a band-aid to
24 the rules. Subsequent to that, my understanding is
25 that Congress directed the NRC to fix the problem,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hence the development of Part 52 to account for all
2 these issues before the plant is built.

3 If you look at the administrative
4 legislative history of the Part 52 rulemaking, you'll
5 see that language in the discussion where it talks
6 about you want to settle these issues prior to
7 spending \$2 billion building a plant and then finding
8 you can't operate it.

9 MEMBER MAYNARD: And I think from a
10 practice standpoint, it's not going to be an issue
11 much with the new plants coming on, recognize that for
12 the plants when the existing rules were imposed, many
13 of these plants were either already built or in the
14 process of being built.

15 Now I don't think too many people are
16 going to build one in an area where they did not
17 believe they would get some support from them.

18 CHAIRMAN WALLIS: This agency's
19 responsibilities, would that include, for instance,
20 local police department?

21 MR. BARSS: Yes.

22 CHAIRMAN WALLIS: But there are police
23 departments in towns in New Hampshire and Vermont. Is
24 there no confidence in the citizenry at all? There
25 are all kinds of things that happen in small towns

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with police departments, give rise to scandals and
2 hassles and dismissals.

3 MR. BARSS: They are all part of the
4 planning process.

5 CHAIRMAN WALLIS: They're all part of
6 this. You're dealing with people. I can just see all
7 kinds of things that come into this.

8 MEMBER MAYNARD: They have to have a
9 responsibility.

10 MR. BARSS: They're part of the process.
11 They're part of the planning. They have
12 responsibility, but there are state laws and
13 regulations that identify who has the decision-making
14 process and who has signature authority for those
15 things and that's where you need to get the
16 certifications.

17 MEMBER BONACA: Plus, I mean, there is a
18 planning phase. For example, all the roads by which
19 you are going to evacuate are identified and the rules
20 are made on who controls them. I mean there is full
21 planning in place. Now they also tested the
22 emergencies, in fact, because if only the plant does
23 the emergency exercise, there is local authority that
24 is trying to get lessons learned. So to what degree
25 may work in a natural condition, I don't know. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the planning is there.

2 MR. BARSS: Another thing to remember too
3 is that the Nuclear Emergency Plan, or the
4 Radiological Emergency Plan is generally a small
5 subsection of the all hazards emergency plan that a
6 community will have. It's not the only thing that
7 they have to worry about. They've got trains going
8 through their community, they've got trucks from the
9 highway with chemicals in them, things like that.
10 This is just another hazard, but it's only one of
11 many. And most police and fire departments and most
12 emergency services people know how to deal with those
13 things and deal with them quite frequently. And this
14 is just another aspect of the planning that they do.

15 MEMBER SIEBER: And it's not only local
16 police, it's the county sheriff and the state police,
17 and they have a hierarchy they use if they need
18 additional assistance.

19 MR. MUSICO: Let me add something. This
20 is Bruce Musico again. To address the question more
21 specifically with respect to individual police
22 departments, one of the items that we look at in order
23 to support our reasonable assurance determination in
24 most cases is the existence of letters of agreement
25 that have been put together that are available prior

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to us making that final finding.

2 Now understanding that the reasonable
3 assurance determination made pursuant to 10 CFR
4 50.47(a) is not a conclusion of absolute assurance.
5 It's reasonable assurance. And the way that we make
6 that reasonable assurance, there may be deficiencies,
7 but we utilize NUREG 0654 primarily, which has very
8 detailed evaluation criteria in it. We look at the
9 individual evaluation criteria and looking at it as a
10 whole, we determine can they reasonably respond to an
11 emergency. Is the super structure in place, are the
12 agreements in place, and we make a call on it. Again,
13 it's a subject matter expert call, in our judgement is
14 there are reasonable assurance? I don't believe
15 reasonable assurance is defined anywhere, but again
16 reasonable assurance is not absolute assurance.

17 MR. BARSS: All right. Let me move
18 forward if I can, and this may create more fireworks
19 but there is in the proposed regulation a new
20 50.54(gg), which allows operation --

21 CHAIRMAN WALLIS: G or --?

22 MR. BARSS: GG. It's double g, it's double
23 g. That's correct, it's not a typo. It allows
24 operation of up to five percent power with off-site
25 deficiencies. That's very much like what is already

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in there under 50.47(d) in the existing regulation,
2 and basically that provision became necessary looking
3 at the ITAAC process and how it works in that the on-
4 site agents or the on-site plan and the utility is the
5 ones reasonable for ITAACs, but there can be things
6 off-site that need to be developed further after the
7 COL is submitted. Certainly there will be, but they
8 can't really write an ITAAC because it's the licensee
9 that has to do ITAACs, not the off-site. So there may
10 be conditions or things which need to be finished or
11 resolved after the exercise has been conducted, and
12 that's what this provision is meant to employ or to
13 accommodate. And remembering that there is the
14 50.54(s), which we talked about earlier, that we
15 maintain the ability to shut a plant down any time,
16 should there not be reasonable assurance to adequately
17 protect the health and safety of the public.

18 MEMBER KRESS: Was the determination made
19 that five percent power public health and safety is
20 safe enough even without an evacuation?

21 MR. BARSS: It's not that there
22 is not an evacuation. There are criteria in 50.54(g)
23 and in 50.47(d), they're exactly the same criteria.
24 There are seven criteria with regards to the off-site
25 plan that we do need to look at, and have some level

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of confidence that they exist. So it's not saying
2 that there is a complete absence of any off-site
3 planning. It's saying that the off-site planning may
4 not be fully complete or may not be the FEMA finding
5 of reasonable assurance there. But I would say that
6 there are major pieces of that plan in place and
7 functional.

8 MEMBER KRESS: That's part of the
9 definitions of deficiencies in, that they not be a
10 bridge out of --

11 MR. BARSS: Bridge not built yet --

12 MEMBER KRESS: Or something.

13 MR. BARSS: Generally, a bridge-out, and
14 it happens frequently in construction and things like
15 that, they have alternate means and the locals know
16 how to do that. That's not really a significant --

17 MEMBER KRESS: But I was wondering, if
18 off-site deficiencies actually has some sort of
19 definition?

20 MR. BARSS: It does. In the FEMA
21 regulations, there is a definition for that. I'm not
22 sure that I can quote it exactly, but basically if I
23 remember right it says that in an exercise, if you
24 identify something that in real life would have
25 prevented them from protecting the health and safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the public, then that's considered deficiency. If
2 they cannot physically do what their plan says they
3 should be able to do, that's a deficiency. And that
4 needs to be fixed. It's a fairly high bar.

5 MEMBER KRESS: It seems to imply to me
6 that the five percent power is okay without an
7 evacuation, or without emergency planning.

8 MR. BARSS: Well, the source term is low
9 enough at that point.

10 MEMBER KRESS: Well, I just wondered if
11 that was the basis of that.

12 MR. BARSS: That is, I think, the basis
13 for that number is the fact that the --

14 CHAIRMAN WALLIS: Why is the source term
15 low if you have five percent power for a very long
16 time.

17 MEMBER CORRADINI: You'd have to
18 do the equivalent of 20 years at five percent power to
19 get close to that.

19 CHAIRMAN WALLIS: In saturation.

20 MEMBER MAYNARD: First of all, I don't
21 think you're going to find plants operating for a long
22 period of time at five percent power. What this
23 really allows them to do is go ahead and load fuel and
24 do a lot of the testing for plant systems, and get
25 some of their physics testing out of the way. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you're not going to set there a long time. You're not
2 going to make any money off of five percent power.
3 You're better off shutting down.

4 CHAIRMAN WALLIS: But you're operating at
5 full pressure and temperature and all of that?

6 MEMBER MAYNARD: Yes.

7 CHAIRMAN WALLIS: So the typical accident
8 might be very similar.

9 MEMBER SIEBER: If your boiler --

10 CHAIRMAN WALLIS: Just as your inventory
11 is left?

12 MEMBER CORRADINI: Decay heat is
13 proportional to your power. You're not going to have
14 high burn-up fuel.

15 MEMBER MAYNARD: It depends on how much
16 inventory you've got.

17 MR. BARSS: Let me move forward, if I can.
18 Part 52, the combined license, there are, as we said,
19 two additional considerations there. In the combined
20 license you can incorporate by a reference a design
21 certification and an early site permit. That adds a
22 degree of excitement or difficulty to us in the
23 emergency planning world and I'd like to explore some
24 of that with you.

25 One of the things to remember though that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 once we issue an early site permit in a design
2 certification, the things which we resolve in those
3 permits or those certifications is -- are considered
4 or they're precluded at that point from
5 reconsideration at the COL stage. That gives the
6 applicant some finality in that once we've made that
7 finding on the design certification, or the early site
8 permit, particularly pertaining to emergency planning,
9 they get the finality and that issue is not reopened,
10 once they come in for the COL. That's what's
11 important to them and buys them a lot in this process
12 and why they might pursue, particularly the early site
13 permit in looking at emergency planning.

14 In subpart B of Part 52 is where it talks
15 about the design certification. It's important to
16 note there are no specific requirements for EP in the
17 design certification.

18 In the early site permit, which is
19 independent of plant design, it can be done for 10 to
20 20 years and it's renewable for another 10 to 20
21 years. And its intent was to resolve early issues
22 such as site safety, emergency preparedness and
23 environmental protection.

24 In the early site permit regulations in
25 52.17, we find some unique things. First, is (b)(1).

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 They are required, anyone who has applied for an early
2 site permit, to identify the physical characteristics
3 of the site that could cause a significant impediment
4 in developing emergency plans.

5 Everyone that applies for an early site
6 permit has to do that. Then they're allowed two other
7 options. That's the minimum; (b)(1), all of them have
8 to do that. They can choose either (b)(2)(i) or
9 (b)(2)(ii), (b)(2)(i) being a major feature's plan
10 where they could submit certain features and those
11 features can be identified probably most easily if you
12 take the 16 planning --

13 CHAIRMAN WALLIS: Let's go back to this.
14 Almost all of these new plants will be on sites where
15 there were existing reactors. They have an existing
16 emergency plan. It must be very easy to say we have
17 an existing emergency plan, here are its features.

18 MR. BARSS: That's correct. That is the
19 great advantage of using the existing site. Yes.

20 MEMBER POWERS: And it has never been --
21 it is not easy to do this.

22 MR. BARSS: It is not easy.

23 CHAIRMAN WALLIS: It's already there.
24 They already have this emergency plan. And presumably
25 it's been approved and everything.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: No, they don't. They have
2 an emergency plan for an existing facility.

3 MEMBER SIEBER: They have to get new
4 letters of agreement.

5 CHAIRMAN WALLIS: Is it going to be very
6 different.

7 MR. BARSS: It could. I will talk about
8 that as we go forward. That's one of our
9 considerations is how they treat that existing plan in
10 their application.

11 Remember two options to them here, major
12 features would be taking those 16 planning standards
13 and addressing some or all, some parts of -- some of
14 them or some parts of all of them, but not the entire
15 part.

16 If they come in under (b) (2) (ii), complete
17 integrated plans, at that point they basically have to
18 send everything that they would for a COL at the early
19 site permit stage and that buys them the most as far
20 as certainly, is they can get their emergency planning
21 part of it cleared at the early site permit stage.

22 MEMBER CORRADINI: So a clarification
23 here, so you said it and I just want to repeat it so
24 that I get it right. That under (b) (2) (i), they
25 wouldn't address all 16 of the features, necessarily.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. BARSS: It's up to them to choose what
2 they want to address.

3 MEMBER CORRADINI: And complete integrated
4 implies addressing all 16 of the features? That's
5 what I guess I'm trying to --

6 MR. BARSS: That's correct. Under
7 (b)(2)(ii) complete integrated, they have to address
8 the full spectrum of emergency planning as they would
9 at the COL stage.

10 MEMBER CORRADINI: And then just to get
11 back to Graham's question, when Dan was kind of
12 explaining this to us, does that mean that under
13 (b)(2)(ii) that then they would relate the plan to the
14 other sites -- the other units that would be on the
15 site?

16 Is that coming later? Okay, fine.

17 MR. BARSS: I'll get into that as we go
18 forward. That's a significant issue.

19 MR. MUSICO: Dan, excuse me, can I clarify
20 something? This is Bruce Musico again. The
21 distinction between the planning standards under major
22 features are somewhat different than the planning
23 standards under complete integrated plan. Where the
24 planning standards for major features consist of 14 of
25 the 16 basic planning standards, and then you have an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 additional planning standard that deals with the
2 evacuation time estimates.

3 The scope of detail in the major feature
4 planning standards are such that they merely require
5 a description of various aspects of the plan, the
6 proposed plan that's not in place yet. Compared to
7 that, the complete and integrated plan would add two
8 additional planning standards dealing with exercises
9 and recovery/re-entry operations and what it would
10 require is the implementation versus just a basic
11 description of the earlier stage, it would require the
12 implementation of the plants.

13 So major feature requires a description of
14 what the plans would be. Complete integrated would
15 require not only a description, but the
16 implementation.

17 MR. BARSS: Not to confuse too much, but
18 there is a minimum level and that's the description
19 that Bruce has referred to, that we would need to see
20 in the major features part, but the way the regulation
21 is going forward and the intent of the staff and our
22 discussions with NEI is the major feature can be that
23 minimum which is kind of laid out now in R002 and
24 Supplement 2 to NUREG 0654 in that there's a minimum
25 threshold of descriptions, but they can also flesh out

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the entire -- if they picked number two or B of those
2 planning standards, they could flesh out the entire
3 part of that and get that and they maybe did F and G,
4 but that's the only ones they addressed, they could
5 get those major features and get some certainty on
6 those. But they're not getting the full plan.

7 MR. MUSICO: One more clarification,
8 that's a good point. What Dan has just described is
9 the proposed final rule for Part 52 that's not out
10 yet. It's out for review. What I described is the
11 current Part 52 rule.

12 MEMBER CORRADINI: Go ahead.

13 MR. BARSS: Hopefully, we don't have you
14 too confused on that. We need to move forward.

15 There are also in 52.17(b)(3) if they
16 choose either the minimum which is only the
17 impediments part for the major features, they have to
18 describe the contacts they've made and the
19 arrangements with the off-site agencies that have the
20 emergency preparedness responsibilities. If they
21 choose the (b)(2)(ii), complete integrated plans, then
22 they have to meet those same criteria we talked about
23 under the COL application and that is that the plans
24 are practical, that the off-site agencies are
25 committed to further development and that they will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 implement or execute the responsibilities when the
2 time comes.

3 Now let's get eventually, finally to the
4 standards themselves.

5 MEMBER POWERS: Let me ask before you go
6 to the next slide, but you may want to answer in
7 connection with your next slides rather than
8 immediately, have you attempted to benchmark your
9 requirements and review standards for emergency
10 planning against those of other countries?

11 MR. BARSS: I wouldn't say that we have
12 done a line-them-up comparison, but I would say that
13 many people on our staff have experienced through
14 travel and review work. For example, myself, I've
15 done two OSARTs. If you're familiar with what an
16 OSART is, one in Mexico and one in the Czech Republic.
17 So I have some knowledge of how their programs are
18 implemented and how they do them.

19 Recently, this year, we sent someone to
20 England and watched a plan or an exercise there. We
21 had someone in Russia this year also from our staff.
22 So we are aware and knowledgeable of how they do it.
23 A lot of them use our regulations and our guidance or
24 shadow it somewhat. But as far as benchmarking, have
25 we lined them up side by side, I would say we have not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 done that specifically. But I believe that we are on
2 parallel with them and I don't think that --

3 MEMBER POWERS: The fact that you might be
4 commensurate with Czechoslovakia or Mexico or Russia
5 is comforting, but I would think that you find some
6 interest in comparing yourself against those that
7 might take a different view and not be parroting
8 American regulations such as Germany or France or
9 Sweden and I -- or Belgium.

10 MR. BARSS: South Africa, too.

11 MEMBER POWERS: I'm quite certain that you
12 would learn nothing in comparison yourself to South
13 Africa, but you might learn something in Japan. And
14 I'm wondering why that wouldn't be a good idea to not
15 saying that they have anything better or worse or
16 anything like that, but more as a benchmark, an
17 edification, an exploration of the space for emergency
18 planning.

19 I have no reason to think that they do a
20 better job than you do. As you know, I have quite a
21 great deal of confidence in your abilities in this
22 area. But just for the -- the problem is that you
23 lack peers. To some extent, FEMA might constitute
24 peers of yours, but in truth because of your unique
25 responsibilities to radiological protection of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 health and public, you lack peers in this country.
2 And so you have to go search for peers and your peers,
3 you know, with equal levels of experience and equal
4 sizes of nuclear communities would probably lie in
5 Europe and Japan and probably not in Czechoslovakia or
6 Mexico or Russia.

7 MR. BARSS: Let me add, beyond the scope
8 of our discussion today, but currently before the
9 Commission, in fact, is we did a review of our
10 emergency plan regulations and our guidance documents
11 and submitted it to the Commission some
12 recommendations and they're right now writing the SRM
13 and it may come out today or in the near future.
14 We've seen a draft already. But in that we're
15 proposing to go through our regulations and to refresh
16 some of them, do some revision work add in some of the
17 things that have come out since 9/11, some of the
18 security things that need to be put in the regulations
19 and as part of that process, the process, we did some
20 looking at some of the international things. And I
21 believe as we go forward, and those that are
22 responsible for that are in the room, we will do that,
23 to look at that. That is a longer range project.

24 MEMBER POWERS: Long range, yes. Not on
25 any crisis review. It's again peer review. Quite

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frankly, you carry a huge burden because you're kind
2 of on your own right now and I think that if I were in
3 your position I would relish the opportunity to share
4 it with somebody with somewhat similar kinds of burden
5 and experience.

6 MR. BARSS: I'm faced with the pleasant
7 opportunity of doing that on a long-range. However,
8 I do have a rather tight budget and time line getting
9 ready for some new reactor applications that are
10 coming in. So understanding that --

11 MEMBER POWERS: I understand there's penny
12 wise and pound foolish.

13 MR. BARSS: Yes, I appreciate that wisdom.
14 Let me move forward now. We've covered many of the
15 points, but into the guidance documents themselves.
16 The standard review plan 13.3 addresses emergency
17 planning. It provides for us and when we do our
18 review, how to review the emergency preparedness part
19 on a construction permit, an operating license, an
20 early site permit, the standard design certification
21 and also combined license. They're all covered in
22 that same document.

23 The document includes the many things
24 listed there. I'll try to expedite some of this, but
25 it talks about the interfaces throughout the standard

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 review plan, who looks at different sections of it and
2 how we interface with different parts of it, the
3 siting criteria and things like that, the
4 instrumentation. Those all play into emergency
5 planning and how we interact with those different
6 parts of the plan or of the review itself.

7 It identifies the regulatory requirements.
8 It establishes the acceptance criteria and identifies
9 existing regulatory guidance to use. It provides the
10 technical rationale. It outlines the review procedure
11 that would be followed by a reviewer. It proposes
12 some generic evaluation findings that can be used.
13 There is an extensive reference list included in there
14 and it also includes the generic EP ITAAC table which
15 we'll talk more about in just a moment.

16 One of the considerations we've built into
17 the standard review plan is how do we deal with
18 existing programs? We mentioned this earlier. This
19 is important because an applicant has the opportunity
20 to do many different things and in the three
21 applications or four applications we've seen so far,
22 for early site permits they've chosen each a different
23 path it seems. They can -- I don't want to say
24 ignore, but they can set aside the existing plan and
25 create a separate and independent plan for the new

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 facility.

2 They can use the existing plan almost
3 wholly and just make minor modifications to it to add
4 in the new features of the new facility or they can do
5 some hybrid combination of both of those. And it
6 depends upon what the applicant chooses to do, what
7 amount of review work we have and what we have to look
8 at. But what we have tried to state and make clear to
9 everybody is that when we are looking at an existing
10 program, the part we want to look at is is what's
11 there applicable to the proposed reactor?

12 Is the information they're using
13 applicable to this site, this design and does it
14 apply? Is it up to date? Is it current in the form
15 that they're providing it and does it reflect or
16 incorporate that new reactor into the process?

17 That's how we plan on dealing with
18 existing programs, using those three criteria as we
19 look at them going forward.

20 MEMBER BONACA: Just a question I have, on
21 this Section 13.3 ultimately, at the end of the game,
22 the emergency plan will be what? Does it matter if
23 you enter through with the, you know, early site
24 permit or if you can't. So this is more, I mean, how
25 flexible is the process to the fact that the applicant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will maybe miss some information, but ultimately will
2 have to get back to the emergency planning anyway at
3 a later time, I mean.

4 MR. BARSS: At the COL stage, he won't
5 miss anything. We're not going to let him

6 MEMBER BONACA: Right.

7 MR. BARSS: At the early site permit
8 stage, it depends on what he chooses to do. But if
9 he's chosen the minimum of just the significant
10 impediments, it's not a very high hurdle to jump over.
11 If he's chosen the major figures, he can address
12 whatever he feels he can appropriately cover. If he's
13 chosen the complete integrated plan at that stage,
14 then it all needs to be in there. Like Ragu, it's all
15 got to be there.

16 MEMBER BONACA: But you're leaving it
17 pretty open, I mean.

18 MR. BARSS: It's open, but it's up to the
19 applicant to choose which path they're taking. Once
20 they've chosen that path, there's constraints as to
21 what they need to do.

22 MEMBER POWERS: We'll be coming back to
23 that in just a little bit. It can take any one of the
24 16 categories for his major features, and he does so
25 and he comes in and he persuades gosh and darn he's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 got the best damn thing I've ever seen in my life. He
2 doesn't come into effect for 20 years, some not all of
3 us, 16. But in some cases, that no longer reviewable
4 plan is out of date badly. It may not be applicable
5 anymore.

6 MR. BARSS: We expect that they will
7 update that information when they come into the COL.

8 MEMBER POWERS: They're required to update
9 it after they get started. But I'm not sure they're
10 required to update it when they come in for the COL.

11 MR. BARSS: I believe we've built that
12 into the regulation, that they are required to do that
13 when they submit it. And we built in there, at the
14 industry's encouragement, if you're familiar with the
15 50.54(q) process, which says basically an applicant or
16 a licensee can make changes to the plan. And these
17 are done, emergency plannings are dynamic. We expect
18 them to change and to grow. And they can make changes
19 to that plan without our approval as long as they
20 don't decrease the effectiveness of the plan. If they
21 do something that's going to decrease the
22 effectiveness of the plan, they need our approval
23 first.

24 And we've stated in the regulation at
25 least as it's proposed now that when they submit those

1 revised plans or those updated plans, if they made
2 changes under the 50.54(q) process or a like process
3 that don't affect, or don't decrease the
4 effectiveness, that's okay. But if they are going to
5 decrease the effectiveness, they have to specifically
6 tell us because that requires our review. But there
7 is a process built into it.

8 MEMBER POWERS: You've answered my
9 question.

10 MR. BARSS: EALs, Emergency Action Levels,
11 and I believe Alan Nelson will talk a little bit more
12 about that. The existing document NEI 9901 is
13 applicable, but some of the EALs, and we expect them
14 to use that document or whatever else they choose, but
15 that's the one we expect most of them will use. We
16 expect them to use that and most of those EALS will be
17 applicable.

18 However, with the passive plant designs,
19 particularly the AP 1000 and the ESBWR, there are a
20 lot of those EALs that are currently existing that
21 would no longer apply, such as ones dealing with off-
22 site power and on-site diesels. You no longer worry
23 about them with the passive plant, at least not from
24 a safety standpoint. So there's some significant
25 modifications that need to be made to some of those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 EALs. And the industry is working on that and we
2 expect -- we'll let Alan tell us about what they're
3 doing with that.

4 We do expect them to use the guidance
5 that's in that document in developing those new EALs
6 to address the passive reactors. The inspection test
7 and analysis acceptance criteria or ITAAC. There's a
8 generic table in there, these were developed by us and
9 industry and DHS and public participation through a
10 series of workshops, and as you know if you read the
11 comments from NEI in the Standard Review Plan and also
12 DG 1145, we've included the table of those.

13 We've expanded upon that table from what
14 was reviewed and added some additional ITAACs that we
15 think are usable. It's important to remember that
16 these were based on existing criteria in NUREG 0654.
17 That's where we started when we started looking at
18 what could be ITAAC-able, as we call it.

19 What the staff did was look for those
20 things which we felt the applicant could not show us
21 at the time of the application, but they needed to
22 physically build something before they could show us
23 that. That's the kind of thing that we thought they
24 could ITAAC, and that's kind of the process we went
25 through in developing them. When we expanded that, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 were thinking particularly about an early site permit-
2 type applicant, where you're talking about a 20 year
3 or more time period before they may use that.

4 There may be a need for them to expand
5 that ITAAC a little bit, where the original set that
6 were developed were more focused on a COL applicant,
7 where the construction was more likely to be within
8 three to five years, than it was 20 years or more out
9 window. So that's one of the reasons we added things.

10 We think ITAAC are the friend to everybody
11 because they add some flexibility to the process and
12 give the ability to do that flexibility. We support
13 it. It's important to recognize that what we propose
14 for the generic ITAAC are not all inclusive, nor are
15 they exclusive. We expect that the applicant will
16 have to pick and choose from them and all of the
17 things that are in NUREG 0654 and decide which ones
18 they want to ITAAC.

19 The important thing to remember is the
20 burden is on the applicant to propose those ITAACs.
21 It's their responsibility to propose them and their
22 responsibility to accomplish them and to report to us
23 the accomplishment of them. We inspect to make sure
24 that's been accomplished. But the ITAAC really are
25 theirs to propose them to do. And these will be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 developed and approved on a case by case
2 determination, depending on the applicant and what
3 they're doing.

4 Off-site EP guidance. This is one of the
5 comments that we'll get to later. But our document is
6 rather scant referring to off-site things. It pretty
7 much says what's on the slide there, that we will use
8 the current REP-series guidance documents, the
9 associated memorandums. These are guidance
10 memorandums that FEMA published over the years and a
11 document published in February of 2003, called
12 Radiological Emergency Preparedness Planning Guide.
13 It's kind of an update. Those are, as far as we're
14 aware, the current available documents and that's what
15 are going to be used until such times there are new or
16 additional documents provided or produced.

17 MEMBER CORRADINI: So there is nothing
18 else simply because of the lack of it being exercised,
19 or
20 --

21 MR. BARSS: Well, I wouldn't say being
22 exercised. These documents are looked at and used
23 every day as FEMA does their daily business. The
24 people that are responsible for the off-site planning
25 and the FEMA reviewers are very aware and know what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 their documents are and what they're using, and those
2 that do the off-site planning are aware of them.

3 It's not that these things are a mystery
4 and not well-known, but they are somewhat I would say
5 in a state of flux because of the changes of FEMA from
6 one organization to another and back again. Not that
7 their guide's documents change, but there's been a lot
8 of changes there and for that and probably other
9 reasons there's not been a refurbishment of them or a
10 publication of them. But certainly that's a project
11 that is ripe for work on, I guess.

12 Again, FEMA is an independent agency. I
13 don't speak for them. We rely upon them for their
14 participation in this process and we work hand in hand
15 with them. So these are their guidance documents
16 pretty much.

17 MEMBER CORRADINI: Well, let me just
18 translate what you said to go back to. So there is
19 early in 13.3 guide on the second page it says
20 something like it goes off -- it says, at a minimum,
21 and applies it to the ESP, but I think it's applicable
22 to COL also. At a minimum, the review includes, that
23 is for off-site, it includes physical characteristics
24 unique to the proposed site that could pose a
25 significant impediment to emergency plans and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 description of contacts or arrangements made with
2 state, local, and federal government agencies,
3 etcetera. So these three bullets essentially give
4 further guidance beyond that, because as I search
5 through the 13.3 for off-site guidance in terms of how
6 you review it, what should you look for when you
7 review it? As you said, it's scant.

8 MR. BARSS: It is. And NUREG 0654, which
9 is a common document, is the base backbone that they
10 will use. But there are additional guidance
11 memorandums and things that they use that embellish
12 upon that. And they are well known in the community
13 of reviewers that I guess would be using them.

14 MEMBER CORRADINI: Okay, thank you.

15 MR. BARSS: Standard design criteria for
16 emergency planning. As I said, there is nothing
17 required. However, we do provide guidance in Section
18 13.3 about that. Specifically, that the features that
19 may be addressed, they need to be technically relevant
20 to the design. They shouldn't be site specific and
21 they should be usable at a multiple number of sites or
22 units. That's one of the criteria we expect for what
23 we would be looking at in design certification.

24 Generally speaking though, EP aspects are
25 a programmatic type thing and would usually be left up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the COL applicant and not the designer to address.
2 Some of the things that they could address though are
3 the facilities, the functions, and the equipment that
4 support emergency planning. Particularly, the TSE or
5 the technical support center, the operational support
6 center, personal decontamination facilities, things
7 like that. They could choose to describe if they
8 wanted to. There is guidance available which talks
9 about where the location of those things should be the
10 size, habitability of them, ventilation systems,
11 things like that and they would need to comply with
12 those guidance documents if they do choose to address
13 them.

14 The emergency response data system or the
15 safety parameter display system, SPDS, the voice and
16 data communications, those are other things that they
17 could also address should they choose to, but that's
18 up to a designer, if they want. Again, no
19 requirement.

20 MEMBER CORRADINI: So if I could just turn
21 to, Mr. Chairman, we're officially at the point where
22 we should turn to NEI comments. Can we proceed a
23 little bit longer on this because we're switching over
24 to DG1145.

25 CHAIRMAN WALLIS: We seem to be getting

1 very close to the end. Let's wrap this up quickly and
2 move on.

3 MR. BARSS: Okay, basically DG1145
4 provides guidance on EP information in a combined
5 license as we talked about this morning. For custom
6 design, one that's not referencing a certified design
7 with an early site permit and it also addresses
8 certified design in the certified design with an early
9 site permit. That just basically tells the applicant
10 what information they need to provide us and it
11 addresses information that should be in both the
12 application and the emergency plan.

13 There are basically two things that they
14 need to submit to us. One is their application and
15 there is a lot of information that would be in it and
16 then along with that is the actual emergency plan
17 itself.

18 When I say application and additional
19 information, the additional information is things like
20 the state and local plans. Those are not the
21 applicant's plans, but are things to submit. DG1145
22 also addresses how to deal with multi-unit sites and
23 some considerations there that we've addressed and
24 again, that talks about the plans and how to integrate
25 the plans and it also talks about the EP ITAAC and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 gives guidance on them.

2 We had some preliminary questions from you
3 folks which I hope I've answered to some degree and I
4 think we talked about many of them here. What
5 substantive changes did Section 13.3 have? Really,
6 there's no substantial changes in 13.3, but it
7 integrates the Part 52 process. The things that are
8 really new is the EP ITAAC, the predictive reasonable
9 assurance finding be made, basically the COL stage
10 instead of after they've demonstrated it in an
11 exercise They still have to do that exercise before
12 making a predictive finding much sooner and the timing
13 of that exercise is different in the new Part 52
14 process, where that exercise had to be completed
15 before operating. If the license was issued, it has
16 to be done before they can load fuel in order to meet
17 that ITAAC that they will be presenting to us.

18 Guidance on green-field sites was another
19 question you had. In our opinion, existing guidance
20 is applicable. We have 65 sites out there and they
21 are all green-site at one time, so it's not something
22 new to us. We do have guidance to address that. The
23 green-field site was considered when we developed the
24 ITAAC, that was one of the things in our mind, at
25 least when we generated our initial -- that that is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 what do you with a site that's brand new and how could
2 they do this?

3 We continue discussions with DHS to figure
4 out what we need to review and on what level for a
5 green-field site. It needs to be clear to everyone,
6 the applicants and those present that the plans need
7 to be submitted at the COL application stage and we do
8 require those plans, but implementing procedures are
9 not required with the COL application. The
10 implementing procedures come later and they have time
11 to develop that information as they go along.

12 Preliminary question we received about the
13 completeness of the ITAAC table for the early site
14 permit and I think I explained it, we've added a few
15 ITAAC in there. Again, it's not all inclusive or
16 exclusive and it's got the flexibility for the
17 applicant to include what they want.

18 MEMBER CORRADINI: I'll wait until you get
19 to comments.

20 MR. BARSS: Okay, diversity of the
21 planning options, Mr. Powers asked about and it does
22 include evacuation, sheltering or KI. If you look at
23 NUREG 0654, particularly the planning standards or the
24 subcriteria mentioned in there, J10, F, G and M, it
25 gets into very specifics about using KI, about doing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 evacuation or about sheltering. That's part of the
2 planning process and what we expect them to include in
3 their plans to have those considerations as part of
4 the planning, so there is the full spectrum of
5 response capability there and then they can choose as
6 appropriate when they need.

7 MEMBER POWERS: What experience tells us
8 is that the combination of inspection emphasis and
9 staff's prejudices leads licensees to draw logical
10 conclusions and to deemphasize J10M, in favor of J10G
11 and J10F is site- and locale-dependent, so whether
12 they address it or not is -- but it's really the
13 discrepancy between on sheltering and evacuation.

14 As we move toward plants whose risk-
15 dominant accident is going to be a seismic event or
16 the infrastructure to support evacuation, emergency
17 plans gets degraded along with the plant, sheltering
18 becomes much more important.

19 My question to you is how do we counteract
20 this emphasis that in the inspection of plans and the
21 review of plans the emphasis on evacuation at the
22 expense of sheltering?

23 MR. BARSS: And in fact, supplement 3 that
24 was put out some time ago really pointed to evacuation
25 as the preliminary thing we expected them to do. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that's true, there is an emphasis on that in the
2 current mindset, I would say.

3 I think following our presentation here
4 later today, you're going to have Randy Sullivan here
5 talking about some studies that they're doing and one
6 of the studies he's working on is looking at that.
7 We're using Sandia Lab, look at what other things can
8 you do instead of evacuating all the time, when would
9 sheltering may be a better possibility? And that is
10 being studied by this and will be factored in. We're
11 giving a look at our regulations and our guidance and
12 we'll be revising them in the future here. So we're
13 not blind to that that consideration is going forward.
14 But as far as the current standard review plan, we've
15 not factored a change in there to our guidance
16 documents.

17 MEMBER POWERS: Shouldn't we -- the new
18 plants we're talking about are going to have internal
19 events, core damage frequencies that are quite low,
20 yet the seismic hazard is going to be handing in
21 roughly 10^{-5} or maybe 10^{-6} , but it's somewhere in that
22 region. And so it's going to be just totally dominant
23 over the internal events. And quite frankly any
24 seismic event capable of damage to the nuclear power
25 plant is going to damage all your infrastructure for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 supporting these magnificent -- you're simply not
2 going to have overpasses and bridges for evacuation
3 processes.

4 And so, you know, we're planning for the
5 events that are not going to occur, it seems to me and
6 that's silly.

7 MR. BARSS: I understand your point. I
8 don't have an answer for you today.

9 MEMBER POWERS: I only ask you to think
10 about it.

11 MR. BARSS: It's an important
12 consideration.

13 MEMBER POWERS: Luckily we're building
14 plants where seismic won't be the dominant risk.

15 (Off the record comments.)

16 CHAIRMAN WALLIS: Very quickly, is KI
17 required?

18 MR. BARSS: They are required by our
19 regulations to consider KI as a protective action. It
20 is up to the individual states whether or not they
21 implement or have a plan for that. And in fact,
22 you're probably familiar with that we have offered to
23 buy potassium iodide for states that choose to use it
24 and not all of them have taken us up on the offer.

25 MEMBER APOSTOLAKIS: How is the seismic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 issue handled in existing plans, existing emergency
2 plans?

3 MR. BARSS: Seismic is considered --

4 MEMBER APOSTOLAKIS: I mean the issue of
5 the same earthquake damage the civil infrastructure.

6 MR. BARSS: That's why you have a flexible
7 emergency plan and you have local authorities that
8 know their communities and the roads and things like
9 that and if there is an event like that, it will be up
10 to them to look at what available infrastructure they
11 have left and determine what they can do and how they
12 can do it.

13 MEMBER APOSTOLAKIS: So that's not part of
14 the planning?

15 MR. BARSS: It is part of the planning in
16 that you don't -- but you don't plan for an earthquake
17 that wipes out all your bridges, I wouldn't say that.
18 That's not specific --

19 MEMBER POWERS: But you have to.

20 MEMBER BONACA: But you would focus on
21 sheltering.

22 MR. BARSS: Then you would focus on
23 sheltering at that point.

24 MEMBER CORRADINI: I guess -- if I could
25 just interject, so I think where Dana is going with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this is and maybe this is -- I'm slicing it a bit is
2 that the 13.3 doesn't necessarily speak to this, but
3 the 0654 and the supplement you mentioned in some
4 sense, as you said seems to be pointing people to a
5 direction that's not as diverse as we might need to.

6 So does that mean that we're going to have
7 to -- that there's going to be a relook at 0654? Is
8 that in the plan?

9 In other words, to address what Dana's
10 concern is, which seems quite valid, it's not 13.3.
11 It's really the base document that 13.3 points to that
12 gives him guidance that might be leading him down one
13 preferable path and may not be appropriate for the
14 future.

15 Is there any plan to look at 0654 again?

16 MR. BARSS: Yes. 0654 is one of the
17 documents that we are currently planning to work on,
18 I believe. I see Catherine back there and she's
19 shaking her head in the affirmative, so that's on our
20 list of things to look at. I wouldn't say that this
21 specific concern was on our radar prior to today's
22 discussion, but it certainly is now and will be. And
23 I'm not sure in the studies that Mr. Sullivan has been
24 conducted with Sandia, whether or not that's played
25 into it, but it's certainly a data point that we would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consider and we appreciate the insight that you bring
2 to that.

3 There were comments from the public,
4 primarily from NEI. One about not opening the
5 existing site emergency plan for review. That was
6 the three criteria I talked about earlier, whether or
7 not it's applicable to the new reactor, up to date and
8 addresses the new reactor. That's how we intend to
9 handle that. It's up to the applicant as to how they
10 address their existing plan and what they submit to us
11 for the new site. We agree that they shouldn't fear
12 their existing plan being open for review. However,
13 I would add that as we do these reviews, if we do
14 identify problems or things there, that deal with the
15 site, then we would expect them to be corrected.

16 However, I would also add that these plans
17 have been around for a long time. They've been
18 exercised and tested and we have reasonable assurance
19 for them, so I'm not so concerned that that's going to
20 be a big issue. And it has not, to this date, been a
21 big issue for the three we've done and the fourth one
22 we're working on now where they've been open for this
23 review.

24 We did ask a lot of questions initially
25 that caused some concerns. Hopefully, we've reined in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our question asking to keep it focused on the right
2 thing, but I don't think we did any harm to anybody's
3 plan or planning programs in that.

4 Expansion of the ITAAC was expressed as a
5 concern and I've already addressed that as to why we
6 did it and we think it is a good thing and beneficial.
7 I don't believe in the comments we got that anybody
8 said there was anything wrong with what we expanded,
9 but just that they were disappointed that we had gone
10 beyond what had already previously been discussed in
11 the public forum.

12 Use of the term "generic communications"
13 was mentioned, particularly because we seem to
14 reference a lot of generic communications and it's
15 clear that many of our generic communications require
16 no action on the part of the applicant or the licensee
17 and that continues to be true. We don't expect them
18 to address all those generic communications in their
19 application, only the ones that require specifically
20 that they have taken action.

21 But we do want applicants to be aware,
22 because there is as time as gone forward, there's a
23 lot of people retiring and new people coming into this
24 industry. There's a lot of lessons that can be
25 learned from reviewing those old documents, those old

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information notices that are out there so we don't
2 repeat the mistakes of the past. So we think it's
3 important that they have those documents available to
4 them so they can learn from those things.

5 Submittal of implementing procedures, we
6 agree with that comment that was made that we do not
7 require the submittal of implemental procedures for
8 the off-site. They are required for the on-site, but
9 that is later in the process, before fuel loading, but
10 the off-site procedures had never been required to be
11 submitted and we are not requiring them now at this
12 time to be submitted in our regulations. And the
13 comment about the absence of DHS or FEMA rep planning
14 preferences, limited off-site response plan related
15 review criteria.

16 Again, it's not in our document other than
17 a vague reference to what's already existing. But
18 those are existing documents and as I've said fairly
19 well known in the community that uses them.

20 MEMBER CORRADINI: So if you're done with
21 that one, I had a question about that one. So I
22 didn't -- maybe I missed it and the NEI representative
23 will remind us of it, but I guess I would like to
24 understand that more about their concern there,
25 because that was one of our concerns about trying to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 understand how limited information there was.

2 MR. BARSS: I will let Alan Nelson get the
3 rest of that.

4 MEMBER CORRADINI: Okay, then I have
5 another one which is so given what occurred with
6 Katrina and evacuation, were there any lessons learned
7 that one can point to this relative to -- guidance
8 now, not necessarily what the 13 -- so, we're
9 branching again. This is not really within the realm
10 of the 13.3, but within the realm of what you would
11 point somebody to to review in terms of guidance for
12 the applicant?

13 MR. BARSS: I will say that there are
14 probably some lessons learned that we can gain from
15 Katrina. We are in the process now of studying that.
16 We did a study some years ago, just a couple of years
17 ago we completed one, where we took the last 15 years
18 worth of events that had happened where there were
19 evacuations of some size. We pared it down to 50
20 specific ones that were reviewed and we looked at that
21 and learned from them and we're applying that.

22 The Hurricane Katrina and Rita happened
23 after that was done. They are significant events and
24 they did have significant consequences. We have
25 opened a contract with the Sandia Labs to look at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 those again. So we are in the process of studying
2 that.

3 There were lessons learned published by I
4 believe FEMA, DHS, other government studies. Most of
5 them have dealt with internal government processes and
6 things that the government could do better, but they
7 have not been directed to off-site emergency planning,
8 particularly in the radiological areas, things that
9 they should make changes. So there really have not
10 been lessons learned that are applied directly to the
11 REP program, but we are studying that and looking for
12 them, and we will certainly include them at the
13 appropriate time and place.

14 MEMBER CORRADINI: Thank you.

15 MEMBER POWERS: You would be surprised if
16 one learned profound things from Katrina evacuation,
17 because there seems to be a distinction between
18 natural event emergencies, especially one like Katrina
19 where there's substantial warning period of time, and
20 what are called technological events, which are abrupt
21 and poke at the human's natural concern over things
22 that you don't know much about. Thing like chlorine
23 tank releases and stuff like that, where there is this
24 mortal dread.

25 Whereas a hurricane, especially if you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 live in a hurricane region, is something that's quite
2 frankly the problem is that people don't want to
3 evacuate. Seldom is that a problem --

4 MEMBER CORRADINI: The manmade versus the
5 natural.

6 MEMBER POWERS: -- that poison is coming
7 under the door stop. I just don't hold -- I think the
8 lesson that's going to come out of Katrina is that
9 it's good to have emergency plans. And that's all I
10 personally hold out there. I think that within this
11 50 that he speaks of, there are set of 26 or so, maybe
12 a few less than that, much more likely to hold
13 information than Katrina.

14 The one thing that I think comes out of
15 looking at these is that there is are a lot of myths
16 about evacuation that can get dispelled. You hear
17 myths like oh well, evacuation is terrible because
18 lots and lots of people get killed in evacuations and
19 things like that. I think that you find that in fact
20 evacuations aren't particularly fatality prone.

21 MEMBER APOSTOLAKIS: Does evacuation
22 planning include taking care of the people after you
23 evacuate them?

24 MR. BARSS: Yes --

25 MEMBER APOSTOLAKIS: Katrina, there is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 lot of lessons there. I don't think they did a good
2 job with that, did they?

3 MEMBER POWERS: Like I said, I myself hold
4 out no hope for learning very much from Katrina. I
5 think there's something else --

6 CHAIRMAN WALLIS: Well, I think the public
7 learned some.

8 MEMBER POWERS: I think what you will
9 learn is that having the plan is a good idea. And
10 Katrina will simply teach you, gee, if you have a poor
11 plan for handling people that are evacuated, you're
12 going to get a lot of catastrophe. I don't think it's
13 going to --

14 MEMBER APOSTOLAKIS: Katrina --

15 MR. BARSS: But the radiological emergency
16 plans do have reception centers built into the process
17 in monitoring capabilities for people coming to them.

18 MEMBER APOSTOLAKIS: But do you see a case
19 where you will have to evacuate the numbers of people
20 that have to be evacuated in Katrina. I mean, you're
21 talking about --

22 MEMBER BONACA: Well, that's an issue. I
23 mean, Katrina, the tragedy of Katrina was a major city
24 being hit. Now power plants, they don't have that
25 many people around, so you can move them out to a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 degree if you have any constructions still that you
2 can use. It's a big difference.

3 MEMBER APOSTOLAKIS: Who is in charge, by
4 the way, when this happens?

5 MR. BARSS: When what happens?

6 MEMBER APOSTOLAKIS: A major accident.

7 MR. BARSS: Well, the utility remains the
8 responsibility for operating the plant and notifying
9 people of the event. Depending upon the governmental
10 structure, the responsibility for protecting the
11 health and safety of the public usually rests with the
12 state, with the governor, that can be delegated. Like
13 Texas, if I remember right, it's a county judge that
14 has that responsibility about the planning. So it
15 depends on the jurisdiction and who makes the final
16 decision.

17 MEMBER APOSTOLAKIS: The agency is what?

18 MR. BARSS: As far as the NRC goes, we
19 have a role and FEMA and DHS has a role under the
20 federal plans to provide advice and information. But
21 the actual protecting of the health and safety of the
22 public, that lies with the state. That is their
23 responsibility.

24 MEMBER POWERS: I believe that FEMA and
25 NRC share the responsibility for coordinating federal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 response.

2 MR. BARSS: That's correct. And when
3 we're called upon by the State, we provide that
4 assistance. And we have an elaborate system in
5 process which we process which we practice --

6 MEMBER APOSTOLAKIS: This federal response
7 takes place only if the governor says do it?

8 MEMBER POWERS: There are a couple of
9 instances where the federal response is provoked
10 without the governor, but in general, the governor has
11 to ask for it.

12 MEMBER MAYNARD: And typically they will
13 declare a state of disaster emergency, which is a
14 magical term that then opens up mechanisms.

15 MR. BARSS: That's correct.

16 MEMBER MAYNARD: Roles and
17 responsibilities are defined as part of the emergency
18 plan.

19 MR. BARSS: Yes, and that's the purpose of
20 the emergency plan is to establish those things ahead
21 of time as to who does what and who calls who and who
22 has the authority request that assistance should it be
23 needed. That's the whole idea of the plan.

24 CHAIRMAN WALLIS: I'm surprised at this
25 idea that we didn't learn something about Katrina.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Well, maybe we didn't but I think the public
2 perception really changed as a result of Katrina. It
3 does affect the public perception for emergency
4 planning for a nuclear event.

5 MEMBER BONACA: I mean, a nuclear plant,
6 even in a crowded area, you still have a void with
7 respect to what you had in Katrina, hit a major center
8 like that, so, the issue there, the challenge was to
9 move our people from a very highly-populated area
10 through roads that were inaccessible.

11 MEMBER MAYNARD: I think one of the key
12 differences you would see with a licensee having a
13 radiological emergency that activated the emergency
14 plan, roles, responsibilities, training is already
15 taken place and you have some leadership driving it
16 and you're going to end up with the people in one
17 location. With a natural event the government agency
18 seemed to be hesitant to take advantage of some of
19 that and co-locate and drive that. So, I think in a
20 radiological event, you know, you have a driving force
21 and you have a central location and you have the
22 leadership in one area to where it would drive more
23 things to happen.

24 What I did not see happening in Katrina,
25 I did not see the agencies communicating, working

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 together, making things happen.

2 MEMBER POWERS: Get some local leadership
3 issues, the mayor and the governor --

4 MEMBER MAYNARD: Those are always
5 interesting kinds of questions.

6 MEMBER POWERS: They didn't contribute
7 much.

8 MR. BARSS: I heard the comment that we
9 hadn't learned anything from Katrina. It's not that
10 we didn't learn anything, but specifically the REP
11 Program, we -- specific to the REP program, we, the
12 NRC and DHS as an agency have not made any
13 recommendations to the REP program to make changes
14 based upon the lessons learned. We will do that once
15 we've completed our studies and identified there are
16 specific things to the REP program that need changing.

17 MEMBER CORRADINI: Okay. So, if this is
18 a good point let's move on to hear from NEI and then
19 we'll wrap it up with comments from the --

20 CHAIRMAN WALLIS: Will you try to get us
21 back on time?

22 MEMBER CORRADINI: Yes. I'm shooting for
23 3:30.

24 MR. NELSON: Thank you and good afternoon.
25 My name is Alan Nelson, Director of Emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Preparedness at NEI. I have Marty Hug here with me
2 from my staff, and let me first thank you for the
3 opportunity and before I get into my presentation, a
4 number of the issues and topics that were discussed
5 this afternoon were clearly expounded on by the NRC
6 and in some ways there may need to be some
7 clarification between what our comments said and as we
8 proceed because we have been engaged with the staff
9 and had several meetings with them.

10 I'd like to go back to a couple of topics
11 that I, I think are critical for us to discuss or at
12 least to have a better understanding.

13 The programs that are in place today
14 around these nuclear sites have been used for real
15 events. An example, outside of Raleigh, I think about
16 a month or so ago, the Apex chemical plant evacuated
17 17,000 people. It's not that far from the Sharon-
18 Harris plant. The program in place in that community
19 for the nuclear was utilized in many parts to evacuate
20 those people.

21 In the real world today, this year alone,
22 there were 17 unusual events and two alerts. Those
23 events in themselves don't constitute protective
24 actions, okay. They are notifications and to the
25 state and locals to let them know that an event has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 occurred at a site and to make them aware if they need
2 to man their emergency operating facilities in the
3 case that the events escalated. In the case of, no
4 events this year were, you know, needed to take that
5 progression.

6 One of the topics that was discussed, the
7 licensee, local and states are partners in emergency
8 preparedness. The licensee evaluates the event under
9 classification system, whether it be a unusual event,
10 alert, site emergency, general emergency being the
11 highest of the, that would require some protective
12 action to be made. That protective action, as you
13 discussed, could be sheltering evacuation and the
14 consideration of KI range or combination of those.

15 You discussed to some detail reasonable
16 assurance and how do you determine there is reasonable
17 assurance that these programs or these plans will
18 protect the public in the off-site environment within
19 the EPZ and sometimes the ingestion pathway.

20 I think that, looking at the 16 planning
21 standards, okay, which really weren't labeled out,
22 they are to find an organization, on-site and off-
23 site. A classification methodology of what events
24 will require what actions and how do you determine
25 them.

1 Notification, how are you going to notify
2 them on a 24/7-type basis? Can you notify the public,
3 whether it be by tone-alert radios or by sirens or by
4 a reverse 911? The facilities, are they equipped,
5 maintained and tested? Communicating among the
6 public, pamphlets and so forth, makes the public
7 understand what events and what actions they would
8 need to take in an emergency as well as the transient.
9 You talked about some skiing, if he's staying in a
10 hotel, he gets that information. If he's staying
11 nearby in someone's home, they have that information.

12 And then there's the specifics of
13 training. Those make up, constitute the basic of the
14 plan in itself. If any one of those points of those
15 16 planning standards are not met, that defines a
16 deficiency. And how do they evaluate the assessment
17 of reasonable assurance, looking at those planning
18 standards during an exercise, looking at them as a
19 thorough review through the FEMA process, as well as
20 an annual letter to FEMA that states that they have
21 done multiple activities in support to assure a
22 readiness of that program.

23 I just wanted to give you an idea of some
24 of the things that you talked with the NRC. It will
25 give you a level of confidence of how these programs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are used in the real world, how a deficiency is
2 defined and how they are implemented and trained on
3 during the course of a year.

4 Turning to the topic of today, NEI has
5 formulated a task force of experts to look at the
6 emergency preparedness. As you can see, there are 10
7 licensees that are involved and a series of four
8 reactor types that are being evaluated at this time.
9 We have met, almost on a monthly/weekly basis and
10 conference calls to review and discuss many of the
11 projects that we have at hand. The key projects that
12 we've listed are of course the emergency action levels
13 which began with a NUMARC document, became 99-01 and
14 now we're looking at a rev. 5 which is for the
15 operating plant and we're going to talk a little bit
16 about NEI 07-01.

17 We have provided comments to the staff and
18 met with them on a series of occasions, public
19 meetings on the Draft Guide 1145 in the standard
20 review plan.

21 99-01, which is the basis for today's
22 emergency preparedness programs and identifying the
23 classification system has been endorsed in Reg. Guide
24 1.101. It's for the existing fleet. Right now, about
25 70 percent of the fleet uses 99-01 and that's a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 barrier-based process versus the remaining 30 percent
2 uses 0654 which is an event base.

3 You talked about do you revise 0654? In
4 this case, it's supplemented by the NRC's endorsement
5 of the NEI methodology. So you don't have to do a
6 whole landscape retooling of 0654. You can provide
7 supplements. In that case, that's what we did and we
8 requested endorsement.

9 The EISs themselves recognize about six or
10 seven, what we call tabs or events that can occur that
11 need to be observed and recognized by the operators in
12 order to make a classification of an unusual event
13 alert, site and general emergency.

14 The 07-01 which is in draft right now is
15 looking at the AP 1000 and the ESBR and adapts the 99-
16 01 methodology. And we will develop it as a stand
17 alone, but the philosophy and the methodology are
18 concisely used together. So there is a pedigree
19 between them. Because we want our operators to use
20 the same pedigree methodology at an existing site as
21 they would for a new site.

22 Taking a look at 13.3, as the NRC staff
23 had said, we submitted comments by November 9th and we
24 had reviewed the ALWR, the task force had provided
25 those comments.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Specific comments were addressed by the
2 NRC, was the reactor that the staff wanted to look at,
3 existing procedures at the site and this becomes -- I
4 think we're going to need to discuss this further with
5 the staff because where it becomes a concern is that
6 those procedures and those programs are already
7 approved. So if they were to make a finding, does
8 that mean that that particular license portion is
9 invalid? And that's where it drives the concern.

10 I understand the expansion of the original
11 agreed on ITAAC, but there are certain elements that
12 are crossed over from one ITAAC to another. I think
13 there was a radiologic ITAAC that was seen somewhere
14 else and there seemed to be a mix and match. There
15 ought to be a single set of ITAAC that applies and I
16 think that with further discussion with the staff we
17 could probably have a better understanding and see
18 where that approach comes to be.

19 The generic communication issue is very
20 interesting. There are, I believe, correct me if I'm
21 -- I think in the SRP there are 133 cited references.
22 Sixty-eight of those are NUREGs and so forth. From 69
23 on, there are information notices, what they call
24 EPOS, RIS and a whole gaggle of opinions and ideas.

25 In developing a plan for submittal, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 staff has asked us to reference where in that plan
2 where those references. So you've got 133 that may
3 get RAIs and say well, you didn't reference number 90,
4 but wait a minute, 90 you said -- you know, we think
5 those ought to be stripped out of there, taken out.
6 On one hand, you're saying those are generic
7 communications, but on the other hand, you may be
8 looking to see those referenced in the plan itself.
9 So that's why the industry is sensitive to what is an
10 actual reference in a legitimate.

11 And again, we appreciate the staff's
12 review of our comment on the requirement to submit
13 off-site procedures as a new requirement that I think
14 Dan adequately discussed.

15 I would say the single most concern that
16 we have brought before you is the guidance or -- we
17 applaud the NRC and the staff for the guidance they've
18 provided in the SRP in itself. We find that it's
19 short on the limited guidance and expectations for the
20 FEMA review.

21 The fact that, as Dan had stated, it's
22 this, this and this. It's not included in the SRP.
23 Our current thinking is we, as a task force at NEI,
24 should consider developing a template for this off-
25 site submittal. There is some consistency of review.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If there isn't a template or a standard SRP for both
2 the on-site and the off-site, there will be a series
3 of RAIs that will cause a great deal of confusion on
4 what is required and what is the standard in which to
5 be evaluated. That in time will cause delays in the
6 whole approval process of the ALWR. And we certainly
7 don't want this portion of it to say to be the
8 Achilles' heel of the review process so that the
9 process can be on time, on schedule and potentially
10 streamlined in some manner.

11 Of course, we look forward to working with
12 the NRC as well as DHS and continue our discussions in
13 13.3 and we will engage, we will have a first draft of
14 07-01, we believe next week to present it after the
15 first of the year and seek the staff's endorsement in
16 a Reg. Guide 1.101 as we had in the past for the EALs.
17 In that regard, the licensee, whether it be a
18 Westinghouse or a G.E. type model, they, in fact, will
19 reference 07-01 as brought to maturity.

20 MEMBER BONACA: What kind of changes do
21 you have because of the passive reactors on the
22 emergency action levels?

23 MR. NELSON: I think Dan had mentioned the
24 AC, what was the other one that was brought up?

25 MEMBER BONACA: Okay.

1 MR. NELSON: Marty, what was some of the -
2 - you've been working with Westinghouse --

3 MR. HUG: GDC power requirements, use of
4 digital indication versus --

5 MEMBER BONACA: He can't speak from there.

6 MR. BARSS: We had two there. These
7 passive plans depend on large tanks of water which are
8 new and there's a certain level which that tank may be
9 emptied and that's a concern. So that's some of the
10 things we're looking at.

11 MEMBER APOSTOLAKIS: that confuses me a
12 little bit. Is the ASBWR a passive plant?

13 MR. NELSON: Yes.

14 MEMBER APOSTOLAKIS: The dominant
15 contributor loss of preferred power?

16 MR. NELSON: Yes.

17 MEMBER APOSTOLAKIS: So what are we
18 talking about here?

19 I mean AC power apparently is important.

20 VICE CHAIRMAN SHACK: If your internal
21 events CDF is 3 times 10^{-8} something dominates.

22 MEMBER APOSTOLAKIS: No, but still -- no.
23 I thought the argument was for passive plants you
24 don't need off-site power. And here I have a passive
25 plant where the dominant contributor is loss of off-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 site power. Is that something that is obvious to
2 everyone?

3 CHAIRMAN WALLIS: You need more than just
4 a passive system.

5 MEMBER APOSTOLAKIS: All plants have
6 reactor systems because they don't create a mess with
7 the passive.

8 MR. HUG: Marty Hug, NEI. I work for Alan
9 Nelson. It does come in time in an accident sequence
10 where loss of AC power and subsequently then loss of
11 DC power would be an issue. It would be somewhere
12 around 72 hours into the event and at that point in
13 time the reactor would still inherently stay safe.
14 However, the operators at that point in time because
15 of loss of battery power would not have an available
16 indication.

17 MEMBER BANERJEE: Long-term cooling always
18 needs power.

19 MEMBER APOSTOLAKIS: It just strikes me as
20 strange that the licensee says, I mean the vendor says
21 this is what dominates the risk and the emergency plan
22 says --

23 MEMBER BONACA: The point that Bill made,
24 that's because you get down to such a low risk, you
25 have some procedural sequences there that where you've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 got long term you depend on full power.

2 MEMBER CORRADINI: Can I broaden the
3 discussion though just to follow the point. I want to
4 go back to what Dana, I wrote it down as something
5 that we might want to at least comment on, maybe not
6 recommend, relative to 06-54 and supplements.

7 And you kind of said back that -- unless
8 I wrote it down wrong, 75 percent of the current
9 operating plants do not use 06-54 nor the supplements,
10 but use rather the --- I can't remember what you call
11 them, essentially the NEI action guidelines, action
12 plans, whatever.

13 So let's play out the concept that his
14 concern is which is now I've gotten to the point that
15 the new plants, passive, quasi-passive, maybe passive,
16 are of low enough CDF from internal events that now
17 it's external events that dominate. What is the NEI
18 procedure say relative to a seismic event and how
19 would that change the emergency planning guidance?

20 So I'm --

21 MR. NELSON: It wouldn't change the off-
22 site reaction. It would still require the same
23 notifications, whether it be an unusual event alert or
24 --

25 MEMBER CORRADINI: Right, but let me just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 -- maybe you weren't in the room when Dana brought
2 this up which I thought was a good point which is that
3 the supplement 3 of 06-54 tends to favor, suggest to
4 favor evacuation. What would NEI suggest when I now
5 have flipped it and the external event which
6 essentially wipes out all possibilities or large
7 portions of possibilities for evacuation, what would
8 be the guidance or how has the guidance changed with
9 these new plant designs from the NEI side, if they
10 would be the supplement or the substitute for what 06-
11 54 might say.

12 MR. NELSON: I'm not in a position at this
13 time to answer the question because there are studies
14 underway. I think that would address what the margin
15 might be. That may be a future topic that we might
16 want to pursue.

17 MEMBER BONACA: Emergency Action Level is
18 pretty much keys on loss of barrier, right?

19 MR. NELSON: Correct.

20 MEMBER APOSTOLAKIS: But about the issue,
21 there is an assumption there, Mike, that we establish
22 the emergency plans for the dominant contributors.
23 That's not true, because even for existing plants, the
24 seismic risk is very often on the same order as
25 contribution from other events. So the question

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 remains even for the existing plants.

2 MEMBER BONACA: The actual levels are
3 based on a number of barriers that you have lost,
4 okay, so if you have no loss of barrier and so you
5 have a situation where you might be within the 72
6 hours, you're still cooling, etcetera, I don't know
7 what the actual level will be. It will not be a
8 general emergency. It's simply your barriers are
9 still intact.

10 So the question is not so much what the
11 event is, but what the conditions of the plants are,
12 given a certain time. Now clearly however you get
13 there, if you have AC power, you save the day because
14 at that point if you have no failed barriers, you
15 don't proceed to work through the degradation and you
16 can cool.

17 I can see how the loss of power, it would,
18 in fact, generate an event where in the long term you
19 just can't -- you need to have power to feed and you
20 don't have it.

21 MEMBER APOSTOLAKIS: Are you agreeing then
22 that for passive systems, the requirements regarding
23 off-site power should be reduced for at least 72 hours
24 because the passive systems will save the day and then
25 for long-term cooling?

1 MEMBER BONACA: Yes, it seems to me that
2 that's the kind of scenario I can see here.

3 MEMBER APOSTOLAKIS: Why? Why?

4 MEMBER BONACA: Okay, because they say for
5 72 hours you have passive systems working, okay? Now
6 that implies at some point after the 72 hours you're
7 going to --

8 MEMBER APOSTOLAKIS: You're forcing me now
9 to become a structuralist defense-in-depth guy. The
10 whole thing is a defense-in-depth issue.

11 MEMBER POWERS: As well you should be,
12 George.

13 MEMBER APOSTOLAKIS: I have always been.

14 (Laughter.)

15 MEMBER APOSTOLAKIS: I don't think this is
16 a defense-in-depth issue. That's why you have
17 emergency planning.

18 MEMBER BONACA: I was answering the
19 question about the seismic and the point I'm making is
20 that the emergency action levels are not based on the
21 event. They're based on the loss of barriers that you
22 may have --

23 MEMBER CORRADINI: Throughout the plant.

24 MEMBER MAYNARD: They're based on the
25 likelihood of a release. They're based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 likelihood of a --

2 MEMBER BONACA: So whatever causes that,
3 you know, and the reason is that otherwise you have
4 the people speculating what will happen here. Well,
5 fundamentally you have to ascertain if your barriers
6 are intact, then you have to maintain cooling, but so
7 that's --

8 MEMBER CORRADINI: Let me just -- maybe
9 I'm misunderstanding. I'm trying to take notes for
10 things that might be discussion points and I want to
11 make sure I get it.

12 But what I sense from what Dana was saying
13 before which made sense to me was if I get in a
14 situation where the initiator is external and it
15 changes how I would fundamentally respond external,
16 outside of the off-site, then there's got to be some
17 sort of appropriate guidance so that you have a
18 diversity of how you'd respond. That's what I guess
19 I'm getting at. So I'm kind of curious what's in the
20 NEI version of this since I didn't realize that 75
21 percent of the plants were kind of taking that
22 approach versus the 06-54 approach. That was new to
23 me.

24 MR. NELSON: Let me recommend something.
25 As we pursue the completion of 07-01, let me ask you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 if we can come back and give you a detailed review of
2 the document and the process in which we can to the
3 conclusions we had and I think I may answer a great
4 deal of your questions. It's complete understanding
5 of the design, the impact, the barrier approach within
6 that design and how we've maintained the pedigree of
7 99-01 and the off-site response.

8 MEMBER BONACA: The plant will determine
9 the emergency action level.

10 MR. NELSON: Absolutely.

11 MEMBER BONACA: The state, to which the
12 information goes, will be determining what to do,
13 depending on the conditions outside of the site. So
14 therefore, they may decide, the state may decide that
15 they're going to shelter because they cannot move
16 quickly people out, irrespective of how bad the plume
17 may be at some point.

18 MEMBER APOSTOLAKIS: Right, but the big
19 question in my mind is this is after the fact. There
20 is an event and I see what has happened. When I plan,
21 because you know, that's what it's called, emergency
22 planning, what assumptions do I make? And it seems to
23 me that for the passive plans, the assumption is that
24 whatever the vendor says is true, that for 72 hours,
25 the passive system will work five and then you don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 need electric power. And then that's where I get
2 uncomfortable because defense-in-depth says what if,
3 what if it doesn't work, what if the earthquake itself
4 has distorted the geometry of the system so you don't
5 get the flow that you think you would be getting?
6 Then you say, oh my God, I made a mistake?

7 MR. NELSON: The fundamental question
8 though is the design is reviewed and approved by the
9 staff to assure, you know, that is 72 hours enough?
10 That's one -- so the design and systems are approved
11 and reviewed by the staff.

12 We're going to present EILs that match up
13 to that approval and then the EILs and themselves 07-
14 01 go out for public comment or will go out for the
15 staff review and as I said we --

16 MEMBER APOSTOLAKIS: The point I wanted to
17 make to your comment again is that the actual levels
18 are not tied to the design of the plant. They're tied
19 to the event, to the conditions of the plant which is
20 do you have the barriers' integrity? You have
21 cladding, you have primary site and the containment.
22 If the answer is yes, it will not be a general
23 emergency. If it will be a site emergency, it will be
24 an alert, something of that kind.

25 Now then the accident has evolved and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there will be a response to that. This still centers
2 around not whether it's 72 hours that will occur,
3 whatever. It's centered around have I lost control
4 of the barrier. When you have the first barrier
5 penetration, you begin to lose -- then there will be
6 an escalation of the --

7 MEMBER CORRADINI: Yes, I think we can
8 continue.

9 MEMBER KRESS: I think, Mario, it's more
10 of an impending loss of power.

11 MEMBER CORRADINI: I was going to ask for
12 Member comments, but that's where we're going.

13 MEMBER KRESS: You don't wait for the
14 barrier to be lost.

15 MEMBER BONACA: No, no. I understand
16 that.

17 MEMBER MAYNARD: Based on the loss or the
18 potential loss or likelihood.

19 MR. NELSON: Loss or potential loss.

20 MEMBER BONACA: Essential level is based
21 on communication.

22 MEMBER CORRADINI: So now were in the
23 discussion mode. I've heard from almost everybody,
24 all the Members. I wanted to know if Jack or Bill or
25 Graham or Sam would have any other discussion points?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Said, too, I apologize.

2 MEMBER ABDEL-KHALIK: No problem.

3 MEMBER CORRADINI: I missed the TV.

4 MEMBER ABDEL-KHALIK: I have a question
5 regarding the concern that has been raised regarding
6 co-locating a new reactor at an existing site and how
7 that might open the review of an existing emergency
8 plan.

9 Philosophically, if in the process of you
10 know, co-locating a new reactor at an existing site
11 you find a deficiency in the existing emergency plan,
12 what's wrong with reviewing it?

13 MEMBER CORRADINI: This is addressed to
14 NEI, I assume.

15 MEMBER ABDEL-KHALIK: NEI and/or the
16 staff.

17 MR. BARSS: This is Dan Barss. The
18 staff's answer is if we find that the deficiency in
19 the existing plan, they're going to have to fix it.
20 No questions are asked.

21 MEMBER MAYNARD: I would think that
22 probably issue is not so much an oh my God, a
23 deficiency. It's a review of something that maybe
24 could be done different or maybe under the new
25 requirements would require one thing, the old

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 requirements are different and how do you handle that
2 discrepancy between the old versus the new?

3 MR. NELSON: But not an oh my God, which
4 way is better, but you still meeting the same
5 objective.

6 MR. BARSS: And generally, the old
7 requirements are the same requirements. It really
8 does not change the emergency planning requirements.
9 The only thing that changes is the timing of when we
10 look at them, review them that is really the change,
11 but the requirements have not changed.

12 MEMBER CORRADINI: Said, any other, any
13 follow-up?

14 MEMBER ABDEL-KHALIK: Yes. That's fine.
15 thank you.

16 MEMBER CORRADINI: Other Members? Jack?

17 MEMBER SIEBER: The requirements haven't
18 changed.

19 CHAIRMAN WALLIS: Yes. My only question
20 is how does all this discussion we've been having
21 here, reflect what we're going to say about Section
22 13.3?

23 MEMBER CORRADINI: I took a lot of the
24 notes because some of it, Dana has left the room, but
25 I think some of what Dana's concerns are are valid,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 but they aren't relative to 13.3. They're relative to
2 what is referenced and then gives technical guidance
3 on which things are reviewed. So they're more of a
4 discussion point, not really relative to 13.3.

5 CHAIRMAN WALLIS: thank you.

6 MEMBER CORRADINI: So Mr. Chairman, I
7 think we're done.

8 CHAIRMAN WALLIS: We're done. Great.
9 Thank you very much indeed.

10 MEMBER CORRADINI: Thank you very much.

11 CHAIRMAN WALLIS: I thank the staff too
12 for their presentation.

13 We do have another major item after the
14 break. It may last another couple of hours. We'll
15 take a break until 10 minutes to 4.

16 (Off the record.)

17 CHAIRMAN WALLIS: Please come back into
18 session.

19 I'd like to proceed with our agenda. The
20 next item on the agenda is the state-of-the-art
21 reactor consequence analyses, and Bill Shack is our
22 cognizant member, and I turn to him to lead us through
23 the presentations and discussion.

24 VICE CHAIRMAN SHACK: Okay. We've heard
25 a little bit about the state-of-the-art reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consequence analyzes in earlier presentations, but the
2 only written documentation we have at the moment is
3 the SECY and the SRM, and so this is our chance to
4 find out what's been going on since the last time we
5 heard about it, which was mostly the planning stage,
6 and I'm just very curious to know what we will find
7 out today.

8 And Bob Prato from the Office of Nuclear
9 Regulatory Research is going to be leading the staff
10 presentation today.

11 MR. PRATO: Good afternoon. Again, I'm
12 Bob Prato. I'm the program manager for the --

13 VICE CHAIRMAN SHACK: You need a
14 microphone close to you. There you go.

15 MR. PRATO: I'm Bob Prato, the program
16 manager for the state-of-the-art reactor consequence
17 analysis.

18 It seems like once every decade I get a
19 project interesting enough to come in front of this
20 distinguished panel, and certainly this --

21 MEMBER KRESS: Lucky you.

22 (Laughter.)

23 MR. PRATO: The consequence analysis
24 qualifies.

25 I'm new to the project. My expertise is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 primarily project management, but I do have a whole
2 slew of experts sitting out in the audience, and if
3 need be, I will call on them to help answer any
4 questions.

5 PARTICIPANT: The slew?

6 MR. PRATO: There is a group out there.
7 would you like me to introduce a few of them?

8 MEMBER KRESS: I see some experts.

9 MR. PRATO: Okay. The agenda today is
10 going to be we're going to cover the code
11 improvements. We're going to talk about plant
12 groupings. We're going to talk a little bit about
13 scenario selection, LNT versus threshold, and then
14 there's going to be an emergency preparedness
15 presentation by Randy Sullivan.

16 The last item is just administrative, and
17 we'll touch on that after the important stuff is over.

18 Our objective is to provide the ACRS a
19 list of code improvement plans for MELCOR and MACCS,
20 and to inform you of our intent not to improve annular
21 resolution for SOAR-CA. Since the development of
22 these slides that may have changed, and I'll explain
23 that when I get to that topic.

24 We also want to provide you with the plant
25 grouping list for your information. In front of --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: This is supposed to be
2 an information meeting, that you're telling us what
3 you're doing, or is this one where you expect us to
4 contribute?

5 MR. PRATO: It's primarily information,
6 but we would like feedback on certain topics. Any
7 time ACRS has feedback, we'd like to hear it first at
8 the meetings.

9 MEMBER APOSTOLAKIS: Is LNT something that
10 I'm supposed to know what it means?

11 MR. PRATO: Linear no threshold.

12 MEMBER APOSTOLAKIS: Now I do. So that's
13 what it is.

14 MEMBER KRESS: It drives all of the cancer
15 risks.

16 MEMBER APOSTOLAKIS: I've got it.

17 MR. PRATO: We're going to also discuss
18 the options for considering with regards to scenario
19 selection the approach we currently intend to adopt,
20 and we would like feedback on this subject
21 particularly.

22 We're going to discuss our thoughts and
23 opinions on applying LNT versus threshold, and again,
24 if you have feedback on this, we would like to hear it
25 as well.

1 And we plan to provide you with a
2 presentation on the site specific simulation of off-
3 site emergency response for SOAR-CA by Randy Sullivan.

4 MR. YEROKUN: If I may just try to -- I
5 hate to interrupt early in the process, but my name is
6 Jimi Yerokun. I'm Branch Chief in the Office of
7 Research.

8 I need to clarify something. Somebody
9 asked a question as to is this just for information.
10 For this project, you know, one of the things we need
11 to do, we're coming to the ACRS. We have technical
12 issues on technical decisions we have to make as we go
13 along. This is an appropriate junction to come here.
14 There are some topics being discussed that we are
15 prepared to make some technical judgments so we can
16 move on with the project.

17 So it's not merely just information to the
18 ACRS. You know, these issues, the technical concerns
19 that ACRS might have on these issues, you know, we ar
20 really anxious to hear those so that as we move along,
21 you know, we don't go off and start doing this project
22 and, you know --

23 MEMBER APOSTOLAKIS: This may be the final
24 analysis. Are we writing a letter this time or not?

25 CHAIRMAN WALLIS: Well, these may be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 rather off-the-cuff remarks because we haven't had
2 material to study.

3 VICE CHAIRMAN SHACK: Yeah, that's the
4 problem. We don't know because we have no material to
5 look at for the meeting, except for the SECY and the
6 SRM. So whether we'll write a letter or not sort of
7 depends on what we happen to hear today and what we
8 think about it.

9 CHAIRMAN WALLIS: We don't want to make a
10 premature judgment if we haven't had material
11 sufficient to reach a judgment.

12 MR. YEROKUN: I'm sorry. We're not asking
13 for a --

14 MEMBER APOSTOLAKIS: You're not asking for
15 that?

16 MR. YEROKUN: No.

17 CHAIRMAN WALLIS: You're not asking for a
18 letter?

19 MR. YEROKUN: No, we're not asking for a
20 letter, but --

21 CHAIRMAN WALLIS: Not. Okay. Thank you.

22 MR. PRATO: Okay. I've got a list of all
23 the improvements, but the primary issue that we think
24 is of interest is the annular resolution.

25 We had four MELCOR code improvements, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we are implementing --

2 CHAIRMAN WALLIS: Is this a new code,
3 MELCORE (phonetic)?

4 (Laughter.)

5 MEMBER KRESS: The "E" gets marked off.

6 PARTICIPANT: It's the European version.

7 MEMBER APOSTOLAKIS: You got it covered
8 already.

9 (Laughter.)

10 MR. PRATO: I'm being indoctrinated?

11 We had ten MACCS-2 code improvements, and
12 we are implementing eight out of that ten for sure,
13 but there are two that we are not, and I think these
14 two are two that we need to discuss with you.

15 The wet disposition model aerosol size
16 dependency, and that's specific to precipitation. The
17 greatest impact in stimulation with relative
18 inefficiency swelling, which generally is not a
19 concern.

20 So the bottom line is there's very little
21 benefit from this in our analysis, and we're putting
22 that off as part of the max improvement project, and
23 it's not going to be part of SOAR-CA.

24 The annular resolution is another issue.
25 the annular resolution, right now the Europeans and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the Asians are using 32 sectors. MACCS currently uses
2 16.

3 There were three things that initially
4 drove us to deciding not to include it initially.
5 There were concerns that this improvement may be
6 driven by results rather than by technical
7 justification. In other words, the European models
8 have shown that when you do increase the resolution,
9 you get a significant drop in dose, which would
10 significantly change the outcome.

11 So because that was the initial report to
12 us, it was a motivation for us to consider it for
13 improvements, but we were concerned that that was
14 driving the message, that it had an attractive
15 outcome.

16 The other thing was this whole number
17 of --

18 CHAIRMAN WALLIS: If it's more realistic,
19 why is it bad?

20 MEMBER KRESS: It may not --

21 MR. PRATO: I'll get to that, sir.

22 MEMBER KRESS: It seemed to me like the
23 choice had something to do with the fact that if you
24 make it coarser, like 16 instead of 32, that you
25 somehow might have accounted for meandering of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plume rather than a straight line plume. And that had
2 some benefit in terms of accounting for that sort of
3 thing that you really didn't account for.

4 CHAIRMAN WALLIS: So it's a conservatism
5 to account for things --

6 MEMBER KRESS: Yeah. It's attendant to --

7 CHAIRMAN WALLIS: -- you might have not
8 modeled very well or something?

9 MEMBER KRESS: Yeah.

10 MEMBER APOSTOLAKIS: What is conservative?
11 Our way?

12 MEMBER KRESS: Yeah, 16 would be more
13 conservative than 32.

14 CHAIRMAN WALLIS: But if you put in proper
15 mixing, I would think it would not be.

16 MEMBER KRESS: Well, the mixing is in
17 pretty well. It's just the fact that you think the
18 plume goes in a straight line.

19 CHAIRMAN WALLIS: But mixing doesn't know
20 you're going in a straight line.

21 MEMBER KRESS: Oh, yeah, it matters, but -
22 -

23 CHAIRMAN WALLIS: Well, maybe we should
24 move on.

25 MR. PRATO: There were a number of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 budgeting and scheduling issues. The 16 sectors is
2 very deeply into our code, and doing the changes as
3 well as the QA and the validation, it's not an easy
4 task, and it would probably take a number of weeks
5 beyond what we had initially intended to --

6 CHAIRMAN WALLIS: Well, if 16 is better
7 than 32, how about eight?

8 MEMBER KRESS: Well, it's a judgment call.

9 MEMBER SIEBER: Or one.

10 MR. PRATO: And the third item was that we
11 were considering other improvements that would
12 compensate for the larger sectors. We were thinking
13 about improving plume meander mode improvements and
14 network evacuation models into our code.

15 Initially we decided not to include this,
16 but with second thought and further investigation in
17 the technical benefits for this, we are reevaluating
18 it, and we had our staff at Sandia, the Sandia
19 contractor, call the technical expert and had
20 discussions with him, and we're going to have further
21 discussions before we make our final decisions.

22 We are also investigating the
23 possibilities of improving the schedule and the budget
24 on this so that if we decide to go ahead with it, that
25 we can still meet our overall schedule.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: Meandering plume implies to
2 me you're looking at real time, whereas MACCS is sort
3 of an averaged probabilistic thing over a whole lot of
4 time frames, where the plume may be going in all sorts
5 of different directions you don't know about. I don't
6 see the advantage of having a meandering plume in
7 MACCS unless you're going to use it for real time
8 analysis, and there are other codes to deal with that.

9 I mean, I'm giving you early input on some
10 of these things.

11 MEMBER SIEBER: Well, plumes don't meander
12 anyway.

13 MEMBER KRESS: Well --

14 MEMBER SIEBER: They go in river valleys
15 and up the creeks and stuff like that.

16 MEMBER KRESS: That's right. That's
17 right. They do that.

18 MEMBER SIEBER: And that's where all of
19 the people live.

20 MR. PRATO: Do you want further discussion
21 on this?

22 CHAIRMAN WALLIS: Can you move on?

23 MEMBER KRESS: I just wanted to give some
24 input.

25 MR. PRATO: The next item is the plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 grouping. What you have is a list of the eight
2 different plant classes that we've identified, and on
3 one of the slides in the back, it shows each
4 individual plant that was put in each group. This is
5 being provided for your information.

6 If after you review this you have concerns
7 with it, we'll be glad to address those concerns.

8 MEMBER CORRADINI: So there's ten plants?
9 There's eight groupings, but one Westinghouse dry
10 ambient, one dry atmospheric, and one dry atmospheric
11 four-loop and three-loop. Do I have this right?

12 PARTICIPANT: That's all the same group.

13 MEMBER CORRADINI: Oh, okay.

14 PARTICIPANT: It's just different
15 containment designs.

16 MEMBER CORRADINI: Okay. All right. So
17 I have another question, and I apologize for this
18 since we're still on plant grouping.

19 Is it thermal power that makes me worry
20 about differentiating between a Westinghouse two and
21 three-loop and a four-loop? I don't understand that
22 differentiation. I mean, there's --

23 MR. TINKER: Charles Tinkler from the
24 Office of Research.

25 Oftentimes the three-loop subatmospheric

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plants have been grouped separately in past PRA and
2 various studies of this nature. So we made the
3 distinction for the three-loop, but rather than create
4 yet another group for two-loop plants, we elected to
5 combine those with the three loop because of the
6 greater proximity to the same thermal rating than from
7 the four-loop.

8 MEMBER CORRADINI: So it is a thermal
9 power differentiation between Category 7 and 8.

10 MR. TINKER: It is a thermal power
11 consideration with the two loops to group them with
12 the three loops as opposed to combining them with the
13 four loops.

14 MEMBER CORRADINI: Okay. Thank you,
15 Charles.

16 MEMBER SIEBER: And for your information,
17 too, the plants that are three-loop subatmospheric are
18 no longer subatmospheric.

19 MR. TINKER: We are aware that two of the
20 subatmospherics have come in with the alternate source
21 term and then applied to go to a --

22 MEMBER SIEBER: Right, and it is completed
23 now.

24 MEMBER KRESS: Now, when you do these, are
25 you going to do the actual sites, the real site for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 those plants, or are you going to --

2 MR. PRATO: We'll get into those details
3 in a few minutes.

4 MEMBER KRESS: Okay. I hope so.

5 DR. BANERJEE: Just for my information,
6 does MACCS stick into account topography?

7 MR. PRATO: No. No, it doesn't.

8 CHAIRMAN WALLIS: It doesn't?

9 MEMBER CORRADINI: That would be the
10 meandering versus the averaging.

11 DR. BANERJEE: No, no, just to know where
12 the plume goes.

13 MR. PRATO: No, it doesn't.

14 MEMBER KRESS: It goes in the direction of
15 the wind.

16 DR. BANERJEE: And spreads in a Gaussian
17 way.

18 MEMBER KRESS: Yes.

19 MR. PRATO: Yes.

20 MEMBER KRESS: Depending on the mixture.

21 CHAIRMAN WALLIS: There's nothing about
22 valleys and hills and things like that?

23 MR. PRATO: No.

24 MEMBER SIEBER: For MACCS it does.

25 CHAIRMAN WALLIS: But we know the plumes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do things in valleys.

2 PARTICIPANT: It would be a little bit
3 more difficult of a calculation.

4 CHAIRMAN WALLIS: But the tone isn't to do
5 a good calculation. It's to represent a reality
6 reasonably.

7 DR. BANERJEE: But it's certainly within
8 our capabilities today to do that.

9 MEMBER SIEBER: Well, I don't think they
10 have --

11 MR. PRATO: Our goal for this project is
12 not to present a conservative representation. It's to
13 present a realistic representation, as close to
14 realism as we can get it.

15 CHAIRMAN WALLIS: With no topology.

16 MR. PRATO: Excuse me, sir?

17 CHAIRMAN WALLIS: With no topology?

18 MR. PRATO: We have limitations.

19 CHAIRMAN WALLIS: Well, all the plumes I
20 see from my house go down in valleys and things like
21 that and around mountains.

22 MEMBER KRESS: It can be done.

23 MEMBER CORRADINI: I just want to say I'm
24 just kibitzing with Dr. Kress. I think that would be
25 a fairly difficult calculation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: It wouldn't be MACCS
2 anymore.

3 MEMBER CORRADINI: No, it wouldn't.

4 MEMBER KRESS: It would be another code
5 almost.

6 MEMBER CORRADINI: It would be much more
7 three dimensional. It would be a much more complex
8 calculation, particularly, and I'm not exactly sure if
9 it was a hot release, that you would actually care
10 that much about it relative to where it's released in
11 the plume. So there would be --

12 DR. BANERJEE: There are codes which do
13 this for chemical plants.

14 MEMBER SIEBER: Yes.

15 DR. BANERJEE: And they were developed at
16 Lawrence Livermore, for example.

17 MEMBER SIEBER: Particle cell type codes.

18 MEMBER CORRADINI: Right, but the
19 calculations today exist, but the calculations for
20 Chernobyl that I've seen with Lawrence Livermore code
21 is quite, quite substantial.

22 MEMBER KRESS: MACCS has probability of
23 winds blowing in a particular direction and at
24 different speeds, and those probabilities are averages
25 over years times. So sometimes a wind is blowing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 along a valley and sometimes it's not. It's blowing
2 another way, and I don't know how you really -- and
3 the probabilities are developed from measurements,
4 actual measurements at the site right near the plant,
5 anyway.

6 I don't know how you incorporate
7 topography and more details of meandering.

8 MEMBER CORRADINI: What you're thinking of
9 is you'd have to do essentially a realization or a
10 simulation and then impose some sort of arbitrary
11 meteorological conditions that evolve, and that's not
12 how MACCS does it.

13 MEMBER SIEBER: You take the wind droves
14 and you --

15 CHAIRMAN WALLIS: But the Connecticut
16 River Valley, there are drifting plumes up and down
17 the Connecticut River Valley all the time. I see them
18 all the time from my house, and that's where Vermont
19 Yankee is. It seems ridiculous to do some sort of a
20 calculation for Vermont Yankee without considering the
21 fact that there's a major river valley there.

22 MEMBER KRESS: Some of that would have
23 been reflected in the fact that the wind rows will
24 reflect it had been blowing in that direction most of
25 the time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: Well, I hope it is
2 included in that, yeah. I hope it is.

3 MEMBER SIEBER: Well, I think what they're
4 doing here is to try to do a relatively simple
5 calculation using the best codes that they have in
6 house, and this is it.

7 CHAIRMAN WALLIS: But you don't just for
8 engineering purposes do a calculation. You do what's
9 appropriate for the situation.

10 MEMBER SIEBER: Well, yeah, you can get
11 more complex if you've got the money.

12 CHAIRMAN WALLIS: Okay. Well, we should
13 perhaps go on.

14 MEMBER CORRADINI: Yeah, let's just move
15 on. We sort of know where we're at here at this, and
16 we can come to this later.

17 CHAIRMAN WALLIS: Can we move on from that
18 one? Yes, thank you.

19 MR. PRATO: Use of core damage frequency
20 versus release frequency. The Commission directed the
21 staff to examine significant radiological release
22 scenarios having essential likelihood of one in a
23 million or greater per year as an initial focus.

24 With this in mind, full scope Level 2 PRAS
25 are not available for all plants, limiting the staff's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ability to select scenarios based on release
2 frequency. For the purpose of SOAR-CA, the NRC is
3 considering defining release broadly as early or late,
4 large or small, on the basis of this definition: all
5 core damage events will release in the release.

6 That includes core damage events that do
7 not have containment failure. Okay? And the release
8 would be based on normal leakage similar to what
9 happened at TMI.

10 CHAIRMAN WALLIS: I think we understand
11 this. It does not have core damage with no release at
12 all if the containment is intact.

13 MR. PRATO: No, there is release.

14 MEMBER KRESS: No, there's some release.

15 CHAIRMAN WALLIS: Well, maybe there is,
16 but it's --

17 MEMBER CORRADINI: It's small, but it's --

18 CHAIRMAN WALLIS: It's very different,
19 yeah.

20 MEMBER APOSTOLAKIS: But I don't
21 understand this slide though. It says we don't have
22 a Level 2 PRA, which is correct. We don't. We have
23 estimates of the frequency of large early release. So
24 that limits the staff's ability to select scenarios.

25 I thought you didn't know what was being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 released. Do you? Because you don't have a Level 2
2 PRA.

3 MR. PRATO: We don't have a Level 2 PRA.

4 MEMBER APOSTOLAKIS: Right. Therefore, we
5 don't know what?

6 MR. PRATO: We don't have release
7 frequencies.

8 MEMBER APOSTOLAKIS: But it's not only the
9 frequency that matters, is it? It's also what you are
10 releasing, and you don't have that.

11 MR. PRATO: And I'm sure that that was
12 included in the intent.

13 MEMBER APOSTOLAKIS: Okay.

14 MR. PRATO: It's not only the frequency,
15 but also the materials that are being released as
16 well.

17 MEMBER APOSTOLAKIS: The materials. So
18 now the conclusion is that the staff is evaluating
19 scenarios using the core damage frequency. You still
20 don't have, you know, information regarding what has
21 been released.

22 MR. PRATO: That's correct.

23 MEMBER APOSTOLAKIS: So I don't
24 understand. I mean, let's say that the current PRAS
25 give you a Level 2 minus, which is just the frequency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of release. They don't give you the Level 2 result.
2 By backing off that, and you're going back to the core
3 damage frequency, somehow things become better?

4 MR. HUNTER: This is Chris Hunter, Office
5 of Research.

6 No core is going to be used to calculate
7 actually what is released. Basically this slide, what
8 we're just trying to say is in house we don't have
9 Level 2 PRAs for the plants, and this all has to do
10 with the screening threshold on the scenarios that was
11 given in the SRM and the Commission paper, the one in
12 a million per year release frequency, which was given
13 as initial focus.

14 So this slide, basically what we're trying
15 to say is we can't realistically calculate in house
16 release frequencies for scenarios. So we're going to
17 use core damage frequency as a surrogate, and then
18 we'll feed the scenarios into MELCOR, and that will
19 produce actually what is released.

20 MEMBER APOSTOLAKIS: But the sequences
21 that dominate core damage, are they the same as the
22 ones that dominate releases?

23 MR. HUNTER: Basically what we're seeing
24 is if we apply a threshold, we're going to see similar
25 sequences. However, if we applied a release

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequency, those numbers would drop and in some cases
2 we might have very little or even no scenarios based
3 on the plant class. If we use a strict ten E to the
4 minus six release frequency.

5 MEMBER KRESS: The idea is that when you
6 make the calculation of the consequences, which is
7 what you're after, that you want to be sure you
8 capture most of the consequences.

9 Now, what I hear you saying is that we can
10 select sequences that are mostly dominant in producing
11 those consequences just by looking at the core damage
12 frequency and making a cutoff on the core damage
13 frequency will not consider sequences below a certain
14 level.

15 I have a little difficulty with that
16 because the consequences involve both the frequency of
17 core damage and the quantity released and when it's
18 released --

19 MEMBER APOSTOLAKIS: And the containment.

20 MEMBER KRESS: -- and the containment, and
21 I have a little problem thinking that you're going to
22 capture the majority of the consequence, which is what
23 I think you're after, by doing that.

24 Is there some systematic way you can
25 demonstrate that that will do the job for you?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: I think the point is though
2 the Commission give us an initial starting point of
3 ten to the minus six. If we use core damage
4 frequency, we're going to capture everything that has
5 a consequence, a release frequency equal to greater
6 than E to the minus six.

7 MEMBER KRESS: Okay. Using what, ten to
8 the minus six cutoff?

9 MR. PRATO: Yes, for core damage
10 frequency.

11 MEMBER KRESS: That would be responsive to
12 the SRM.

13 MR. PRATO: That's correct.

14 MEMBER KRESS: I'm not sure it's
15 responsive to what you want to accomplish.

16 MEMBER APOSTOLAKIS: No, but this is just
17 a frequency. I mean, so you have a sequence that ends
18 of core damage or you take it all the way to the
19 release?

20 MR. PRATO: We take it all the way through
21 it.

22 MEMBER APOSTOLAKIS: But you say you don't
23 have a full Level 2 PRA.

24 MEMBER KRESS: But they will. They'll use

25 --

1 MR. PRATO: We plug in -- we plug in the
2 scenario into MELCOR, and we end up with a source
3 term.

4 MEMBER CORRADINI: So can I try it a
5 different way?

6 MEMBER KRESS: Yeah.

7 MEMBER CORRADINI: Just so I've got it
8 right and you guys will correct. So let's pick
9 something. Let's take a loss of off-site power, just
10 to pick an old fashioned one.

11 And so now you have a loss of off-site
12 power. You get a frequency of X. It now is of low
13 enough frequency and generating or it's of high enough
14 frequency and generates core damage such that it's in
15 the bin where it's going to be computed.

16 So now you go off and compute and you plug
17 in the conditions from that into the set of boundary
18 and initial conditions for MELCOR, and it goes
19 crunching away and produces a release.

20 You then do a max calculation and you've
21 got a point, and then you do that at 103 locations,
22 and you get 103 points. Have I got it?

23 PARTICIPANT: Right.

24 MEMBER CORRADINI: Okay. So the only
25 other part of this that I want to get clear is so that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 if I have a containment that's robust, you will be
2 erring in the side of conservatism because you'll use
3 the core damage frequency as your filter because a
4 robust containment could have a probability of --

5 MEMBER KRESS: Containment would be a part
6 of the calculation.

7 MEMBER CORRADINI: No, no, but I'm trying
8 to get to the filtering, which is thou shalt not
9 consider sequences below a certain frequency. By
10 using the frequency measure, you're assuming all
11 releases are essentially probability one; that
12 something is going to be released that will be
13 significant enough to compute.

14 Do I have this right?

15 MR. TINKER: That is correct. Now, where
16 that falls short is if you think for a general
17 scenario or sequence that there is a significant
18 fraction of those plant damage states that involve an
19 intact containment.

20 MEMBER CORRADINI: Say it again. I'm
21 sorry.

22 MR. TINKER: If we select based on our
23 screening criteria a general scenario and as part of
24 that general scenario there are a number of cut sets
25 that would involve an intact containment, we would be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 overstating the probability of a release.

2 But we stated --

3 MEMBER CORRADINI: Overstating or
4 understating?

5 MR. TINKER: Overstating. We would be
6 overstating the probability of a release because a
7 probability of a release would be that frequency that
8 we had selected minus those cut sets that involve an
9 intact containment because various containment systems
10 continue to function, presuming you have some ultimate
11 heat sink that you can remove.

12 But in the example you gave, you know,
13 these station blackouts, you're hard-pressed to argue
14 that you won't eventually get containment failure in
15 a station blackout.

16 Now, are there a lot of contributors to
17 core damage that are going to loom large where you
18 have no safety systems, no way of getting water to the
19 reactor vessel, but you were able to somehow get
20 substantial quantities of water and heat removal to
21 the containment?

22 I guess we would want to suggest at the
23 outset, going in at least, that they're not going to
24 be significant contributors overall to the core damage
25 frequency. Much has been done in the last ten to 15

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 years to improve flexibility in plumbing and piping
2 systems such that if pumps are available and pumping
3 capability is available, there are ways to redirect
4 water to the reactor vessel.

5 That has pushed that differential, made
6 that differential smaller than it once was. It will
7 still show up once in a while, and we will look at
8 that, and we expect to get feedback from the industry
9 on those.

10 I can give you other anecdotes like the
11 hardened wet well vent of a Mark I that can prolong
12 survivability of the containment and turn an earlier
13 release to a later release.

14 MEMBER CORRADINI: But what you're going
15 to be missing is early versus late.

16 MR. TINKER: We will consider that. Okay?
17 That kind of differentiation, that kind of distinction
18 we will reflect in these calculations.

19 We expect to take these basic scenarios,
20 ask for industry feedback on SAMGs, EDMGs so that we
21 can capture that in the calculation.

22 MEMBER CORRADINI: So can I go one step --

23 MR. TINKER: So --

24 MEMBER CORRADINI: I'm sorry.

25 MR. TINKER: But don't confuse that with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our screening criteria to identify important
2 scenarios.

3 MEMBER CORRADINI: I understand.

4 CHAIRMAN WALLIS: Well, that's what I'm
5 trying to get at. We should be going beyond this
6 screen. I'm trying to figure out what I'm being told
7 by what's on this screen.

8 Is the only thing you're saying that
9 you're going to use CDF frequency as a cutoff?

10 MEMBER KRESS: Correct.

11 CHAIRMAN WALLIS: I didn't get that
12 message. I never got that message.

13 MR. HUNTER: The main purpose of this
14 slide was in previous ACRS meetings we've said we're
15 using release frequency because we --

16 CHAIRMAN WALLIS: Is evaluating scenario
17 selection using core damage frequency, but then that
18 doesn't tell me what you're doing with it. It's
19 simply a screening for a cutoff value. Is that all it
20 is?

21 MR. HUNTER: Yes.

22 CHAIRMAN WALLIS: Then it would be very
23 nice if that had been said at the beginning.

24 MEMBER APOSTOLAKIS: That's inconsistent
25 with the exchange between Mike and the gentleman here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: No.

2 MEMBER APOSTOLAKIS: The sequence that
3 leads you to core damage, do you add the extra events
4 then in the actual calculation to account for
5 containment functions?

6 MR. HUNTER: Yes.

7 PARTICIPANTS: Yes.

8 MEMBER APOSTOLAKIS: So you do. It's used
9 only to select the frequency.

10 MR. HUNTER: Yes, but like I said, if it
11 is apparent from the description or if in examination
12 of the scenario the possibility of prolonged
13 containment integrity or permanent containment
14 integrity is a potential outcome, it's not for a
15 station blackout, but if the scenario involves
16 multiple other common mode failures, but the
17 containment could be intact, we will examine to see
18 what fraction of those could involve an intact
19 containment and then we would have to adjust that
20 frequency to account for the fact that either SAMGs or
21 EDMGs would enable that containment to remain intact
22 for some substantial period of time.

23 MEMBER APOSTOLAKIS: But if I look at the
24 ultimate result of this study, I will be able to find
25 a sequence that says the initiating event, such-and-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 such a system fails. The core is damaged. Then the
2 containment spray system doesn't work. Something else
3 in the containment doesn't work, and you have these
4 consequences. I will be able to find it.

5 MR. HUNTER: Yes.

6 MEMBER APOSTOLAKIS: Okay.

7 MR. TINKER: Now, let me just say one
8 other thing. We are mindful that there are certain
9 unique scenarios that may create an opportunity for
10 more severe consequences that have a lower frequency,
11 and we especially look at those, and we view the
12 criteria for those in a somewhat different way.

13 MEMBER CORRADINI: they're not in the
14 computation. Is that a fair way of putting it?

15 MR. TINKER: No. I'm just saying that,
16 you know, the IS LOCA scenario.

17 MEMBER CORRADINI: Oh, okay.

18 MR. TINKER: A bypass scenario. Because
19 it is fundamentally different, we do not rigorously
20 apply that ten to the minus --

21 CHAIRMAN WALLIS: You say you look at them
22 in a different way. That means you --

23 MR. TINKER: We look at them in a
24 different way.

25 CHAIRMAN WALLIS: -- took them into

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consideration and you evaluated.

2 MR. TINKER: Now, we don't look at them
3 with no consideration of frequency. For example, if
4 they have an extremely low frequency, there may be
5 grounds for eliminating them because their frequency
6 is incredibly low, and that's because ten to 15 years
7 of risk analysis and examination of these issues has
8 identified the importance, and people have taken
9 measures to cause those scenarios to have low
10 frequency.

11 MEMBER CORRADINI: I had a slightly
12 different question, if I'm allowed. I don't know,
13 unless people still want to beat up Charlie on this
14 one.

15 So now let's say you've picked, back to
16 station blackout. So the CDF gives you the set of
17 initial conditions from the plant state that says,
18 "Okay. Now, go forward and simulate."

19 But then George asked one thing, which is
20 now there are certain systems that as the accident
21 progresses, the systems will function or won't
22 function or partially function.

23 But then there's uncertainties in the
24 physics that the code doesn't know. It just computes.
25 So how are those uncertainties going to be taken care

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of and how are the uncertainties going to be taken
2 care of relative to the initial conditions that if I
3 give a plant state, I might get -- so you know where
4 I'm going with this -- I might have 30 percent molten,
5 50 percent molten, 80 percent molten. It may be a ten
6 centimeter hole, a 20 centimeter hole, a who knows
7 hole.

8 Where does that wiggle room fit into the
9 computation?

10 MR. TINKER: Well, the preliminary plan
11 was not to go down the traditional road of event
12 trees, accident progression event trees to determine
13 multiple end states --

14 MEMBER CORRADINI: Oh, okay.

15 MR. TINKER: -- with branch points and
16 split fractions. The preliminary thinking for this
17 project is that the capability exists with MELCOR to
18 do an ordered sampling or a different sampling scheme,
19 you know, an LHS type, Latin hypercube sampling
20 scheme --

21 PARTICIPANT: A Monte Carlo --

22 MR. TINKER: -- so that we could simply
23 develop -- we could examine the parameters that we
24 think influence phenomenological uncertainty and to a
25 degree stochastic uncertainty, how many times a valve

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 has to lift before it fails open, actuarial data, as
2 well as thermal data, and then for important
3 scenarios, do an integrated uncertainty analysis on
4 phenomenological accident progression and perhaps all
5 the way through the MACCS calculation, as a coupled
6 calculation.

7 Because typically people have done these
8 sorts of things to look at what is principally thermal
9 hydraulic information. How does it affect the timing
10 of vessel failure, hydrogen generation. Those are all
11 interesting parameters, but they're not interesting
12 relative to release. So there may be ways to look at
13 the uncertainty in the release pathway, the extent to
14 which it travels to an aux. building and other
15 buildings.

16 So we want to look at that a little more
17 broadly, and the current thinking is we would examine
18 uncertainties in that fashion.

19 MEMBER APOSTOLAKIS: Is there going to be
20 a time when we will actually see some of these results
21 at the subcommittee level?

22 MR. TINKER: Absolutely.

23 MEMBER APOSTOLAKIS: Okay. Now, I think
24 here is an example of risk communication or
25 miscommunication because I think you should complement

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this last statement there to explain what you mean by
2 scenario. Because I think most of us, I think,
3 thought that a scenario ends at the core damage and
4 you said, no, it doesn't.

5 You're just selecting those, but then
6 you're putting the extra events that are needed to go
7 out.

8 CHAIRMAN WALLIS: Who thought the
9 scenarios ended at core damage?

10 MEMBER APOSTOLAKIS: What?

11 CHAIRMAN WALLIS: I never thought they
12 ended at core --

13 MEMBER APOSTOLAKIS: Some of us I said.

14 CHAIRMAN WALLIS: It's to predict
15 releases, the whole purpose of this exercise.

16 MEMBER APOSTOLAKIS: You were excluded.

17 MEMBER KRESS: Some means more than one.

18 MEMBER APOSTOLAKIS: Yes.

19 MEMBER KRESS: I still have a question
20 about this frequency selection on CDF. Suppose you
21 run your Level I and find two sequences that have five
22 times ten to the minus seven. Will you add those in
23 as one of the --

24 MR. HUNTER: If they're similar. It
25 depends. You know, looking at our Level 1, the SPAR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 models, you're going to have similar type sequences
2 that give you essentially -- you have the same system
3 unavailabilities and similar paths to core damage.

4 MEMBER KRESS: No, I'm assuming they're
5 entirely different sequences, but --

6 MR. HUNTER: If they're that close, we'll
7 consider uncertainty into the fact that they might --

8 MEMBER KRESS: So ten to the minus six is
9 not a firm --

10 MEMBER SIEBER: No.

11 MEMBER KRESS: It's a guidance.

12 MR. HUNTER: Right. That's our initial
13 focus. We're going to factor in uncertainty in those
14 calculations, and like I said, or like Charlie says --
15 excuse me -- we're considering scenarios that might
16 bypass containment or potentially have higher
17 consequences with lower frequencies.

18 Right now we've preliminarily essentially
19 lowered the threshold for those types of sequences by
20 an order of magnitude.

21 MEMBER APOSTOLAKIS: You said that you
22 don't want to go into the accident progression event
23 trees; is that correct?

24 MR. TINKER: Well, I said for addressing
25 accident progression uncertainty to determine the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 multiple end states that we weren't planning on using
2 the accident progression event tree methodology, you
3 know, the logic structure of an event tree. We have
4 a code. We have a mechanistic code that we can use to
5 examine those rather than arbitrarily assigning a
6 split fraction and then arguing about split fractions
7 and the effect of the split fraction.

8 To a large extent, we think we can
9 parameterize that uncertainty.

10 MEMBER APOSTOLAKIS: Why do you say
11 arbitrarily? I mean, why should it be arbitrary? Is
12 that what 1150 did? It was arbitrary?

13 VICE CHAIRMAN SHACK: It relies less on
14 judgment.

15 MEMBER APOSTOLAKIS: Yeah, right.

16 CHAIRMAN WALLIS: I must say through all
17 of this I am praying for a structured presentation so
18 that I can be led through so that I can understand
19 what is going on. With all of this question and
20 answer and dancing around all kinds of stuff, I really
21 need to be led through something here.

22 VICE CHAIRMAN SHACK: This is almost the
23 heart of it though. I mean, to get to this core
24 damage frequency and then to go through the MELCOR
25 calculation to the release is --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: That's trivial?

2 VICE CHAIRMAN SHACK: No, no.

3 CHAIRMAN WALLIS: That's all trivial?

4 VICE CHAIRMAN SHACK: No, no, that's very
5 instructive to understand what they intend to do.

6 DR. BANERJEE: Do you take seismic into
7 account?

8 MR. PRATO: We're going to be talking
9 about that as well, sir. We've got a number of
10 options. We can set those options, and then we're
11 going to tell you what our --

12 CHAIRMAN WALLIS: would it be useful to
13 return to the structured presentation that you
14 prepared? Would that be useful?

15 MR. PRATO: It might be.

16 MEMBER APOSTOLAKIS: Now, Graham, what was
17 the probability that the speaker would say no?

18 (Laughter.)

19 DR. BANERJEE: If he had good judgment.

20 MR. PRATO: Selection of scenarios. This
21 slide shows you the tools that we have available to
22 us. We have 103 up to date SPAR models, and we have
23 13 external events SPAR models that are up to date.
24 Other than that, for seismic, we have 37 IPEEE PRAS
25 that are 1996 vintage old information, as well as 66

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seismic marginal analysis which are 1996 vintage
2 information.

3 For IRIS, we have 23 PRAs and 85 methods,
4 methodology that EPRI developed that also is old
5 information. It dates back to 1996. And that's what
6 we have available to us right now.

7 So let's talk about scenario selection.

8 MEMBER APOSTOLAKIS: So what does this
9 slide mean now?

10 MR. PRATO: Which one?

11 MEMBER APOSTOLAKIS: The one that's on the
12 screen now.

13 MR. HUNTER: The purpose of this slide is
14 just to show you our current in-house limitations of
15 what we have, especially concerning external events.

16 MEMBER APOSTOLAKIS: You don't have NUREG
17 1150?

18 MR. HUNTER: We do, but since we're trying
19 to look at all 103 sites, you're looking at a very
20 limited scope with essentially four plant left.

21 MEMBER APOSTOLAKIS: But are you implying
22 here that margin analysis is useful to you?

23 MR. HUNTER: It's not going to be applying
24 a screening threshold because there's no quantified
25 data. The sole purpose of this slide was just to show

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you what we have currently in house.

2 MR. PRATO: And why our options are what
3 they are and why we're going to proceed in the
4 direction we plan to proceed in right now. Okay?

5 CHAIRMAN WALLIS: So this might constrain
6 what you can do, right?

7 MR. PRATO: Right now that's correct, sir,
8 without additional information.

9 CHAIRMAN WALLIS: Okay.

10 MR. PRATO: We've had a number of options,
11 and when we went through all of those options, we came
12 up really with only two that are viable.

13 CHAIRMAN WALLIS: Where does FAR fit in
14 this?

15 MR. PRATO: Excuse me?

16 CHAIRMAN WALLIS: Does FAR fit into this
17 at all?

18 MR. PRATO: It will, sir.

19 CHAIRMAN WALLIS: It does?

20 MR. PRATO: It will. I'll show you in
21 just a moment.

22 CHAIRMAN WALLIS: Okay.

23 MR. PRATO: Okay? Okay. The two options
24 that we feel are viable is internal event CDF with
25 uncertainty considerations and internal event CDF with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 uncertainty and external event considerations.

2 As we go through the next couple of
3 slides, please keep in mind that the real issues are
4 how do we select the scenarios. For example, do we
5 consider external events?

6 And the other is do we do scenario
7 selection by class of plant or by individual plant,
8 and those are the two questions we have to wrestle
9 through to get through to where we came up with the
10 methodology that right now we're considering to
11 proceed on.

12 MEMBER APOSTOLAKIS: So why isn't there a
13 third bullet, internal events and external events CDF?

14 MR. PRATO: We do have one. Internal
15 events CDF with uncertainty and external event
16 considerations.

17 MEMBER APOSTOLAKIS: Considerations, but
18 why not external events CDF? There are some plants --

19 MR. HUNTER: The reason why we're being a
20 little bit vague about that is because right now we
21 won't have core damage frequencies assigned for all
22 external events, including seismic. So we're going to
23 have to do that in a slightly different manner than
24 our internal event core damage frequency estimates.

25 MEMBER APOSTOLAKIS: But there are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 estimates for some plants of the seismic and fire
2 contribution.

3 MR. HUNTER: Correct. There's essentially
4 33 sites have submitted size of PRAs.

5 VICE CHAIRMAN SHACK: I mean, when you
6 have the seismic PRA in the file you'll use it. For
7 the others you'll have to take an estimate of whether
8 a seismic CDF from this plant is okay to use for the
9 plant that I don't have a seismic on.

10 MR. HUNTER: Correct. What we're
11 wrestling with is can we apply essentially plant class
12 or industry-wide data from the limited sources of
13 quantified data that we have, especially seismic.

14 CHAIRMAN WALLIS: Can I go back to my --

15 MR. PRATO: I remind you that 37 seismic
16 PRAs we have in house is old information. It dates
17 back to 1996 and it really hasn't been updated since.

18 CHAIRMAN WALLIS: Fires are not internal
19 events; is that right?

20 MR. HUNTER: No, fires are considered
21 external events.

22 CHAIRMAN WALLIS: So, again, I don't
23 understand why it's not here.

24 MR. PRATO: It's being considered.

25 CHAIRMAN WALLIS: It's not. It doesn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 say anything about fires on this slide.

2 MEMBER APOSTOLAKIS: External events.

3 MR. PRATO: External events, sir.

4 MEMBER KRESS: The second bullet.

5 CHAIRMAN WALLIS: Oh, it's enclosed in
6 external events.

7 MR. HUNTER: Yes.

8 CHAIRMAN WALLIS: Ah, thank you very much.
9 But are they just considered? You don't look at the
10 FAR CDF?

11 MEMBER APOSTOLAKIS: Well, they said that
12 if they have it they will.

13 VICE CHAIRMAN SHACK: If they have it they
14 do.

15 CHAIRMAN WALLIS: When they have it they
16 did. Well, it may be --

17 MEMBER APOSTOLAKIS: "Consider" is a very
18 broad term.

19 PARTICIPANT: And they'll estimate when
20 they don't.

21 MEMBER SIEBER: But look at this. One
22 hundred and three --

23 CHAIRMAN WALLIS: I know, but I'm just
24 trying to figure out why you have a list of options
25 that doesn't put down fire when fire is often bigger

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 than internal events. That's what puzzled me. Okay.

2 MR. PRATO: I'm going to refer you to
3 these two slides back in your package. I'm going to
4 try to put them up on the screen here.

5 MEMBER APOSTOLAKIS: On the long paper; is
6 that --

7 MR. PRATO: Yes, sir.

8 VICE CHAIRMAN SHACK: And the muddy
9 colors.

10 MEMBER APOSTOLAKIS: Multi-colors.

11 VICE CHAIRMAN SHACK: Muddy colors.

12 DR. BANERJEE: Let me ask you a question
13 which some of us are puzzled by. Why did you pick
14 these classes rather than doing at least initially a
15 pilot project for a specific plant? Was there a
16 reason for that, plants about which you have a lot of
17 information?

18 MR. PRATO: And basically that's what
19 we're going to be doing. We have a reference plant,
20 and then we're going to have a group of -- right now
21 we're thinking about the first initial group of three
22 or four plants from each of the first two, the
23 Westinghouse four-loop and the BWR --

24 DR. BANERJEE: You are going to speak
25 specific plants and do it?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: Yes.

2 CHAIRMAN WALLIS: Could I get this from
3 some member of the public point of view? I mean, you
4 want to consider anything that's important in
5 evaluating the consequences, don't you? And all of
6 these technologies of how you're going to choose this
7 and the next thing, really the only thing that's
8 important is that you have really picked out what
9 matters. That's the only thing that's important to
10 the public.

11 You have analyzed what matters. Is that
12 what you've done here?

13 MR. PRATO: With the limitations that we
14 have.

15 CHAIRMAN WALLIS: Is that what you've done
16 here?

17 MR. PRATO: We do have limitations.

18 CHAIRMAN WALLIS: But, I mean --

19 MR. PRATO: There are code limitations.

20 CHAIRMAN WALLIS: -- all of this business
21 about picking scenarios and stuff doesn't tell the
22 public anything about the fact that you have covered
23 what matters, does it?

24 MEMBER APOSTOLAKIS: Within your
25 limitations, will you be confident that you will have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 captured what matters?

2 MR. PRATO: I believe so, but you have
3 to --

4 CHAIRMAN WALLIS: Is that clear?

5 MR. PRATO: -- go through a process to get
6 to the information in this matter.

7 CHAIRMAN WALLIS: Is that clear?

8 MR. PRATO: Part of that process is
9 determining how we're going to present that
10 information and how we're going to group that
11 information.

12 MELCOR, sometimes their runs are in days.
13 MACCS right now on the average is ten hours per run.

14 CHAIRMAN WALLIS: Well, when you write
15 your final report, I hope you make it clear that this
16 process, which is somewhat confused to me, really does
17 cover what matters.

18 MEMBER APOSTOLAKIS: At least it's
19 conservative.

20 CHAIRMAN WALLIS: Right. Okay.

21 MEMBER APOSTOLAKIS: That's what you mean,
22 that it's sort of a bounding analysis.

23 CHAIRMAN WALLIS: You have actually looked
24 at things and you've covered the things that matter.

25 MR. PRATO: We certainly are, sir.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: You haven't excluded
2 things that are important. That's a very simple thing
3 to say.

4 VICE CHAIRMAN SHACK: To say, yes. To do,
5 that's another.

6 CHAIRMAN WALLIS: You seem to be making
7 excuses for why you can't do the proper job. Maybe I
8 should be quiet, but I'm puzzled by what you're saying
9 here.

10 MEMBER APOSTOLAKIS: So are you going to
11 explain to us this screen?

12 MR. PRATO: Yes, sir. The important piece
13 on this slide, there were two items I think that are
14 important to point out. The one that's to scale down
15 here, that shows what the color coding represents, and
16 then if you look at the note, Note 1 and 2, the
17 relatively high ATWS CDF for Plant 2 and 10 are due to
18 the conservative modeling assumptions contained in
19 these SPAR models. These modeling artifacts are
20 currently being corrected.

21 Okay. So what we're trying to let you
22 know is that we don't believe that these will fall in
23 the red area, but will probably fall in the green or
24 the yellow.

25 And the second item --

1 MR. HUNTER: Bob, if I may interrupt.

2 MR. PRATO: Go ahead.

3 MR. HUNTER: Basically this is the core
4 damage frequencies for the dominant scenarios or maybe
5 even on the initiating event basis. Basically what
6 we're trying to just show you here is just what the
7 SPAR models are generating and show the different
8 scenarios on a per plant basis within the first two
9 plant groups.

10 That's all we're really trying to show and
11 basically what we're saying is the initiating events
12 or scenarios that are colored green are basically
13 you're looking at they're particular less than 5E
14 minus seven or in a lot of cases a lot lower than
15 that.

16 CHAIRMAN WALLIS: So you have picked seven
17 scenarios which matter.

18 MR. HUNTER: No, we're not trying to say
19 we're picking seven scenarios.

20 CHAIRMAN WALLIS: Well, where did these
21 seven scenarios come from? Why did you choose them
22 and how much of the total --

23 MR. HUNTER: That's basically the dominant
24 scenarios that are coming up, the --

25 CHAIRMAN WALLIS: And they cover 95

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent of the likely releases or what?

2 MR. HUNTER: What we're basically trying
3 to show is per scenario, per plant, the core damage
4 frequency estimated per plant, and from that we're
5 trying to essentially get an overall plant group look
6 to see what really the dominant scenario is per the
7 class.

8 CHAIRMAN WALLIS: Now, just talk right
9 into plain English. You've looked at seven possible
10 accidents, which cover --

11 MR. HUNTER: No, we looked at --

12 CHAIRMAN WALLIS: -- a certain percent of
13 the possible hazard to the public.

14 MR. HUNTER: We looked at the entire
15 internal events model. Basically what we're saying is
16 if there's -- there's probably more scenarios than
17 this. Well, there are more scenarios. However, they
18 are a lot lower and pretty much off the map.

19 These are essentially -- they were either
20 a dominant scenario for multiple plants or just one or
21 two plants. All we are trying to show is in some
22 cases you see essentially reds for every plant, and in
23 some cases you see a mixture, and there's plant
24 specific differences for the mixture.

25 CHAIRMAN WALLIS: How much of the picture

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 are you covering doing it this way? Are you omitting
2 50 percent of what matters? Are you omitting five
3 percent of what might matter or what?

4 MR. HUNTER: This is the entire internal
5 events modeling. So, I mean, this includes LOCAs,
6 ATWS, station blackouts.

7 MEMBER APOSTOLAKIS: No, I think the
8 question is you list seven scenarios. If I add the
9 frequencies of these scenarios, is it 95 percent of --

10 MR. HUNTER: It's about 95 percent of the
11 core damage frequency.

12 CHAIRMAN WALLIS: And is that 95 percent
13 of the situations where you actually release
14 significant radioactivity?

15 MR. PRATO: Those that exceed one in a
16 million per year, one to the tenth to the minus sixth.
17 It includes them, yes, sir.

18 MEMBER CORRADINI: I think the way I'd
19 answer it is yes, because if I assumed a probability
20 of containment failure of one, it's still in that less
21 than five percent category. That's the way I'd think
22 of it, Graham, right?

23 CHAIRMAN WALLIS: Right.

24 MEMBER CORRADINI: In other words, let's
25 say there's Scenarios 8 through 30 that they're not --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: I'm just trying to think
2 that if I go back home and try to explain to my
3 colleagues what you've done, how do you put it into
4 plain English, right?

5 MEMBER CORRADINI: Well, let me try
6 because this is my way of trying to understand the
7 answer.

8 The answer is all of the greens are too
9 low. All of the yellows are maybe too low. All of the
10 reds are definitely worrisome, and then if you ask
11 about completeness, Scenarios 8 to upty-ump are there,
12 but their probabilities are so low, and even with a
13 probability of --

14 CHAIRMAN WALLIS: Even if you have a big
15 consequence we don't have to worry about it.

16 MEMBER CORRADINI: Even though the
17 probability of containment failure is one, the
18 probability is still a small percentage.

19 But that hasn't answered the second part
20 of your question, which is even though the probability
21 is less than something or other, it still may have a
22 very large consequence.

23 CHAIRMAN WALLIS: Right.

24 MEMBER CORRADINI: Okay? So there's a
25 tail. There's a tail in this, whatever the --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: So if I'm risk averse in
2 some way, I might want to conserve those a swell.
3 Right. Okay. So I'm very interested --

4 MR. PRATO: And again, we're using the
5 guidance of the Commission to initially start with
6 one --

7 MEMBER APOSTOLAKIS: Right.

8 MR. PRATO: -- to the minus six, and this
9 is more conservative because it is CDF, not release
10 frequency.

11 MEMBER APOSTOLAKIS: Now, the total CDF
12 that is listed on the second column, is this the mean
13 value?

14 MR. HUNTER: It's a point estimate.

15 MEMBER APOSTOLAKIS: Yeah?

16 MR. HUNTER: It's a point estimate.

17 MEMBER APOSTOLAKIS: What does that mean?
18 It's a mean.

19 MR. HUNTER: Something like a mean value.

20 MEMBER APOSTOLAKIS: Something like a
21 mean.

22 MR. HUNTER: It will be very close to the
23 mean.

24 MEMBER APOSTOLAKIS: Okay. Now, the slide
25 before said use SPAR or whatever, factoring in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 uncertainties. So how would you factor in uncertainty
2 here?

3 MR. HUNTER: Basically what we're trying
4 to say here typically you're looking at uncertainty
5 factors of possibly two or three in natural parameter
6 uncertainty if you're calculating it, and how we're
7 saying this is essentially if we factor in
8 uncertainty, we're going to assume that the yellows
9 are essentially reds. That's how we're kind of using
10 it.

11 MEMBER APOSTOLAKIS: I see.

12 MR. HUNTER: So essentially, scenarios
13 that are close to the threshold but are below,
14 factoring in uncertainty, they're going to be
15 essentially we're going to consider them above the
16 threshold.

17 MEMBER APOSTOLAKIS: Okay.

18 MR. PRATO: Let me move on to the BWR
19 slide, please. And I'm going to walk you through.

20 CHAIRMAN WALLIS: So it's very interesting
21 that the failure of the core CP seals LOCA (phonetic)
22 is more significant than all these other LOCAs?

23 MR. PRATO: That's the latest information
24 according to SPAR.

25 MR. HUNTER: Yes, large CP seal LOCAs will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 dominate because it can be generated from blackouts
2 and, you know, losses of service water. You see it in
3 many different --

4 CHAIRMAN WALLIS: All these other LOCAs
5 we've been fascinated with for years are irrelevant?

6 MR. HUNTER: Pretty much.

7 (Laughter.)

8 MR. HUNTER: From a risk standpoint,
9 pretty much.

10 CHAIRMAN WALLIS: That's because you've
11 done such a good job of protecting against them. Is
12 that it?

13 MEMBER APOSTOLAKIS: So let me ask a
14 question. Are you on the BWR?

15 MR. PRATO: Do you want to go back to the
16 page, sir?

17 MEMBER APOSTOLAKIS: Yeah.

18 MR. PRATO: It's just a --

19 MEMBER APOSTOLAKIS: Yeah, it really
20 doesn't matter what. If I look now at Scenario 6 for
21 -- yeah, the Scenario 6 is loss of service water or
22 component cooling water with failure of the reactor
23 coolant pump seal and I have a LOCA.

24 MR. HUNTER: Correct.

25 MEMBER APOSTOLAKIS: Now, this sequence

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 takes me to core damage.

2 MR. HUNTER: yes.

3 MEMBER APOSTOLAKIS: So this will be
4 supplemented by additional event if they're into
5 containment before you do your calculations?

6 MR. HUNTER: Right. We'll have to factor
7 in the -- yes. This won't work because essentially
8 you might be without containment spray, but you'd have
9 coolers and other such mitigation factors.

10 MEMBER APOSTOLAKIS: So this is not
11 verbatim the scenario you're analyzing.

12 MR. HUNTER: No, this is just explaining
13 up until core damage, all of these --

14 MEMBER APOSTOLAKIS: I understand that.
15 So this is not the scenario that will lead to
16 consequences. You will have to consider additional
17 containment functions.

18 MR. HUNTER: Yes.

19 MEMBER APOSTOLAKIS: Yes. Okay. Very
20 good. Now I understand.

21 CHAIRMAN WALLIS: Is surface water a
22 safety significant system?

23 MR. HUNTER: It's a support system that
24 essentially feeds --

25 DR. MAYNARD: Some plants call it surface

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 water. You have to put in a -- there's a service
2 water and an essential service water, and it is that
3 safety related or essential service water part that is
4 important to safety.

5 MEMBER APOSTOLAKIS: Yeah, this is what
6 I'm --

7 CHAIRMAN WALLIS: That's sort of
8 extraordinary though. I mean, here's something like
9 surface water, which is just of the faucet.

10 MEMBER APOSTOLAKIS: This is one of the --

11 CHAIRMAN WALLIS: And there's the seals of
12 a pump. There's the seals of a pump, which is really
13 not a major part of the system at all, and yet you've
14 got more reds in that column than you've got in almost
15 all of the others.

16 MEMBER APOSTOLAKIS: Yeah, that's right.
17 This is one of the great results of the reactor safety
18 study, Graham, the importance of the support systems.

19 CHAIRMAN WALLIS: Yeah, I realize that,
20 but it's so extraordinary that these things turn out
21 to be much more important than all of these safety
22 systems we worried about so much.

23 MEMBER APOSTOLAKIS: Right. This was a
24 great insight, and it has been confirmed many times by
25 industry response from PRAs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: Okay. Let me walk you through
2 a simple process. Okay? Let's take 5(a). Okay.
3 What we're going to do is we're going to have a
4 reference plant, and we're going to run that reference
5 plant through MELCOR and come out with a source term
6 for each one of these dominant scenarios.

7 MEMBER APOSTOLAKIS: Yeah.

8 MR. PRATO: And then we're going to take
9 the input from each plant, each individual plant, put
10 the input into MACCS using the source term from the
11 reference plant, okay, and run our MACCS calculation
12 to determine consequence. Okay? that's our intent.

13 The question is, okay -- I'll go back to
14 the previous question -- when we identify the
15 dominating scenarios, okay, do we run every single
16 plant through that exercise or do we leave out Plant
17 No. 9 because it's green?

18 Now, if you look at the BWR scenarios, if
19 we did it based on individual plant, we would have to
20 leave out Plant 16 because it's all green, and there
21 would be no consequence to report for that site.

22 If we base it on class of plants and run
23 the dominating scenarios for all of those plants
24 within that class of plant, we will have a consequence
25 analysis for each. It will be linked to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequency, but the bottom line is it's the only way
2 we're going to get consequences for all the plants, is
3 if we do it by class of plant.

4 CHAIRMAN WALLIS: What is black on this
5 picture?

6 MR. HUNTER: Black in this picture
7 typically means it's a plant specific scenario.
8 Typically the SPAR models in their benchmarking
9 process have identified a specific action or specific
10 licensee PRA modeling.

11 CHAIRMAN WALLIS: Is black worse than red
12 or better than green?

13 MR. HUNTER: Black is not modeled.

14 MEMBER SIEBER: It doesn't exist.

15 CHAIRMAN WALLIS: It doesn't exist.

16 MR. HUNTER: Yes.

17 CHAIRMAN WALLIS: So it's just a maybe.
18 You don't know. Black is a don't know?

19 MR. HUNTER: It's a no.

20 PARTICIPANT: Black in a non-modeled
21 event.

22 MR. HUNTER: Right. It's a non-modeled
23 event. It's actually an attempt by the SPAR models to
24 match the licensee --

25 CHAIRMAN WALLIS: Does that mean that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they're not important or it just means you can't do
2 them?

3 MR. HUNTER: Not applicable.

4 PARTICIPANTS: Not applicable.

5 MEMBER APOSTOLAKIS: I think it makes
6 sense, what they're doing.

7 VICE CHAIRMAN SHACK: So far so good.

8 MEMBER APOSTOLAKIS: Yeah, I mean, with
9 the last explanation it makes sense to me.

10 MR. PRATO: Okay. Now, the question is --

11 MEMBER APOSTOLAKIS: I mean, I wanted to
12 make a positive statement.

13 (Laughter.)

14 CHAIRMAN WALLIS: You mean having black
15 holes is a positive --

16 MEMBER APOSTOLAKIS: I'm sorry?

17 CHAIRMAN WALLIS: You mean having black
18 holes makes sense? Is that what you mean?

19 MEMBER APOSTOLAKIS: Well, that's what the
20 RAC said.

21 MR. HUNTER: Now, the real question is
22 looking at these, these are internal events only.
23 These are generated just from the spire mouse
24 (phonetic) right now. So how do we integrate the
25 external event, what we have, the information we have?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: And our intent is to do an
2 information to licensees, ask the ones that have
3 updated their information. Based on the information
4 that we get from the updated Level 3 PRAs, we will
5 come up with a mean and apply it to the plants that
6 don't have updated information.

7 MEMBER APOSTOLAKIS: What is the ultimate
8 goal of this? You calculate the consequences and
9 then?

10 MR. PRATO: The ultimate goal is to find
11 a source term for each plant, for each applicable
12 scenario, and run that source term to max for each
13 plant to insure that -- to get a consequence.

14 VICE CHAIRMAN SHACK: But you're still
15 debating over whether to compute source terms for
16 classes of plants and then do the max calc. on an
17 individual basis or to do --

18 MR. PRATO: We have --

19 VICE CHAIRMAN SHACK: -- source terms for
20 each plant.

21 MR. PRATO: We got kind of limited for
22 that. We're limited in the plants we can do because
23 of the time it takes to run them.

24 MR. HUNTER: It complicates things because
25 as we showed, we have limited information on external

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 events for every plant. So it does simplify it if we
2 can look at it on a class-by-class basis for external
3 events.

4 MEMBER APOSTOLAKIS: My question was not
5 answered. So, okay, you calculate the consequences.
6 Now what? Is somebody going to make a decision of
7 some sort or are we just calculating this?

8 MEMBER CORRADINI: This is essentially --
9 I thought they told us whenever it was, in September -
10 -

11 MEMBER APOSTOLAKIS: Yeah.

12 MEMBER CORRADINI: -- it was essentially
13 a replicate of the siting study where the siting study
14 showed.

15 MEMBER APOSTOLAKIS: right.

16 MEMBER CORRADINI: So is that not the
17 point of all of this?

18 MR. PRATO: It is, but we're considering
19 other things.

20 MEMBER APOSTOLAKIS: Like?

21 MEMBER CORRADINI: Like, yeah.

22 MR. PRATO: First of all, I believe the
23 siting study only used LNT. We're going to include
24 other thresholds.

25 MEMBER APOSTOLAKIS: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. PRATO: And we're going to get to that
2 in just a minute. And then we're considering other
3 ways of presenting the information. We don't want a
4 range of consequences. We would like to try to
5 combine that and come up with a single consequence,
6 and we have been directed by the steering committee to
7 try and figure out a way to do that, and we're not
8 ready to present anything on that approach.

9 MEMBER APOSTOLAKIS: No, but my question
10 is -- maybe you mentioned it at the beginning. I
11 wasn't here. After the study is completed --

12 MR. PRATO: Yes, sir.

13 MEMBER APOSTOLAKIS: -- who is going to us
14 it for what purpose?

15 MR. PRATO: We had a variety of purposes.
16 I'm sorry I didn't write them down, but the bottom
17 line, this -- Jason, do you remember the list of
18 purposes and potential applications?

19 MR. TINKER: Well, the original SECY has
20 a section that talks about potential regulatory uses.

21 MEMBER APOSTOLAKIS: Okay. What?

22 MR. TINKER: Well, other than, you know,
23 the important aspect of providing an updated picture
24 of the consequences, it is believed that this kind of
25 work could provide new insights into those aspects of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 behavior that dominate consequences by inference, by
2 inference risk, although this is not strictly speaking
3 a risk study.

4 MEMBER APOSTOLAKIS: Right.

5 MR. TINKER: So to the extent we want to
6 improve our understanding of what now dominates the
7 consequences, it provides the technical basis for
8 prioritization of future activities to examine where
9 you might want to achieve improvements.

10 MEMBER APOSTOLAKIS: Improvements --

11 MR. TINKER: Improvements in both
12 performance and understanding.

13 MEMBER APOSTOLAKIS: But, for example,
14 would you say that maybe the SAMGs need some changes
15 or is that out of the question?

16 Would the emergency planning need some?

17 MR. TINKER: If practical and feasible
18 changes were identified that could alter the path of
19 some of these calculations, if these analyses point to
20 such opportunities, then they would be a subject for
21 more discussion, but you know --

22 MEMBER APOSTOLAKIS: But there is no
23 specific goal at this time. It's just do it, gain the
24 inside, see what you have.

25 MR. TINKER: Well, we think -- we think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we're providing a realistic picture of the
2 consequences from the important scenarios is an
3 important outcome in itself. But we would also see
4 this as an opportunity to improve our risk
5 communication with the public, with all our
6 stakeholders, and like I said, to the extent it
7 provides a vehicle for examining where additional
8 improvements in analysis could take place, while this
9 is state of the art, it will still probably identify
10 areas where some improvement may be warranted to
11 further understand.

12 CHAIRMAN WALLIS: But, Charlie, for
13 instance --

14 MR. TINKER: You're going to that state at
15 the end of all of these calculations. We would expect
16 that to be at the end of this set of calculations.

17 CHAIRMAN WALLIS: Well, Charlie, for
18 instance, if you look at Scenario 4, which has the
19 most of the reds, you might say, well, maybe something
20 is to be done about RHR reliability.

21 MR. TINKER: Yes, but I'll caution you.
22 The fact that it shows up high in CDF does not
23 necessarily mean it's going to have significant --

24 CHAIRMAN WALLIS: But that's what's
25 confusing about using CDF all the time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TINKER: It is still the screen.
2 Okay? But we will do the consequence calculations,
3 and if the consequence calculations for particular
4 scenarios reveal a strong uncertainty influence or
5 where there may be, you know, something that becomes
6 apparently from examination of the SAMGs or EDMGs,
7 they would be the subject for any further discussion.

8 But myself personally, a personal view, it
9 provides an excellent vehicle for examining the EDMGs,
10 extensive damage mitigation guidelines.

11 MEMBER APOSTOLAKIS: Right. Okay.

12 MR. TINKER: New measures that have been
13 put in place at the plants in the last several years.
14 This provides a vehicle for systematic evaluation of
15 those through the important scenarios.

16 MEMBER APOSTOLAKIS: So you may even relax
17 some of those?

18 MR. TINKER: I didn't say that.

19 MEMBER APOSTOLAKIS: I know you didn't.
20 That's why I'm asking.

21 (Laughter.)

22 MR. TINKER: No, no.

23 VICE CHAIRMAN SHACK: Effectiveness,
24 George.

25 MR. TINKER: No, but I mean, those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 additional measures -- and they are important measures
2 -- were done under a different umbrella and were not
3 done looking through the full gamut of scenarios, and
4 this is a vehicle for doing that, and frankly, it's
5 the vehicle by which we can assess the true magnitude
6 of the benefit of those measures.

7 We believe those measures have benefit,
8 but we do not know the full extent. They may prove to
9 be much more beneficial than we realize at this point.

10 VICE CHAIRMAN SHACK: How did the SAMGs
11 work into this now? You're getting to a core damage
12 state and then MELCOR takes over.

13 MR. TINKER: Well, this tells us our going
14 in plant damage state. That plant damage state will
15 be modified by SAMGs or EDMGs. Operators may bring in
16 other systems. Operators may use cross-connects.

17 VICE CHAIRMAN SHACK: So you'll end up
18 doing multiple calculations for these things then.

19 MR. TINKER: There could very well be
20 iterations on some of these.

21 MEMBER APOSTOLAKIS: And I suspect what's
22 going to happen is that ten years from now after this
23 has been completed, where we have a similar project,
24 calculate the actual risk and then Tom Kress will be
25 so happy, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: If I'm still alive.

2 PARTICIPANT: He'll still be alive.

3 VICE CHAIRMAN SHACK: Maybe we'd better
4 move on.

5 MEMBER APOSTOLAKIS: But, Graham, these
6 reds have been known all along and the decisions have
7 been made not to do anything about it. So that's not
8 the issue here. This is just a selection of the
9 scenarios because look at the actual. I mean, at some
10 point you have to say, you know, that risk is low
11 enough.

12 CHAIRMAN WALLIS: But it's going to look
13 rather strange to the public, the things you --

14 MEMBER APOSTOLAKIS: Well, the public has
15 to learn a little bit, too.

16 CHAIRMAN WALLIS: More loss of water from
17 the faucet essentially.

18 (Laughter.)

19 MEMBER APOSTOLAKIS: Use different shades
20 of green then. What can I tell you?

21 MR. PRATO: Okay. So that was the first
22 option. Our two options were to use just uncertainty
23 or to use external events, and we went through the
24 external events. We plan to incorporate external
25 events. We're going to ask for updated --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 VICE CHAIRMAN SHACK: Assume that first
2 option was a strawman, right?

3 MR. HUNTER: Yes, yes. We're going to be
4 factoring uncertainty, and we're going to factor in
5 external events. We just don't know to the extent of
6 how we are going to factor in external events yet.

7 MR. PRATO: And our current plan is to
8 request information from the licensee. Those that
9 have updated information will incorporate it
10 appropriately, and those that don't will come up with
11 a mean and include those in the blanks that we have
12 for external events.

13 We believe that this is our best approach.
14 It's a relatively simple approach for plants with no
15 external event PRAs. There's just no other way we can
16 consider external events if we don't have an alternate
17 means of including it for those that have not updated
18 the PRA.

19 We don't have a feel yet for how many have
20 or have not updated it, but we'll provide you with
21 that information as we go along.

22 CHAIRMAN WALLIS: Now, you didn't have
23 anything on your big charts with reds and greens about
24 fires.

25 MR. PRATO: What was that?

1 CHAIRMAN WALLIS: In your reds and greens,
2 you didn't have the external events include fires, and
3 we know that fire PRAs tend to give similar CDFs to
4 these internal events PRAs, right?

5 MR. HUNTER: Correct.

6 CHAIRMAN WALLIS: So if you're using CDF
7 as a screen, you ought to consider --

8 MR. HUNTER: And we are.

9 MR. PRATO: Right now we just don't have
10 the external event information, and we wanted to
11 present you with a basic approach with what
12 information we had.

13 MR. HUNTER: We'll have a similar chart.

14 MR. PRATO: This will be updated. That
15 drawing will be updated.

16 CHAIRMAN WALLIS: You'll have a similar
17 chart for fires?

18 MR. PRATO: No, we'll have --

19 CHAIRMAN WALLIS: The various scenarios
20 produced by fires?

21 MR. HUNTER: What we'll have is we'll have
22 preliminary looks. Fires are going to give you very
23 similar scenarios to what we already have. They're
24 going to -- the dominant fire scenarios are typically
25 going to give a similar trend as to what we're seeing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in internal events.

2 In regards to seismic, because of
3 essentially the 33 plants that essentially had IPEEE
4 center PRA submittals, we're going to have to look at
5 those a little bit differently.

6 CHAIRMAN WALLIS: You're going to take
7 these fire scenarios and put them through MELCOR and
8 all of that kind of stuff?

9 MR. HUNTER: It might be a sensitivity
10 case. If it turns out to be where the MELCOR run for
11 those type of scenarios are different than the
12 internal event scenarios, we'll look at what's
13 dominating. You know, if we have essentially low E to
14 the minus six but the external event scenario is
15 actually going to have a higher core damage frequency,
16 but also be more limiting in the cases of recovery and
17 equipment available. So we'll take in those factors.

18 CHAIRMAN WALLIS: Can we move on?

19 MR. PRATO: Yes, sir.

20 That brings us to LNT and thresholds. The
21 Commission directed the staff not to solely rely on
22 conservative collective dose models. They told us to
23 use a range. In our plan to implement the guidance,
24 the direction from the Commission, we identified a
25 range of zero to five rem and the Commission approved

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that plan, in the SRM.

2 MEMBER KRESS: Question. When you make
3 the max calculations for the cancers, you stop at some
4 distance?

5 MR. PRATO: When you use LNT, it goes all
6 the way out to 1,000 months.

7 Okay. Go ahead.

8 MR. SULLIVAN: Randy Sullivan.

9 Distance is an input parameter. It's a
10 decision we have to make, what distance to choose.

11 MEMBER KRESS: Isn't that equivalent to
12 using a threshold?

13 MR. SULLIVAN: It is, but really we want
14 to address the threshold issue as the threshold issue
15 and the distance issue as the distance issue.

16 MEMBER KRESS: So you can make the
17 threshold determine your distance. Is that the way
18 you plan on doing it?

19 MR. SULLIVAN: No. I mean --

20 CHAIRMAN WALLIS: The threshold is zero.
21 It's a pretty long distance.

22 MR. HUNTER: But they don't have to be
23 internally consistent though.

24 MR. SULLIVAN: There's several reasons to
25 choose a distance, the accuracy of models, what you're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 attempting to do, et cetera, et cetera. One byproduct
2 of choosing a distance is that you reduce the number
3 of tiny doses that are given to a lot of people, but
4 really we're attempting to address the threshold issue
5 as the threshold issue and the distance issue as the
6 distance issue rather than use one as a surrogate for
7 the other.

8 I don't know that we're prepared to go all
9 the way into that, but we can discuss it as much as --

10 MEMBER KRESS: I think it's a good idea to
11 separate them. We use the same set of -- use a set of
12 thresholds for the same distance. It gives you an
13 idea of what the threshold means.

14 MR. SULLIVAN: That's true.

15 MEMBER CORRADINI: So if I could just get
16 to say it differently. So these will be
17 sensitivities. The distance will be a sensitivity and
18 the threshold will be a sensitivity on certain select
19 cases.

20 MR. SULLIVAN: That's not quite our
21 intent. We will choose a distance. It will be based
22 on judgment and arguments, and we haven't done that
23 yet, but we're on it, and we're --

24 CHAIRMAN WALLIS: What sort of distances
25 are you likely to pick?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SULLIVAN: Fifty-two, fifty or 1,000.

2 CHAIRMAN WALLIS: Miles?

3 MR. SULLIVAN: Right.

4 MEMBER KRESS: Yeah, those are traditional
5 numbers.

6 CHAIRMAN WALLIS: Thank you.

7 MR. SULLIVAN: And we're struggling with
8 that. We don't know the answer right now.

9 CHAIRMAN WALLIS: Now, in terms of this
10 threshold, it's not just the threshold you need, but
11 where do you go when you start up from the threshold?
12 How do you leave the threshold and how do you get onto
13 some curve which you believe?

14 MR. SULLIVAN: I'm prepared to discuss
15 threshold a bit if you'd care to.

16 CHAIRMAN WALLIS: I'm just curious about
17 how you get from the threshold to --

18 MR. SULLIVAN: I didn't understand your
19 question.

20 CHAIRMAN WALLIS: Well, first of all, it
21 tells you when you start, right?

22 MR. SULLIVAN: No.

23 CHAIRMAN WALLIS: Where do you go from
24 there?

25 MR. SULLIVAN: No. It's two separate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 subjects. Distance is a subject. When we --

2 CHAIRMAN WALLIS: No, I'm talking about
3 threshold. Distance is irrelevant.

4 MR. SULLIVAN: Fine. Right now the linear
5 no threshold model is used internationally as I'm sure
6 you know.

7 CHAIRMAN WALLIS: Goes down to the origin.
8 It's a straight line.

9 MR. SULLIVAN: Exactly.

10 MEMBER APOSTOLAKIS: A straight line to
11 the origin.

12 CHAIRMAN WALLIS: And there's no
13 threshold. You have to figure out how you get up to
14 the straight line from the threshold.

15 MR. SULLIVAN: Oh, well, that's what we're
16 going to have to figure out.

17 CHAIRMAN WALLIS: So vertically up to the
18 threshold from the --

19 MR. SULLIVAN: We're going to use zero
20 threshold and five rem.

21 CHAIRMAN WALLIS: And then you go
22 vertically up to the straight line?

23 MR. SULLIVAN: No, and then something in
24 between.

25 CHAIRMAN WALLIS: Oh, so you have a curve

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of some sort.

2 MR. SULLIVAN: But we're not going to
3 present a curve. The idea on the table, we're
4 considering methods. It would be -- one method is to
5 publish a range. One method is to pick a threshold.
6 Right now what we're discussing is perhaps an expert
7 elicitation to do something in between, but the staff
8 is struggling with that. That's not decided.

9 Did that answer your question at all?

10 MEMBER APOSTOLAKIS: Is there any evidence
11 that would say that, say, five rem is a likely
12 threshold? I mean, you're treating it completely as
13 a sensitivity parameter.

14 MR. SULLIVAN: It's almost a matter of
15 conviction. The major international groups have
16 decided that there is not enough evidence to do away
17 with linear, no threshold. However, there are many
18 people and societies, the Health Physics Society, in
19 America, the French that feel that some threshold is
20 appropriate.

21 MEMBER APOSTOLAKIS: But it's not
22 specified.

23 MR. SULLIVAN: But the evidence for
24 regulatory purposes, linear no threshold is used. You
25 know, is this a regulatory purposes document? You

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know, we're going to have to struggle with what to
2 use, and we've come up with some preliminary ideas
3 yesterday.

4 CHAIRMAN WALLIS: Isn't your purpose for
5 public consumption, to give them something believable?

6 MR. SULLIVAN: Yes, it is.

7 CHAIRMAN WALLIS: Not just to pick things?

8 MR. SULLIVAN: Well, you can't just pick
9 things. That's exactly right. That's why we're
10 struggling.

11 MEMBER APOSTOLAKIS: But if they show, for
12 example, that makes a big difference in the
13 consequences whether the threshold is one or five.
14 That's a useful insight because they're also saying we
15 don't know which one it is.

16 CHAIRMAN WALLIS: But then what do you
17 tell the public? Do you say it's more likely to --

18 MEMBER APOSTOLAKIS: You do exactly that.

19 MR. PRATO: That's what we're struggling
20 with. How do you present this information?

21 MR. SULLIVAN: What we're going to tell
22 the public is the NRC's judgment of what the likely
23 consequences are from these kinds of accidents.
24 That's what the document is going to do.

25 Now, we're going to have to back that up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: It could make a big
2 difference. It could make a very big difference if
3 it's zero or five.

4 MR. SULLIVAN: Yes, it does.

5 CHAIRMAN WALLIS: Close to a big
6 population center or --

7 MR. SULLIVAN: Let me give you a data
8 point. The Health Physics Society says you should
9 pick five.

10 MEMBER APOSTOLAKIS: Wow.

11 MR. SULLIVAN: All right? Now, the
12 international bodies --

13 CHAIRMAN WALLIS: I'll bet you can find
14 someone who says you should pick zero.

15 MR. SULLIVAN: You can find plenty of
16 people who say you should pick zero, but usually
17 they're from ICRP or NCRP as opposed to somebody who
18 actually does this for a living, but nevertheless --

19 MEMBER APOSTOLAKIS: You mean these are
20 part-timers?

21 (Laughter.)

22 PARTICIPANT: Is that on the public
23 record?

24 MR. SULLIVAN: Let's just say -- let's
25 just say that that's one --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Like an advisory
2 committee, right?

3 (Laughter.)

4 MR. SULLIVAN: That's one man's opinion.

5 PARTICIPANT: Semi-useless.

6 MR. SULLIVAN: Well, actually we've
7 thought of going to the advisory committee.

8 MEMBER KRESS: I think it would be a very
9 useful exercise to do what you're saying just to see
10 what effect it has.

11 MEMBER APOSTOLAKIS: Sure, sure.

12 MEMBER CORRADINI: So if I can go back to
13 distance, since we're doing things that are useful,
14 I'm very curious. So have you talked out what are the
15 benefits from a small distance, middle distance, and
16 clearly a large distance? Because it seems to me if
17 you're going to do this sensitivity --

18 MEMBER KRESS: That could be another one.

19 MEMBER CORRADINI: WITNESS VAIL: -- that
20 would be a sensitivity. I would think you would be
21 open for criticism if you did not do.

22 MR. SULLIVAN: I think that's exactly
23 right. You know, there are staff members who believe
24 1,000 is correct. There are those who believe 50 are
25 correct. We're going to --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER KRESS: Or parameterize that, and
2 you'll get different results depending on --

3 VICE CHAIRMAN SHACK: It's only money and
4 time.

5 MEMBER KRESS: -- specific sites.

6 MEMBER CORRADINI: Well, that's what I
7 guess I wanted to ask, since Dr. Shack threw that one
8 in. When you do a MACCS calculation, since I'm not
9 familiar with that part of the calculation, and it is
10 not time dependent but really an average of how it
11 flows, that's a fairly quick calculation or am I wrong
12 about that?

13 MR. SULLIVAN: When you don't use a
14 threshold, it's a fairly quick calculation. If you go
15 to a threshold that really draws the run time out.

16 MEMBER CORRADINI: Does it draw it out as
17 a function of the distance you consider? I would
18 think no.

19 MR. SULLIVAN: No, I think distance is a
20 parameter, yeah, but I mean the more cells we have to
21 calculate a result in --

22 DR. BANERJEE: But for your 1,000 mile
23 calculation, if it's sufficiently nodalized, surely
24 you get your 50 and your 500 or 300 as part of it.

25 MR. SULLIVAN: The issue is whether you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 really think those are realistic results, and--

2 MEMBER KRESS: A lot depends on wind rows
3 and the population distribution as to whether or not
4 you might end up going to the desert and not hit
5 anybody.

6 CHAIRMAN WALLIS: You should calculate it
7 out until it stops being important.

8 DR. BANERJEE: The time and variant
9 calculation.

10 MEMBER KRESS: Oh, yeah, definitely.

11 DR. BANERJEE: And you pick your wind
12 direction or whatever based on the class of weather.

13 MEMBER KRESS: But you also input your
14 population distributions.

15 MR. SULLIVAN: If you go out to 1,000
16 miles --

17 DR. BANERJEE: But that's not changing.
18 I mean it's there.

19 MEMBER KRESS: No, that's not changing.

20 DR. BANERJEE: So all I'm saying is as
21 part of your 1,000 mile calculation, if your
22 population is static, if your wind direction doesn't
23 change and your 1,000 mile calculation, it's not a
24 meandering plume --

25 MEMBER KRESS: Yeah, that's right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. BANERJEE: -- then everything else is
2 a subset of that.

3 MR. SULLIVAN: Yeah, exactly.

4 CHAIRMAN WALLIS: But you can't just pick
5 numbers of miles. I mean, if you're still killing all
6 of the people at 1,000 miles, you should go to 2,000
7 miles. You go on until you stop killing people.

8 MR. SULLIVAN: We don't believe you're
9 killing people at 1,000 miles is the argument that
10 we're going through.

11 CHAIRMAN WALLIS: But you should stop when
12 you stop having any consequences, but you go as far as
13 you need to go in order to predict a realistic
14 consequence.

15 MEMBER KRESS: And that will be site
16 dependent.

17 DR. BANERJEE: That will depend on whether
18 you have a threshold or not, right?

19 MEMBER CORRADINI: So this leads me to the
20 obvious question, which I'm sure you do this because
21 you don't really want to spend a lot of money for the
22 sake of it. Somebody can come up with a hand
23 calculation. It was in 10 CFR 100 in the '50s, that
24 you could do it forever and it's a closed form
25 solution relative to a dispersion calculation. Have

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you done these hand calculations to know the
2 sensitivity of the number you'd expect?

3 TID 14844 tells you how to do it with a
4 closed form formula. Has anybody in the staff started
5 doing those calculations to, shall I say, bound a
6 computer calculation?

7 MR. SULLIVAN: Heavens, no. We don't even
8 have a scenario to get a source term to get to MACCS.
9 You know, it's a --

10 MEMBER CORRADINI: No, and that's what I -
11 - you misunderstand my point. My point is what Sanjoy
12 is getting at or what Graham is getting at is there
13 are cruder calculational methods that would give you
14 some insight as to whether 50, 250 or 1,000 is
15 reasonable.

16 DR. BANERJEE: It's hard to do with
17 multiple radionuclides. I mean, if you had a very
18 simple release scenario like --

19 MEMBER CORRADINI: If you were able to
20 build 100 plants with 10 CFR 100 and 14844, it would
21 seem to me you could do a hand calculation to see what
22 the global parameters might be. I'm curious if you
23 did that.

24 DR. BANERJEE: If you take a very simple
25 decay law or whatever, you know, you can do much of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this by hand.

2 MEMBER APOSTOLAKIS: There was a question
3 earlier that when you say a threshold of five, that
4 means below five is zero?

5 MR. SULLIVAN: Yes.

6 MEMBER APOSTOLAKIS: Okay.

7 CHAIRMAN WALLIS: Well, tell me about
8 plumes. Now, at Chernobyl there was a big plume and
9 very energetic and it blew over France, and according
10 to the French for a long time nothing ever happened in
11 france, but then after going off to France, it landed
12 in Scotland and it had tremendous effects in Scotland.

13 So now, how does your miles and diffusion
14 account for the fact that this thing skipped France
15 and landed in Scotland?

16 MEMBER CORRADINI: This is not Chernobyl.
17 You don't really want to --

18 CHAIRMAN WALLIS: It's not Chernobyl?
19 You're going to allow Chernobyl to happen?

20 MS. MITCHELL: The energetic release,
21 there isn't a code -- Jocelyn Mitchell from the Office
22 of Research -- there isn't a code that will model the
23 explosive release that releases it into --

24 CHAIRMAN WALLIS: Oh, so this is something
25 you're not going to model at all.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SULLIVAN: It can't happen.

2 MS. MITCHELL: Right. We don't have the
3 reactivity --

4 CHAIRMAN WALLIS: It won't happen?

5 MS. MITCHELL: -- initiated accidents,
6 have been designed out --

7 CHAIRMAN WALLIS: But it has happened.

8 MS. MITCHELL: -- of U.S. plants.

9 CHAIRMAN WALLIS: Oh.

10 MR. SULLIVAN: You need some, you know,
11 charcoal to help.

12 DR. BANERJEE: But people have tried to
13 model Chernobyl. So presumably it can be done.

14 MEMBER KRESS: Sure.

15 CHAIRMAN WALLIS: But you have to know
16 something about the weather.

17 MS. MITCHELL: People usually don't model
18 the first day's very explosive release, and there were
19 probably about four major wind shifts that occurred
20 during the next eight days, and they take the measured
21 values of Cesium-137, and they back calculate to
22 determine what the source term was on that day.

23 So the fact that you can now take the
24 source term and use the met. models and find that you
25 can get the answer to me seems incestuous.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. BANERJEE: Well, it depends how far
2 away and what you did, but this is sort of traditional
3 also with release models for chemical plants where
4 they actually take the data and the met. data, and
5 then they back out what actually happened and then
6 tried to predict in real time where the plume is
7 going.

8 These are called "trace." No relation to
9 the TRACE we talk about, but they try to do that.

10 MR. SULLIVAN: If we're going to discuss
11 Chernobyl, I'd like to give you one data point. We're
12 20 years on from Chernobyl, and according to linear no
13 threshold, there should have been a blip in the
14 leukemia rate in Europe and there is not. All right?

15 So you mentioned consequences from
16 Chernobyl. Of course there were grave consequences,
17 but not latent cancer fatalities, as were expected by
18 the LNT theory.

19 VICE CHAIRMAN SHACK: Maybe we had better
20 move on to the rest of the presentation.

21 CHAIRMAN WALLIS: Well, this is the reason
22 for bringing up Chernobyl. Is it something which
23 actually happened? And you seem to be in a world
24 where you're just creating models of something and
25 there must be some connection between the two.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: They have a different
2 design of reactor.

3 (Simultaneous conversations.)

4 MEMBER KRESS: -- gave you the right
5 answer. Chernobyl is not one of the scenarios for a
6 U.S. plant. It doesn't show up.

7 MEMBER APOSTOLAKIS: So what is the next
8 subject?

9 MEMBER KRESS: Why bother with it?
10 There's no U.S. plants --

11 DR. BANERJEE: Well, what most of these
12 things show is that human error is the main
13 contributor to --

14 MEMBER KRESS: You can't even get a
15 Chernobyl with human error with a U.S. plant.

16 THE REPORTER: One at a time.

17 MEMBER KRESS: One at a time.

18 DR. BANERJEE: Chernobyl and these other
19 accidents, sure, is that most of the probability comes
20 from human error.

21 MEMBER KRESS: Sure. That's a lesson
22 learned.

23 DR. BANERJEE: Yes.

24 MEMBER KRESS: From Chernobyl, sure. But
25 supposedly we've accounted for that in the PRA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. BANERJEE: Are we accounting for human
2 error in the PRA?

3 MEMBER KRESS: yes.

4 CHAIRMAN WALLIS: The PRA.

5 DR. BANERJEE: You were telling us that
6 all of these different models for human error exist
7 and none of them agree with each other and --

8 MEMBER APOSTOLAKIS: Accounting does not
9 make me aware.

10 DR. BANERJEE: All right?

11 MEMBER APOSTOLAKIS: Accounting is like
12 considering.

13 (Laughter.)

14 VICE CHAIRMAN SHACK: Hopefully it's not
15 quite the same.

16 MR. SULLIVAN: I understand that the
17 committee was interested in how emergency response
18 would be modeled in the SOAR-CA project. We have been
19 working on this since the inception of the project.
20 We have an outline that I hope I can communicate
21 clearly as to how we're going to model emergency
22 preparedness.

23 But let me say at the outset we've got
24 substantial resources, but not infinite. We've
25 attempted to set aside enough time and money to do a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 decent evolutionary job of modeling emergency
2 preparedness. It will not be an exact model for, you
3 know, 65 sites, 62 sites. We just cannot do that.

4 But we can certainly make several steps
5 forward in how we model emergency preparedness. We
6 think this substantially improves the realism. We did
7 this during the security assessments and some of the
8 other classified work to more realistically model the
9 movement of people and the response of off-site
10 response agencies to protect the public.

11 All nuclear plants have EP programs.
12 they're inspected. They're drilled.

13 I have some assumptions. They're pretty
14 basic assumptions. Officials will implement the plan.
15 You mentioned Katrina. That is perhaps an example of
16 when the plans weren't implemented. We expect these
17 plans to be implemented. They're drilled several
18 times a year. They're inspected very other year. We
19 believe these are real programs.

20 CHAIRMAN WALLIS: they don't go out to
21 1,000 miles.

22 MR. SULLIVAN: I'm sorry?

23 CHAIRMAN WALLIS: They don't go out to
24 1,000 miles.

25 MR. SULLIVAN: No, we certainly don't. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 go out to ten, and we expect ad hoc actions beyond ten
2 should they be necessary. We believe that the public
3 will largely obey what they're told. That's borne out
4 by the report that I cite at the bottom there.

5 Emergency workers will do their job.
6 That's borne out both by the report and a series of
7 recent focus groups that we conducted across five
8 sites.

9 DR. BANERJEE: But ten must depend on
10 topography and things like that, right?

11 MR. SULLIVAN: It depends on geography, on
12 geopolitical boundaries. For instance, Duane Arnold
13 is 16 miles due to Cedar Rapids being included.
14 Vermont Yankee is nine miles in one direction due to
15 an unpopulated forested area.

16 It's really a state decision. NRC would
17 have accepted, you know, whatever FEMA approved as
18 long as it compared with --

19 DR. BANERJEE: How far is Brattleboro from
20 Vermont Yankee?

21 MR. SULLIVAN: Sorry. Can't tell you.
22 It's --

23 DR. BANERJEE: We took some heat there.
24 That's why I'm, asking you.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SULLIVAN: Yeah, I understand that was
2 -- you had that memorized. Is that what you're
3 saying?

4 Is Brattleboro in the EPZ? I'm not sure.

5 DR. BANERJEE: I don't know, but --

6 MR. SULLIVAN: I was thinking maybe it
7 wasn't.

8 PARTICIPANT: It's outside the EPZ.

9 CHAIRMAN WALLIS: Fifteen miles or
10 something? It's not far away.

11 MEMBER SIEBER: Yeah, it's not. It's
12 outside.

13 MR. SULLIVAN: Okay. One of the major
14 differences between what we're going to do in CIRC and
15 what we've done in the past is we're going to attempt
16 to model implementing the plan as we go along.

17 The first start of that is I need
18 scenarios. When I can see the scenarios, I will be
19 able to, with the help of my peers, declare the
20 emergencies as those EALs are reached. So there will
21 be an alert. There will be a side area emergency
22 before the general emergency for the vast -- well, for
23 all of these scenarios that we're considering. I
24 mean, I haven't seen the final scenario. So I'm
25 projecting from what I've seen so far.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 You see, there's precautionary actions
2 taken at the alert and the site area emergency.
3 Sirens are sounded. Schools are closed. Certain
4 special needs groups are prepared for evacuation or
5 maybe even evacuated. Parks and Lakes are cleared.

6 We're going to model all of that this time
7 because that's a large percentage of the population.

8 CHAIRMAN WALLIS: You assume they all
9 work. You don't do a PRA which says what's the
10 probability that the sirens won't work and the
11 probability that things won't work. You don't do that
12 at all, do you?

13 MR. SULLIVAN: No.

14 CHAIRMAN WALLIS: Because there has been
15 problems. I think Vermont Yankee was running samples
16 when the sirens were not operational, and --

17 MR. SULLIVAN: The sirens at Vermont
18 Yankee are more than 96 percent operational.

19 CHAIRMAN WALLIS: They are now. They are
20 now.

21 MR. SULLIVAN: They have been.

22 CHAIRMAN WALLIS: But there was a period
23 when they had a problem with them.

24 MEMBER APOSTOLAKIS: All of them? All of
25 them were inoperable?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: I don't know whether it
2 was all of them. There was --

3 MR. SULLIVAN: Sirens fail.

4 MEMBER APOSTOLAKIS: Clearly one or two.

5 MR. SULLIVAN: It's usually one or two,
6 and sirens do fail. There's a backup called route
7 alerting that we're also going to model. It's
8 possible that a small segment of the population don't
9 hear the sirens.

10 CHAIRMAN WALLIS: Some are deaf.

11 MR. SULLIVAN: Well, yeah, but they'd be
12 special needs, and special needs are treated in a
13 different way. We intend to tease out many, many
14 cohorts from the population. With a good evacuation
15 time estimate, I can get reasonable estimates site by
16 site on the size of those problems.

17 CHAIRMAN WALLIS: So if we're in a room
18 like this and a siren goes out on Rockville Pike, do
19 we hear it?

20 MR. SULLIVAN: Dozens of your beepers and
21 cell phones go off in here.

22 CHAIRMAN WALLIS: They do?

23 MR. SULLIVAN: there's a thing called
24 societal notification that is real. So it's not just
25 the sirens. It's your office calling you and your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 neighbors calling you and your relatives calling you,
2 and the TV might be on.

3 CHAIRMAN WALLIS: So if you're ever in the
4 school and it's a big event and there's a big concert
5 and a lot of noise and all of the parents and all of
6 the kids and all of the teachers are in one room.
7 Someone is going to come in and say, "I've heard a
8 siren"?

9 MR. SULLIVAN: Yeah.

10 CHAIRMAN WALLIS: That's what's going to
11 happen?

12 MR. SULLIVAN: Yes, as a matter of fact.
13 The kid that's outside smoking may come back in and
14 say that the siren sounded, et cetera, et cetera.

15 MEMBER APOSTOLAKIS: But I wasn't smoking.

16 (Laughter.)

17 MR. SULLIVAN: At least I didn't inhale.

18 Societal notification is a real thing, and
19 it does exist, and it's not just sirens. It's the
20 whole picture.

21 MEMBER APOSTOLAKIS: And when people hear
22 the sirens, what do they do?

23 MR. SULLIVAN: Yes. Good question. What
24 we want them to do is turn on their television. We
25 think a good 15 percent of them get in their cars

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and --

2 CHAIRMAN WALLIS: There has been a loss of
3 off-site power, which has affected all of the
4 televisions. There's a blackout in the whole
5 northeast.

6 MEMBER APOSTOLAKIS: You have to have a
7 radio with batteries.

8 DR. MAYNARD: The message goes out by
9 radio also, and the radio stations have dedicated
10 power supplies. For the ones that you choose to be
11 your official notification system --

12 CHAIRMAN WALLIS: So you have to use your
13 car radio or something which is still working?

14 DR. MAYNARD: Yes, right. In all of the
15 public buildings you have a mechanism. You don't have
16 to depend on people hearing the siren inside the
17 building because if you notice even around here, when
18 we have like a fire alarm you have people that come
19 through to make sure people know to get out or
20 whatever. The same thing in all of the public schools
21 in the public buildings. So you're not relying on
22 people inside hearing.

23 MEMBER APOSTOLAKIS: I think information
24 spreads very quickly. I mean, there's no question
25 about it because you're not -- sometimes something

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 unusual happens somewhere and within ten, 15 minutes
2 everybody in the building knows about it.

3 MR. SULLIVAN: Tell my wife and it goes
4 even faster perhaps.

5 MEMBER APOSTOLAKIS: You're on the record.
6 You're on the record.

7 VICE CHAIRMAN SHACK: World Trade Center
8 showed how fast it can go. the World Trade Center
9 issue showed how fast it can go. It had a practically
10 fully evacuated building, too.

11 MEMBER APOSTOLAKIS: I found out through
12 Athens. My mother saw it on television and called me.
13 Amazing.

14 MEMBER SIEBER: You know what it's like to
15 walk down 100 flights of stairs.

16 MEMBER APOSTOLAKIS: Because it was the
17 evening time there. It was the evening news.

18 MR. SULLIVAN: We're going to be working
19 out of the evacuation time estimates, and we're going
20 to tease a lot of data out of them, but it is still
21 going to be judgment involved in this whole thing.

22 Fortunately, we were able to modify MACCS
23 or it is being modified to accept numerous cohorts.
24 There's literally a dozen cohorts that you could
25 identify. There's the school children whose

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 evacuation will begin at an alert or a site area
2 emergency, depending on the state and county plan.
3 There's the shadow evacuation. There's people leaving
4 the parks, et cetera, et cetera.

5 We can identify, you know, literally a
6 dozen cohorts where we can more realistically model
7 the population movements.

8 DR. BANERJEE: So MACCS has built into it
9 these evacuation models and things or how does it
10 work?

11 MR. SULLIVAN: yes.

12 DR. BANERJEE: Because things are changing
13 in real time, right?

14 MR. SULLIVAN: yes, it's perfect. I'm
15 going to get to that in just a slide or two. So bear
16 with me.

17 There are limitations. I'm not going to
18 be able to analyze 62 sites and account for time of
19 day, time of year, good weather, bad weather, bridges
20 out. I'm going to have to do a judgment based
21 agglomeration of those conditions. We're going to be
22 doing three to five scenarios per site. I can't do
23 three to five EP runs on top of the three to five
24 scenarios. The matrix gets too big.

25 So we're simply going to have to use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 judgment and take an evolutionary step forward in
2 modeling emergency response.

3 Now, there's another very useful
4 modification that's been done to MACCS that will
5 answer your question, sir. As a population moves in
6 an emergency planning zone, some of them have limited
7 access highways. Like Duane Arnold, for instance, has
8 a limited access highway going through the middle of
9 the planning zone. We think traffic moves faster
10 there than it does on a two-lane road.

11 On the other hand, in Cedar Rapids, for
12 instance -- I'm using Duane Arnold, not that --
13 they'll eventually get modeled one way or another, but
14 it's an illustrative example.

15 In Cedar Rapids proper we expect traffic
16 to move slower. All right? Well, MACCS previously
17 couldn't model a change in speed in space. It could
18 do something in time.

19 It's now modeled. I saw a demonstration
20 of a change to MACCS. It will be wind MACCS when it
21 gets qualified, where you can directionally change --
22 you can change the direction of the population and
23 their speed as they enter a crowded area of a free
24 area.

25 MEMBER KRESS: I don't know how you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consistently match that to wind rows, which is a
2 probability of the plume going in that particular
3 direction. I don't know how you properly match those
4 things up.

5 MEMBER SIEBER: You can't.

6 MR. SULLIVAN: You touched on a subject
7 that has caused us a lot of thought.

8 CHAIRMAN WALLIS: Do you tell them which
9 way to go?

10 MR. SULLIVAN: I'm sorry?

11 CHAIRMAN WALLIS: You tell them which way
12 to go depending on the wind?

13 MR. SULLIVAN: See, as I said, I can only
14 model this site once. I can't model it 16 times.
15 MACCS, when it does a calculation, it picks a weather
16 sequence of ten or 12 hours, and it runs it. It then
17 points that weather sequence in each of 16 sectors.
18 It then creates a very rich -- and multiplies
19 consequences times the wind rows' probabilities. But
20 the population is the population.

21 Have I lost you yet? Because I have lost
22 myself several times.

23 MEMBER KRESS: I think you've got it.

24 DR. BANERJEE: Direction and weather
25 class, I take it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SULLIVAN: No. One weather, one
2 weather sequence is then moved around in 16
3 directions.

4 CHAIRMAN WALLIS: One weather sequence?

5 MR. SULLIVAN: One weather sequence --

6 MEMBER KRESS: They use a battery.

7 MR. SULLIVAN: -- is moved around in 16
8 weather directions.

9 DR. BANERJEE: And then you give it a
10 probability distribution.

11 MR. SULLIVAN: Yes. And then you choose
12 some 600 or 200 weather sequences. That's where the
13 stability class, et cetera, comes in. But each result
14 is a rich hunk of data with the wind pointed in 16
15 directions.

16 From an EP point of view, I can only model
17 this site once. I can't model it with 16 different
18 wind directions times 62 sites. I don't have the
19 resources to do that. So I'm going to have to make a
20 judgment, and entailed in that judgment is that in
21 general it would be a quadrant being evacuated,
22 Pennsylvania being the exception. I'm going to use
23 the quadrant ETE data rather than the 360 ETE data and
24 apply it to the 360 ETE.

25 We've got to make simplifying assumptions

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 like that to come out of this project, you know, with
2 a reasonable answer.

3 Now, once again, the end product is going
4 to be a probabilistic representation of consequences.
5 There are no absolute cases. We don't blow the wind
6 at the town and blow the wind at the corn. It's
7 probabilistic representation. I'm just trying to do
8 my best to improve the EP model as a piece of this.

9 Did that make sense to anybody?

10 MEMBER KRESS: Yeah, but good luck on
11 that.

12 (Laughter.)

13 MR. SULLIVAN: Well, okay.

14 MEMBER SIEBER: Are you going to model
15 Pennsylvania with the 360 evacuation?

16 MR. SULLIVAN: I am because that's what
17 their plan calls for. We intend to use the state plan
18 and county procedures to the extent that we can. I
19 have an issue with that, that I'll discuss in a little
20 bit though.

21 DR. BANERJEE: The other plans are what,
22 quadrant evacuations?

23 MR. SULLIVAN: What I tried to communicate
24 was in general when an -- in general? There's never
25 been an evacuation called under current emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plans, but when we practice them, we evacuate three or
2 four sectors, 22 and a half degree sectors. That's
3 about a quadrant.

4 So in a general emergency, the utility
5 recommends evacuation in the direction of the wind.
6 That might be changed later on if there's a wind shift
7 or whatever, but it's about a quadrant.

8 I've got quadrant data in even the oldest
9 ETEs. So that's what I'm going to use. Some of the
10 more modern ETEs have finer data, but you know, we
11 have to find our way through it.

12 It's possible that protective actions
13 could be needed beyond the ten mile EPZ. We don't
14 know that to be the case, but it's possible. The
15 emergency preparedness planning basis recognizes this
16 potential, although unlikely, and expects that the
17 planning within the EPZ will form a substantial basis
18 for ad hoc actions outside of the EPZ.

19 We intend to model that as best we can
20 also.

21 In general, MACCS models are radial
22 evacuation, but it will also model a lateral
23 evacuation. There is no evacuation route that is
24 radially outward. This is one of the false over
25 conservatisms of MACCS.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Walk with me for a second. First off, if
2 there's a plume in a sector, MACCS assumes it's in the
3 center of that sector. It then assumes that the
4 evacuation route is in the center of that sector.
5 What that means is there's a cohort of the population
6 directly under the plume for the whole ten miles.
7 That never happens. That is not realistic.

8 So earlier you heard the talk about going
9 to 32 sectors rather than 16. That's an attempt to
10 add realism with this over conservatism. All right?
11 So if the wind will bounce a little bit, it will
12 bounce into the next sector, you know, rather than
13 staying in a 22 and a half degree sector.

14 That's the purpose of that, and we had
15 originally thought we couldn't implement that. I
16 understand that we're rethinking it.

17 But another way to add realism is to model
18 the evacuation routes, and we're now able to do that
19 with wind MACCS. So it may be coarse. We can't model
20 every evacuation route in 62 sites, but we'll model
21 them coarsely at the very least.

22 We're going to model KI. States that use
23 KI, we're going to do something with it. Thyroid
24 cancer is not the rate determining step here, but
25 we're going to model it as best we can.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I've got issues. One of them is it's all
2 very --

3 CHAIRMAN WALLIS: Is there any kind of
4 verification of your model?

5 MR. SULLIVAN: My model hasn't been
6 invented yet. I'm hoping that --

7 CHAIRMAN WALLIS: No, but it seems to me,
8 you know, it's wonderful. It may be very good, but
9 it maybe somewhat of a fantasy. How do you relate it
10 to reality?

11 MEMBER KRESS: It could melt down a
12 reactor.

13 CHAIRMAN WALLIS: Is there any way you
14 can?

15 DR. BANERJEE: But you know, there have
16 been a lot of things like chlorine releases which have
17 been followed by evacuations, and even fairly
18 populated regions have been evacuated, a few hundred
19 thousand. I think in --

20 MR. SULLIVAN: Oh, yes.

21 DR. BANERJEE: -- a couple hundred
22 thousand. So you've got --

23 CHAIRMAN WALLIS: Real examples.

24 DR. BANERJEE: Yeah, you've got real data.

25 CHAIRMAN WALLIS: It would be interesting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to compare. You try to model a real historical event.

2 DR. BANERJEE: There was a rail car
3 that --

4 MEMBER KRESS: Not with a probabilistic
5 model.

6 DR. BANERJEE: -- and they have to
7 evacuate --

8 CHAIRMAN WALLIS: Run it several times and
9 see how close you can get.

10 DR. BANERJEE: -- a very large population.

11 MR. SULLIVAN: Once again, this is a
12 probabilistic representation of consequences. It's
13 not really meant to be a real case. There is no real
14 case.

15 MEMBER KRESS: And I don't think you can
16 even match it to a real case. I don't see the value
17 of that.

18 MR. SULLIVAN: I'm going to point the wind
19 in 16 directions. I'm going to multiply the
20 consequences by the wind rows, you know, times the
21 population. There is no real case. It is a
22 probabilistic representation of consequences.

23 So is it realistic? I mean, I think as we
24 go along presenting it to committees like this for
25 review --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. BANERJEE: To get the consequences,
2 you're multiplying things by probabilities, but when
3 you're trying to model, say, now more realistically
4 evacuation routes and stuff like that, that you can
5 actually compare to some real data because that's
6 deterministic.

7 The probabilities are coming through the
8 wind direction.

9 MR. SULLIVAN: Actually the ETEs,
10 especially the modern ETEs for large population sites,
11 are really quite sophisticated, and since I'm going to
12 be working out of them, you know, when I have these,
13 you know, that's what you would compare to the
14 historical experience.

15 What I'm doing here is an agglomeration of
16 time of year, time of day, and wind direction and
17 coming up with a--

18 CHAIRMAN WALLIS: Then the close up ten
19 miles or something, this is --

20 MR. SULLIVAN: Well, --

21 CHAIRMAN WALLIS: But if you go beyond
22 that, then it's not clear there are any evacuation
23 routes.

24 MR. SULLIVAN: Yeah, that's exactly right.
25 There's no ETE for the distance beyond that. We're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going to have to model it as best we can should it be
2 necessary.

3 Go back one. This is an important point.

4 So it's all very well for me to have a
5 path forward on how to model emergency preparedness,
6 but I'm going to be making assumptions on behalf of 32
7 states, and we think that there might be some
8 opportunity for input from those 32 states to help us
9 with a set of guidelines that we can repeat.

10 Now, we can't present, you know, five
11 scenarios to 32 states and walk them through it and
12 ask them how they would make each decision, but we
13 certainly can ask them a series of questions that will
14 help us with guidelines so that we can at least
15 comport with the opinions of our stakeholders.

16 So we're not going to do this in a vacuum.
17 Some ETEs are very old where in rural sites the
18 population is small and declining, and they haven't
19 updated their ETEs because they're not required to.
20 We're going to have to work with some old evacuation
21 time estimates in some cases.

22 We have already talked about this
23 probabilistic representation. When we do a threshold
24 calculation, the run time in MACCS gets very long. so
25 in order not to -- and it is done by cohort. So in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 order to minimize that we will take some cohorts off
2 the table, and what I mean by that is if it's eight
3 hours or 12 hours to release in a given scenario and
4 the sirens are sounded at an alert or a site area
5 emergency, there will be a shadow evacuation. Ten
6 percent of the population, 15 percent of the
7 population is going to get in their cars and leave.

8 The schools will be evacuated at a site
9 area emergency. In the case of Duane Arnold, which
10 I've studied, that's 49 of 170,000 people would be
11 moved out of the EPZ. There's no real reason to put
12 those cohorts through MACCS. You know, we know they
13 can leave within 12 hours. So we'll just simply say
14 the population is now 15 percent smaller.

15 So we're going to make some simplifying
16 assumptions like that, where it's appropriate.

17 MEMBER ARMIJO: Will you make assumptions
18 on people who just can't leave, hospital people --

19 MR. SULLIVAN: Yeah.

20 MEMBER ARMIJO: -- people who are --

21 MR. SULLIVAN: We get that out of the ETE.
22 I'm sorry. Yes. The ETE treats that as special needs
23 populations, and once again, in the case of Duane
24 Arnold, just because we used it as an example to learn
25 this stuff better, they have a 22 hour estimate for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 special needs, and although some of that is -- the
2 school is about eight hours, but beyond that, there is
3 nursing homes and hospitals that require ambulances,
4 and even the National Guard, and evacuation of those
5 people could be as long as 22 hours.

6 However, they're sheltered in substantial
7 facilities. A good number of them is moving long
8 before. Twenty-two hours is a final ambulance leave
9 a ten mile EPZ. So yes.

10 Then there's another cohort of people who
11 don't hear the sirens, but are warned by the follow-up
12 route alerting.

13 And finally, there's a cohort of people
14 who refuse to leave. We're going to treat them
15 perhaps outside the system, but they will be treated
16 in one way or another.

17 I hold out to you that they're a special
18 class of citizen.

19 CHAIRMAN WALLIS: Well, the people who are
20 opposed to nuclear power, one of their strategies is
21 to declare that they won't leave.

22 MR. SULLIVAN: Okay.

23 MEMBER SIEBER: Yeah, but that doesn't
24 mean that they won't leave.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 PARTICIPANT: We all make choices in life.

2 MR. SULLIVAN: Well, I mean, rather than
3 do this huge analysis and show, you know, the
4 potential for early fatalities because people who were
5 warned by the sirens and warned by the police refuse
6 to leave, we could perhaps treat that in a special way
7 that, yes, indeed, if people don't leave, you know,
8 there could be fatalities, right?

9 I mean, so that's -- usually when you see
10 the early fatality numbers in this kind of analysis,
11 it's the .5 percent of the population who refuse to
12 leave.

13 MEMBER APOSTOLAKIS: But then it's not --
14 I mean the nature of the risk is different.

15 MR. SULLIVAN: It certainly is.

16 MEMBER APOSTOLAKIS: Because now it's not
17 involuntary anymore.

18 MR. SULLIVAN: That's --

19 MEMBER APOSTOLAKIS: They were warned and
20 they refused to go. I mean, society in general treats
21 those kinds of risks differently. So you know --

22 MR. SULLIVAN: And I think we should, too.
23 So we don't know what the publication looks like, but
24 we're thinking that that cohort should be treated
25 differently.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: It should be on the cover.

2 MEMBER CORRADINI: Now, when you say MACCS
3 is a probabilistic calculation, every time I run MACCS
4 I get essentially another sample in a distribution.
5 So essentially I have to run MACCS over and over again
6 even to get my distribution. It does it, right?

7 MS. MITCHELL: If I can understand your
8 question, when you run a MACCS calculation, right now
9 the only probabilistic aspect of it is the weather so
10 that you have 8,760 possible hours in a year that that
11 the accident could actually begin, and so that is
12 sampled, and you may take several hundred of the 8,760
13 values, and so you get an answer that way.

14 Each one of those weather scenarios
15 represents others, and so each one has a weight. So
16 if I choose this one, it has a weight. If I choose
17 another one, it has another weight.

18 MEMBER CORRADINI: Oh, and the answer I
19 get then is the weighted estimate of that?

20 MS. MITCHELL: Is the weighted value over
21 the weather.

22 PARTICIPANT: But it's deterministic.

23 MS. MITCHELL: Yeah, it's deterministic.
24 Once you choose the weather, then it goes on.

25 CHAIRMAN WALLIS: But the effective

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 weather on evacuation ability is not taken into
2 account?

3 MS. MITCHELL: You could. You could,
4 indeed, take into account an uncertainty in the delay
5 time before somebody starts to move and/or the speed
6 with which they move when they start by putting in a
7 range of values and degrees of belief in those values,
8 and then running MACCS in a sampling mode, which would
9 require then running multiple MACCS runs.

10 DR. BANERJEE: At the moment you just have
11 to do one, right?

12 MS. MITCHELL: At the moment, you can
13 choose whether you do one or you do many.

14 MEMBER CORRADINI: Now, for this one,
15 would you do the estimate for a bad weather? Would
16 you do the average result or you'd do a bad weather
17 case?

18 MS. MITCHELL: We normally use for a
19 single MACCS run, we normally sample the weather with
20 several hundred of the 8,760 possibilities. So when
21 you get an answer, it's an answer over the weather,
22 weighted average over the weather.

23 MEMBER CORRADINI: Okay.

24 MS. MITCHELL: Okay? And the question of
25 whether or not you wanted to look at the uncertainty

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in all the other parameters, you can do that by
2 running multiple MACCS runs in an LHS mode.

3 MR. SULLIVAN: So that's how we plan to
4 model emergency response. I'm sure we're going to
5 learn a lot from the pilot plans then and course
6 correct as we go along.

7 MEMBER ABDEL-KHALIK: Bill, I have a
8 question.

9 VICE CHAIRMAN SHACK: Yes, Said.

10 MEMBER ABDEL-KHALIK: Let's say you're
11 going to do this for Waterford 3 and assume in your
12 analysis like you explained that everyone will do his
13 or her job, and all of the evacuation will be done as
14 planned. Do you think the public in that area and
15 they meet in the vicinity of that plant, who are
16 really the customers of this analysis, will believe
17 this result?

18 MR. SULLIVAN: Yes.

19 CHAIRMAN WALLIS: With 100 percent
20 probability, right?

21 MR. SULLIVAN: I think there will be those
22 who don't believe it, those who don't listen, but my
23 job, our job on this project is to do the best job we
24 can to present the NRC's judgment of the potential
25 consequences.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER ABDEL-KHALIK: I have selected the
2 name of the plant sort of with care.

3 MR. SULLIVAN: Balance of forethought is
4 the word.

5 (Laughter.)

6 MEMBER ABDEL-KHALIK: Right. And I'm just
7 wondering that given the recent history with
8 evacuation in a certain vicinity, in a certain area,
9 that if you go through this process, that your
10 customers will really believe what you're telling
11 them.

12 MR. SULLIVAN: Okay. I have a data point
13 for you. As we discussed the Katrina incident with
14 emergency responders around the country, we find that
15 they take great umbrage with the idea that they would
16 not implement their plans.

17 We think that the plans around nuclear
18 power plants will be implemented. They are tested
19 regularly. They are drilled regularly, and they're
20 inspected. They are certified annually as being
21 adequate. So we think there's a higher level of
22 assurance that these plans will be implemented and
23 will protect public health and safety than, for
24 instance, there was -- I wouldn't have had so much
25 confidence if we're talking about a major city.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN WALLIS: No, you cannot be 100
2 percent confident. If I do a thermal hydraulic
3 analysis of a problem which is difficult and I haven't
4 solved before, I would say maybe I would be lucky to
5 get something, 75 percent confidence that I got the
6 right answer when I first did it.

7 You're going to do something very --
8 you're going to do something very complicated here
9 that no one has really done before, and you're going
10 to say the answer is perfect. Now, that can't be
11 right.

12 MR. SULLIVAN: I'm not saying the answer
13 is perfect. No, individuals will fail. Things will
14 go wrong. As a matter of fact, during biennial
15 exercise, roads are closed and the off-site response
16 organization is --

17 CHAIRMAN WALLIS: Well, there's a huge
18 amount of uncertainty about how closely your model
19 represents reality, isn't there?

20 MR. SULLIVAN: I --

21 CHAIRMAN WALLIS: Some uncertainty.

22 MR. SULLIVAN: There's certainly some
23 uncertainty.

24 MEMBER APOSTOLAKIS: Well, there are also
25 cases. I remember in Canada they evacuated what,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 100,000 people within a few hours.

2 DR. BANERJEE: Well, a few hours.

3 MEMBER APOSTOLAKIS: Yeah. I mean, that's
4 remarkable, I think.

5 MR. SULLIVAN: We just looked at 239
6 evacuations between 1992, is it, and 2003? There's an
7 evacuation in the U.S. every three weeks, big
8 evacuation, 1,000 people, more than one building, and
9 those evacuations, all of them, all 232 were
10 successful in saving lives.

11 Now, they weren't all, you know, smooth.
12 We then studied 50 of them, and we picked out some of
13 the worst case ones to study because we thought we
14 could learn something from them. They all saved
15 lives. They all moved people. The public does what
16 they are told. The emergency workers show up. Even
17 ad hoc plans will get people moving in the right
18 direction.

19 Now, up until Rita, Hurricane Rita, an
20 evacuation never killed anybody. Now, sometimes the
21 hazard caught up with the tail end of an evacuation --
22 it was usually wild fires -- and killed people, but an
23 evacuation itself never killed anybody until Hurricane
24 Rita.

25 And that's one of the reasons we want to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 study these new evacuations, because it's new data,
2 but we have good data that evacuations are done ad
3 hoc, and they're successful, and they save lives.
4 These evacuations are planned and inspected. They
5 have sirens. So we think there's a higher level of
6 probability that they will be successful.

7 CHAIRMAN WALLIS: But see, they are
8 evacuated from, let's say, ten miles. How far do they
9 have to go before they stop their car?

10 MR. SULLIVAN: Some of them go to
11 Grandma's house.

12 CHAIRMAN WALLIS: Well, how far should
13 they be told to go?

14 MEMBER SIEBER: They should go 1,000
15 miles.

16 MR. SULLIVAN: Some go --

17 CHAIRMAN WALLIS: Is there any --

18 MR. SULLIVAN: Actually they are not told.

19 CHAIRMAN WALLIS: Does it matter?

20 MR. SULLIVAN: They are told to get out of
21 the EPZ, either go to a congregate care center. The
22 data shows that ten, 12 percent go to a congregate
23 care center. We're rigged for 20 --

24 CHAIRMAN WALLIS: You were talking earlier
25 about modeling hazards to health out to 1,000 miles.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Does that mean that people should try to go 1,000
2 miles?

3 MR. SULLIVAN: Certainly not.

4 CHAIRMAN WALLIS: No.

5 MR. SULLIVAN: Frankly, I think modeling
6 out to 1,000 miles is not a good representation of
7 reality, but you know, the project will have to decide
8 where it's going to go.

9 MEMBER CORRADINI: How far away are the
10 care centers typically?

11 MEMBER SIEBER: Twenty-five miles.

12 MR. SULLIVAN: Twenty-ish, at least 15.

13 CHAIRMAN WALLIS: Isn't there a problem of
14 gas? I mean, what's the average range of a car on an
15 average day if he doesn't fill up his tank? You know,
16 that must be a consideration.

17 MR. SULLIVAN: It depends on what car they
18 own.

19 MEMBER SIEBER: Yes.

20 (Simultaneous conversations.)

21 DR. BANERJEE: If it's an SUV like
22 yours --

23 (Laughter.)

24 MEMBER CORRADINI: Do you mean my Hummer?

25 DR. BANERJEE: Your Hummer.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: But I don't
2 understand what --

3 DR. BANERJEE: Hydrogen power.

4 MEMBER APOSTOLAKIS: -- where are you
5 going with this, Graham?

6 CHAIRMAN WALLIS: Well, I'm just wondering
7 when you ask if people believe it, I mean, the
8 question is when you present these results, how are
9 you going to present them in terms of the sort of
10 range of the uncertainty around what you're presenting
11 and all of that? That seems to be a rather awkward,
12 but essential thing you have to do.

13 MR. SULLIVAN: Well, we're certainly open
14 to guidance. I mean, we don't know how the results of
15 the study are going to be presented yet. That has
16 really not been decided. We're still looking.

17 MEMBER ABDEL-KHALIK: I guess my question
18 was sort of motivated by the basic issue of who are
19 the customers for this analysis and what will they do
20 with the information that you gave them.

21 And that's why I asked myself. I mean,
22 you go through and do this for the people living in
23 that part of Louisiana, and then you tell them this is
24 the result of our analysis, and they will sort of
25 ignore you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: My personal view is
2 that the customers are not these people. The
3 customers are the Commission and the state and federal
4 agencies that will respond.

5 MR. SULLIVAN: Anything to add?

6 MEMBER APOSTOLAKIS: Not the general
7 public.

8 DR. BANERJEE: But these documents will
9 have a long term effect on the perception of nuclear
10 power by the general public.

11 MEMBER CORRADINI: But, I mean, just look
12 at it the opposite way. You have the 1982 study
13 that's been out there for 25 years and nobody is
14 running away from the power plant sites. I very
15 carefully memorized what happened in Kiwanee and Point
16 Beach relative to the '82 study.

17 MEMBER KRESS: '84, wasn't it?

18 MEMBER CORRADINI: No, I thought it was
19 '82.

20 PARTICIPANTS: '82.

21 MEMBER CORRADINI: '82, the site
22 character, whatever it's called, and --

23 DR. BANERJEE: I'm not saying they'll run
24 away.

25 MEMBER CORRADINI: No, no, but I guess my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 view is from what at least the first presentation gave
2 us and then this one, they're trying to do I want to
3 call it an update, a re-do job of it, and I can't
4 believe the consequence is going to be higher than
5 what I saw in '82, and I didn't see massive panic
6 around the sites in the northern Midwest.

7 So my first assumption would be we're
8 going to get a more realistic, reasonable first ut at
9 it.

10 I do think, though relative to your
11 evacuation, I think you're right about distances
12 there, but I think in some sense it would be very
13 interesting that you can unwrap certain things about
14 if you only had evacuation in the first ten, whatever
15 it is, miles in certain directions, outside of that
16 how the consequence or the dose is not affected, and
17 how you might actually not want to move them as much.

18 Dana is not here at the moment, but this
19 whole idea about sheltering versus -- there is another
20 Ph.D. thesis out of MIT by Burke in 1981. I remember
21 all of these.

22 MEMBER APOSTOLAKIS: That was before my
23 time.

24 MEMBER CORRADINI: Yeah, it was before you
25 were there. I apologize.

1 but the doctoral student at the time
2 indicated that sheltering was by far the most
3 reasonable thing to do beyond a very few miles out.
4 So I would be very curious to see if you change your
5 evacuation strategy within this context what
6 interesting results you'd get relative to that.

7 I think there's a lot of interesting stuff
8 that can come out.

9 MEMBER BONACA: The materials to report
10 will not disappear, especially for those scenarios
11 which are now reproduced by a new study, but I don't
12 know.

13 CHAIRMAN WALLIS: Do you want to --

14 MEMBER BONACA: I said the 1982 study
15 would not disappear. It's still there.

16 MEMBER CORRADINI: Right.

17 MEMBER BONACA: But figuring for those
18 scenarios which are not repeated or reproduced in the
19 new study. Is there any --

20 MEMBER APOSTOLAKIS: Presumably this would
21 be more realistic. Why are you saying this?

22 MEMBER BONACA: Yeah, of course.

23 DR. BANERJEE: There is one sort of
24 Achilles heel of this though. This is not based on
25 risk. It's based on sort of frequency.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: In some sense --

2 MEMBER KRESS: You know, one thing they
3 could do about that is have this CDF cutoff of ten to
4 the minus six. They might take at least one of the
5 plant types at several sites and do a cutoff of ten to
6 the minus seven and see if it makes any difference,
7 but it wouldn't be definitive because it would just be
8 a sample, but that might be something they could do
9 without a lot of resources.

10 MEMBER CORRADINI: I'm sure Tom will give
11 them a suggested one.

12 MEMBER KRESS: Yeah, I can pick out one
13 for them. I'll let them do that.

14 MEMBER BONACA: I really would like to
15 know about the issue of 1982 study, you know, the
16 comment I made. I think you were responding to that.
17 I would like to know what you think about that.

18 MR. TINKER: Well, we do expect that as
19 part of this study that we will, as part of the
20 report, explicitly discuss the connection between this
21 study and the 1982 study, and without prejudging I
22 don't reasonably think we'll see anything that
23 resembles the SST-1 release from the 1982 study. So we
24 will explicitly describe for the reader why that
25 scenario, why that release is no longer feasible or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applicable to nuclear power plant sites.

2 MEMBER BONACA: Okay. That answered my
3 question.

4 MR. TINKER: So if they're looking for why
5 is the SST-1 not in this study, this report will
6 address why it is not in the study.

7 MEMBER BONACA: Good.

8 VICE CHAIRMAN SHACK: Unless there's
9 another burning question, I'd like to pull this to a
10 halt since we need to discuss some issues here before
11 we leave tonight and we're getting late.

12 MR. PRATO: Just before I sign off, I'd
13 like to just make one additional statement. Our
14 objective here is to provide the most realistic
15 results within the limitations of our tools. If you
16 can help us do that, that's what we're looking for.
17 If you see us going in the wrong direction, we would
18 appreciate that feedback. If you can think of other
19 realistic approaches that we can add to our approach,
20 that's what we're looking for from this committee.

21 And we are going to be updating you
22 regularly, and we're going to be asking for feedback
23 regularly, and as we develop written documents, you
24 will get that information.

25 MEMBER CORRADINI: Yeah, I mean, when will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 we see, say, the first report on a real attempt to do
2 this process on a plant? I mean, you said that was
3 sort of your --

4 MR. PRATO: Probably, we probably won't be
5 processing any information until the February time
6 frame at the soonest, I would think.

7 MEMBER APOSTOLAKIS: That's early enough.

8 MR. PRATO: At the soonest, and probably
9 more likely time frame is probably March, but there's
10 a lot of process development that we need to do, and
11 as we do that, we will provide you with that
12 information.

13 MEMBER APOSTOLAKIS: But you'll come here,
14 say, some time in the June time frame?

15 MR. SULLIVAN: Oh, I think I'd like to see
16 you before that.

17 MEMBER APOSTOLAKIS: Well, in March
18 they're going to have a draft report. They will not
19 rush to give it to us.

20 MR. PRATO: No, no, no, no.

21 MEMBER APOSTOLAKIS: No, what?

22 DR. BANERJEE: Updated.

23 MR. PRATO: We didn't mean to imply that.

24 MR. SULLIVAN: They're not going to have
25 anything by then.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: You have results in
2 March?

3 MR. PRATO: No.

4 MEMBER APOSTOLAKIS: Some results?

5 MR. PRATO: We believe that we're shooting
6 to get that up from the licensees that we need to
7 process.

8 MEMBER APOSTOLAKIS: Oh, before you start.

9 MR. PRATO: At starting the models and the
10 process.

11 MEMBER APOSTOLAKIS: But you will not have
12 exercised the model.

13 MR. PRATO: No, sir.

14 MEMBER APOSTOLAKIS: And you want to come
15 here before you do that? Is that what you're saying?

16 MR. SULLIVAN: Well, I think it's very
17 important to engage the ACRS very periodically. You
18 know, for example, this meeting here was very
19 important for us to discuss our scenario selection,
20 how we viewed CDF versus release, et cetera.

21 You know, as we continue to have issues
22 that we believe we need and we would like input,
23 feedback and direction from the ACRS, we will come
24 here as often as needed.

25 In addition to that, as results are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 developed and reviewed, we would expect, you know, to
2 present them to the ACRS also. I mean, right now it's
3 very important to recognize that we are still
4 developing the process. You can't start the
5 calculations until a lot of these decisions are made.

6 MEMBER APOSTOLAKIS: Why isn't there a
7 subcommittee meeting on this? I mean, we can't keep
8 doing this, have the full committee.

9 MR. SULLIVAN: Well, part of it was we
10 simply thought that this was of interest to the whole
11 committee.

12 MEMBER APOSTOLAKIS: Today I agree, but I
13 mean do you plan to --

14 MR. SULLIVAN: Yes. I mean, we will
15 proceed with subcommittees as appropriate.

16 MEMBER APOSTOLAKIS: Which subcommittee is
17 this? The new one?

18 VICE CHAIRMAN SHACK: I'm not sure which
19 one it's under.

20 MEMBER APOSTOLAKIS: You're chairing it,
21 right?

22 VICE CHAIRMAN SHACK: I'm -- I don't know.
23 It's under regulatory policy, I guess.

24 MR. PRATO: I believe that Sam has
25 scheduled a meeting for March. I think it's --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Of the full
2 committee?

3 MR. PRATO: -- the 8th or the 19th. I'm
4 not so sure.

5 MEMBER APOSTOLAKIS: The full committee?

6 DR. BANERJEE: This is submitting of
7 the -- yeah, okay, yeah.

8 MEMBER APOSTOLAKIS: This is the shock
9 supplement.

10 VICE CHAIRMAN SHACK: Whatever committee
11 we stick it under, right.

12 CHAIRMAN WALLIS: The name doesn't matter.
13 It's what they do that matters.

14 MEMBER APOSTOLAKIS: It does, it does.

15 DR. BANERJEE: But if it's a while
16 updating of the full committee, that's not so bad.

17 MEMBER APOSTOLAKIS: No, but I mean as
18 they get into details, it seems to me one hour is not
19 enough.

20 DR. BANERJEE: No. I'm just saying --

21 MEMBER APOSTOLAKIS: I mean, there should
22 be a briefing of the full committee.

23 DR. BANERJEE: Yeah, yeah, update.

24 MEMBER BONACA: I think the March meeting,
25 however, was focused on the performance of scoping

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 studies for new designs. You remember we recommended
2 the security issues.

3 DR. BANERJEE: I mean, do we want to get
4 into MACCS?

5 VICE CHAIRMAN SHACK: I think we want to
6 get into everything in this at some point. It's just
7 a question of when it's appropriate to do that.

8 MEMBER BONACA: Well, I mean, that's the
9 time that we're discussing he would be ready. He
10 would want to come and talk to us for an hour or so
11 about their plan.

12 MEMBER SIEBER: An hour and a half.

13 CHAIRMAN WALLIS: Do you want to discuss
14 this later on off the record when we make plans for
15 the future? Are we finished now?

16 MEMBER SIEBER: Before you go off the
17 record, I think Alan Nelson would like to make a
18 statement.

19 CHAIRMAN WALLIS: Oh, we have somebody
20 that wishes to make a statement? Bill, do you want to
21 do that?

22 MEMBER SIEBER: Biff Bradley would like
23 to.

24 CHAIRMAN WALLIS: Biff Bradley. Okay.

25 MEMBER KRESS: NEI here.

1 MR. BRADLEY: Biff Bradley, NEI.

2 Just briefly, while we understand and
3 empathize with the intent of the Commission on
4 undertaking an update of this study, one thing, we
5 can't even see the SRM or SECY. So we don't have a
6 full understanding of the rationale for the Commission
7 in proceeding in this area. So we've had to learn
8 what we can from interactions with the staff and
9 meetings like this.

10 I just want to say we have two large
11 general areas of concern. One is the fact that this
12 is being done as a pure consequence study, and
13 understand that the original study was done that way,
14 but in the interim since that study was done, we've
15 had a safety goal policy statement. We have QHOs, and
16 we have measures of comparative risk.

17 We also have a PRA policy statement that
18 says PRAs should be used in matters as appropriate,
19 and it seems in 2006 to do a pure consequence study is
20 not the right way to be proceeding. We believe the
21 study should be a risk study or a safety study or a
22 study that looks at the fleet relative to the QHOs or
23 something along those lines, and that it's going to be
24 extremely difficult no matter how you try to package
25 this to produce a pure list of fatalities plant by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant for every plant, and to have good understanding
2 of that in the context of risk.

3 The second point I'd like to make is I
4 think it was elucidated today. There is a very large
5 number of unanswered questions about technically how
6 this study is going to proceed, everything from
7 scenario selection to how EP is modeled.

8 We're concerned that there's a lot of
9 scheduler pressure on the staff to proceed, and
10 they're proceeding with the study and data collection
11 and actually proceeding with the analysis of actual
12 operating plants apparently before all of these issues
13 are getting resolved. It's a parallel path kind of
14 effort, and we're pretty concerned about that.

15 In that regard, we've already submitted 40
16 technical questions to the staff relative to technical
17 aspects of the study, some of which came up today, and
18 I'd just like to say those are our two major areas of
19 concern right now.

20 MEMBER APOSTOLAKIS: That's an interesting
21 point you're making, Biff. In fact, that's a good
22 question. Why isn't this study doing the Level 3 PRA?

23 CHAIRMAN WALLIS: Unavailable.

24 MEMBER APOSTOLAKIS: Why not? Do you
25 think the consequences is much less a job? It could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be longer. It doesn't have to be completed by the set
2 date.

3 That would make more sense, I think, in
4 the sense that now you are really calculating risk.
5 Because Biff has a point, I think. I mean, you know,
6 we are focusing, again, on consequences. People can
7 pick a couple of results and start using them the way
8 that suits their purpose, and we have the safety
9 goals.

10 I mean, after you get the consequences,
11 what do you do? You compare them with the '82 study,
12 but still that doesn't say much. Is that acceptable?
13 Does it meet any criteria, any goals?

14 I appreciate there is a lot more work, but
15 since we're undertaking this, why not? I think that's
16 an interesting point. I mean we could have a Level 3
17 PRA.

18 MEMBER CORRADINI: So, George, can I ask
19 you a question?

20 MEMBER APOSTOLAKIS: Yes.

21 MEMBER CORRADINI: I was just asking Tom.
22 Why isn't this the equivalent of a Level 3 PRA?

23 MEMBER APOSTOLAKIS: Because they're not
24 going all the way to latent deaths and early
25 fatalities.

1 MS. MITCHELL: We are.

2 PARTICIPANTS: Yes, they are.

3 MS. MITCHELL: But when you say PRA, I
4 figure that what you probably that you --

5 MEMBER APOSTOLAKIS: With the probability.

6 MS. MITCHELL: With the probabilities.

7 MEMBER APOSTOLAKIS: With the
8 probabilities, yeah.

9 VICE CHAIRMAN SHACK: Well, they will.

10 MEMBER APOSTOLAKIS: But they're not
11 giving probabilities.

12 MS. MITCHELL: We're not because the Level
13 1 doesn't have -- we don't have a Level 1 PRA with
14 uncertainties for 103 plants.

15 MEMBER CORRADINI: Ah, you're going to
16 give a point estimate.

17 MEMBER APOSTOLAKIS: Even the Level 2 you
18 are not handling probabilities, correct?

19 MR. TINKER: But we talked about the use
20 of the CDF for the screening. We expect that there
21 will be some means to modify that CDF frequency to
22 account for issues like the difference between that
23 and release frequency, incorporating the plant
24 improvements which have taken place.

25 It is the expectation that this report

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will not see -- there cannot be a divorcing of
2 consequences from the probability of frequency of
3 events. There has to be a close connection in any
4 discussion of consequence with the frequency of these
5 events. We're just reluctant to say this is a full
6 bore, full blown Level 3 PRA.

7 But I've described our approach to
8 addressing uncertainty. That's different from the
9 Level 2 approach to uncertainty, but we do expect that
10 we will combine the elements of the Level 1 with the
11 consideration of uncertainty and consequences.

12 MEMBER APOSTOLAKIS: I'll come back to a
13 comment I made earlier, and it's still not clear to me
14 why you're not following that way. This agency spent
15 a lot of resources when it did NUREG 1150. I mean,
16 the methodology is there, right? They have developed
17 the codes.

18 I mean you chose not to use their accident
19 progression reviews for whatever reason, but it's not
20 like we're asking -- well, I'm not asking. I'm just
21 speculating -- why not take that methodology, update
22 it if you need to, but that produced risk estimates.
23 I mean, if you go to the -- in fact, I was very
24 pleased to see that you guys put it on the Web site.
25 So now students go and use it and so on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 You can go and find the curves for latent
2 fatalities. There is a beautiful discussion in the
3 text, what the major contributors are to early
4 fatalities. Why not try to reproduce that then and
5 have the risk estimate? Would that increase your
6 amount of required effort by -- I don't know -- a
7 factor of five or is it -- well, whatever it is
8 though, but it makes sense, it seems to me, after so
9 many years after 1989 when 1150 was published to take
10 advantage of it.

11 When you said earlier that, you know, we
12 are not using the progression trees and we're using
13 something else, my mind didn't go all the way to risk
14 at that time, I must admit.

15 MEMBER CORRADINI: So, I mean, I'm
16 reflecting, I guess. I don't disagree with what
17 George is saying though, but in some sense this is a
18 progression. It seems to me if you go
19 chronologically, we're essentially retracing what
20 occurred 25 years ago, right? In the sense that,
21 first, you had --

22 MEMBER APOSTOLAKIS: No.

23 MEMBER CORRADINI: Well, but really it's
24 true. I mean, this siting study was done in '80 and
25 '81 following the design Indian Point study which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 said, you know, there was this bifurcation that either
2 it's coolable as the dickens and don't worry about it
3 or, oh, my God.

4 Now we're back to what could it be at
5 various plant sites, right? And then which led to
6 NUREG 1150 and containment working group information.
7 So it's a natural progression.

8 I would guess that this is due to be ended
9 in a year?

10 MS. MITCHELL: Three years.

11 MEMBER CORRADINI: Three years, and
12 eventually they may want to do more.

13 CHAIRMAN WALLIS: So looking back to this
14 question of Level 3 PRA, if all of the plants in the
15 country had a Level 3 PRA, you could just look at
16 those results and reach conclusions, couldn't you?

17 MEMBER CORRADINI: but I think there is
18 something --

19 CHAIRMAN WALLIS: But is that true?

20 MEMBER APOSTOLAKIS: Unless they are using
21 updated models.

22 CHAIRMAN WALLIS: One reason for all of
23 this effort is that we haven't required that the
24 plants have a Level 3 PRA.

25 MEMBER CORRADINI: But if I might just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 interject though, there's something that Charlie said
2 in the explanation that I thought was very good
3 technically. Maybe I misheard it, but the way they're
4 approaching the containment loads or the in between
5 study, which are all of the uncertainty, is much more
6 physically palatable than what was done in NUREG 1150.

7 However good NUREG 1150 was, it was pretty
8 hodge-podge in terms of how the containment failed.
9 If I understood what's being done here, this is
10 technically much more defensible. To the extent that
11 they can actually show that that's the case, this has
12 a very big benefit that has nothing to do with the end
13 state or calculational state, but might do the next
14 Level 3 PRA.

15 DR. BANERJEE: It depends on what sort of
16 models are going into MELCOR to do this.

17 MEMBER CORRADINI: Sure, but if you go
18 back to NUREG 1150, this one unfortunately I got
19 involved in. So I remember distinctly. There is a
20 lot of calculations there that were not highly robust
21 and a lot of decision making that required people
22 making judgments.

23 In this case, to the extent that you've
24 done it, they're making a series of calculations based
25 on a plant state and running through those

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 calculations where you essentially now have a
2 relatively well known tool that's walking you through
3 the calculations.

4 That strikes me as a much better technical
5 approach, personally, unless I misunderstood what
6 we've done.

7 DR. BANERJEE: But I hope we have council
8 look at it at some point.

9 MEMBER APOSTOLAKIS: Right. We need a
10 subcommittee meeting.

11 MEMBER BONACA: I think so, too.

12 MR. TINKER: I didn't want to get into how
13 we view the 1990 vintage of accident progression event
14 tree logic tools versus MELCOR, but it's clear. The
15 underlying basis for this is we've done 20 years of
16 phenomenological research on severe accident behavior.
17 We do not believe that those old models in PRA reflect
18 that understanding. We've done tests. We've done
19 analysis. We've done tests around the world, most
20 recently fievish (phonetic) tests and so forth that
21 provide a great deal of information that is not
22 reflected in most of the NRC's examination of Level 2
23 and Level 2-Level 3, and this is meant to update that
24 level of understanding.

25 MEMBER APOSTOLAKIS: But you are not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 updating all the way. That's the question. Why don't
2 you go all the way?

3 I agree with you.

4 MR. TINKER: Now, we've touched on this.
5 We talked about what fraction of the core damage
6 events we think we're capturing here. You heard
7 numbers like 90, 95 percent of the core damage
8 frequency. We didn't make similar statements about
9 percent of the risk. I think we will be able to say
10 more about that in the future.

11 MEMBER APOSTOLAKIS: Okay, all right.

12 MR. TINKER: But that's the focus here.
13 The idea is that we have this '82 study where we're
14 talking about alpha mode failure and things of that
15 nature.

16 Now, that may be a good example for some
17 people, may not be for others, but we think there are
18 many instances where those past studies were by
19 today's standards extraordinarily, extremely
20 conservative because they identified LERF states that
21 we don't think exist.

22 MEMBER APOSTOLAKIS: Maybe that's a good
23 time to stop this.

24 MEMBER BONACA: Yeah, I think so.

25 CHAIRMAN WALLIS: Bob, are you ready to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stop? You don't look as if you're eager to present
2 any more.

3 MR. PRATO: I'd be happy to go home.

4 CHAIRMAN WALLIS: Are you happy? Are the
5 members happy?

6 It has been very, very informative, I must
7 say, and --

8 MEMBER BONACA: I think we need to have a
9 subcommittee meeting.

10 CHAIRMAN WALLIS: -- there are so many
11 things to grasp.

12 MEMBER APOSTOLAKIS: The problem with
13 subcommittee meetings is you don't have everybody.

14 CHAIRMAN WALLIS: Thank you very much.

15 MR. PRATO: Thank you, sir.

16 MEMBER APOSTOLAKIS: This was very good.

17 MR. PRATO: Thank you.

18 CHAIRMAN WALLIS: We now are ready for a
19 break. Is that true? The members are determined to
20 work.

21 We'll break until 6:30.

22 (Whereupon, at 6:16 p.m., the meeting was
23 adjourned.)

24

25

CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on
Reactor Safeguards
538th Meeting

Docket Number: n/a

Location: Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.



Charles Morrison
Official Reporter
Neal R. Gross & Co., Inc.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701



UNITED STATES
NUCLEAR REGULATORY COMMISSION
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
WASHINGTON, D. C. 20555

November 20, 2006 (REVISED)

SCHEDULE AND OUTLINE FOR DISCUSSION
538th ACRS MEETING
DECEMBER 7-9, 2006

THURSDAY, DECEMBER 7, 2006, CONFERENCE ROOM T-2B3, TWO WHITE FLINT
NORTH, ROCKVILLE, MARYLAND

- 1) 8:30 - 8:35 A.M. Opening Remarks by the ACRS Chairman (Open) (GBW/JTL/SD)
1.1) Opening statement
1.2) Items of current interest

- 2) 8:35 - 10:30 A.M. Draft Final Regulatory Guide, DG-1145, "Combined License Applications for Nuclear Power Plants" (Open) (TSK/DCF)
2.1) Remarks by the Subcommittee Chairman
2.2) Briefing by and discussions with representatives of the NRC staff regarding Draft Final Regulatory Guide, DG-1145, "Combined License Applications for Nuclear Power Plants," and resolution of significant public comments.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

10:30 - 10:45 A.M. *****BREAK*****

- 3) 10:45 - 12:15 P.M. Draft Final Regulatory Guide, DG-1144, "Guidelines for Evaluating Fatigue Analyses Incorporating the Life Reduction of Metal Components Due to the Effects of the Light-Water Reactor Environment for New Reactors" (Open) (JSA/CGH/CS)
3.1) Remarks by the Subcommittee Chairman
3.2) Briefing by and discussions with representatives of the NRC staff regarding Draft Final Regulatory Guide, DG-1144 and the resolution of public comments.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

12:15 - 1:15 P.M. *****LUNCH*****

- 4) 1:15 - 3:15 P.M. Proposed Revisions to Standard Review Plan Section 13.3, "Emergency Planning" (Open) (MLC/DAP/MB)
4.1) Remarks by the Subcommittee Chairman
4.2) Briefing by and discussions with representatives of the NRC staff regarding proposed revisions to Standard Review Plant Section 13.3, "Emergency Planning," and related matters.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

3:15 - 3:30 P.M. ***BREAK***

- 5) 3:30 - 5:30 P.M. State-of-the-Art Reactor Consequence Analysis Project (Open)
(WJS/HPN)
- 5.1) Remarks by the Subcommittee Chairman
 - 5.2) Briefing by and discussions with representatives of the NRC staff regarding status of the staff's efforts associated with the state-of-the-art reactor consequence analysis project.

Representatives of the nuclear industry and members of the public may provide their views, as appropriate.

5:30 - 5:45 P.M. ***BREAK***

- 6) 5:45 - 7:00 P.M. Preparation of ACRS Reports (Open)
Discussion of proposed ACRS reports on:
- 6.1) Draft Final Regulatory Guide, DG-1145, "Combined License Applications for Nuclear Power Plants" (TSK/DCF)
 - 6.2) Draft Final Regulatory Guide, DG-1144, "Guidelines for Evaluating Fatigue Analyses Incorporating the Life Reduction of Metal Components Due to the Effects of the Light-Water Reactor Environment for New Reactors" (JSA/CGH/CS)
 - 6.3) Proposed Revisions to Standard Review Plan Section 13.3, "Emergency Planning" (MLC/DAP/MB)
 - 6.4) State-of-the-Art Reactor Consequence Analysis Project (Tentative) (WJS/HPN)
 - 6.5) Collaborative Research on Human Reliability Analysis Methods (GEA/EAT)

FRIDAY, DECEMBER 8, 2006, CONFERENCE ROOM T-2B3, TWO WHITE FLINT NORTH, ROCKVILLE, MARYLAND

- 7) 8:30 - 8:35 A.M. Opening Remarks by the ACRS Chairman (Open) (GBW/JTL/SD)
- 8) 8:35 - 9:30 A.M. Proposed Revisions to Regulatory Guides and Standard Review Plan Sections in Support of New Reactor Licensing (Open)
(OLM/DCF)
- 8.1) Remarks by the Subcommittee Chairman
 - 8.2) Discussion of proposed revisions to Regulatory Guides and Standard Review Plan Sections that are being made in support of new reactor licensing.


- 9) 9:30 - 10:30 A.M. Future ACRS Activities/Report of the Planning and Procedures Subcommittee (Open) (GBW/JTL/SD)
9.1) Discussion of the recommendations of the Planning and Procedures Subcommittee regarding items proposed for consideration by the full Committee during future ACRS meetings.
9.2) Report of the Planning and Procedures Subcommittee on matters related to the conduct of ACRS business, including anticipated workload and member assignments.
- 10:30 - 10:45 A.M. ***BREAK*****
- 10) 10:45 - 11:00 A.M. Reconciliation of ACRS Comments and Recommendations (Open) (GBW, et al./SD, et al.)
Discussion of the responses from the NRC Executive Director for Operations to comments and recommendations included in recent ACRS reports and letters.
- 11) 11:00 - 11:30 A.M. Election of ACRS Officers for CY 2007 (Open) (JTL/SD)
Election of Chairman and Vice-Chairman for the ACRS and Member-at-Large for the Planning and Procedures Subcommittee.
- 11:30 - 1:00 P.M. ***LUNCH*****
- 12) 1:00 - 7:00 P.M. Preparation of ACRS Reports (Open)
Discussion of proposed ACRS reports on:
12.1) Draft Final Regulatory Guide, DG-1145, "Combined License Applications for Nuclear Power Plants" (TSK/DCF)
12.2) Draft Final Regulatory Guide, DG-1144, "Guidelines for Evaluating Fatigue Analyses Incorporating the Life Reduction of Metal Components Due to the Effects of the Light-Water Reactor Environment for New Reactors" (JSA/CGH/CS)
12.3) Proposed Revisions to Standard Review Plan Section 13.3, "Emergency Planning" (MLC/DAP/MB)
12.4) State-of-the-Art Reactor Consequence Analysis Project (Tentative) (WJS/HPN)
12.5) Collaborative Research on Human Reliability Analysis Methods (GEA/EAT)

**SATURDAY, DECEMBER 9, 2006, CONFERENCE ROOM T-2B3, TWO WHITE FLINT
NORTH, ROCKVILLE, MARYLAND**

- 13) 8:30 - 12:00 Noon Preparation of ACRS Reports (Open)
(10:15-10:30 A.M. BREAK) Continue discussion of proposed ACRS reports listed under
Item 12
- 14) 12:00 - 12:30 P.M. Miscellaneous (Open) (GBW/JTL)
Discussion of matters related to the conduct of Committee
activities and matters and specific issues that were not
completed during previous meetings, as time and availability
of information permit.

NOTE:


- Presentation time should not exceed 50 percent of the total time allocated for a specific item. The remaining 50 percent of the time is reserved for discussion.
- Thirty-Five (35) hard copies and (1) electronic copy of the presentation materials should be provided to the ACRS.



ACRS Full Committee
Meeting

Presentation on DG-1145

December 7, 2006



Draft Regulatory DG-1145,
“Combined License (COL)
Applications for Nuclear Power
Plants (LWR Edition)”

Eric R. Oesterle, Lead PM
NRO/DNRL/NGIF




DG-1145 Overview

Purpose

- Provide guidance to potential applicants on format and content for a combined license (COL) application pursuant to 10 CFR 52
- COL referencing neither a certified design (CD) nor an early site permit (ESP)
- COL referencing a CD but not an ESP
- COL referencing a CD and an ESP

December 7, 2006

3




DG-1145 Overview (cont'd)

Background and Developmental Basis

- Industry guidance for COL applications (NEI 04-01)
- NEI 04-01 provided guidance for “base case” COL application
- NRC interactions with external stakeholders identified several COL application scenarios
- Staff recognized the need for more comprehensive guidance for COL applicants

December 7, 2006

4



DG-1145 Overview (cont'd)

Development Basis

- RG 1.70, "Standard Format and Content of Safety Analysis Reports for Nuclear Power Plants (LWR Edition)
- Updated SRP revisions (including draft 1996 updates)
- Draft NEI 04-01 guidance for COL applications
- NRC design certification and ESP experience
- SECY papers and associated SRMs

December 7, 2006

5



DG-1145 Overview (cont'd)

Development Basis (cont'd)

- Proposed Part 52 rule issued on March 13, 2006 (71 FR 12782)
- Monthly public workshops (March 2006 – September 2006) ~ 500 comments
- All draft work-in-progress sections publicly available via NRC's website by June 30, 2006
- DG-1145 issued for 45-day public comment period on September 7, 2006 (71 FR 52826)

December 7, 2006

6




DG-1145 Overview (cont'd)

Format and Structure


- Part C.I – guidance for a COL applicant that references neither a CD nor an ESP (consistent with proposed 10 CFR Part 52.79)
- Part C.II – additional technical information (consistent with proposed 10 CFR Part 52.80)
- Part C.III – COL applicants referencing CDs and ESPs
- Part C.IV – Miscellaneous Topics

December 7, 2006

7





DG-1145 Overview (cont'd)



December 7, 2006

8

 DG-1145 Overview (cont'd) Format and Structure – Part C.I	
C.I.1 Introduction and General Plant Description*	C.I.11 Radioactive Waste Management
C.I.2 Site Characteristics	C.I.12 Radiation Protection
C.I.3 Design of Structures, Systems, Components and Equipment	C.I.13 Conduct of Operations
C.I.4 Reactor	C.I.14 Verification Programs
C.I.5 RCS and Connected Systems	C.I.15 Transient and Accident Analyses
C.I.6 Engineered Safety Features	C.I.16 Technical Specifications
C.I.7 Instrumentation and Control	C.I.17 Quality Assurance and Reliability Assurance
C.I.8 Electrical Power	C.I.18 Human Factors Engineering
C.I.9 Auxiliary Systems	C.I.19 Probabilistic Risk Assessment Information and Severe Accidents*
C.I.10 Steam and Power Conversion System	
December 7, 2006	9

 DG-1145 Overview (cont'd)	
Format and Structure – Part C.II	
C.II.1 - Probabilistic Risk Assessment (PRA)	
C.II.2 - Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC)	
C.II.3 - Environmental Report	
December 7, 2006	10



DG-1145 Overview (cont'd)

Format and Structure – Part C.III

- C.III.1 - Information Needed for a COL Application Referencing a CD (consistent format with C.I)
- C.III.2 - Information Needed for a COL Application Referencing a CD and an ESP (consistent format with C.I)
- C.III.3 - Finality of an EIS Associated with an ESP
- C.III.4 - COL Action Items
- C.III.5 - Design Acceptance Criteria
- C.III.6 - COL Application Timing
- C.III.7 - ITAAC for COL Applications Referencing a CD and/or an ESP

December 7, 2006

11



DG-1145 Overview (cont'd)

Format and Structure – Part C.IV

- C.IV.1 - COL Application Acceptance Review Checklist
- C.IV.2 - Submittal Guidance for COLs
- C.IV.3 - General Description of Change Process
- C.IV.4 - Operational Programs
- C.IV.5 - General and Financial Information
- C.IV.6 - Limited Work Authorizations and Site Redress Plan*
- C.IV.7 - Pre-Application Activities
- C.IV.8 - Generic Issues
- C.IV.9 - deleted
- C.IV.10 - Regulatory Treatment of Non-Safety Systems (RTNSS)
- C.IV.11 - relocated to App. I (responses to public workshop questions)
- C.IV.12 - Applicability of Industry Guidance*

December 7, 2006

12



DG-1145 Overview (cont'd)

Status

- Comment period on DG-1145 closed on October 23, 2006
- Approximately 700 total comments received
- Staff is currently working to resolve public comments and revise DG-1145, as appropriate, and conform to proposed final Part 52 rule
- Process in place to ensure consistency between DG-1145 and the SRP and Reg. Guide updates
- Plan to publish final (RG 1.206) after incorporation of public comments and final issuance of the Part 52 rule
- Staff considering additional public forums to update external stakeholders on RG 1.206 prior to publication


December 7, 2006

13



DG-1145 Overview (cont'd)

New Reactor Licensing Infrastructure Timeline



December 7, 2006

14

DG-1145

PRA & Severe Accident Evaluations

ACRS Presentation

Donnie Harrison
Senior Reliability & Risk Analyst
NRR Division of Risk Assessment (DRA)

December 7, 2006

Discussion Topics

- **Recent Change to Proposed 10 CFR Part 52**
- **Bases for Regulatory Guidance**
- **Objectives of PRA & Severe Accident Evaluations**
- **Chapter 19 Regulatory Guidance**

Recent Change to Proposed 10 CFR Part 52

- Proposed 10 CFR Part 52 rulemaking included new 52.80(a) requirement for COL applicants to submit plant-specific PRA
- After completion of DG-1145, the NRC position changed to accept the industry comment to delete this requirement - PRA maintained available for staff inspection at the applicant's office
- Requirement deleted throughout Part 52, including the existing requirement for design certification applications

3

Impact of Change to Proposed 10 CFR Part 52

- DG-1145 will need to be revised to reflect the change in NRC position
 - Majority of guidance presented in C.II.1 (PRA) will need to be incorporated into C.I.19 (FSAR Chapter 19)
- Since FSAR Chapter 19 is a qualitative, summary description of the PRA, results, insights, uses, etc., staff audits will be necessary to fully understand, review, and confirm the bases for the PRA results and insights and adequacy for the PRA uses/applications

4

Bases for Regulatory Guidance

- NRC Policy Statements and SECYs/SRMs
- Experience with Design Certification reviews for CE System 80+, ABWR, AP-600, and AP-1000
- 10 CFR 52.79 PRA/Severe Accident Requirements

5

Objectives of PRA & Severe Accident Evaluations

- Derived from NRC Policy Statements and SECYs/SRMs
- Two Groups of Objectives
 - Identify and assess the balance of preventive and mitigative features (including operator actions) such that the plant design reflects a reduction in risk compared to existing plants(contemporary with Severe Accident Policy Statement of 1985)
 - Specific uses and applications of the PRA results and insights in support of other programs (e.g., RAP, RTNSS, ITAACs, COL and interface requirements)

6

Chapter 19 Regulatory Guidance

19.1 Introduction

19.2 PRA Results and Insights


19.3 Severe Accident Evaluations

19.4 PRA Maintenance

19.5 PRA-Related ITAACs, COL Action
Items, & Other Commitments

19.6 Conclusions

7



DG-1145: Workshop Issues and Public Comments

Eric R. Oesterle, Lead PM
NRO/DNRL/NGIF



DG-1145: Workshop Issues and Public Comments

- Development began in January 2006
- Draft work-in-progress sections posted on the NRC's website following completion to facilitate public workshop discussions
- Monthly public workshops on DG-1145 held from March 2006 to September 2006
- Resolved and incorporated 500 public workshop comments to issue draft for public comment (Appendix I)

December 7, 2006

2



DG-1145: Workshop Issues and Public Comments

- Issued DG-1145 for public comment on September 7, 2006
- Comment period closed October 23, 2006
- Staff received approximately 700 public comments on DG-1145
- Comments also reflect external stakeholder concerns raised during the monthly public workshops on development of DG-1145

December 7, 2006

3




DG-1145: Workshop Issues and Public Comments

- COL information availability
- Verification activities (inspections vs. ITAAC)
- First-of-a-kind-Engineering (FOAKE) inspections/audits
- Engineering design verification (EDV)


December 7, 2006

4



DG-1145
**Conformance, Completeness,
and Consistency**

Eric R. Oesterle, Lead PM
NRO/DNRL/NGIF



**DG-1145: Conformance,
Completeness, and Consistency**

- Staff is currently working to resolve public comments and revise DG-1145
- Conform DG-1145 to proposed final Part 52 rule and updated SRPs
- Internal staff review for consistency, completeness and usability began in early October 2006 (DG-1145 Reading Team)
- Team has confirmed approx. 1/3 of public comments and has made additional comments to those provided by public

December 7, 2006 2



DG-1145: Conformance, Completeness, and Consistency

- DG-1145 to be published final as Regulatory Guide 1.206
- RG 1.206 to be published following Commission approval of Part 52 rule and resolution of public comments
- Staff considering additional public forums to update external stakeholders on RG 1.206 prior to publication

December 7, 2006

3



DG-1145: Workshop Issues and Public Comments

- Plants incorporating passive safety design features
- Plant-specific PRA (LRF, CCFP, COL PRA Information)
- Maintenance Rule (breakout session)
- Digital I&C (breakout sessions)
- ITAAC

December 7, 2006

5



DG-1145: Workshop Issues and Public Comments

- Environmental Reports and Finality of an EIS associated with an ESP
- Human factors engineering
- Radwaste treatment facilities
- Including guidance contained in responses to public workshop questions

December 7, 2006

6



**RG 1.207 -
GUIDELINES FOR EVALUATING FATIGUE
ANALYSES INCORPORATING THE LIFE
REDUCTION OF METAL COMPONENTS DUE TO
THE EFFECTS OF THE LIGHT-WATER REACTOR
ENVIRONMENT FOR NEW REACTORS**

Hipólito J. González
Corrosion and Metallurgy Branch
Division of Fuel, Engineering and Radiological Research
Office of Nuclear Regulatory Research
(301) 415-0068
hjg@nrc.gov

Omesh K. Chopra
Nuclear Engineering Division
Argonne National Laboratory
(630) 252-5117
okc@anl.gov

Presented to
Advisory Committee on Reactor Safeguards
Rockville, Maryland
December 7, 2006

1



Agenda

- Motivation
- Discuss RG 1.207
 - Objective and Implementation
 - Technical Basis
 - Regulatory Positions
- Resolution of public comments on DG-1144 and draft NUREG/CR-6909
- Conclusion

2



RG 1.207 User Need

- NRR User Need Request 2005-004 (January 7, 2005):
 - Develop guidance for determining the acceptable fatigue life of ASME pressure boundary components, with consideration of the LWR environment
 - For use in supporting reviews of applications that the agency expects to receive for new reactors.
 - Industry immediately notified
- High priority RG to be completed by March 2007

3



How RG 1.207 relates to the Regulatory Requirements

- General Design Criterion 1
 - Safety related SSC must be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety function performed
- General Design Criterion 30
 - Components included in the reactor pressure boundary must be designed, fabricated, erected, and tested to the highest practical quality standards
- 10 CFR 50.55a (c), endorses ASME BPV Code for design of safety-related systems and components (Class 1)
 - ASME BPV Code Section III, includes fatigue design curves
- Fatigue design curves do not address the impact of the reactor coolant system environment

4



Objective and Implementation of RG 1.207

Objective

- To provide guidance for determining the acceptable fatigue life of ASME pressure boundary components, considering the LWR environment
 - Major structural materials: carbon steels, low-alloy steels, austenitic stainless steels, and Ni-Cr-Fe alloys (e.g., Alloy 600 and 690)
- Describes an approach that the NRC staff considers acceptable to support reviews of applications for new reactors

Implementation

- Applies to New Plants
- No Backfitting is intended (conservatism on current reactors)
- Regulatory guides are not substitutes for regulations, and compliance with regulatory guides is not required.

5



How the Technical Basis was Developed?

6



Technical Basis Report: NUREG/CR-6909 Rev. 1 – Effect of LWR Coolant Environment on Fatigue Life of Reactor Materials

Omesh K. Chopra
Nuclear Engineering Division
Argonne National Laboratory



7



Issue - Environmental Effects on Fatigue Life

- Fatigue data indicate significant effects of LWR environment
- Data are consistent with each other & with much larger database for fatigue crack growth (da/dN)
 - in LWR environments, effects of material, loading, and environmental parameters are similar for fatigue ϵ -N & CGR data
- ϵ -N data have been evaluated to
 - identify key parameters that influence fatigue life, &
 - define range for these parameters where environmental effects are significant, i.e., establish threshold & saturation values
- If these conditions exist during reactor operation, environmental effects will be significant & must be addressed
 - subsection NB-3121 recognizes that the data used to develop the fatigue design curves did not include tests in environments that might accelerate fatigue failure

8



Fatigue Life

- Existing fatigue data define fatigue life of specimens as cycles to 25% load drop; typically this corresponds to a ≈ 3 mm crack
- Surface cracks ≈ 10 μm deep form early during fatigue loading
- Fatigue life associated with growth of cracks; 10 to 3000 μm
- Represented by two stages:
 - Initiation: growth of cracks, < 300 μm
 - Propagation: growth of cracks 300-3000 μm (EPFM)
- LWR coolant environment affects both stages:
 - initiation & propagation

9





ASME Code Fatigue Design Curves

- Code design curves based on data obtained on small, smooth specimens in RT air under constant loading conditions
- To use small-specimen data for reactor components, best-fit curves must be adjusted to cover effects of variables that influence fatigue life but were not investigated in the data
 - such variables include mean stress, surface finish, size, & loading history. Data scatter & material variability must also be addressed
- To obtain Code design curves the best-fit curves were
 - first adjusted for effects of mean stress on fatigue life
 - then reduced by factor of 2 on stress & 20 on life to account for these variables, but not an aggressive environment

10



Current Code Mean Curve for Austenitic SSs



- Current Code mean curve is not consistent with existing fatigue data in air, at $\epsilon_a < 0.3\%$ it predicts significantly longer lives
- New design curves have been proposed that are consistent with the existing fatigue data

11



Environmental Effects on Carbon & Low-Alloy Steels

- The effects of critical parameters on fatigue life:
 - **Steel type**: effects identical for carbon & low-alloy steels
 - **Strain amp**: strain threshold near fatigue limit; no effect below threshold
 - **Strain rate**: logarithmic decrease in life below 1%/s, saturation at 0.001%/s; moderate effects above 1%/s
 - **Temperature**: linear decrease in life above 150°C; moderate effects below 150°C
 - **Dissolved Oxygen**: logarithmic decrease in life above 0.04 ppm, saturation at 0.5 ppm; moderate effects below 0.04 ppm
 - **Sulfur**: effects increase with increasing S level, saturation at 0.015 wt.%
 - **Surface roughness**: life of rough specimens is decreased in air; in high-DO water, surface roughness has little or no effect on fatigue life
 - **Flow rate**: in high-DO water, effects decrease with increasing flow rate

12



Environmental Effects on Austenitic Stainless Steels

- The effects of critical parameters on fatigue life:
 - Steel type: effects identical for wrought & cast austenitic stainless steels
 - **Strain amp**: threshold near fatigue limit; no effect below threshold
 - Strain rate: logarithmic decrease in life below 0.4%/s, saturation at 0.0004%/s; moderate effects above 0.4%/s
 - Temperature: linear decrease in life above 150°C; moderate effects below 150°C
 - Dissolved Oxygen: in high-DO, effect may be lower for some steels; in low-DO, effect significant for all steels & heat treat conditions;
 - Surface roughness: life of rough specimens decreased in air & low-DO water
 - Flow rate: no effect of flow rate on fatigue life in high-purity water

13



Carbon and Low-Alloy Steels

Air	$\ln[N] = 6.583 - 1.975 \ln(\epsilon_a - 0.113)$	(CSs)
	$\ln[N] = 6.449 - 1.808 \ln(\epsilon_a - 0.151)$	(LASs)
Env	$\ln[N] = 5.951 - 1.975 \ln(\epsilon_a - 0.113) + 0.101 S^*T^*O^*R^*$	(CSs)
	$\ln[N] = 5.747 - 1.808 \ln(\epsilon_a - 0.151) + 0.101 S^*T^*O^*R^*$	(LASs)
where	$S^* = S$	(S ≤ 0.015 wt.%)
	$S^* = 0.015$	(S > 0.015 wt.%)
	$T^* = 0$	(T < 150°C)
	$T^* = T - 150$	(T = 150 to 320°C)
	$O^* = 0$	(DO < 0.04 ppm)
	$O^* = \ln(DO/0.04)$	(0.04 ppm < DO ≤ 0.5 ppm)
	$O^* = \ln(12.5)$	(DO > 0.5 ppm)
	$R^* = 0$	(R > 1%/s)
	$R^* = \ln(R)$	(0.001 ≤ R ≤ 1%/s)
	$R^* = \ln(0.001)$	(R < 0.001%/s)

- These expressions represent average fatigue life of the median material

14



Wrought & Cast Austenitic SSs

Air $\ln[N] = 6.891 - 1.920 \ln(\epsilon_a - 0.112)$
 Env $\ln[N] = 6.157 - 1.920 \ln(\epsilon_a - 0.112) + T^*O^*R^*$
 where $T^* = 0$ ($T < 150^\circ\text{C}$)
 $T^* = (T - 150)/175$ ($150 \leq T < 325^\circ\text{C}$)
 $T^* = 1$ ($T \geq 325^\circ\text{C}$)
 $O^* = 0.281$ (all DO levels)
 $R^* = 0$ ($R > 0.4\%/s$)
 $R^* = \ln(R/0.4)$ ($0.0004 \leq R \leq 0.4\%/s$)
 $R^* = \ln(0.0004/0.4)$ ($R < 0.0004\%/s$)



- These expressions represent average fatigue life of the median material

15



Stainless Steel Tube U-Bend Tests in PWR Water at 240°C

- Applicability of laboratory data to component behavior has been demonstrated by several component tests



- Measured environmental reduction factor
 $F_{en} = 10,000/1,728 = 5.8$ at $0.0005\%/s$ & $= 10,000/3,624 = 2.8$ at $0.01\%/s$.
 Predicted values are 5.5 and 3.6, respectively

16



Fatigue Life of Components

- Available information reviewed to better define adjustment factor on life that must be applied to mean-data curve to account for effects of variables that influence life but were not explicitly addressed in the data



Parameter	ASME Code	Presented Study
Material Variability & Data Scatter	2.0	2.1 - 2.8
Size	2.5	1.2 - 1.4
Surface Finish	4.0	2.0 - 3.5
Loading History	–	1.2 - 2.0
Total Adjustment Factor	20	6 - 27

- Monte Carlo simulations performed to determine distribution of A for adjusted fatigue curve that represents behavior of actual component.
- Use material variability & data scatter results from present analysis
- Assume a lognormal distribution for effects of size, surface finish, & loading history, & min and max values of adjustment factor assumed to represent 5th and 95th percentile, respectively
- Assume effects can be considered as independent based on engineering judgment

17



Fatigue Design Adjustment Factors



- Monte Carlo analysis suggests adjustment applied to mean values of specimen fatigue life to bound component fatigue life of 95% of population is ≈ 12 . Thus, current Code requirements of factor of 20 on life is conservative by about a factor of ≈ 1.7 for components

18



Methods for Incorporating Environmental Effects

- Two approaches proposed for incorporating effects of LWR coolant environments into Code fatigue evaluations:
 - develop new fatigue design curves for LWR environments
 - use an environmental fatigue correction factor F_{en}
- Because fatigue life in LWR environments depends on several loading & environmental parameters, design curve approach would require developing multiple design curves to cover range of conditions or a conservative bounding curve
- The F_{en} approach is relatively simple and flexible enough to address effects without unnecessary conservatism

19



F_{en} Method for Incorporating Environmental Effects

- F_{en} is defined as ratio of fatigue life in air at RT to that in water under service conditions

$$\ln[F_{en}] = \ln(N_{RTair}) - \ln(N_{water})$$

$$F_{en} = \exp(0.632 - 0.101 S^*T^*O^*R^*) \text{ (Carbon Steels)}$$

$$F_{en} = \exp(0.702 - 0.101 S^*T^*O^*R^*) \text{ (Low-Alloy Steels)}$$

$$F_{en} = \exp(0.734 - T^*O^*R^*) \text{ (Stainless Steels)}$$

$$F_{en} = 1 \quad (\epsilon_a \leq 0.07\% \text{ CLAS \& } \leq 0.10\% \text{ SSs})$$

- To incorporate environmental effects, fatigue usage based on air curve is multiplied by F_{en}

$$U_{en} = U_1 F_{en,1} + U_2 F_{en,2} \dots U_n F_{en,n}$$

20



Fen Method (Contd.)

- For CSs & LASs, current Code design curves are either consistent or conservative with respect to existing data
 - usage factors can be based on current Code design curves, or
 - to reduce conservatism, use design curves based on ANL models and adjustment factors of 2 & 12
- For austenitic SSs & Ni-Cr-Fe alloys, current Code design curve for SSs is nonconservative with respect to existing data
 - usage factors should be determined from the new design curves based on ANL model and adjustment factors of 2 & 12
 - current Code design curve should not be used because it will yield nonconservative estimates of CUF

21



Regulatory Positions

22



Regulatory Position 1: Carbon and Low-Alloy Steels

- ✓ Calculate fatigue usage in air with ASME Code Analysis procedures +

- ✓ ASME Code air curves, **or**
 - ✓ New ANL model air curves

- ✓ Calculate the F_{en} using

- ✓ Equation A.2 (CS),

$$F_{en} = \exp(0.632 - 0.101 S^* T^* O^* \dot{\epsilon}^*)$$

- ✓ Equation A.3 (LAS)



$$F_{en} = \exp(0.702 - 0.101 S^* T^* O^* \dot{\epsilon}^*)$$

(Appendix A of NUREG/CR-6909)

- ✓ Calculate the environmental fatigue usage (U_{en})

$$U_{en} = U_1 F_{en,1} + U_2 F_{en,2} \dots U_n F_{en,n}$$

23



Regulatory Position 2: Austenitic Stainless Steels

- ✓ Calculate fatigue usage in air with ASME Code Analysis procedures +

- ✓ **New ANL model air SS curve**

- ✓ Calculate the F_{en} using

- ✓ Equation A.9


$$F_{en} = \exp(0.702 - 0.101 S^* T^* O^* \dot{\epsilon}^*)$$

(Appendix A of NUREG/CR-6909)

- ✓ Calculate the environmental fatigue usage (U_{en})

$$U_{en} = U_1 F_{en,1} + U_2 F_{en,2} \dots U_n F_{en,n}$$

24






Regulatory Position 3: Ni-Cr-Fe Alloys (e.g., Alloy 600 and 690)

- ✓ Calculate fatigue usage in air with ASME Code Analysis procedures +
 - ✓ **New ANL model air SS curve**
- ✓ Calculate the F_{en} using
 - ✓ Equation A.14
$$F_{en} = \exp(T \cdot O \cdot \dot{\epsilon}^*)$$

(Appendix A of NUREG/CR-6909)
- ✓ Calculate the environmental fatigue usage (U_{en})

$$U_{en} = U_1 F_{en,1} + U_2 F_{en,2} \dots U_n F_{en,n}$$



25



Summary

- RG 1.207 endorses the use of new air curve for SSs
- RG 1.207 endorses the F_{en} methodology
- Guidance on incorporating environmental correction factor to fatigue design analyses
 - Appendix A of NUREG/CR-6909 Rev. 1
- NUREG/CR-6909 Rev. 1 describes in detail the technical basis

26



Resolution of Public Comments

- July 24, 2006 - DG-1144 and draft NUREG/CR-6909 published for public comments (60 day comment period)
- Public comment period ended September 25, 2006

27



Resolution of Public Comments (cont.)

- 8 correspondents submitted a total of 56 comments on DG-1144 and draft NUREG/CR-6909
 - All comments addressed individually
- Final RG 1.207 and NUREG/CR-6909 Rev. 1 reflects the resolution of these comments
- 6 main issues identified

28



Resolution of Public Comments (cont.)

Staff Response to Public Comments on DG-1144 and Draft NUREG/CR-6909

#	Source	Comment**	Response
1	I-1a.	Each Comment appears individually in this column.	NRC staff response for each comment.

Source I:	Ronnie L. Gardner, AREVA NP, Inc.	ML060900256
Source II:	Takao NAKAMURA, The Kansai Electric Power Co., Inc.	ML060790143
Source III:	James H. Riley, Nuclear Energy Institute	ML060790126
Source IV:	C. L. Funderburk, Dominion Resources Services, Inc.	ML060790144
Source V:	Makoto HIGUCHI, Ichikawa-Jima-Hitachi Heavy Industries Co., Ltd.	ML060790138
Source VI:	Robert E. Brown, GE Energy Nuclear	ML060790141
Source VII:	Gerry C. Slagis, G.C. Slagis Associates, Consulting Engineering	ML060600349
Source VIII:	Kenneth R. Balkey, Nuclear Codes and Standards, American Society of Mechanical Engineers	ML060790139

** Comments are quoted directly from the letter submitted by the commenter.



Resolution of Public Comments (cont.)

- Six issues (comment id #'s):
 1. Operating experience and applicability of specimen data (1, 7, 14, 16, 45)
 2. Details on approach (22, 24, 27, 37)
 3. Ni-Cr-Fe alloy fatigue curve (20, 25, 44)
 4. Burden due to increase in locations required to be analyzed (2, 43)
 5. Overly conservative position (4, 5, 15)
 6. ASME Code case (56)



1. Operating experience and applicability of specimen data (1, 7, 14, 16, 45)

Issue:

- *There is no operating experience that supports the need for these conservative design rules.*
- *Comments questioning the applicability of specimen data being representative of actual components in service.*

Staff Response:

- Numerous examples of fatigue cracking of nuclear power plant components reported - EPRI TR-106696.
- Applicability of laboratory data to component behavior has been demonstrated by mock-up and component tests (references provided in previous presentation). In fact, is the basis for the current ASME Code fatigue curves.

31



2. Details on approach (22, 24, 27, 37)

Issues:

- *References made to other guidance containing similar Fen approach (Japan) also acceptable/endorsed?*
- *"Since DG-1144 utilizes a similar Fen methodology to that evaluated in MRP-47, Rev.1, the issues identified in MRP-47, Rev.1 are considered to be equally applicable to the DG-1144 methodology. Some, but not all, of the issues raised in MRP-47, Rev.1 have been specifically addressed in DG-1144. Based on this, the MRP would like to see clarification on the remaining issues included in DG-1144 or the supporting document".*

Staff Response:

- The papers listed in NUREG/CR-6909 are for reference only. Section C, Regulatory Position, of the regulatory guide contains the methodology endorsed by the staff.
- The level of analytical detail discussed on additional items on MRP-47, Rev.1 are beyond the scope of this regulatory guide.

32



3. Ni-Cr-Fe alloy fatigue curve (20, 25, 44)

Issue:

Provide guidance for Ni-Cr-Fe alloys (e.g., Alloy 600 and 690).

Staff Response:

The staff incorporated F_{en} methodology for Ni-Cr-Fe alloy materials into RG 1.207 (RP 3) and NUREG/CR-6909 Rev. 1 (Section 6).

33



4. Burden due to increase in locations required to be analyzed (2, 43)

Issue:

Increase in the CUFs will lead to more analyzed piping break locations, to more installed pipe whip restraints, and to designs that will be more detrimental for normal (thermal expansion) operating conditions.

Staff Response:

- Staff will consider a justified modification with the appropriate technical basis of the fatigue criteria for postulation of pipe breaks if implementation of the current criteria results in a significant increase in the number of required pipe whip restraints.
- The necessity for additional pipe restraints will disappear with a successful LBB analysis

34



5. Overly conservative position (4, 5, 15)

Issue:

Commenter believes that the alternative methods for fatigue analysis provided in NUREG/CR-6909 and DG-1144 are too conservative and should not be used for the design of new reactors.

Staff Response:

The staff position is based on a 95% confidence that there is less than 5% probability of fatigue crack initiation. Implementation of this criteria resulted in a carbon steel and low-alloy steel air curves which are less conservative than the existing ASME Code curve

35



6. ASME Code case (56)

Issue:

“ASME will continue to develop other Code Cases covering alternative ways of addressing [the impact of the LWR environment]... and the Code Case will be issued early in 2007. Once these Code Cases are issued, ASME requests the NRC to endorse these Code Cases in a revision of the Regulatory Guide 1.84”.

Staff Response:

The NRC staff will consider endorsing available ASME Code Cases through its normal process for revising Regulatory Guide 1.84.

36



Revisions made from DG-1144 to RG 1.207

Main revision:

- The staff incorporated F_{en} methodology for Ni-Cr-Fe alloy materials into RG 1.207 (RP 3) and NUREG/CR-6909 Rev. 1 (Section 6).
- High Cycle Fatigue Regime ($> 10^6$ cycles)

Other:

Some editorial changes for clarification on the technical basis NUREG/CR-6909

37



Conclusion

RG 1.207 is ready for issuance

- Final RG 1.207 and NUREG/CR-6909 Rev. 1 reflects the resolution of these comments
- Final RG 1.207 and NUREG/CR-6909 Rev.1 will be published by March 2007 (High priority RG)
- Seeking ACRS concurrence to publish final effective guide

38



Proposed Revision to Section 13.3, “Emergency Planning” (EP) of the Standard Review Plan (SRP) & Combined License Application Guidance (DG-1145)

Presented By

Daniel M. Barss

Sr. Emergency Preparedness Specialist
Division of Preparedness and Response
Office of Nuclear Security and Incident Response
U.S. Nuclear Regulatory Commission

DMB1@NRC.GOV


301-415-2922



Section 13.3, “EP” of the SRP and DG-1145

- Standard Review Plan (SRP) (NUREG-0800) Section 13.3, “Emergency Planning”
- COL Application Guidance (DG-1145) Section 13.3, “Emergency Planning”

Combined Licenses, Early Site Permits, and Standard Design Certifications



* or equivalent process



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process

- Emergency Planning continues to be a part of the licensing process. (10 CFR 50.33, 50.34, 50.47, 50.54, and Appendix E, and 10 CFR part 52)
- President’s decision of December 7, 1979 reemphasizes the NRC’s continuing statutory responsibility for the radiological health and safety of the public.



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process (cont'd.)

- Emergency Preparedness "Reasonable Assurance" finding needed prior to issuing License - 10 CFR 50.47(a)
- **NRC** makes this finding based on:
 - A review of FEMA (**DHS**) findings and determinations concerning **offsite** plans
 - and **NRC** findings and determinations concerning **onsite** plans.
 - NRC/FEMA Memorandum of Understanding establishes working relationship - 44 CFR 353, Appendix A



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process (cont'd.)

- 16 Planning Standards of 10 CFR 50.47(b)
- Requirements of 10 CFR 50, Appendix E
- Regulatory Guide 1.101
 - NUREG-0654, FEMA-REP-1, Rev. 1
Acceptance Criteria
 - NEI 99-01, Rev. 4, EALs



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process *(cont'd.)*

- Emergency Preparedness (EP)
 - A “Licensing Condition” - 10 CFR 50.54(q)
 - Deficiency 120 day clock - 10 CFR 50.54(s)
 - Reality presumption - 10 CFR 50.47(c)
 - Supported by two sets of plans:
 - “Onsite” emergency plan (Facility plan)
 - “Offsite” emergency plan (State & local plans)



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process *(cont'd.)*

- **10 CFR Part 50**
 - **2-Step Process:**
 - Construction Permit
 - Operating License



An EP Perspective on New Reactor Licensing

Regulatory Process (cont'd.)

- **10 CFR Part 52 – Alternative licensing process**
 - **Established in 1989**
 - Improve Regulatory Efficiency
 - Add Greater Predictability
 - Essentially the Same Information as Part 50
 - Combines Construction Permit & Operating License with Conditions for Plant Operation – Combined License (COL)
 - Specify Applicant Inspection, Tests, Analysis and Acceptance Criteria (ITAAC)



An EP Perspective on New Reactor Licensing

Regulatory Process (cont'd.)

- **10 CFR Part 52 – Alternative licensing process**
 - **Acceptance Criteria**
 - Provide Reasonable Assurance that the facility has been constructed and will operate in conformity with the license and applicable regulations



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process *(cont'd.)*

- 10 CFR Part 52 – Combined License
 - NRC
 - Authorize fuel load ONLY after ITAAC met
 - Periodic Federal Register Notice as ITAAC met
 - 180 days prior to scheduled initial loading of fuel
 - *Publish notice of intended operation in Federal Register*
 - Hearing opportunity if petitioner demonstrates that Acceptance Criteria not met



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process (cont'd.)

- COL
 - **10 CFR 52.79(d) *proposed* 10 CFR 52.79(22)**
 - Obtain Certifications from agencies with EP responsibilities that:
 - (A) Plans are practicable
 - (B) Commitment to further develop plans including field demonstrations
 - (C) Commitment to execute responsibilities



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process (cont'd.)

- COL
 - *Proposed 10 CFR 50.54(gg)*
 - Allows operation up to 5% power with offsite deficiencies
 - Much like existing requirement in 10 CFR 50.47(d)



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process *(cont'd.)*

- **10 CFR Part 52 – Combined License**
 - **COL can incorporate by reference**
 - Design Certification
 - Early Site Permit
 - **Issues resolved in ESP or Design Certification are precluded from reconsideration at COL Stage**



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process *(cont’d.)*

- Standard Design Certification
 - ***10 CFR 52 Subpart B***
 - Allows certification of Nuclear power facilities separate from filing an application for construction or combined license
 - No specific EP Requirements



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process *(cont'd.)*

- **Early Site Permit (ESP)**
 - **Independent of Plant Design**
 - **Valid for 10 – 20 Years, Renewable**
 - **Resolve early issues on**
 - **Site Safety**
 - **Emergency Preparedness**
 - **Environmental Protection**



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process *(cont'd.)*

- **Early Site Permit (ESP)**
 - **10 CFR 52.17**
 - (b)(1) Unique Physical Characteristics that could pose significant impediment to developing EP
 - (b)(2)(i) Major Features (NUREG-0654, Supplement 2)
 - (b)(2)(ii) Complete and Integrated Plans



Section 13.3, “EP” of the SRP and DG-1145

Regulatory Process (cont'd.)

- ESP (cont'd.)
 - **10 CFR 52.17 (cont'd.)**
 - (b)(3) Describe contacts and arrangements with agencies with EP responsibilities [(b)(1) & (b)(2)(i)],
OR
 - Obtain Certifications from agencies with EP responsibilities that [(b)(2)(ii)]:
 - (3)(i) Plans are practicable
 - (3)(ii) Commitment to further develop plans including field demonstrations
 - (3)(iii) Commitment to execute responsibilities



Section 13.3, “EP” of the SRP and DG-1145

- Standard Review Plan (SRP) (NUREG-0800) Section 13.3, “Emergency Planning”
- COL Application Guidance (DG-1145) Section 13.3, “Emergency Planning”



Section 13.3, “EP” of the SRP and DG-1145

SRP Section 13.3, EP

- Provides for review of EP in
 - Construction Permit (CP)
 - Operating License (OL)
 - Early Site Permit (ESP)
 - Standard Design Certification (DC)
 - Combined License (COL)



Section 13.3, “EP” of the SRP and DG-1145

SRP Section 13.3, EP

- Identifies Review Interfaces within SRP
- Identifies Regulatory Requirements
- Establishes Acceptance Criteria to existing Regulatory Guidance
- Provides Technical Rationale
- Outlines Review Procedure
- Proposes generic Evaluation findings
- Extensive Reference list
- Generic EP ITAAC Table



Section 13.3, “EP” of the SRP and DG-1145

SRP Section 13.3, EP

- Consideration of existing programs
 - Is it applicable to proposed reactor
 - Is it up-to-date
 - Reflects and incorporates new reactor



Section 13.3, “EP” of the SRP and DG-1145

SRP Section 13.3, EP

- Emergency Action Levels (EALs)
 - NEI 99-01 applicable EALs used
 - NEI 99-01 EAL development guidance
 - Passive reactor designs EALs



Section 13.3, “EP” of the SRP and DG-1145

SRP Section 13.3, EP

- Inspection, Test, Analysis, Acceptance Criteria (ITAAC)
 - Generic EP ITAAC provided in Table 13.3.1
 - Develop with Industry & public participation
 - Based on existing NUREG-0654 criteria
 - Not all-inclusive, or exclusive
 - Applicant proposes and accomplishes
 - Case-by-case determination



Section 13.3, “EP” of the SRP and DG-1145

SRP Section 13.3, EP

- Offsite EP Guidance
 - Current REP-series guidance documents
 - Associated Memoranda
 - Radiological Emergency Preparedness:
Planning Guidance, February 28, 2003



Section 13.3, “EP” of the SRP and DG-1145

SRP Section 13.3, EP

- Standard Design Certification EP (not required)
 - EP features are technically relevant to the design, and not site-specific, and usable for a multiple number of units or sites
 - Programmatic aspects of EP are COL applicants’ responsibility
 - Facilities, functions, and equipment to support EP
 - TSC, OSC, Personnel Decontamination
 - Location, size, habitability, ventilation systems
 - ERDS, SPDS, Voice and data Communications



Section 13.3, “EP” of the SRP and DG-1145

DG-1145 Section 13.3, EP

- Provides guidance on EP information in a Combined License for a
 - Custom design
 - Certified Design
 - Certified Design with ESP



Section 13.3, “EP” of the SRP and DG-1145

DG-1145 Section 13.3, EP

- Addresses EP information in a Combined License
 - Application & Emergency Plan Content
 - Multi-Unit Site considerations
 - EP ITAAC



Section 13.3, “EP” of the SRP and DG-1145

ACRS Preliminary Questions

- Substantive change to Section 13.3 is incorporation of Part 52 process
 - EP ITAAC
 - “Predictive” reasonable assurance finding
 - Timing of exercise



Section 13.3, “EP” of the SRP and DG-1145

ACRS Preliminary Questions

- Guidance for “green-field” sites
 - Existing guidance is applicable
 - Considered in development of generic EP ITAAC
 - Continue discussion with DHS
 - Plans needed at COL application stage
 - Implementing Procedures developed later



Section 13.3, “EP” of the SRP and DG-1145

ACRS Preliminary Questions

- **Completeness of EP ITAAC Table for ESP**
 - Generic EP ITAAC provided in Table 13.3.1
 - Develop with Industry & public participation
 - Based on existing NUREG-0654 criteria
 - Not all-inclusive, or exclusive
 - Applicant proposes and accomplishes
 - Case-by-case determination



Section 13.3, “EP” of the SRP and DG-1145

ACRS Preliminary Questions

- Diversity of planning options including evacuation, sheltering, and KI
 - NUREG-0654, J.10.f – KI
 - NUREG-0654, J.10.g - Evacuation
 - NUREG-0654, J.10.m - Shelter



Section 13.3, “EP” of the SRP and DG-1145

Comments from public review period

- Not open the existing site emergency plan for review
- Expansion of ITAAC
- Use of the term “generic communications”
- Submittal of offsite implementing procedures
- Absence of DHS/FEMA/REP, planning references and limited offsite emergency response plan related review criteria.



Section 13.3, “EP” of the SRP and DG-1145

Questions?

Daniel M. Barss

Sr. Emergency Preparedness Specialist
Division of Preparedness and Response
Office of Nuclear Security and Incident Response
U.S. Nuclear Regulatory Commission

DMB1@NRC.GOV

301-415-2922



Proposed Revision to Section 13.3, “Emergency Planning” (EP) of the Standard Review Plan (SRP) & Combined License Application Guidance (DG-1145)

Presented By

Daniel M. Barss

Sr. Emergency Preparedness Specialist
Division of Preparedness and Response
Office of Nuclear Security and Incident Response
U.S. Nuclear Regulatory Commission

DMB1@NRC.GOV

301-415-2922

December 7, 2006

538 Meeting of ACRS

1




Section 13.3, “EP” of the SRP and DG-1145

- Standard Review Plan (SRP) (NUREG-0800) Section 13.3, “Emergency Planning”
- COL Application Guidance (DG-1145) Section 13.3, “Emergency Planning”

December 7, 2006

538 Meeting of ACRS

2



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process

- Emergency Planning continues to be a part of the licensing process. (10 CFR 50.33, 50.34, 50.47, 50.54, and Appendix E, and 10 CFR part 52)
- President's decision of December 7, 1979 reemphasizes the NRC's continuing statutory responsibility for the radiological health and safety of the public.



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- Emergency Preparedness "Reasonable Assurance" finding needed prior to issuing License - 10 CFR 50.47(a)
- **NRC** makes this finding based on:
 - A review of FEMA (**DHS**) findings and determinations concerning **offsite** plans
 - and **NRC** findings and determinations concerning **onsite** plans.
 - NRC/FEMA Memorandum of Understanding establishes working relationship - 44 CFR 353, Appendix A

December 7, 2006

538 Meeting of ACRS

5



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- 16 Planning Standards of 10 CFR 50.47(b)
- Requirements of 10 CFR 50, Appendix E
- Regulatory Guide 1.101
 - NUREG-0654, FEMA-REP-1, Rev. 1 Acceptance Criteria
 - NEI 99-01, Rev. 4, EALs

December 7, 2006

538 Meeting of ACRS

6



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- Emergency Preparedness (EP)
 - A "Licensing Condition" - 10 CFR 50.54(q)
 - Deficiency 120 day clock - 10 CFR 50.54(s)
 - Reality presumption - 10 CFR 50.47(c)
 - Supported by two sets of plans:
 - "Onsite" emergency plan (Facility plan)
 - "Offsite" emergency plan (State & local plans)

December 7, 2006

538 Meeting of ACRS

7



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- 10 CFR Part 50
 - 2-Step Process:
 - Construction Permit
 - Operating License

December 7, 2006

538 Meeting of ACRS

8



An EP Perspective on New Reactor Licensing

Regulatory Process (cont'd.)

- **10 CFR Part 52 – Alternative licensing process**
 - **Established in 1989**
 - Improve Regulatory Efficiency
 - Add Greater Predictability
 - Essentially the Same Information as Part 50
 - Combines Construction Permit & Operating License with Conditions for Plant Operation – Combined License (COL)
 - Specify Applicant Inspection, Tests, Analysis and Acceptance Criteria (ITAAC)

December 7, 2006

538 Meeting of ACRS

9



An EP Perspective on New Reactor Licensing

Regulatory Process (cont'd.)

- **10 CFR Part 52 – Alternative licensing process**
 - **Acceptance Criteria**
 - Provide Reasonable Assurance that the facility has been constructed and will operate in conformity with the license and applicable regulations

December 7, 2006

538 Meeting of ACRS

10



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- 10 CFR Part 52 – Combined License
 - NRC
 - Authorize fuel load ONLY after ITAAC met
 - Periodic Federal Register Notice as ITAAC met
 - 180 days prior to scheduled initial loading of fuel
 - *Publish notice of intended operation in Federal Register*
 - Hearing opportunity if petitioner demonstrates that Acceptance Criteria not met

December 7, 2006

538 Meeting of ACRS

11



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- COL
 - 10 CFR 52.79(d) *proposed 10 CFR 52.79(22)*
 - Obtain Certifications from agencies with EP responsibilities that:
 - (A) Plans are practicable
 - (B) Commitment to further develop plans including field demonstrations
 - (C) Commitment to execute responsibilities

December 7, 2006

538 Meeting of ACRS

12



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- COL
 - **Proposed 10 CFR 50.54(gg)**
 - Allows operation up to 5% power with offsite deficiencies
 - Much like existing requirement in 10 CFR 50.47(d)

December 7, 2006

538 Meeting of ACRS

13



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- **10 CFR Part 52 – Combined License**
 - **COL can incorporate by reference**
 - Design Certification
 - Early Site Permit
 - **Issues resolved in ESP or Design Certification are precluded from reconsideration at COL Stage**

December 7, 2006

538 Meeting of ACRS

14



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- Standard Design Certification
 - **10 CFR 52 Subpart B**
 - Allows certification of Nuclear power facilities separate from filing an application for construction or combined license
 - No specific EP Requirements

December 7, 2006

538 Meeting of ACRS

15



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- **Early Site Permit (ESP)**
 - Independent of Plant Design
 - Valid for 10 – 20 Years, Renewable
 - Resolve early issues on
 - Site Safety
 - Emergency Preparedness
 - Environmental Protection

December 7, 2006

538 Meeting of ACRS

16



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- **Early Site Permit (ESP)**
 - **10 CFR 52.17**
 - (b)(1) Unique Physical Characteristics that could pose significant impediment to developing EP
 - (b)(2)(i) Major Features (NUREG-0654, Supplement 2)
 - (b)(2)(ii) Complete and Integrated Plans

December 7, 2006

538 Meeting of ACRS

17



Section 13.3, "EP" of the SRP and DG-1145

Regulatory Process (cont'd.)

- **ESP** (cont'd.)
 - **10 CFR 52.17** (cont'd.)
 - (b)(3) Describe contacts and arrangements with agencies with EP responsibilities [(b)(1) & (b)(2)(i)],
OR
 - Obtain Certifications from agencies with EP responsibilities that [(b)(2)(ii)]:
 - (3)(i) Plans are practicable
 - (3)(ii) Commitment to further develop plans including field demonstrations
 - (3)(iii) Commitment to execute responsibilities

December 7, 2006

538 Meeting of ACRS

18



Section 13.3, "EP" of the SRP and DG-1145

- Standard Review Plan (SRP) (NUREG-0800) Section 13.3, "Emergency Planning"
- COL Application Guidance (DG-1145) Section 13.3, "Emergency Planning"

December 7, 2006

538 Meeting of ACRS

19



Section 13.3, "EP" of the SRP and DG-1145

SRP Section 13.3, EP

- Provides for review of EP in
 - Construction Permit (CP)
 - Operating License (OL)
 - Early Site Permit (ESP)
 - Standard Design Certification (DC)
 - Combined License (COL)

December 7, 2006

538 Meeting of ACRS

20



Section 13.3, "EP" of the SRP and DG-1145

SRP Section 13.3, EP

- Identifies Review Interfaces within SRP
- Identifies Regulatory Requirements
- Establishes Acceptance Criteria to existing Regulatory Guidance
- Provides Technical Rationale
- Outlines Review Procedure
- Proposes generic Evaluation findings
- Extensive Reference list
- Generic EP ITAAC Table

December 7, 2006

538 Meeting of ACRS

21



Section 13.3, "EP" of the SRP and DG-1145

SRP Section 13.3, EP

- Consideration of existing programs
 - Is it applicable to proposed reactor
 - Is it up-to-date
 - Reflects and incorporates new reactor

December 7, 2006

538 Meeting of ACRS

22



Section 13.3, "EP" of the SRP and DG-1145

SRP Section 13.3, EP

- Emergency Action Levels (EALs)
 - NEI 99-01 applicable EALs used
 - NEI 99-01 EAL development guidance
 - Passive reactor designs EALs

December 7, 2006

538 Meeting of ACRS

23



Section 13.3, "EP" of the SRP and DG-1145

SRP Section 13.3, EP

- Inspection, Test, Analysis, Acceptance Criteria (ITAAC)
 - Generic EP ITAAC provided in Table 13.3.1
 - Develop with Industry & public participation
 - Based on existing NUREG-0654 criteria
 - Not all-inclusive, or exclusive
 - Applicant proposes and accomplishes
 - Case-by-case determination

December 7, 2006

538 Meeting of ACRS

24



Section 13.3, "EP" of the SRP and DG-1145

SRP Section 13.3, EP

- Offsite EP Guidance
 - Current REP-series guidance documents
 - Associated Memoranda
 - Radiological Emergency Preparedness: Planning Guidance, February 28, 2003

December 7, 2006

538 Meeting of ACRS

25



Section 13.3, "EP" of the SRP and DG-1145

SRP Section 13.3, EP

- Standard Design Certification EP (not required)
 - EP features are technically relevant to the design, and not site-specific, and usable for a multiple number of units or sites
 - Programmatic aspects of EP are COL applicants' responsibility
 - Facilities, functions, and equipment to support EP
 - TSC, OSC, Personnel Decontamination
 - Location, size, habitability, ventilation systems
 - ERDS, SPDS, Voice and data Communications

December 7, 2006

538 Meeting of ACRS

26



Section 13.3, "EP" of the SRP and DG-1145

DG-1145 Section 13.3, EP

- Provides guidance on EP information in a Combined License for a
 - Custom design
 - Certified Design
 - Certified Design with ESP

December 7, 2006

538 Meeting of ACRS

27



Section 13.3, "EP" of the SRP and DG-1145

DG-1145 Section 13.3, EP

- Addresses EP information in a Combined License
 - Application & Emergency Plan Content
 - Multi-Unit Site considerations
 - EP ITAAC

December 7, 2006

538 Meeting of ACRS

28



Section 13.3, "EP" of the SRP and DG-1145

ACRS Preliminary Questions

- Substantive change to Section 13.3 is incorporation of Part 52 process
 - EP ITAAC
 - "Predictive" reasonable assurance finding
 - Timing of exercise

December 7, 2006

538 Meeting of ACRS

29



Section 13.3, "EP" of the SRP and DG-1145

ACRS Preliminary Questions

- Guidance for "green-field" sites
 - Existing guidance is applicable
 - Considered in development of generic EP ITAAC
 - Continue discussion with DHS
 - Plans needed at COL application stage
 - Implementing Procedures developed later

December 7, 2006

538 Meeting of ACRS

30



Section 13.3, "EP" of the SRP and DG-1145

ACRS Preliminary Questions

- **Completeness of EP ITAAC Table for ESP**
 - Generic EP ITAAC provided in Table 13.3.1
 - Develop with Industry & public participation
 - Based on existing NUREG-0654 criteria
 - Not all-inclusive, or exclusive
 - Applicant proposes and accomplishes
 - Case-by-case determination

December 7, 2006

538 Meeting of ACRS

31



Section 13.3, "EP" of the SRP and DG-1145

ACRS Preliminary Questions

- **Diversity of planning options including evacuation, sheltering, and KI**
 - NUREG-0654, J.10.f – KI
 - NUREG-0654, J.10.g - Evacuation
 - NUREG-0654, J.10.m - Shelter

December 7, 2006

538 Meeting of ACRS

32



Section 13.3, "EP" of the SRP and DG-1145

Comments from public review period

- Not open the existing site emergency plan for review
- Expansion of ITAAC
- Use of the term "generic communications"
- Submittal of offsite implementing procedures
- Absence of DHS/FEMA/REP, planning references and limited offsite emergency response plan related review criteria.

December 7, 2006

538 Meeting of ACRS

33



Section 13.3, "EP" of the SRP and DG-1145

Questions?

Daniel M. Barss

Sr. Emergency Preparedness Specialist
Division of Preparedness and Response
Office of Nuclear Security and Incident Response
U.S. Nuclear Regulatory Commission

DMB1@NRC.GOV

301-415-2922

December 7, 2006

538 Meeting of ACRS

34

State-of-the-Art Reactor Consequence Analyses ACRS Meeting

December 7, 2006

Robert J. Prato

Office of Nuclear Regulatory Research

AGENDA

- MELCOR AND MACCS CODE IMPROVEMENTS
- PLANT GROUPING
- SCENARIO SELECTION
- LNT – vs – THRESHOLD
- EMERGENCY PREPAREDNESS
- ACRS ISSUES AND QUESTIONS

CODE IMPROVEMENTS

- 4 of 4 MELCORE CODE IMPROVEMENTS ARE BEING IMPLEMENTED
- 8 OF 10 MACCS2 CODE IMPROVEMENTS ARE BEING IMPLEMENTED
- 2 MACCS2 CODE IMPROVEMENTS ARE NOT BEING IMPLEMENTED
 - WET DEPOSITION MODEL AEROSOL SIZE DEPENDENCE
 - ANGULAR RESOLUTION

PLANT GROUPINGS

- GE, Mark 1
- GE, Mark 2
- GE, Mark3
- B&W, Dry Ambient
- CE, Dry Ambient
- W, 4 loop, Ice Condenser
- W, 2 and 3 loop, Dry Ambient, and Dry Sub-atmospheric
- W, 4 loop, Dry Ambient, and Dry Sub-atmospheric

USE OF CDF / RELEASE FREQUENCY

FULL-SCOPE LEVEL -2 PRAs ARE NOT AVAILABLE FOR ALL PLANTS, LIMITING THE STAFF'S ABILITY TO SELECT SCENARIOS BASED ON RELEASE FREQUENCY.

FOR THE PURPOSE OF SOAR-CA, THE NRC IS CONSIDERING DEFINING "RELEASE" BROADLY AS EARLY OR LATE, LARGE OR SMALL. ON THE BASIS THIS DEFINITION, ALL CORE DAMAGE EVENTS WILL RESULT IN A RELEASE

HENCE, THE STAFF IS EVALUATING SCENARIOS SELECTION USING CORE DAMAGE FREQUENCY.

Selection of Scenarios
to Use for
Consequence Analysis

Current PRA Tools

MODELS/METHODOLOGY	NUMBER OF PLANTS WITH MODELS
INTERNAL EVENTS	
SPAR Models	103
EXTERNAL EVENTS	
EE SPAR Models	13
IPEEE- Seismic PRAs	37
IPEEE- Seismic Margin Analysis	66
IPEEE- Fire PRA	23
IPEEE- FIVE Methodology (FIVE+, FIVE/PRA, and FIVE/FPRAIG)	80

SCENARIO SELECTION OPTIONS

- INTERNAL EVENTS CDF WITH UNCERTAINTY CONSIDERATIONS
- INTERNAL EVENTS CDF WITH UNCERTAINTY AND EXTERNAL EVENTS CONSIDERED

INTERNAL EVENTS CDF WITH UNCERTAINTY

- USE SPAR CDF FACTORING IN UNCERTAINTY, EXCLUDE EXTERNAL EVENTS, TO DETERMINE SCENARIO SELECTION
- IMPLEMENT USING INDIVIDUAL PLANT RESULTS OR SELECT DOMINANT SCENARIOS FOR CLASS OF PLANT
- NOT VIABLE, BETTER OPTIONS AVAILABLE
 - SIMPLISTIC APPROACH
 - EXCLUDES EFFECTS OF EXTERNAL EVENTS

INTERNAL EVENTS CDF WITH UNCERTAINTY AND EXTERNAL EVENTS CONSIDERED

- USE SPAR CDF FACTORING IN UNCERTAINTY AND EXTERNAL EVENTS TO DETERMINE SCENARIO SELECTION
- EXTERNAL EVENTS CAN BE INCLUDED USING OLD DATA OR NEW DATA (SCENARIOS and CDFs) OBTAINED FROM LICENSEES. WHERE NEW DATA NOT AVAILABLE, CONSIDER USING MEAN VALUES
- IMPLEMENT USING INDIVIDUAL PLANT RESULTS OR SELECT DOMINANT SCENARIOS FOR CLASS OF PLANT
- VIABLE OPTIONS AVAILABLE
 - BEST APPROACH FOR INCLUDING EXTERNAL EVENTS
 - SIMPLISTIC APPROACH FOR PLANTS WITH NO EXTERNAL EVENTS PRAs

LNT – vs – THRESHOLD

- The Commission directed the staff not solely rely on conservative collective dose models to assess latent cancer health effects from low doses of radiation, but to utilize a range of potential latent cancer health effects estimated from low levels of radiation.
- The staff identified a range of thresholds from 0 to 5 rem.
- To use a range of 0 to 5 rem, would require the use of Linear, no threshold for the treatment of “0” dose in modeling, and for the remaining range of doses would require a threshold.
- Options for Doses, the staff is considering the use of 0, 100 mrem, 1 rem, and 5 rem
- The staff is considering different methods of presenting the results that we will be prepared to present at the next ACRS meeting.

EMERGENCY PREPAREDNESS

Site-Specific Simulation
Of Offsite Emergency Response
for SOARCA

ACRS ISSUES AND QUESTIONS



Site-Specific Simulation of Offsite Emergency Response for SOARCA

Randolph L. Sullivan, CHP
Presentation to ACRS
December 7, 2006



EP Modeling

- Modeling the protective response afforded by NPP Emergency Preparedness (EP) programs substantially improves realism
- All NPPs have regularly inspected and exercised EP programs
- Modeling realistically represents NRC Defense-in-Depth Policy



ASSUMPTIONS

- Officials will implement emergency plans
- The public will largely obey direction from officials
- Emergency workers will implement the plans
- Basis from NUREG/CR-6864, "Identification and Analysis of Factors Affecting Emergency Evacuations" and PAR Study Focus Groups



Emergency Declaration

- Emergencies will be declared when EALs are reached
- Control room readings not available to SOARCA project, but can be inferred from MELCOR output
- “SRO discretion EAL” may be considered



Precautionary Actions

- Early precautionary actions are taken at Alert and Site Area Emergency
- Evacuation of special needs populations
 - Schools
 - Parks
- Prepare nursing homes
- Sirens sound and the public is notified
 - Shadow evacuation



Population Movement

- Evacuation Time Estimates (ETEs) provide:
 - Site-specific evacuation travel times
 - Population preparation time
- Divide population into cohorts
- Cohorts start at different times and move at different speeds



**MACCS2 is being modified to
accommodate multiple
cohorts**



Time of Day

- Accounting for variations in cohort travel for time of day, time of year, weather, peak population densities, etc. goes beyond current scope/resources
- A composite estimate for each cohort will consider these variations
 - Assumptions documented



Travel Speed

- Limited access roads and towns affect evacuation speed
 - Reflected in cohort travel speed where practical
- **MACCS is being modified to allow variation of travel speed by cohort in space and time**



Beyond the EPZ

- Protective actions beyond the EPZ are required by regulation but detailed planning is not
- Need would be identified via dose projection (plant, state, NRC) but implementation is ad hoc
- Population density, scenario timing, road networks and shadow evacuation will inform estimates of public preparation time and evacuation speed
- Less detailed than within EPZ



Radial Evacuation

- MACCS2 models radial evacuation
- Evacuation routes are not radially outward
- MACCS2 has been modified to easily model lateral movement
 - Improves realism
- Travel speed will be estimated for each cohort and modified by roads and towns



KI

- Considered for programs that use it
- For pre-distributed KI assume 50% of the population takes it
- For programs that do not use KI, 0% will be assumed
- Where KI is distributed at congregate care centers (and the like), 20% assumed
- Assumptions used for all cohorts



ISSUES

- Assumptions made regarding discretionary protective action decisions by offsite response organizations (OROs)
 - Develop ORO advisory group
- Some ETEs are very old
 - Develop models based on best available information



ISSUES

- Probabilistic representation of weather affects modeling of evacuation
 - Estimate cohort speeds as though one quadrant were evacuated
- MACCS2 run time for latent cancer fatality threshold calculations is affected by number of cohorts
 - Minimize evacuation cohorts (e.g., some leave before release)



Questions?

Randy Sullivan

(301) 415-1123

RXS3@NRC.GOV

Plant/Containment Class Matrices

BWRs

MELCOR Class	Class 1			Class 2		Class 3
	GE 2 / Mark 1	GE 3 / Mark 1	GE 4 / Mark 1	GE 4 / Mark 2	GE 5 / Mark 2	GE 6 / Mark 3
1	Nine Mile Point 1	Dresden 2	Browns Ferry 2	Limerick 1	Columbia	Clinton
2	Oyster Creek	Dresden 3	Browns Ferry 3	Limerick 2	LaSalle 1	Grand Gulf
4		Monticello	Brunswick 1	Susquehanna 1	LaSalle 2	Perry
5		Pilgrim	Brunswick 2	Susquehanna 2	Nine Mile Point 2	River Bend
6		Quad Cities 1	Cooper			
7		Quad Cities 2	Duane Arnold			
-8			Hatch 1			
9			Hatch 2			
10			Fermi 2			
11			Hope Creek			
12			Fitzpatrick			
13			Peach Bottom 2			
14			Peach Bottom 3			
15			Vermont Yankee			
	2	6	14	4	4	4
	22			8		4

Total # of BWRs = 34

PWRs

MELCOR Class	Class 4	Class 5	Class 6	Class 7			Class 8	
	B&W / Dry Amb.	CE / Dry Amb.	W 4-Loop / Ice Cond.	W 2-Loop / Dry Amb.	W 3-Loop / Dry Sub.	W 3-Loop / Dry Amb.	W 4-Loop / Dry Sub.	W 4-Loop / Dry Amb.
1	ANO 1	ANO 2	Catawba 1	Ginna	Beaver Valley 1	Robinson 2	Millstone 3	Braidwood 1
2	Crystal River 3	Calvert Cliffs 1	Catawba 2	Kewaunee	Beaver Valley 2	Farley 1		Braidwood 2
4	Davis-Besse	Calvert Cliffs 2	D.C. Cook 1	Point Beach 1	North Anna 1	Farley 2		Byron 1
5	Oconee 1	Fort Calhoun	D.C. Cook 2	Point Beach 2	North Anna 2	Shearon Harris		Byron 2
6	Oconee 2	Millstone 2	McGuire 1	Prairie Island 1	Surry 1	Summer		Callaway
7	Oconee 3	Palisades	McGuire 2	Prairie Island 2	Surry 2	Turkey Point 3		Comanche Peak 1
8	TMI 1	Palo Verde 1	Sequoyah 1			Turkey Point 4		Comanche Peak 2
9		Palo Verde 2	Sequoyah 2					Diablo Canyon 1
10		Palo Verde 3	Watts Bar					Diablo Canyon 2
11		San Onofre 2						Indian Point 2
12		San Onofre 3						Indian Point 3
13		St. Lucie 1						Salem 1
14		St. Lucie 2						Salem 2
15		Waterford 3						Seabrook
16								South Texas 1
17								South Texas 2
18								Vogtle 1
19								Vogtle 2
20								Wolf Creek
	7	14	9	6	6	7	1	19
	7	14	9	19			20	

Total # of PWRs = 69

Notes
 * Reviews are still need to be performed to determine grouping of these plants. After the reviews are completed, 2-3 additional MELCOR classes may be formed from the plants currently listed in Class 7.

Mark I BWRs Internal Events Screening

Date Modified: 12/01/06

Plant Name	Total CDF	LLOCA	MLOCA	SLOCA	ISLOCA	ATWS	Scenario 1	Scenario 2	Scenario 3	Scenario 4	Scenario 5	Scenario 6
Plant 1	4.E-06											
Plant 2	3.E-06											
Plant 3	1.E-05											
Plant 4	8.E-06											
Plant 5	4.E-06		Note 1			Note 2						
Plant 6	4.E-06											
Plant 7	2.E-06											
Plant 8	5.E-06					Note 2						
Plant 9	1.E-05											
Plant 10	3.E-06											
Plant 11	4.E-06											
Plant 12	5.E-06											
Plant 13	1.E-06											
Plant 14	1.E-05									Note 3		
Plant 15	1.E-05											
Plant 16	8.E-07											

Scenario Descriptions :

1. Reactor transients with unavailabilities of high-pressure injection systems (HPCI/RCIC) and RCS depressurization.
2. Station blackout with unavailability of high-pressure injection systems (HPCI/RCIC) and the failure of operators to recover emergency power within 30 minutes.
3. Station blackout with failure of operators to recover emergency power prior to battery depletion. This scenario could have sequence contributors with and without successful shedding of DC loads to extend the battery life.
4. Reactor transients with unavailabilities of RHR which leads to the unavailabilities of SPC/SDC/CSS, along with unavailabilities of containment venting or late injection. This scenario includes non-recoverable losses of service water/CCW.
5. Reactor transients with common-cause failure of the SRVs to open. This scenario is a plant-specific scenario to Plant 15 (i.e., derived from licensee PRA).
6. Reactor transients with common-cause failure of the transformer power supply inverters leads to the unavailabilities of all high- and low-pressure injection systems. This scenario is a plant-specific scenario for Plant 15 (i.e., derived from licensee PRA).

Notes :

1. There is no MLOCA event tree for Plant 5.
2. The relatively high ATWS CDFs for Plants 5 and 8 are due to conservative modeling assumptions in these SPAR models. These modeling artifacts are currently being corrected by INL.
3. Plant 14 has dominant sequences with and without a stuck-open SRV. The CDF sum for the sequences involving a stuck-open SRV equal 4×10^{-6} . The CDF sum for the sequences involving a stuck-open SRV equal 3×10^{-6} .

Westinghouse 4-Loop, Large Dry PWRs Internal Events Screening

Date Modified: 12/01/05

Plant Name	Total CDF	LLOCA	MLOCA	ATWS	Scenario 1	Scenario 2	Scenario 3	Scenario 4	Scenario 5a	Scenario 5b	Scenario 6	Scenario 7
Plant 1	2.E-05				Note 2							
Plant 2	3.E-05			Note 1	Note 2							
Plant 3	5.E-06				Note 2							
Plant 4	5.E-05				Note 2							
Plant 5	4.E-05				Note 2							
Plant 6	9.E-06				Note 2							
Plant 7	9.E-06											
Plant 8	8.E-06											
Plant 9	5.E-06				Note 2							
Plant 10	1.E-05			Note 1	Note 2							
Plant 11	5.E-05											
Plant 12	4.E-05				Note 2							
Plant 13	4.E-05				Note 2							

Scenario Descriptions :

1. ISLOCA from the RHR system.
2. Steam generator tube rupture (initiating event).
3. Reactor transients with unavailabilities of AFW and bleed and feed.
4. Station blackout with failure of turbine-driven AFW pump and the failure of operators to recover emergency power within 1 hour.
5. (a) Station blackout with failure of operators to recover emergency power prior to battery depletion.
(b) Station blackout with RCP seal failure (LOCA) and failure to recover power prior to battery depletion time or 4 hours (which ever is less).
6. Loss of service water or CCW (non-recoverable or operators fail to recover) with failure of RCP seals (LOCA).
7. SLOCA with failure of RHR/HPR or RHR/LPR.

Color Coding Scale		
	Cont. Bypass	No Cont. Bypass
Green	CDF < 5E-8	CDF < 5E-7
Yellow	5E-8 ≤ CDF < 1E-7	5E-7 ≤ CDF < 1E-6
Red	CDF ≥ 1E-7	CDF ≥ 1E-6

Notes :

1. The relatively high ATWS CDFs for Plants 2 and 10 are due to conservative modeling assumptions contained in these SPAR models. These modeling artifacts are currently being corrected by INL.
2. ISLOCA is only calculated for 3 of the 12 plants within this group. However, due to the future use of the same ISLOCA event tree for all PWR SPAR models and similar valve orientations, the ISLOCA CDFs for all plants within this group are expected to be in the range of the three completed plants.