

LICENSEE: Dept of Army - CECOM
ADDRESS: Ft. Monmouth, NJ

REPORT NO. 90-01

LICENSEE CONTACT: J SANTARSIERO, RSO

Telephone No. (201) 532 9000

LICENSE NUMBER	DOCKET NUMBER	CATEGORY	PRIORITY	PROGRAM CODE
<u>29-01022-06,07</u>	<u>3005248</u>	<u>EIA</u>	<u>2</u>	<u>3616</u>
<u>10,13,14</u>	<u>3006989</u>	<u>F</u>	<u>3</u>	<u>3511</u>
<u>SMM-1323</u>	<u>3009718</u>	<u>E3</u>	<u>21</u>	<u>3521</u>
	<u>3029741</u>	<u>K</u>	<u>7</u>	<u>3124</u>
	<u>7001351</u>	<u>F</u>	<u>65</u>	<u>2240</u>

INSPECTION DATE(S) 9/18-19/90

TYPE OF INSPECTION

INSPECTION LOCATION(S)

FT. Monmouth, NJ

Evans Area, NJ

- SPECIAL ROUTINE
 ANNOUNCED UNANNOUNCED
 DAYSHIFT BACKSHIFT

SUMMARY OF FINDINGS AND ACTION

- NO NONCOMPLIANCE, 591 ACTION ON PREVIOUS NONCOMPLIANCE, APPENDIX B
 NO NONCOMPLIANCE LETTER SUPPLEMENTAL INFORMATION, APPENDIX C
 NONCOMPLIANCE, 591
 NONCOMPLIANCE, LETTER

PERSONS CONTACTED (Name, Title)

* M. Zarick, Alt. RSO

* C. Kenny, Branch Chief

G. Ziola, h.p.

J. Tomaini, electronics tech.

* SSG H. Branchi, h.p. tech.

W. Hulse, Act Chief CECOM

Safety Office

Dr. Kronenberg, Physicist

* attended exit meeting

Clair Z. Brum 9/21/90
Inspector Signature, Date

Inspector Signature, Date

APPROVED [Signature]

9/21/90


AA/86

1. ORGANIZATION


(C) NC

a. Describe the management structure.

C NC



b. Describe the radiation protection organization. (C) NC



c. Individuals identified in the license as being responsible for the programs still hold these positions. Barry Siber - RSO on LF license (C) NC

d. Audit and/or Management Control program conducted as required. Joseph Santis - irradiation + R/D > no changes (C) NC NA NI

- 1. records maintained (V) n/na/ni
- 2. appropriate scope (V) n/na/ni
- 3. deficiencies identified and corrected (V) n/na/ni

Comments

7 staff members to carryout majority of program functions!

RSO

Alt RSO

3 h.p

1 h.p. tech

1 contractor (authorized full time)

3. TRAINING AND INSTRUCTIONS TO EMPLOYEES

(C) NC

- a. Instruction to all persons working in a restricted area (19.12). (C) NC NA NI
- b. Additional required training for operators and other specified workers. (C) NC NA NI
 - 1. approved training program y/n/na/ni
 - 2. training provided by Rad Engineers Bn y/n/na/ni
 - 3. operators completed on-the-job training y/n/na/ni
 - 4. tests are given
 - a. written tests y/n/na/ni
 - b. oral (y/n/na/ni)
 - c. practical y/n/na/ni
 - d. records of tests maintained (y/n/na/ni)
 - e. deficiencies noted and corrected (y/n/na/ni)
 - 5. training records reviewed by NRC inspector for period 3/87 to 12/89
 - 6. qualified operator on site during all irradiator operations (y/n/na/ni)
- c. Periodic training is implemented as required. (C) NC NA NI
 - 1. records of retraining maintained (y/n/na/ni)
 - 2. Describe frequency and scope of periodic training: last - 12/89 calendar year

Comments

3b6. 2 Qualified users for vaults + pool:

- 1. Dr. Kronenburg
- 2. Joe Tomaini

no one else permitted to use unless under their supervision

3b4 Annual training lecture given to all personnel on TLD's. Covers Army h.p. regulations

12/89 - list of attendees adequate

* 4/88 - " " " missing - records unsat.

3/87 - " " " adequate

88 missing records was an oversight. Licensee seems conscientious re training. + developed new sign-in sheet

3b1. Approved training program is for RPO's who use field commodities but none for hp's or irradiator use.

RESULTS

4. MATERIALS, FACILITIES, AND EQUIPMENT

C NC

a. Materials inventory as authorized by license. C NC

- 1. type and quantity authorized y/n/na/ni
- 2. six-month inventory as required by license y/n/na/ni
- 3. inventory records reviewed for the period Aug/89 to 5/90
- 4. current inventory: _____ Curies as of _____ (date)

Pool ~ 9000 Ci
 Vault - 2 sources ~ 500 Ci
 balance in Ci range (total) 122 sources

b. Irradiator facility safety systems as required. C NC NA NI

- 1. posted as required by 20.203(c)(1) yes/no
- 2. interlocked as required by 20.203(c)(2)(i) yes/no
- 3. entrance controlled in accordance with 20.203(c)(2) yes/no
- 4. exit controlled in accordance with 20.203(c)(3) yes/no
- 5. entry control devices function as required by 20.203(c)(6) yes/no
- 6. visible and audible signals operate correctly to warn of the presence of radiation: 20.203(c)(6) yes/no but access restricted to RSO
- 7. level control for liquid shield: 20.203(c)(6)(iii) yes/no
- 8. source exposure procedure used yes/no
- 9. control devices tested at intervals required by 20.203(c)(6)(vii) yes/no
- 10. product carriers inspected as required: LC yes/no
- 11. records of control devices tests maintained yes/no N/A

c. Inspector observed proper operation of the following:

- 1. personnel door interlock pass/fail/not tested
- 2. product conveyor door interlock x pass/fail/not tested
- 3. maze radiation monitor x pass/fail/not tested
- 4. exit portal radiation monitor x pass/fail/not tested
- 5. visible and audible signals pass/fail/not tested
- 6. level control alarm for liquid shield x pass/fail/not tested
- 7. clearance of cell at startup x pass/fail/not tested
- 8. emergency shutdown switch in cell x pass/fail/not tested
- 9. ventilation system interlock x pass/fail/not tested

vault interlocks not tested due to system undergoing maintenance. Expect to be completed by end of year sources in storage only for 3-4y. Pool access is restricted.

Other:

d. Postings and labelings as required

C NC NA NI

- 1. 20.203(b) radiation area y/n/na/ni
- 2. 20.203(e) use or storage areas with "Caution - Radioactive Material" y/n/na/ni
- 3. 20.203(f) containers and devices properly labeled y/n/na/ni
- 4. 19.11(a)(b) posting of documents y/n/na/ni
- 5. 19.11(c) posting of NRC-3 y/n/na/ni

5. INSTRUMENTS, EQUIPMENT, AND DEVICES

C NC

a. calibrated and operable meters available and used properly. C NC NA NI

1. number, type, and ranges (e.g 2, ion chamber, 1 R/hr)

Number	Type	Range
_____	_____	_____
_____	_____	_____
_____	_____	_____

high range Ludlum 5
0-2 R/hr
several available

2. 2 mR/hr through 1 R/hr can be measured

calib in house
provided list of instrument inventories

Y/n/na/ni

3. calibrated by: _____

4. calibration method as authorized

Y/n/na/ni

5. calibration performed as required frequency: _____

y/n/na/ni

b. Water treatment systems function as required. C NC NA NI

1. conductivity and pH tested and maintained within license limits.

Y/n/na/ni

2. current water quality:

conductivity <1 microsiemen/cm date: 9/14 + 9/18

pH date: _____

3. ion-exchange resin _____ replaced _____ regenerated

last date: 8/90 filters changed

c. other special equipment (pool water monitors, ion-exchange resins, ventilation systems, automatic fire extinguishing system, etc.) operable and available as described in license C (NC) NA NI

Describe:

Committed to install fire detector or smoke detector inside pool area. One smoke detector in main area on ceiling too far from pool.

Comments

for 14 license: Inventory maintained via database of all field commodities (instruments used in field) by ser #, leak test date, + leak test results.

6. RECEIPT AND TRANSFER OF MATERIALS C NC NA NI

- a. Procedures for picking up, receiving, and opening of packages performed as required by 20.205.

 C NC NA NI

1. written procedures available y/n/ na/ni
2. procedures approved in application y/n/ na/ni
3. survey of packages when received y/n/na/ni
4. 20.401 records of survey of packages y/n/na/ni
5. 20.401 records of receipt of packages y/n/na/ni

inspected 89-190
shipment & receiving records

- b. Source loading procedures performed.

C NC NA NI

1. date of last source load: _____
2. radiation survey performed y/n/na/ni
3. record of survey maintained y/n/na/ni
4. report of survey sent to NRC y/n/na/ni

Sources never changed;
Originals from early '60s

- c. Licensed material transferred as required.

 C NC NA NI

1. 30.41 verification of recipient's license y/n/na/ni
2. 20.401, 30.51 records maintained y/n/na/ni
3. Licensee makes shipments of radioactive materials
 - a. delivered by common carrier yes/no
 - b. transported in licensee's own vehicle as a private carrier. yes/ no

Periodic shipments (5-10/yr.)
of small amts of material; all records maintained

*IF ABOVE IS ANSWERED "YES", COMPLETE 6.A: TRANSPORTATION

Comments

RESULTS

6.A TRANSPORTATION

C NC NA NI

- | | | C | NC | NA | NI |
|-----|---|---------------|----|----------------|--|
| 1. | Are authorized packages used | 173.415-416 | | <u>yes</u> /no | |
| 2. | Types of packages used
(for example, DOT-7A) | 173.415 | | | Special package design for commodities |
| 3. | Performance test records on file | 173.416(a) | | yes/no | |
| 4. | Licensee aware of 6/30/85 cutoff
on use () certified | 173.416(b) | | yes/no | |
| 5. | NRC COC's on file | 71.12(c)(1) | | yes/no | |
| 6. | Registered with NRC as user | 71.12(c)(3) | | yes/no | |
| 7. | Documented NRC-approved Q/A
program?
NRC Q/A Approval number | 71.12(b) | | yes/no | |
| 8. | Special Form Material Performance
test records available for each
source design | 173.476(a) | | yes/no/na | |
| 9. | packages labeled as required | 172.403 (a-f) | | <u>yes</u> /no | |
| | a. Excepted | | | | |
| | b. White I | | | | |
| | c. Yellow II | | | | |
| | d. Yellow III | | | | |
| 10. | surveys performed to select
correct label category and
compliance with radiation limits | 175.475(i) | | <u>yes</u> /no | |
| 11. | Packages marked as required with | 172.300-310 | | <u>yes</u> /no | |
| | a. shipping name | | | <u>yes</u> /no | |
| | b. Spec No. | | | | |
| | c. Certificate of Compliance Number
(COC No.) etc. | | | | |
| 12. | Shipping papers are prepared for
each shipment | 172.200 | | <u>yes</u> /no | |
| 13. | Shipping papers contain required
information | 172.203(d) | | <u>yes</u> /no | |
| 14. | For private carrier shipments: | | | | |
| | a. vehicles placarded as required | 172.500,504 | | yes/no | |
| | b. cargo blocked, braced, tied
down in vehicle | 177.842(d) | | yes/no | n/a all braced |
| | c. any incidents reported to DOT | 171.15-16 | | yes/no | |
| 15. | Licensee carries shipping papers
that are readily accessible when
transporting radioactive material | | | | |

Comments

7. PERSONNEL MONITORING

a. Personnel dosimetry assigned and worn.

C NC NA NI
C NC NA NI

1. whole-body badge used y/n/na/ni
 a. until 12/89 film began Jan '90 TLD
 b. exchange frequency: mo
 c. supplier US Army Ionizing Dosimetry Ctr Lexington, Ky
 d. supplier NVLAP accredited 20.202 y/n/na/ni
2. workers observed wearing dosimetry y/n/na/ni

b. Personnel dosimetry reports maintained.

C NC NA NI

1. records reviewed by management at a frequency of: M y/n/na/ni
2. NRC inspector reviewed personnel monitoring records from 1985 to present y/n/na/ni
 a. whole body quarterly dose: typical Ø max _____
 b. extremity quarterly dose: typical Ø max _____
3. NRC forms or equivalent records completed y/n/na/ni
 a. NRC-4 y/n/na/ni
 b. NRC-5 y/n/na/ni
4. Termination and annual reports to individuals and NRC, as required by 20.407 and 20.408 y/n/na/ni

Comments

final exposure records placed in medical records @ Lexington Bluegrass

- Request for change in exchange frequency from M → Q approved by NRC 4/90. Licensee will begin quarterly TLD program by end of year
- 7d.b. No exposures > 15 mRem ever reported (back to 85) even for technicians who perform instrument calibrations w/ Cs + Co irradiators
- Procedure to badge visitors needs review.
 Visitors w/ outside dosimetry are not given Army badges. Licensee will consider badging all visitors.

8. RADIATION SURVEYS AND LEAK TESTS

C NC NA NI

a. Facility and unrestricted area surveys conducted. C NC NA NI

- 1. area or facility surveys recorded y/n/na/ni
- 2. surveys performed as required frequency: M y/n/na/ni
- 3. appropriate instruments used WDLVMS y/n/na/ni
- 4. NRC inspector reviewed survey records for the period Jan '89 to Aug '90
- 5. maximum radiation levels in unrestricted area: < 0.02 uR/hr

b. Leak tests of sealed sources performed ^{max in unrestricted area up to 20 mR/hr @ contact w/CS-137 calib source} C NC NA NI

- 1. performed by user and method approved y/n/na/ni
- 2. leak testing method used:
 - water sampling yes/no
 - continuous monitoring of ionizers yes/no
 - periodic monitoring of ionizers yes/no
 - direct wiping of sources yes/no
- 3. tested at six-month intervals 34.25(b) y/n/na/ni
- 4. records maintained y/n/na/ni
- 5. records reviewed by NRC inspector for the period 1/3/90 to 9/18/90

Comments

8b2. 10ml aliquot taken from pool instead of 100ml per ^{license} application commitment

9. EFFLUENT CONTROL AND WASTE DISPOSAL

C NC NA NI

a. Releases with the environment in accordance with requirements. C NC NA NI

- 1. liquid releases are made to sewer unrestricted areas y/n/na/ni
 - a. evaluations are adequate y/n/na/ni
 - b. releases are within limits: 20.106,20.303 y/n/na/ni
 - c. typical concentrations: _____
- 2. records maintained y/n/na/ni
- 3. describe disposal of water from the regeneration of ion-exchange resins, if applicable:

b. Waste disposal in accordance with requirements. C NC NA NI

1. Describe disposal of replaced resin, if applicable:

treated as rad waste. Placed in drum +
shipped to waste disposal facility

2. Describe any other methods of waste disposal:

OK except for Pickering source shipment (manifest misplaced)

3. Records of waste transfers maintained y/n/na/ni

Shipping papers provided 9/9; concern resolved

c. Burial of licensed material done in past. Yes No

1. location of past burials: _____

2. types of materials buried: _____

3. describe the types of surveys performed, results, etc:

d. 10 CFR Part 61 requirements reviewed y/n/na/ni

Comments

10. NOTIFICATIONS AND REPORTS

C NC NA NI

a. Licensee is in compliance with

- 1. reports of thefts or losses (20.402)
- 2. reports of incidents (20.403)

y/n/na/ni
y/n/na/ni

b. Licensee took appropriate action in response to the following Bulletins, Circulars, and Information Notices.

y/n/na/ni

- 1. _____
- 2. _____
- 3. _____

Comments

11. OTHER LICENSE CONDITIONSC NC NA NI

List any other license conditions which were reviewed during the inspection, and describe the results.

a.

C NC

b.

C NC

c.

C NC

Comments

- Need corrected cy for irradiator vault license
1. to delete Pickering source
 2. change location of Cs-137 irradiator to Bldg 401, Evam area

12. INDEPENDENT AND CONFIRMATORY MEASUREMENTS

C NC NA NI

a. Areas SurveyedResults

pool irradiator + bldg 401	< 2 mR/R
calibration room	
vault irradiators	
isotope storage area	

b. Survey Instruments Used

1. Type	a. Eberline E-120	b. _____
2. NRC #	a. 000 899	b. _____
3. last calibration date	a. 6/4/90	b. _____

c. Pool Water Sample

NRC - measured concentration _____

Licensee - measured concentration _____
(attach NRC lab results to field notes)Comments

vault irradiator RMS monitor to display rad levels inside vault w/ source exposed inop.

APPENDIX A - DOCUMENTATION OF NONCOMPLIANCE

Requirement	Basis for noncompliance
1. 10 CFR _____ Lic Cond _____	
2. 10 CFR _____ Lic Cond _____	
3. 10 CFR _____ Lic Cond _____	
4. 10 CFR _____ Lic Cond _____	
5. 10 CFR _____ Lic Cond _____	
6. 10 CFR _____ Lic Cond _____	

APPENDIX B - LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS

n/A

Identification and summary of action taken	Status
Report No: _____	Severity Level _____
Describe previous violation:	
Corrective Action taken:	OPEN
	CLOSED
Report No.: _____	Severity Level _____
Describe previous violation:	
Corrective Action taken:	OPEN
	CLOSED
Report No: _____	Severity Level _____
Describe previous violation:	
Corrective action taken:	OPEN
	CLOSED

APPENDIX B (continued)

Identification and summary of action taken	Status
Report No: _____	Severity Level _____
Describe previous violation:	
Corrective action taken:	OPEN
	CLOSED
Report No: _____	Severity Level _____
Describe previous violation:	
Corrective action taken:	OPEN
	CLOSED
Report No: _____	Severity Level _____
Describe previous violation:	
Corrective action taken:	OPEN
	CLOSED

APPENDIX C - SUPPLEMENTARY INFORMATION

() Unusual occurrence, conditions, etc.

() Unresolved items

() Description of attachments to field notes

(x) Inspector's comments

Items for followup during next inspection:

1. Ensure all interlocks, electronics, RMS monitors in vault are operable if licensee has changed irradiators from storage only to actual use.
 2. Licensee to provide heat or smoke sensor inside pool irradiator area.
 3. Check shipping papers for transport of Pu battery.
 4. Review procedure for issuing TLD's to visitors.
-