



FPL Energy
Seabrook Station

FPL Energy Seabrook Station
P.O. Box 300
Seabrook, NH 03874
(603) 773-7000

December 20, 2006

SBK-L-06241

Docket No. 50-443

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Seabrook Station
Withdrawal of License Amendment Request 05-11
"Changes to Technical Specification 3.8.3.1, Onsite Power Distribution, for
Vital Inverter Allowed Outage Time"

Reference:

1) FPL Energy Seabrook, LLC letter SBK-L-05260, dated December 6, 2005, License Amendment Request 05-11, Changes to Technical Specification 3.8.3.1, Onsite Power Distribution, for Vital Inverter Allowed Outage Time

FPL Energy Seabrook, LLC (FPL Energy Seabrook) submitted License Amendment Request (LAR) 05-11 on December 6, 2005 proposing a revision to Seabrook Station Technical Specification (TS) 3.8.3.1 "Onsite Power Distribution," to extend the allowed outage time for the two balance-of plant (BOP) vital inverters from 24 hours to 7 days. FPL Energy Seabrook hereby withdraws LAR 05-11 to allow questions from the NRC staff to be addressed and incorporated in a revised License Amendment Request.

Should you have any questions regarding this letter, please contact Mr. James M. Peschel, Regulatory Programs Manager, at (603) 773-7194.

Very truly yours,
FPL Energy Seabrook, LLC.

Gene F. St. Pierre
Site Vice President

A001

cc: S. J. Collins, NRC Region I Administrator
G. E. Miller, NRC Project Manager, Project Directorate I-2
G.T. Dentel, NRC Senior Resident Inspector

Mr. Christopher M. Pope, Director Homeland Security and Emergency Management
New Hampshire Department of Safety
Division of Homeland Security and Emergency Management
Bureau of Emergency Management
33 Hazen Drive
Concord, NH 03305