

**NFPA-805 Transition Pilot Plant
Frequently Asked Questions**

Plant:	<u>Harris Nuclear Plant (HNP)</u>	FAQ # <u>06-0028 Rev. 0</u>
Submittal Date:	<u>11-30-06</u>	
Licensee Contact:	<u>Alan Holder</u>	Tele/email <u>919-546-3372</u>
NRC Contact:	<u></u>	Tele/email <u></u>

Subject

Interpretive Guidance? Yes / No

Proposed New Guidance not currently in NEI 04-02? Yes / No

Details

NEI 04-02 Guidance needing interpretation (include section, paragraph number, and line number as applicable):

NEI 04-02, Section 4.3.1, Fundamental Fire Protection Program and Design Elements Transition Review, appendices to list acceptable interpretations to the NFPA 805 standard (future).

Circumstances requiring guidance interpretation or new guidance:

Clarification of NFPA-805, Standard for Fire Protection for Light Water Reactor Electric Generating Plants (2001 Edition), Chapter 3, Section 3.3.1.1 General Fire Prevention Activities, “(1) Training on fire safety information for all employees and contractors including, as a minimum, familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms.”

Specifically, clarify what is “familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms” regarding scope of or depth of the training.”?

Detail contentious points if licensee and NRC have not reached agreement:

NA

Potentially relevant existing FAQ numbers:

NA

Response Section

Proposed Resolution of FAQ and basis for the proposal:

This FAQ asks for clarification of what is “familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms” regarding scope of or depth of the training.” Because existing employee general access and indoctrination training is a mature program, and based on NEI 03-04, Guide for Plant Access Training, section 7.5 Fire Protection, consistent information of sufficient detail, is provided at all sites by their General Employee Training (GET) Program. The proposed interpretation contains those key elements listed in the NEI guidance.

If appropriate, provide proposed rewording of guidance for inclusion in next revision.

As follows;

Interpretation for NFPA 805 specific sections as may be applied under NEI 04-02, to be included in Appendices of NEI 04-02 upon approval of interpretation (final formatting to be provided by NEI contract writers).

Where used in section 3.3.1.1, the term, “familiarization with plant fire prevention procedures, fire reporting, and plant emergency alarms”, shall be considered to be equivalent to that information presented in the plant’s approved General Employee Training (GET). Specific training objectives should include;

- State individual responsibilities regarding fire barriers such as fire dampers, doors, and seals.
- State actions an individual is required to take upon discovery of a fire.
- State individual responsibilities regarding the control of fire loading (wood, solvents, oil) and the disposal of flammable materials.
- State examples of the types of hot work requiring a permit.
- Recognize and state the response to a station fire alarm.