TECHNICAL REPORT TITLE PAGE

COPY

Instrument Efficiency Determination for Use in Minimum Detectable Concentration Calculations in Support of the Final Status Survey at Yankee Rowe

Title

YA-REPT-00-015-04
REV. 0

Technical Report Number

Approvals	(Print & Sign Name)		
Preparer:	[signature]	Date:	10-7-04
Reviewer:	James R. Hummer	Date:	10/7/04
Approver (Cognizant Manager):	[signature]	Date:	10/7/04

TABLE OF CONTENTS

Tables

Appendix

1.0 Executive Summary:

The minimum detectable concentration (MDC) of the field survey instrumentation is an important factor affecting the quality of the final status survey (FSS). The efficiency of an instrument inversely impacts the MDC value. The objective of this report is to determine the instrument and source efficiency values used to calculate MDC. Several factors were considered when determining these efficiencies and are discussed in the body of this report. Instrument efficiencies (ε_i), and source efficiencies (ε_s), for alpha beta detection equipment under various field conditions, and instrument conversion factors (E_i), for gamma scanning detectors were determined and the results are provided herein.

2.0 Introduction:

Before performing Final Status Surveys of building surfaces and land areas, the minimum detectable concentration (MDC) must be calculated to establish the instrument sensitivity. Table 5.4 of the License Termination Plan (LTP) [8.6] lists the available instrumentation and nominal detection sensitivities; however for the purposes of this basis document, efficiencies for the 100cm^2 gas proportional and the 2"x2" NaI (Tl) detectors will be determined. Efficiencies for the other instrumentation listed in the LTP shall be determined on an as needed basis. The 100 cm^2 gas proportional probe will be used to perform surveys (i.e. fixed point measurements). A 2" x2" NaI (Tl) detector will be used to perform gamma surveys (i.e., surface scans) of portions of land areas and possibly supplemental structural scans at the Yankee Rowe site. Although surface scans and fixed point measurements can be performed using the same instrumentation, the calculated MDCs will be quite different. MDC is dependent on many factors and may include but is not limited to:

- instrument efficiency
- background
- integration time
- surface type
- source to detector geometry
- source efficiency

A significant factor in determining an instrument MDC is the total efficiency, which is dependent on the instrument efficiency, the source efficiency and the type and energy of the radiation. MDC values are inversely affected by efficiency, as efficiencies increase, MDC values will decrease. Accounting for both the instrument and source components of the total efficiency provides for a more accurate assessment of surface activity.

3.0 Calibration Sources:

For accurate measurement of surface activity it is desirable that the field instrumentation be calibrated with source standards similar to the type and energy of the anticipated contamination. The nuclides listed in Table 3.1 illustrate the nuclides found in soil and building surface area DCGL results that are listed in the LTP.

Instrument response varies with incident radiations and energies; therefore, instrumentation selection for field surveys must be modeled on the expected surface activity. For the purposes of this report, isotopes with max beta energies less than that of C-14 (0.158 MeV) will be considered difficult to detect (reference table 3.1). The detectability of radionuclides with max beta energies less than 0.158 MeV, utilizing gas proportional detectors, will be negligible at typical source to detector distances of approximately 0.5

inches. The source to detector distance of 1.27 cm (0.5 inches) is the distance to the detector with the attached standoff (DP-8534 "Operation and Source Checks of Proportional Friskers")[8.5]. Table 3.1 provides a summary of the LTP radionuclides and their detectability using Radiological Health Handbook [8.4] data.

Table 3.1
Nuclides and Major Radiations: Approximate Energies (Reference 8.4)

Nuclide	α Energy (MeV)	$E_{\beta max}$ (MeV)	Average E_β (MeV)	Photon Energy (MeV)	α Detectable w/ Gas Proportional	β Detectable w/ Gas Proportional	γ Detectable w/ NaI 2x2"
H-3		0.018	0.005				
C-14		0.158	0.049				
Fe-55				0.23 (0.004%) bremsstrahlung			
Co-60		0.314	0.094	1.173 (100%), 1.332 (100%)		√	√
Ni-63		0.066	0.017				
Sr-90		0.544 2.245 (Y-90)	0.200 0.931			√	
Nb-94		0.50	0.156	0.702 (100%), 0.871 (100%)		√	√
Tc-99		0.295	0.085			√	
Ag-108m		1.65 (Ag-108)	0.624 (Ag-108)	0.434 (0.45%), 0.511 (0.56%) 0.615 (0.18%), 0.632 (1.7%)			√
Sb-125		0.612	0.084	0.6, 0.25, 0.41, 0.46, 0.68, 0.77, 0.92, 1.10, 1.34		√	√
Cs-134		1.453	0.152	0.57 (23%), 0.605 (98%) 0.796 (99%), 1.038 (1.0%) 1.168 (1.9%), 1.365 (3.4%)		√	√
Cs-137		1.167	0.195	0.662 (85%) Ba-137m X-rays		√	√
Eu-152		1.840	0.288	0.122 (37%), 0.245 (8%) 0.344 (27%), 0.779 (14%) 0.965 (15%), 1.087 (12%) 1.113 (14%), 1.408 (22%)		√	√
Eu-154		1.850 (10%)	0.228				
Eu-155		0.247	0.044	0.087 (32%), 0.105 (20%)		√	
Pu-238	5.50 (72%) 5.46 (28%)			0.099 (8E-3%) 0.150 (1E-3%) 0.77 (5E-5%)	√		
Pu-239	5.16 (88%) 5.11 (11%)			0.039 (0.007%), 0.052 (0.20%), 0.129 (0.005%)...	√		
Pu-241	4.90 (0.0019%) 4.85 (0.0003%)	0.021	0.005	0.145 (1.6E-4%)			
Am-241	5.49 (85%) 5.44 (13%)			0.060 (36%), 0.101 (0.04%)...	√		
Cm-243	6.06 (6%) 5.99 (6%) 5.79 (73%) 5.74 (11.5%)			0.209 (4%), 0.228 (12%), 0.278 (14%)	√		

NUREG-1507 and ISO 7503-1 provide guidance for selecting calibration sources and their use in determining total efficiency. It is common practice to calibrate instrument efficiency for a single beta energy; however the energy of this reference source should not be significantly greater than the beta energy of the lowest energy to be measured.

Tc-99 (0.295 MeV max) and Th-230 (4.68 MeV at 76% and 4.62 MeV at 24%) have been selected as the beta and alpha calibration standards respectively, because their energies conservatively approximate the beta and alpha energies of the plant specific radionuclides.

4.0 Efficiency Determination:

Typically, using the instrument 4π efficiency exclusively provides a good approximation of surface activity. Using these means for calculating the efficiency often results in an under estimate of activity levels in the field. Applying both the instrument 2π efficiency and the surface efficiency components to determine the total efficiency allows for a more accurate measurement due to consideration of the actual characteristics of the source surfaces. ISO 7503-1 [8.2] recommends that the total surface activity be calculated using:

$$A_s = \frac{R_{S+B} - R_B}{(\varepsilon_i)(W)(\varepsilon_s)},$$

where:

A_S is the total surface activity in dpm/cm^2,
R_{S+B} is the gross count rate of the measurement in cpm,
R_B is the background count rate in cpm,
ε_i is the instrument or detector 2π efficiency
ε_s is the efficiency of the source
W is the area of the detector window (cm^2)

4.1 Alpha and Beta Instrument Efficiency (ε_i):

Instrument efficiency (ε_i) reflects instrument characteristics and counting geometry, such as source construction, activity distribution, source area, particles incident on the detector per unit time and therefore source to detector geometry. Theoretically the maximum value of ε_i is 1.0, assuming all the emissions from the source are 2π and that all emissions from the source are detected. The ISO 7503-1 methodology for determining the instrument efficiency is similar to the historical 4π approach; however the detector response, in cpm, is divided by the 2π surface emission rate of the calibration source. The instrument efficiency is calculated by dividing the net count rate by the 2π surface emission rate ($q_{2\pi}$) (includes absorption in detector window, source detector geometry). The instrument efficiency is expressed in ISO 7503-1 by:

$$\varepsilon_i = \frac{R_{S+B} - R_B}{q_{2\pi}}$$

where:
R_{S+B} is the gross count rate of the measurement in cpm,
R_B is the background count rate in cpm,
$q_{2\pi}$ is the 2π surface emission rate in reciprocal seconds

Note that both the 2π surface emission rate and the source activity are usually stated on the certification sheet provided by the calibration source manufacturer and certified as National Institute of Standards and Technology (NIST) traceable. Table 4.1 depicts instrument efficiencies that have been determined during calibration using the 2π surface emission rate of the source.

Table 4.1
Instrument Efficiencies (ε_i)

Source	**Emission**	**Active Area of Source (cm^2)**	**Effective Area of Detector**	**100 cm^2 Gas Proportional HP-100 Instrument Efficiency (ε_i) (Contact)**
Tc-99	β	*15.2*	100 cm^2	0.4148
Th-230	α	*15.2*	100 cm^2	0.5545

4.2 Source to Detector Distance Considerations:
A major factor affecting instrument efficiency is source to detector distance. Consideration must be given to this distance when selecting accurate instrument efficiency. The distance from the source to the detector shall to be as close as practicable to geometric conditions that exist in the field. A range of source to detector distances has been chosen, taking into account site specific survey conditions. In an effort to minimize the error associated with geometry, instrument efficiencies have been determined for source to detector distances representative of those survey distances expected in the field. The results shown in Table 4.2 illustrate the imposing reduction in detector response with increased distance from the source. Typically this source to detector distance will be 0.5 inches for fixed point measurements and 0.5 inches for scan surveys on flat surfaces, however they may differ for other surfaces. Table 4.2 makes provisions for the selection of source to detector distances for field survey conditions of up to 2 inches. If surface conditions dictate the placement of the detector at distances greater than 2 inches instrument efficiencies will be determined on an as needed basis.

4.2.1 Methodology:
The practical application of choosing the proper instrument efficiency may be determined by averaging the surface variation (peaks and valleys narrower than the length of the detector) and adding 0.5 inches, the spacing that should be maintained between the detector and the highest peaks of the surface. Select the source to detector distance from Table 4.2 that best reflects this pre-determined geometry.

Table 4.2
Source to Detector Distance Effects on Instrument Efficiencies for α- β Emitters

Source to Detector Distance (cm)	Instrument Efficiency (ε_i)	
	Tc-99 Distributed	**Th-230 Distributed**
Contact	0.4148	0.5545
1.27 (0.5 in)	0.2413	0.1764
2.54 (1 in)	0.1490	0.0265
5.08 (2 in)	0.0784	0.0002

4.3 Source (or Surface) Efficiency (ε_s) Determination:

Source efficiency (ε_s), reflects the physical characteristics of the surface and any surface coatings. The source efficiency is the ratio between the number of particles emerging from surface and the total number of particles released within the source. The source efficiency accounts for attenuation and backscatter. ε_s is nominally 0.5 (no self-absorption/attenuation, no backscatter)~backscatter increases the value, self-absorption decreases the value. Source efficiencies may either be derived experimentally or simply selected from the guidance contained in ISO 7503-1. ISO 7503-1 takes a conservative approach by recommending the use of factors to correct for alpha and beta self-absorption/attenuation when determining surface activity. However, this approach may prove to be too conservative for radionuclides with max beta energies that are marginally lower than 0.400 MeV, such as Co-60 with a βmax of 0.314 MeV. In this situation, it may be more appropriate to determine the source efficiency by considering the energies of other beta emitting radionuclides. Using this approach it is possible to determine weighted average source efficiency. For example, a source efficiency of 0.375 may be calculated based on a 50/50 mix of Co-60 and Cs-137. The source efficiencies for Co-60 and Cs-137 are 0.25 and 0.5 respectively, since the radionuclide fraction for Co-60 and Cs-137 is 50% for each, the weighted average source efficiency for the mix may be calculated in the following manner:

$$(0.25)(0.5) + (0.5)(0.5) = 0.375$$

Table 4.3 lists guidance on source efficiencies from ISO 7503-1.

Table 4.3
Source Efficiencies as listed in ISO 7503-1

	$> 0.400\ MeV_{max}$	$\leq 0.400\ MeV_{max}$
Beta emitters	$\varepsilon_s = 0.5$	$\varepsilon_s = 0.25$
Alpha emitters	$\varepsilon_s = 0.25$	$\varepsilon_s = 0.25$

It should be noted that source efficiency is not typically addressed for gamma detectors as the value is effectively unity.

5.0 Instrument Conversion Factor (E) (Instrument Efficiency for Scanning):

Separate modeling analysis (Microshield™) was conducted using the common gamma emitters with a concentration of 1 pCi/g of uniformly distributed contamination throughout the volume. MicroShield is a comprehensive photon/gamma ray shielding and dose assessment program, which is widely used throughout the radiological safety community. An activity concentration of 1 pCi/g for the nuclides was entered as the source term. The radial dimension of the cylindrical source was 28 cm, the depth was 15 cm, and the dose point above the surface was 10 cm with a soil density of 1.6 g/cm^3. The instrument efficiency when scanning, E_i, is the product of the modeled exposure rate (MicroShield™) in $mRhr^{-1}/pCi/g$ for and the energy response factor in cpm/mR/hr as derived from the energy response curve provided by Eberline Instruments (Appendix O). Table 5.1 demonstrates the derived efficiencies for the major gamma emitting isotopes listed in Table 3.1.

TABLE 5.1
Energy Response and Efficiency for Photon Emitting Isotopes

Isotope	Calculations for E_i See appendix A through L	E_i (cpm/pCi/g)
Co-60	See Appendix Aand B	**379**
Nb-94	See Appendix C and D	**416**
Ag-108m	See Appendix E and F	**637**
Sb-125	See Appendix G and H	**210**
Cs-134	See Appendix I and J	**506**
Cs-137	See Appendix K and L	**188**
Eu-152	See Appendix M and N	**344**

When performing gamma scan measurements on soil surfaces the effective source to detector geometry is as close as is reasonably possible (less than 3 inches).

6.0 Applying Efficiency Corrections Based on the Effects of Field Conditions for Total Efficiency:

The total efficiency for any given condition can now be calculated from the product of the instrument efficiency ε_i and the source efficiency ε_s.

$$\varepsilon_{tot} = \varepsilon_i \times \varepsilon_s$$

The following example illustrates the process of determining total efficiency. For this example we will assume the following:

- Surface activity readings need to be made in the Primary Auxiliary Building (PAB) on the concrete wall surfaces using the E-600 and C-100 gas proportional detector.
- Data obtained from characterization results from the PAB indicate the presence of beta emitters with energies greater than 0.400 Mev.
- The source (activity on wall) to detector distance is 1.27 cm (0.5 in detector stand off). To calculate the total efficiency, ε_{tot}, refer to Table 4.2 "Source to Detector Distance Effects on Instrument Efficiencies for α- β Emitters" to obtain the appropriate ε_i value.
- Contamination on all surfaces is distributed relative to the effective detector area.

- When performing fixed point measurements with gas proportional instrumentation the effective source to detector geometry is representative of the calibrated geometries listed in Table 4.2 "Source to Detector Distance Effects on Instrument Efficiencies for α- β Emitters".
- Corrections for temperature and pressure are not substantial.

In this example, the value for ε_i is 0.2413 as depicted in Table 4.2 "Source to Detector Distance Effects on Instrument Efficiencies for α- β Emitters". The ε_s value of 0.5 is chosen refer to Table 4.3 "Source Efficiencies as listed in ISO 7503-1". Therefore the total efficiency for this condition becomes $\varepsilon_{tot} = \varepsilon_i \times \varepsilon_s = 0.2413 \times 0.5 = 0.121$ or 12.1%.

7.0 Conclusion:

Field conditions may significantly influence the usefulness of a survey instrument. When applying the instrument and source efficiencies in MDC calculations, field conditions must be considered. Tables have been constructed to assist in the selection of appropriate instrument and source efficiencies. Table 4.2 "Source to Detector Distance Effects on Instrument Efficiencies for α-β Emitters" lists instrument efficiencies (ε_i) at various source to detector distances for alpha and beta emitters. The appropriate ε_i value should be applied, accounting for the field condition, i.e. the relation between the detector and the surface to be measured.

Source efficiencies shall be selected from Table 4.3 "Source Efficiencies as listed in ISO 7503-1". This table lists conservative ε_s values that correct for self-absorption and attenuation of surface activity. Table 5.1 "Energy Response and Efficiency for Photon Emitting Isotopes" lists E_i values that apply to scanning MDC calculations. The Microshield™ model code was used to determine instrument efficiency assuming contamination conditions and detector geometry cited in section 5.6.2.4.4 "MDCs for Gamma Scans of Land Areas" of the License Termination Plan [8.6].

Detector and source conditions equivalent to those modeled herein may directly apply to the results of this report.

8.0 References

8.1 NUREG-1507, "Minimum Detectable Concentrations with Typical Radiation Survey Instruments for Various Contaminants and Field Conditions," 1998

8.2 ISO 7503-1, "Evaluation of Surface Contamination – Part I: Beta Emitters and Alpha Emitters," 1988-08-01.

8.3 ISO 8769, "Reference Sources for the Calibration of Surface Contamination Monitors-Beta-emitters (maximum beta energy greater 0.15MeV) and Alpha-emitters," 1988-06-15.

8.4 "Radiological Health Handbook," Revised Edition 1970.

8.5 DP-8534, "Operation and source Checks of Portable Friskers".

8.6 Yankee Nuclear Plant Site License Termination Plan, Rev.0, November 2003.

MicroShield v6.02 (6.02-00253)

Page	:1	**File Ref**	:
DOS File	:SPA3-EFF-Co-60.ms6	**Date**	:
Run Date	: September 10, 2004	**By**	:
Run Time	: 8:56:50 AM	**Checked**	:
Duration	: 00:00:00		

Case Title: SPA3-EFF-Co-60
Description: SPA-3 Soil scan - 28 cm radius 1pCi/cm3 Co-60
Geometry: 8 - Cylinder Volume - End Shields



Source Dimensions:

Height	15.0 cm	(5.9 in)
Radius	28.0 cm	(11.0 in)

Dose Points

A	X	Y	Z
# 1	0 cm	25 cm	0 cm
	0.0 in	9.8 in	0.0 in

Shields

Shield N	Dimension	Material	Density
Source	3.69e+04 cm³	Concrete	1.6
Air Gap		Air	0.00122

Source Input : Grouping Method - Actual Photon Energies

Nuclide	curies	becquerels	µCi/cm³	Bq/cm³
Co-60	3.6945e-008	1.3670e+003	1.0000e-006	3.7000e-002

Buildup : The material reference is - Source
Integration Parameters

Radial	20
Circumferential	10
Y Direction (axial)	10

Results

Energy MeV	Activity Photons/sec	Fluence Rate MeV/cm²/sec No Buildup	Fluence Rate MeV/cm²/sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.6938	2.230e-01	9.055e-06	1.590e-05	1.748e-08	3.070e-08
1.1732	1.367e+03	1.098e-01	1.669e-01	1.962e-04	2.982e-04
1.3325	1.367e+03	1.293e-01	1.904e-01	2.244e-04	3.303e-04
Totals	**2.734e+03**	**2.391e-01**	**3.573e-01**	**4.205e-04**	**6.286e-04**

APPENDIX B

Co-60
Microsoft Excel E_i Calculation Sheet

	Energy MeV	Energy keV	Exposure Rate (mR/hr-1/pCi/g)	Energy Response (cpm/mR/h)	E_i (cpm/pCi/g)
694	0.6938	694	3.07E-08	1,112,630	0
1173	1.1732	1,173	2.98E-04	660,557	197
1333	1.3325	1,333	3.30E-04	552,233	182
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
				(E_i) Total:	379

MicroShield v6.02 (6.02-00253)

Page	:1	**File Ref**	:
DOS File	:SPA3-EFF-Nb-94.ms6	**Date**	:
Run Date	: September 16, 2004	**By**	:
Run Time	: 3:22:38 PM	**Checked**	:
Duration	: 00:00:00		

Case Title: SPA3-EFF-Nb-94
Description: SPA-3 Soil scan - 28 cm radius 1pCi/cm3 Nb-94
Geometry: 8 - Cylinder Volume - End Shields

Source Dimensions:

Height	15.0 cm	(5.9 in)
Radius	28.0 cm	(11.0 in)



Dose Points

A	X	Y	Z
# 1	0 cm	25 cm	0 cm
	0.0 in	9.8 in	0.0 in

Shields

Shield N	Dimension	Material	Density
Source	3.69e+04 cm³	Concrete	1.6
Air Gap		Air	0.00122

Source Input : Grouping Method - Actual Photon Energies

Nuclide	curies	becquerels	µCi/cm³	Bq/cm³
Nb-94	3.6945e-008	1.3670e+003	1.0000e-006	3.7000e-002

Buildup : The material reference is - Source
Integration Parameters

Radial	20
Circumferential	10
Y Direction (axial)	10

Results

Energy MeV	Activity Photons/sec	Fluence Rate MeV/cm²/sec No Buildup	Fluence Rate MeV/cm²/sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.0023	9.067e-02	1.391e-10	1.430e-10	1.861e-10	1.913e-10
0.0174	4.834e-01	8.762e-09	9.129e-09	4.729e-10	4.927e-10
0.0175	9.260e-01	1.719e-08	1.792e-08	9.104e-10	9.491e-10
0.0196	2.720e-01	7.924e-09	8.356e-09	2.925e-10	3.085e-10
0.7026	1.367e+03	5.643e-02	9.872e-02	1.088e-04	1.904e-04
0.8711	1.367e+03	7.464e-02	1.228e-01	1.405e-04	2.312e-04
Totals	**2.736e+03**	**1.311e-01**	**2.216e-01**	**2.493e-04**	**4.216e-04**

APPENDIX D

Nb-94					
	Energy MeV	Energy keV	Exposure Rate (mR/hr-1/pCi/g)	Energy Response (cpm/mR/h)	E_i (cpm/pCi/g)
2	0.0023	2	1.91E-10		0
17	0.0174	17	4.93E-10		0
18	0.0175	18	9.49E-10		0
20	0.0196	20	3.09E-10		0
703	0.7026	703	1.90E-04	1,110,370	211
871	0.8711	871	2.31E-04	884,689	205
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
				(E_i) Total:	**416**

APPENDIX E

MicroShield v6.02 (6.02-00253)

Page	:1	**File Ref**	:
DOS File	:SPA3-EFF-Ag-108m.ms6	**Date**	:
Run Date	: September 16, 2004	**By**	:
Run Time	: 3:30:40 PM	**Checked**	:
Duration	: 00:00:00		

Case Title: SPA3-EFF-Ag-108m
Description: SPA-3 Soil scan - 28 cm radius 1pCi/cm3 Ag-108m
Geometry: 8 - Cylinder Volume - End Shields

Source Dimensions:

Height	15.0 cm	(5.9 in)
Radius	28.0 cm	(11.0 in)



Dose Points

A	X	Y	Z
# 1	0 cm	25 cm	0 cm
	0.0 in	9.8 in	0.0 in

Shields

Shield N	Dimension	Material	Density
Source	3.69e+04 cm³	Concrete	1.6
Air Gap		Air	0.00122

Source Input : Grouping Method - Actual Photon Energies

Nuclide	curies	becquerels	µCi/cm³	Bq/cm³
Ag-108m	3.6945e-008	1.3670e+003	1.0000e-006	3.7000e-002

Buildup : The material reference is - Source
Integration Parameters

Radial	20
Circumferential	10
Y Direction (axial)	10

Results

Energy MeV	Activity Photons/sec	Fluence Rate MeV/cm²/sec No Buildup	Fluence Rate MeV/cm²/sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.0028	6.580e+01	1.252e-07	1.287e-07	1.351e-07	1.388e-07
0.003	7.853e+00	1.568e-08	1.612e-08	1.612e-08	1.657e-08
0.021	2.491e+02	9.534e-06	1.015e-05	2.824e-07	3.007e-07
0.0212	4.727e+02	1.862e-05	1.985e-05	5.389e-07	5.744e-07
0.022	7.024e+00	3.202e-07	3.434e-07	8.233e-09	8.831e-09
0.0222	1.330e+01	6.251e-07	6.714e-07	1.568e-08	1.685e-08
0.0238	1.501e+02	9.273e-06	1.010e-05	1.863e-07	2.029e-07
0.0249	4.289e+00	3.145e-07	3.464e-07	5.492e-09	6.050e-09
0.0304	2.902e-04	4.431e-11	5.248e-11	4.230e-13	5.010e-13
0.0792	9.687e+01	2.008e-04	4.802e-04	3.190e-07	7.629e-07
0.4339	1.229e+03	2.705e-02	5.514e-02	5.294e-05	1.079e-04
0.6144	1.236e+03	4.282e-02	7.808e-02	8.347e-05	1.522e-04
0.7229	1.237e+03	5.300e-02	9.194e-02	1.019e-04	1.768e-04
Totals	**4.768e+03**	**1.231e-01**	**2.257e-01**	**2.398e-04**	**4.389e-04**

APPENDIX F

Ag-108m
Microsoft Excel E$_i$ Calculation Sheet

	Energy MeV	Energy keV	Exposure Rate (mR/hr /pCi/g)	Energy Response (cpm/mR/h)	Ei (cpm/pCi/g)
3	0.0028	3	1.39E-07		0
3	0.003	3	1.66E-08		0
21	0.021	21	3.01E-07		0
21	0.0212	21	5.74E-07		0
22	0.022	22	8.83E-09		0
22	0.0222	22	1.69E-08		0
24	0.0238	24	2.03E-07		0
25	0.0249	25	6.05E-09		0
30	0.0304	30	5.01E-13	1086720	0
79	0.0792	79	7.63E-07	11696000	9
434	0.4339	434	1.08E-04	2061265	222
614	0.6144	614	1.52E-04	1402440	213
723	0.7229	723	1.77E-04	1086291	192
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
				(E$_i$) Total:	**637**

APPENDIX G

MicroShield v6.02 (6.02-00253)

Page	:1	**File Ref**	:
DOS File	:SPA3-EFF-Sb-125.ms6	**Date**	:
Run Date	: September 16, 2004	**By**	:
Run Time	: 3:34:07 PM	**Checked**	:
Duration	: 00:00:00		

Case Title: SPA3-EFF-Sb-125
Description: SPA-3 Soil scan - 28 cm radius 1pCi/cm3 Sb-125
Geometry: 8 - Cylinder Volume - End Shields



Source Dimensions:

Height	15.0 cm	(5.9 in)
Radius	28.0 cm	(11.0 in)

Dose Points

A	X	Y	Z
# 1	0 cm	25 cm	0 cm
	0.0 in	9.8 in	0.0 in

Shields

Shield N	Dimension	Material	Density
Source	3.69e+04 cm³	Concrete	1.6
Air Gap		Air	0.00122

Source Input : Grouping Method - Actual Photon Energies

Nuclide	curies	Becquerels	μCi/cm³	Bq/cm³
Sb-125	3.6945e-008	1.3670e+003	1.0000e-006	3.7000e-002

Buildup : The material reference is - Source
Integration Parameters

Radial	20
Circumferential	10
Y Direction (axial)	10

Results

Energy MeV	Activity Photons/sec	Fluence Rate MeV/cm²/sec No Buildup	Fluence Rate MeV/cm²/sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.0038	6.762e+01	1.708e-07	1.756e-07	1.388e-07	1.427e-07
0.0272	1.748e+02	1.785e-05	2.020e-05	2.376e-07	2.689e-07
0.0275	3.262e+02	3.453e-05	3.922e-05	4.461e-07	5.067e-07
0.031	1.132e+02	1.857e-05	2.221e-05	1.670e-07	1.997e-07
0.0355	5.693e+01	1.492e-05	1.918e-05	9.090e-08	1.169e-07
0.117	3.568e+00	1.380e-05	3.715e-05	2.146e-08	5.778e-08
0.159	9.531e-01	5.634e-06	1.499e-05	9.416e-09	2.505e-08
0.1726	2.478e+00	1.634e-05	4.295e-05	2.787e-08	7.326e-08
0.1763	9.422e+01	6.392e-04	1.674e-03	1.096e-06	2.870e-06
0.2041	4.410e+00	3.630e-05	9.230e-05	6.435e-08	1.636e-07
0.2081	3.324e+00	2.805e-05	7.103e-05	4.994e-08	1.264e-07
0.2279	1.796e+00	1.708e-05	4.229e-05	3.098e-08	7.670e-08
0.321	5.701e+00	8.474e-05	1.899e-04	1.620e-07	3.632e-07
0.3804	2.045e+01	3.792e-04	8.052e-04	7.364e-07	1.564e-06
0.408	2.486e+00	5.051e-05	1.049e-04	9.853e-08	2.047e-07
0.4279	4.009e+02	8.668e-03	1.774e-02	1.695e-05	3.470e-05
0.4435	4.130e+00	9.356e-05	1.894e-04	1.832e-07	3.709e-07
0.4634	1.415e+02	3.395e-03	6.781e-03	6.658e-06	1.330e-05
0.6006	2.430e+02	8.174e-03	1.501e-02	1.595e-05	2.930e-05
0.6066	6.864e+01	2.340e-03	4.283e-03	4.564e-06	8.355e-06
0.6359	1.548e+02	5.609e-03	1.012e-02	1.091e-05	1.967e-05
0.6714	2.478e+01	9.640e-04	1.710e-03	1.867e-06	3.311e-06
Totals	**1.916e+03**	**3.060e-02**	**5.901e-02**	**6.046e-05**	**1.158e-04**

Sb-125					
	Energy MeV	Energy keV	Exposure Rate (mR/hr-1/pCi/g)	Energy Response (cpm/mR/h)	Ei (cpm/pCi/g)
4	0.0038	4	1.43E-07	6,618,312	0
27	0.0272	27	2.69E-07	510,290	0
28	0.0275	28	5.07E-07	554,334	0
31	0.031	31	2.00E-07	1,219,281	0
36	0.0355	36	1.17E-07	2,418,948	0
117	0.117	117	5.78E-08	9,167,000	1
159	0.159	159	2.51E-08	8917000	0
173	0.1726	173	7.33E-08	6859000	1
176	0.1763	176	2.87E-06	6192600	18
204	0.2041	204	1.64E-07	6011300	1
208	0.2081	208	1.26E-07	4073050	1
228	0.2279	228	7.67E-08	3110500	0
321	0.321	321	3.63E-07	3000500	1
380	0.3804	380	0.000001564	2348000	4
408	0.408	408	2.047E-07	2155800	0
428	0.4279	428	0.0000347	2083165	72
444	0.4435	444	3.709E-07	2026225	1
463	0.4634	463	0.0000133	1953590	26
601	0.6006	601	0.0000293	1452810	43
607	0.6066	607	0.000008355	1430910	12
636	0.6359	636	0.00001967	1323965	26
671	0.6714	671	0.000003311	1194390	4
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
				(E_i) Total:	**210**

APPENDIX I

MicroShield v6.02 (6.02-00253)

Page	:1	**File Ref**	:
DOS File	:SPA3-EFF-Cs-134.ms6	**Date**	:
Run Date	: September 16, 2004	**By**	:
Run Time	: 3:39:09 PM	**Checked**	:
Duration	: 00:00:00		

Case Title: SPA3-EFF-Cs-134
Description: SPA-3 Soil scan - 28 cm radius 1pCi/cm3 Cs-134
Geometry: 8 - Cylinder Volume - End Shields



Source Dimensions:

Height	15.0 cm	(5.9 in)
Radius	28.0 cm	(11.0 in)

Dose Points

A	X	Y	Z
# 1	0 cm	25 cm	0 cm
	0.0 in	9.8 in	0.0 in

Shields

Shield N	Dimension	Material	Density
Source	3.69e+04 cm³	Concrete	1.6
Air Gap		Air	0.00122

Source Input : Grouping Method - Actual Photon Energies

Nuclide	curies	becquerels	μCi/cm³	Bq/cm³
Cs-134	3.6945e-008	1.3670e+003	1.0000e-006	3.7000e-002

Buildup : The material reference is - Source
Integration Parameters

Radial	20
Circumferential	10
Y Direction (axial)	10

Results

Energy MeV	Activity Photons/sec	Fluence Rate MeV/cm²/sec No Buildup	Fluence Rate MeV/cm²/sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.0045	1.222e+00	3.658e-09	3.760e-09	2.507e-09	2.577e-09
0.0318	2.931e+00	5.271e-07	6.386e-07	4.391e-09	5.320e-09
0.0322	5.407e+00	1.014e-06	1.236e-06	8.157e-09	9.943e-09
0.0364	1.968e+00	5.611e-07	7.321e-07	3.188e-09	4.160e-09
0.2769	4.839e-01	5.931e-06	1.391e-05	1.113e-08	2.610e-08
0.4753	1.996e+01	4.950e-04	9.808e-04	9.712e-07	1.924e-06
0.5632	1.146e+02	3.545e-03	6.648e-03	6.940e-06	1.302e-05
0.5693	2.109e+02	6.619e-03	1.237e-02	1.295e-05	2.421e-05
0.6047	1.334e+03	4.529e-02	8.300e-02	8.836e-05	1.619e-04
0.7958	1.167e+03	5.668e-02	9.564e-02	1.079e-04	1.820e-04
0.8019	1.193e+02	5.852e-03	9.853e-03	1.113e-05	1.874e-05
1.0386	1.367e+01	9.377e-04	1.472e-03	1.717e-06	2.696e-06
1.1679	2.461e+01	1.964e-03	2.990e-03	3.514e-06	5.349e-06
1.3652	4.156e+01	4.055e-03	5.936e-03	6.993e-06	1.024e-05
Totals	**3.058e+03**	**1.254e-01**	**2.189e-01**	**2.405e-04**	**4.202e-04**

APPENDIX J

Cs-134
Microsoft Excel E_i Calculation Sheet

	Energy MeV	Energy keV	Exposure Rate (mR/hr-1/pCi/g)	Energy Response (cpm/mR/h)	Ei (cpm/pCi/g)
5	0.0045	5	2.58E-09		0
32	0.0318	32	5.32E-09	1,406,947	0
32	0.0322	32	9.94E-09	1,505,273	0
36	0.0364	36	4.16E-09	2,696,122	0
277	0.2769	277	2.61E-08	3,637,000	0
475	0.4753	475	1.92E-06	1,910,155	4
563	0.5632	563	1.30E-05	1,589,320	21
569	0.5693	569	2.42E-05	1,567,055	38
605	0.6047	605	1.62E-04	1,437,845	233
796	0.7958	796	1.82E-04	998,082	182
802	0.8019	802	1.87E-05	939,149	18
1039	1.0386	1,039	2.70E-06	752,085	2
1168	1.1679	1,168	5.35E-06	664,161	4
1365	1.3652	1,365	1.02E-05	573,136	6
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
				(E_i) Total:	**506**

MicroShield v6.02 (6.02-00253)

Page	:1	**File Ref**	:
DOS File	:SPA3-EFF-Cs-137.ms6	**Date**	:
Run Date	: September 10, 2004	**By**	:
Run Time	: 8:52:18 AM	**Checked**	:
Duration	: 00:00:00		

Case Title: SPA3-EFF-Cs-137
Description: SPA-3 Soil scan - 28 cm radius 1pCi/cm3 Cs-137 and Daughters
Geometry: 8 - Cylinder Volume - End Shields



Source Dimensions:

Height	15.0 cm	(5.9 in)
Radius	28.0 cm	(11.0 in)

Dose Points

A	X	Y	Z
# 1	0 cm	25 cm	0 cm
	0.0 in	9.8 in	0.0 in

Shields

Shield N	Dimension	Material	Density
Source	3.69e+04 cm³	Concrete	1.6
Air Gap		Air	0.00122

Source Input : Grouping Method - Actual Photon Energies

Nuclide	curies	becquerels	μCi/cm³	Bq/cm³
Ba-137m	3.4950e-008	1.2932e+003	9.4600e-007	3.5002e-002
Cs-137	3.6945e-008	1.3670e+003	1.0000e-006	3.7000e-002

Buildup : The material reference is - Source
Integration Parameters

Radial	20
Circumferential	10
Y Direction (axial)	10

Results

Energy MeV	Activity Photons/sec	Fluence Rate MeV/cm²/sec No Buildup	Fluence Rate MeV/cm²/sec With Buildup	Exposure Rate mR/hr No Buildup	Exposure Rate mR/hr With Buildup
0.0045	1.342e+01	4.020e-08	4.133e-08	2.755e-08	2.833e-08
0.0318	2.677e+01	4.815e-06	5.834e-06	4.011e-08	4.860e-08
0.0322	4.939e+01	9.260e-06	1.129e-05	7.452e-08	9.084e-08
0.0364	1.797e+01	5.126e-06	6.688e-06	2.912e-08	3.800e-08
0.6616	1.164e+03	4.442e-02	7.913e-02	8.611e-05	1.534e-04
Totals	**1.271e+03**	**4.444e-02**	**7.915e-02**	**8.628e-05**	**1.536e-04**

Cs-137
Microsoft Excel E_i Calculation Sheet

	Energy MeV	Energy keV	Exposure Rate (mR/hr 1/pCi/g)	Energy Response (cpm/mR/h)	E_i (cpm/pCi/g)
5	0.0045	5	2.83E-08		0
32	0.0318	32	4.86E-08	1,406.947	0
32	0.0322	32	9.08E-08	1,505.273	0
36	0.0364	36	3.80E-08	2,696.122	0
662	0.6616	662	1.53E-04	1,228.700	188
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
				(E_i) Total:	**188**

APPENDIX M

MicroShield v6.02 (6.02-00253)

Page	:1
DOS File	:SPA3-EFF-Eu-152.ms6
Run Date	: October 7, 2004
Run Time	: 11:25:11 AM
Duration	: 00:00:00

File Ref	:
Date	:
By	:
Checked	:

Case Title: SPA-3-EFF-Eu-152
Description: SPA-3 Soil scan - 28cm radius 1 pCi/cm3 Eu-152
Geometry: 8 - Cylinder Volume - End Shields



Source Dimensions:

Height	15.0 cm	(5.9 in)
Radius	28.0 cm	(11.0 in)

Dose Points

A	**X**	**Y**	**Z**
# 1	0 cm	25 cm	0 cm
	0.0 in	9.8 in	0.0 in

Shields

Shield N	**Dimension**	**Material**	**Density**
Source	3.69e+04 cm³	Concrete	1.6
Air Gap		Air	0.00122

Source Input : Grouping Method - Standard Indices
Number of Groups : 25
Lower Energy Cutoff : 0.015
Photons < 0.015 : Included
Library : Grove

Nuclide	**curies**	**becquerels**	**µCi/cm³**	**Bq/cm³**
Eu-152	3.6945e-008	1.3670e+003	1.0000e-006	3.7000e-002

Buildup : The material reference is - Source
Integration Parameters

Radial	20
Circumferential	10
Y Direction (axial)	10

Results

Energy MeV	**Activity Photons/sec**	**Fluence Rate MeV/cm²/sec No Buildup**	**Fluence Rate MeV/cm²/sec With Buildup**	**Exposure Rate mR/hr No Buildup**	**Exposure Rate mR/hr With Buildup**
0.015	2.077e+02	2.087e-06	2.146e-06	1.790e-07	1.841e-07
0.04	8.088e+02	3.131e-04	4.331e-04	1.385e-06	1.916e-06
0.05	2.022e+02	1.507e-04	2.467e-04	4.014e-07	6.572e-07
0.1	3.887e+02	1.189e-03	3.118e-03	1.819e-06	4.770e-06
0.2	1.024e+02	8.207e-04	2.097e-03	1.448e-06	3.700e-06
0.3	3.696e+02	5.029e-03	1.151e-02	9.540e-06	2.184e-05
0.4	8.590e+01	1.701e-03	3.555e-03	3.314e-06	6.926e-06
0.5	7.711e+00	2.043e-04	3.984e-04	4.010e-07	7.819e-07
0.6	5.797e+01	1.948e-03	3.579e-03	3.802e-06	6.985e-06
0.8	2.434e+02	1.190e-02	2.005e-02	2.263e-05	3.813e-05
1.0	5.849e+02	3.820e-02	6.058e-02	7.042e-05	1.117e-04
1.5	3.171e+02	3.490e-02	4.999e-02	5.871e-05	8.411e-05
Totals	**3.376e+03**	**9.635e-02**	**1.556e-01**	**1.740e-04**	**2.817e-04**

Eu-152					
	Energy MeV	Energy keV	Exposure Rate (mR/hr-1/pCi/g)	Energy Response (cpm/mR/h)	Ei (cpm/pCi/g)
15	0.015	15	1.84E-07		0
40	0.04	40	1.92E-06	3,897,600	7
50	0.05	50	6.57E-07	6,500,000	4
100	0.1	100	4.77E-06	9,958,333	48
200	0.2	200	3.70E-06	4,850,000	18
300	0.3	300	2.18E-05	3,200,000	70
400	0.4	400	6.93E-06	2,185,000	15
500	0.5	500	7.82E-07	1,820,000	1
600	0.6	600	6.99E-06	1,455,000	10
800	0.8	800	3.81E-05	993,000	38
1000	1	1,000	1.12E-04	783,019	87
1500	1.5	1,500	8.41E-05	530,000	45
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
0		0			0
				(E_i) Total:	344

Calculated Energy Response (Eberline Instruments)

CPM/mR/h