

Perry Buckberg - Conference Call Request

From: Perry Buckberg
To: Doug Ellis
Date: 12/4/2006 2:25:00 PM
Subject: Conference Call Request
CC: Bryan Ford; Fred Mogolesko; Rajender Auluck; Rodrigo De La Garza

Doug,

As we have discussed recently, there are several subjects the NRC staff requests you and your staff address. Please review the following 8 issues and let me know when your staff can discuss, via a conference call, these issues with NRC staff.

- 1) RAI 2.3.3.9-8 - was discussed during the 10/10/2006 conference call. A 3/9/1977 letter (listed in 11/2/2006 e-mail from Doug Ellis) addresses commitment to satisfy Appendix A to BTP APCSB 9.5-1. Address this letter or addition to LRA adequately committing Pilgrim to satisfy Appendix A to BTP APCSB 9.5-1.
- 2) RAI 2.4.3-1 NRC staff considers Trash rack and traveling screens in scope for license renewal and requests descriptions of the monitoring programs for these components.
- 3) RAI 2.4.5-1 - In Amendment 8 to the LRA it was stated that "Transmission Towers" are in LRA Table 2.4-1. It appears Transmission Towers are in LRA Table 2.4-5. Please confirm the location within the LRA.
- 4) RAI 2.4.3-1 - Amendment 8 includes "The jib crane does not require aging management review because it does not perform a license renewal intended function." NRC staff requests the applicant clarify and provide additional justification for the above statement that the crane is does not perform a license renewal intended function.
- 5) BWRVIP 94 - Address Pilgrim commitment to this document or provide procedure demonstrating it is in scope (Pete Oskas (?) provided such a procedure for VY or Fitz).
- 6) Address Pilgrim commitment to abide by BWRVIP 76 requirements.
- 7) The core shroud tie rod repair upper bracket is made of Alloy X750. SIL from GE addressed issues with this component at Pilgrim. Please address Pilgrims plans to inspect, replace or repair this component.
- 8) CASS main steam flow restrictor, RCS pump casings and valve bodies, and piping - address Pilgrim testing for Reduction of Fracture Toughness

Thanks,
Perry Buckberg
Project Manager - Division of License Renewal
phone: (301)415-1383
fax: (301)415-3031
phb1@nrc.gov

Mail Envelope Properties (4574760C.E36: 9 : 8248)

Subject: Conference Call Request
Creation Date 12/4/2006 2:25:00 PM
From: Perry Buckberg

Created By: PHB1@nrc.gov

Recipients	Action	Date & Time
entergy.com PM bford CC (Bryan Ford) dellis1 (Doug Ellis) fmogole CC (Fred Mogolesko)	Transferred	12/4/2006 2:25:22

nrc.gov OWGWPO01.HQGWDO01 PM RCA CC (Rajender Auluck)	Delivered	12/4/2006 2:25:00
--	-----------	-------------------

nrc.gov OWGWPO03.HQGWDO01 PM RXD3 CC (Rodrigo De La Garza)	Delivered	12/4/2006 2:25:07
---	-----------	-------------------

Post Office	Delivered	Route
OWGWPO01.HQGWDO01	12/4/2006 2:25:00 PM	entergy.com nrc.gov
OWGWPO03.HQGWDO01	12/4/2006 2:25:07 PM	nrc.gov

Files	Size	Date & Time
MESSAGE	3120	12/4/2006 2:25:00 PM
TEXT.htm	2841	

Options

Auto Delete: No
Expiration Date: None
Notify Recipients: Yes
Priority: Standard
ReplyRequested: No
Return Notification: None

Concealed Subject: No
Security: Standard

